

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
EQUILON PIPELINE COMPANY, LLC
(EQUILON CALIFORNIA PIPELINE COMPANY)

NPDES NO. CAG674001
CI-8375

FACILITY ADDRESS

3284 N. Ventura Avenue
Ventura, CA 93001

FACILITY MAILING ADDRESS

20945 Wilmington Avenue
Carson, CA 90810-1039

PROJECT DESCRIPTION:

The Equilon California Pipeline Company (Equilon) will be upgrading two of their aboveground tanks in their facility located at 3284 N. Ventura Avenue, Ventura. The Equilon proposes to discharge hydrostatic water from Tank No. 800S205 into a storm drain, and will use potable water supplied by the City of Ventura during the hydrostatic testing.

VOLUME AND DESCRIPTION OF DISCHARGE:

A total of approximately 2.1 million gallons of hydrostatic water will be discharged to storm drain tributary to the Ventura River (Latitude: 34° 18' 52", Longitude: 119° 17' 27"). The discharge will be released from the Tank No. 800S205 to the secondary containment basin, and released to the storm drain located along Ventura Avenue that drains into the School Canyon Canal. From the canal, the discharge enters the Ventura River, waters of the United States. The discharge will occur over a period of six days at a rate of up to 350,000 gallons per day. The site plan location and a vicinity maps is shown in Figures 1 and 2.

FREQUENCY OF DISCHARGE:

The discharge will be intermittent. The project anticipates to conduct the hydrostatic testing in March 2002.

REUSE OF WATER:

Several options to reuse water at the facility, such as greenbelt irrigation and dust control, were evaluated. However, none were feasible. Therefore, the majority of the hydrostatic test water will be discharged into the storm drain.