

**State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
THE CLARK CONSTRUCTION GROUP, INC.  
(Replacement of Caltrans District 7 Headquarters Building Project)**

**NPDES NO. CAG994001  
CI-8422**

**PROJECT LOCATION**

100 S. Main Street  
Los Angeles, CA 90012

**FACILITY MAILING ADDRESS**

130 W. 1<sup>st</sup> Street, Suite 200  
Los Angeles, CA 90012

**PROJECT DESCRIPTION**

The Clark Construction Group, Inc. (Clark) proposes to construct a new building to replace the existing Caltrans District 7 headquarters building. Dewatering is anticipated during the construction activities. The City proposes to store the extracted groundwater in a settling tank. Groundwater samples will be taken from the settling tank for analyses prior to discharge to the storm drain.

**VOLUME AND DESCRIPTION OF DISCHARGE**

Clark will discharge up to 10,000 gallons per day (gpd) of groundwater. The groundwater will be discharged to a storm drain located at 2<sup>nd</sup> Street (Latitude 34° 03' 05", Longitude 118° 14' 34"), thence to the Los Angeles River, a water of the United States. The project location is shown on Figure 1, attached.

**FREQUENCY OF DISCHARGE**

The discharge will begin in July 2002 and will last approximately five months.

**REUSE OF WATER**

Some of the groundwater will be used during construction for activities such as dust control and soil compaction. There are no other feasible reuse options for the groundwater. Therefore, the majority of the groundwater will be discharged to the storm drain.