

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CITY OF LONG BEACH WATER DEPARTMENT
(COMMISSION WATER WELLS 24 AND 25)**

**NPDES NO. CAG 994001
CI-8503**

FACILITY ADDRESS

City of Long Beach
Heartwell and Wardlow Parks
Long Beach, CA 90808

FACILITY MAILING ADDRESS

City of Long Beach
2950 Redondo Ave
Long Beach, CA 90806

PROJECT DESCRIPTION

The City of Long Beach proposes to develop two new potable water supply wells. Groundwater will be discharged to Los Cerritos Channel during the development and testing of the wells.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 2,880,000 gallons per day of groundwater will be discharged into storm drains next to Los Cerritos Channel at two separate sites; Latitude: 30° 49' 52"N, Longitude: 118° 07' 56"W and Latitude: 30° 49' 18"N, Longitude: 118° 07' 40"W. 2,880,000 gallons per day will be the maximum rate of discharge and will continue for periods of 24 to 36 hours during the approximately two weeks of well construction. The storm drains flow into Los Cerritos Channel which flows into Alamitos Bay, a water of the United States. The well locations are shown on the attached Figures 1 and 2.

FREQUENCY OF DISCHARGE

Discharge will begin in December of 2002 or January of 2003 and will occur for a period of approximately two weeks for each well.

REUSE OF WATER

Due to the short-term nature of the construction, there is no feasible reuse option for the groundwater at the site.