

**State of California**  
**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD**  
**LOS ANGELES REGION**  
**320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET**  
**WASTE DISCHARGE REQUIREMENTS**  
**FOR**  
**MOLE-RICHARDSON COMPANY**

**NPDES NO. CAG994002**  
**CI-8565**

**PROJECT LOCATION**

Mole-Richardson Company  
937 N. Sycamore Avenue  
Hollywood, CA 90038

**FACILITY MAILING ADDRESS**

Mole-Richardson Company  
937 N. Sycamore Avenue  
Hollywood, CA 90038

**PROJECT DESCRIPTION**

Mole-Richardson Company manufactures, rents, and sells specialized entertainment lighting equipment and accessories. Mole-Richardson proposes to extract and treat volatile organic compounds (VOC) impacted groundwater beneath the facility at 937 N. Sycamore Avenue in Hollywood. The treatment system consists of filtration unit, two granular activated carbon units, and one ion exchange resin to treat VOC as well as metals. Treated wastewater from the treatment system will discharge to a storm drain.

**VOLUME AND DESCRIPTION OF DISCHARGE**

Mole-Richardson Company proposes to discharge up to 13,000 gallons per day of treated groundwater to a storm drain located at Outfall No. 1 (Latitude 34° 05' 07", Longitude 118° 20' 35") thence to the Ballona Creek, a water of the United States. See Figures 1, and 2 for the site locations and schematic of the treatment system, respectively.

**FREQUENCY OF DISCHARGE**

The discharge from the treatment system is proposed to begin in April 2003. The discharge will be continuous and projected to last for at least three years.

**REUSE OF WATER**

Mole-Richardson Company considered alternative reuse and/or method of disposal for the wastewater. It is not economically feasible to discharge to a sanitary sewer or to transport to offsite disposal facility. Therefore, the wastewater will be discharged to the storm drain.