

STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013

FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
CONOCOPHILLIPS COMPANY  
(TORRANCE TANK FARM)

NPDES NO. CAG674001  
CI-8755

**FACILITY ADDRESS**

2650 Lomita Boulevard  
Torrance, CA 90505

**FACILITY MAILING ADDRESS**

3900 Kilroy Airport Way  
Long Beach, CA 90806

**PROJECT DESCRIPTION:**

ConocoPhillips Company proposes to discharge hydrostatic test water from aboveground storage tanks located at its facility at 2650 Lomita Boulevard, Torrance. Hydrostatic testing is required at the facility to test the storage tanks and pipelines for leaks and structural integrity. The wastewater from the tanks will be discharged to a nearby storm drain located along Lomita Boulevard. Potable water supplied by the City of Torrance Department of Water and Power will be used for the hydrostatic testing.

**VOLUME AND DESCRIPTION OF DISCHARGE:**

Approximately 420,000 gallons per day of hydrostatic test water will be discharged to a storm drain located along Lomita Boulevard (Latitude: 33° 48' 23", Longitude: 118° 19' 51"). From the storm drain, the discharge flows into Harbor Lake, thence to Los Angeles Inner Harbor, a water of the United States. The location and site plan are shown in Figures 1 and 2.

**FREQUENCY OF DISCHARGE:**

The discharge will be intermittent. ConocoPhillips Company anticipates conducting the hydrostatic testing for one of its tanks in July 2004. Subsequently, ConocoPhillips will conduct hydrostatic testing at its facility and as needed basis.

**REUSE OF WATER:**

Reuse of water at the facility for irrigation and dust control were evaluated, but were found to be infeasible at the site. Therefore, the hydrostatic test water will be discharged into the storm drain.