

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
RIVER PARK LEGACY, LLC
(SATICOY OPERATIONS YARD)**

**NPDES NO. CAG994004
CI-8934**

FACILITY ADDRESS

State Route 118
Saticoy, CA 93004

FACILITY MAILING ADDRESS

30699 Russell Ranch Road, Suite 290
Westlake Village, CA 91362

PROJECT DESCRIPTION:

The River Park Legacy, LLC proposes to discharge groundwater generated from dewatering activities during the construction of a flood control embankment/levee on the Santa Clara River. The Project site will be a future Ventura County Maintenance Yard and will be located along State Route 118, Saticoy. The construction-dewatering Project will be completed within three months. A desilting tank will be installed to allow sediments to settle out before discharging.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 2.5 million gallons per day (mgd) of groundwater will be discharged into the Santa Clara River (Latitude: 34° 16' 50", Longitude: 119° 8' 22"), a water of the United States. The vicinity map is shown in Figure 1.

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided, the analytical data did not show reasonable potential for toxics to exist in groundwater above the Screening Levels for Potential Pollutants of Concern in your discharge. The discharge of groundwater flows into the Santa Clara River (between Freeman Diversion "Dam" near Saticoy and Highway 118 Bridge). This stream reach of the Santa Clara River is designated as MUN (Potential) beneficial use. The discharge of groundwater satisfies the provisions for creekside construction dewatering operations in Order No. R4-2003-0111. Therefore the limitations in Attachment B.3.g. of Order No. R4-2003-0111 are not applicable to your discharge, except for boron.

August 2, 2005

This Table lists the specific constituents and effluent limitations applicable to your discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Boron	mg/L	1.5	
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD ₅ 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settleable Solids	ml/L	0.3	0.1
Sulfides	mg/L	1.0	
Phenols	mg/L	1.0	
Residual Chlorine	mg/L	0.1	
Methylene Blue Active Substances (MBAS)	mg/L	0.5	

FREQUENCY OF DISCHARGE:

The discharge of groundwater will be intermittent and will last approximately three months.

REUSE OF WATER:

Water reuse alternatives and their applicability were evaluated. A small volume of the groundwater will be used for dust control and soil compaction within the Project area. The majority of the groundwater will be discharged into the Santa Clara River.