

ATTACHMENT A

SCREENING LEVELS FOR POTENTIAL POLLUTANTS OF CONCERN
IN POTABLE WATER USED FOR HYDROSTATIC TESTING
(Screening to be conducted on a source water sample prior to issuance of permit)

Pollutant	Maximum Contaminant Levels	Minimum Levels (ML)
	(µg/L)	(µg/L)
1,1,1-Trichloroethane	200	2
1,1,2,2-Tetrachloroethane	1	0.5
1,1,2-Trichloroethane	5	0.5
1,1-Dichloroethane	5	1
1,1-Dichloroethylene	6	0.5
1,2-Dichloroethane	0.5	0.5
1,4-Dichlorobenzene	5	0.5
Benzene	1	0.5
Carbon tetrachloride	0.5	0.5
Ethylbenzene	700	2
Ethylene dibromide	0.05	na
Methyl tertiary butyl ether (MTBE)	5	na
Tetrachloroethylene	5	0.5
Toluene	150	2
Total Trihalomethanes	80	--
trans 1,2-Dichloroethylene	10	1
Trichloroethylene	5	0.5
Vinyl chloride	0.5	0.5
Xylenes	1750	na
Arsenic	50	10
Cadmium	5	0.5
Chromium (total)	50	10
Copper	1000	0.5
Lead	50	0.5
Mercury	2	0.2
Selenium	10	2
Silver	50	0.25