

ATTACHMENT A

SCREENING LEVELS FOR POTENTIAL POLLUTANTS OF CONCERN IN POTABLE WATER

(Screening to be conducted on untreated water sample for water supply systems discharges, and on actual water being supplied to end users for potable water distribution systems.)

Pollutant	Screening Criteria		Maximum Contaminant Levels	Minimum Levels (ML)
	MUN ^(a)	Others ^(b)		
	(µg/L)	(µg/L)	(µg/L)	(µg/L)
Copper	9.4	3.7	1000	0.5
Arsenic	10.00	10.00	10	1
Total Chromium	50	--	50	10
1,1 Dichloroethane	5	5	5	1
1,1 Dichloroethylene	0.057	3.2	6	0.5
1,1,1 Trichloroethane	200	200	200	2
1,1,2 Trichloroethane	0.60	42	5	0.5
1,1,2,2 Tetrachloroethane	0.17	1	1	0.5
1,2 Dichloroethane	0.38	99	0.5	0.5
1,2-Trans Dichloroethylene	10	10	10	1
Tetrachloroethylene	0.8	8.85	5	0.5
Trichloroethylene	2.7	5	5	0.5
Carbon Tetrachloride	0.25	0.5	0.5	0.5
Vinyl Chloride	0.5	0.5	0.5	0.5
Total Trihalomethanes	--	--	80	--
Benzene	1	1	1	0.5
Methyl tertiary butyl ether (MTBE)	5	5	5	na

(a) = Applies to water with Municipal and Domestic Supply (MUN)
(indicated with E and I in the Basin Plan) beneficial uses designations.

(b) = Applies to all other receiving waters.