

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

REGION 4, LOS ANGELES REGION

320 W. 4th Street, Suite 200, Los Angeles, California 90013
(213) 576-6600 • Fax (213) 576-6640
<http://www.waterboards.ca.gov>

ORDER NO. R4-2012-XXXX

NPDES NO. CA0055531

WASTE DISCHARGE REQUIREMENTS FOR THE CITY OF BURBANK BURBANK WATER RECLAMATION PLANT

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 1. Discharger Information

Discharger	City of Burbank
Name of Facility	Burbank Water Reclamation Plant
Facility Address	740 N. Lake Street
	Burbank, CA 91502
	Los Angeles County
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a major discharge.	

The discharge by the City of Burbank from the discharge point identified below is subject to waste discharge requirements as set forth in this Order:

Table 2. Discharge Location

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
002	Tertiary treated effluent	34°, 10', 58" N	118°, 19', 05" W	Burbank Western Channel

Table 3. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	March 1, 2012
This Order shall become effective on:	April 22, 2012
This Order shall expire on:	February 10, 2017
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	180 days prior to the Order expiration date

I, Samuel Unger, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on March 1, 2012.

Samuel Unger, P.E., Executive Officer

**T
E
N
T
A
T
I
V
E**

Table of Contents

I.	Facility Information	5
II.	Findings	6
III.	Discharge Prohibitions	19
IV.	Effluent Limitations and Discharge Specifications	20
	A. Effluent Limitations	20
	1. Effluent Limitations Applicable to Discharge Point 002	20
	2. Other Effluent Limitations Applicable to Discharge Point 002	22
	B. Reclamation Specifications – Discharge Point 002	24
V.	Receiving Water Limitations	25
	A. Surface Water Limitations	25
	B. Groundwater Limitations	28
VI.	Provisions	28
	A. Standard Provisions	28
	B. Monitoring and Reporting Program (MRP) Requirements	31
	C. Special Provisions	31
	1. Reopener Provisions	31
	2. Special Studies, Technical Reports, and Additional Monitoring Requirements	33
	3. Best Management Practices and Pollution Prevention	34
	4. Construction, Operation and Maintenance Specifications	36
	5. Special Provisions for Municipal Facilities (POTWs Only)	36
	6. Spill Reporting Requirements	38
VII.	Compliance Determination	42
	1. Definition of Acute Toxicity	E-12
	2. Acute Toxicity Effluent Monitoring Program	E-12
	1. Definition of Chronic Toxicity	E-13
	2. Chronic Toxicity Effluent Monitoring Program	E-13
	3. Accelerated Monitoring	E-14
	Standard Mail	E-31
	FedEx/UPS/	E-31
	Other Private Carriers	E-31

List of Tables

Table 1.	Discharger Information	1
Table 2.	Discharge Location	1
Table 3.	Administrative Information	1
Table 4.	Facility Information	5
Table 5a.	Basin Plan Beneficial Uses – Surface Waters	8
Table 5b.	Basin Plan Beneficial Uses – Ground Waters	9
Table 6.	Effluent Limitations Applicable to Discharge Point 001	20

List of Attachments

Attachment A – Definitions	A-1
Attachment B – Map	B-1
Attachment C – Flow Schematic.....	C-1
Attachment D –Standard Provisions	D-1
Attachment E – Monitoring and Reporting Program	E-1
Attachment F – Fact Sheet.....	F-1
Attachment G – Generic Toxicity (TRE) Workplan (POTW).....	G-1
Attachment H – Storm Water Pollution Prevention Plan Requirements (Not Applicable).....	H-1
Attachment I – Biosolids/sludge Use and Disposal Requirements (Not Applicable).....	I-1
Attachment J – Pretreatment Reporting Requirements.....	J-1
Attachment K – TMDL-Related Tasks (Not Applicable).....	K-1

I. FACILITY INFORMATION

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 4. Facility Information

Discharger	City of Burbank
Name of Facility	Burbank Water Reclamation Plant
Facility Address	740 N. Lake Street
	Burbank, CA 91502
	Los Angeles County
Facility Contact, Title, and Phone	Daniel Rynn, Principal Civil Engineer, (818) 238-3940
Mailing Address	275 E. Olive Avenue, CA 91502
Type of Facility	Publicly-Owned Treatment Works
Facility Design Flow	12.5million gallons per day

T
E
N
T
A
T
I
V
E

II. FINDINGS

The California Regional Water Quality Control Board, Los Angeles Region (Regional Water Board), finds:

A. Background. The City of Burbank (Discharger) is currently discharging pursuant to Order No. R4-2006-0085 as amended by R4-2010-0058 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0055531. The Discharger submitted a Report of Waste Discharge, dated April 6, 2011, and applied for an NPDES permit renewal to discharge up to 12.5 million gallons per day (mgd) of treated wastewater from Burbank Water Reclamation Plant (hereinafter Facility or Burbank WRP). The application was deemed complete on July 28, 2011.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

B. Facility Description. The Discharger owns the Burbank WRP, a Publicly-Owned Treatment Works (POTW), and United Water is contracted to operate it. The treatment system consists of flow equalization, primary sedimentation, activated sludge biological treatment with nitrification and denitrification, secondary sedimentation with coagulation, single media deep bed gravity sand filtration, chlorination disinfection with sodium hypochlorite, and dechlorination with sodium bisulfite. Wastewater is discharged from Discharge Point 002 (see Table 2 on the cover page) to Burbank Western Channel, a water of the United States. Discharge Point 001 is abandoned and has not been used since June 14, 2005. Attachment B provides a map of the area around the facility. Attachment C provides a flow schematic of the facility.

C. Legal Authorities. This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (CWC) (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the CWC (commencing with section 13260).

D. Background and Rationale for Requirements. The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, monitoring and reporting reports, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through G and J are also incorporated into this Order.

E. California Environmental Quality Act (CEQA). Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100-21177.

T
E
N
T
A
T
I
V
E

F. Technology-based Effluent Limitations (TBELs). Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations (CFR)¹, require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at 40 CFR part 133 and 40 CFR part 125.3. A detailed discussion of the TBELs development is included in the Fact Sheet (Attachment F).

G. Water Quality-Based Effluent Limitations (WQBELs). Section 301(b) of the CWA and 40 CFR part 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements for biochemical oxygen demand (BOD) and total suspended solids (TSS), expressed as a technology equivalence requirement, more stringent than secondary treatment requirements that are necessary to meet applicable water quality standards. The rationale for these requirements, which consist of tertiary treatment or equivalent requirements or other provisions, is discussed in the Fact Sheet (Attachment F).

40 CFR part 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR part 122.44(d)(1)(vi).

H. Water Quality Control Plans. The Regional Water Board adopted a Water Quality Control Plan for the Los Angeles Region (hereinafter Basin Plan) on June 13, 1994, that designates beneficial uses, establishes water quality objectives (WQOs), and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to the Burbank Western Channel are as follows:

¹ All further statutory references are to title 40 of the CFR unless otherwise indicated.

Table 5a. Basin Plan Beneficial Uses – Surface Waters

Discharge Point	Receiving Water Name	Beneficial Use(s)
002	Burbank Western Channel (Hydro. Unit No. 405.21)	<u>Intermittent:</u> non-contact water recreation (REC-2). <u>Potential:</u> Municipal and domestic water supply (MUN), water contact recreation (REC-1 ²), warm freshwater habitat (WARM) and wildlife habitat (WILD).
002	Los Angeles River (upstream of Figueroa Street) (Hydro. Unit No. 405.21)	<u>Existing:</u> Groundwater recharge (GWR); REC-1 ² ; REC-2; WARM; WILD; and wetland habitat (WET). <u>Potential:</u> MUN ³ , industrial service supply (IND).
002	Los Angeles River (downstream of Figueroa Street) (Hydro. Unit No. 405.15)	<u>Existing:</u> GWR; REC-1 ² ; REC-2; and WARM. <u>Potential:</u> MUN ³ ; IND; and WILD.
002	Los Angeles River to Estuary (Hydro. Unit No. 405.12)	<u>Existing:</u> GWR; REC-1; REC-2; WARM; marine habitat (MAR); wildlife habitat (WILD); and rare, threatened, or endangered species (RARE). <u>Potential:</u> MUN ³ ; IND; industrial process supply (PROC); migration of aquatic organisms (MIGR ⁵); spawning, reproduction, and/or early development (SPWN ⁵); and shellfish harvesting (SHELL ³).
002	Los Angeles River Estuary (Hydro. Unit No. 405.12)	<u>Existing:</u> IND; navigation (NAV); REC-1; REC-2; commercial and sport fishing (COMM); estuarine habitat (EST); MAR; WILD; RARE ⁴ ; MIGR ⁵ ; and SPWN ⁵ ; and WET. <u>Potential:</u> SHELL.

**T
E
N
T
A
T
I
V
E**

² Access prohibited by County of Los Angeles Department of Public Works.

³ The potential municipal and domestic supply (p*MUN) beneficial use for the waterbody is consistent with the State Water Resources Control Board Resolution 88-63 and Regional Water Board Resolution No. 89-003; however, the Regional Water Board has only conditionally designated the MUN beneficial use of the surface water and at this time cannot establish effluent limitation designed to protect the conditional designation.

⁴ One or more rare species utilize all ocean, bays, estuaries, and coastal wetlands for foraging and/or nesting.

⁵ Aquatic organisms utilize all bays, estuaries, lagoons and coastal wetlands, to a certain extent, for spawning and early development. This may include migration into areas which are heavily influenced by freshwater inputs.

Beneficial uses of the receiving ground waters are as follows:

Table 5b. Basin Plan Beneficial Uses – Ground Waters

Discharge Point	Basin Name	Beneficial Use(s)
002	San Fernando Basin East of Highway 405 (overall) DWR Basin No. 4-12	<u>Existing:</u> Municipal and domestic water supply (MUN); industrial service supply (IND); industrial process supply (PROC); and agricultural supply (AGR).
002	Los Angeles Coastal Plain Central Basin DWR Basin No. 4-11	<u>Existing:</u> MUN, IND, PROC, and AGR.
002	Los Angeles Coastal Plain West Coast Basin DWR Basin No. 4-11	<u>Existing:</u> MUN, IND, PROC, and AGR.

T
E
N
T
A
T
I
V
E

Requirements of this Order implement the Basin Plan and subsequent amendments.

- Ammonia WQOs** –Table 3-1 through Table 3-4 of the 1994 Basin Plan provided WQOs for ammonia to protect aquatic life. Those ammonia WQOs were revised on April 25, 2002, by the Regional Water Board with the adoption of Resolution No. 2002-011, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Update the Ammonia Objectives for Inland Surface Waters (Including Enclosed Bays, Estuaries and Wetlands) with Beneficial Use Designations for Protection of Aquatic Life*. The ammonia Basin Plan amendment was approved by the State Water Board, Office of Administrative Law (OAL), and USEPA on April 30, 2003, June 5, 2003, and June 19, 2003, respectively. On December 1, 2005, Resolution No. 2005-014, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Revise the Early Life Stage Implementation Provision of the Freshwater Ammonia Objectives for Inland Surface Waters (including enclosed bays, estuaries and wetlands) for Protection of Aquatic Life*, was adopted by the Regional Water Board. Resolution No. 2005-014 was approved by the State Water Board, OAL, and USEPA on July 19, 2006, August 31, 2006, and April 5, 2007, respectively. On June 7, 2007, the Regional Water Board adopted Resolution No. 2007-005, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate Site-Specific Objectives in Select Waterbodies in the Santa Clara, Los Angeles River and San Gabriel River Watersheds*. This amendment to the Basin Plan incorporates site-specific 30-day average objectives for ammonia along with corresponding site-specific early life stage implementation provisions for select waterbody reaches and tributaries in the Santa Clara, Los Angeles, and San Gabriel River watersheds. The State Water Board, OAL, and

USEPA approved this Basin Plan amendment on January 15, 2008, May 12, 2008, and March 30, 2009, respectively.

2. **Chloride WQOs** – Table 3-8 of the 1994 Basin Plan contains WQOs for chloride. However, the chloride WQOs for some waterbodies were revised by the Regional Water Board on January 27, 1997, with the adoption of Resolution No. 97-02, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Policy for Addressing Levels of Chloride in Discharges of Wastewaters*. Resolution No. 97-02 was approved by the State Water Board, OAL, and USEPA on October 23, 1997, January 9, 1998, and February 5, 1998, respectively, and is now in effect. The chloride WQO was revised from 150 mg/L to 190 mg/L, for the Los Angeles River between Figueroa Street and Los Angeles River Estuary (Willow Street) and between Sepulveda Flood Control Basin and Figueroa Street (including Burbank Western Channel). The final effluent limitations for chloride prescribed in this Order are based on the revised chloride WQOs and apply at the end of pipe.
3. **Integrated Report** – The State Water Board proposed the California 2008-2010 Integrated Report from a compilation of the adopted Regional Water Boards' Integrated Reports containing 303(d) List of Impaired Waters and 305(b) Reports following recommendations from the Regional Water Boards and information solicited from the public and other interested parties. The Regional Water Boards' Integrated Reports were used to revise their 2006 303(d) List. On August 4, 2010, the State Water Board adopted the California 2008-2010 Integrated Report. On November 12, 2010, the USEPA approved California 2008-2010 Integrated Report Section 303(d) List of Impaired Waters requiring TMDLs for the Los Angeles Region.

The Los Angeles River and its tributaries are in the California 2008-2010 Integrated Report. The following pollutants were identified as impacting the receiving waters:

- a. **Los Angeles River Estuary (Queensway Bay)** – Calwater Watershed 40512000 (Hydro. Unit No. 405.12 in Basin Plan)
Pollutants – Chlordane (sediment)⁶, DDT (sediment)⁶, polychlorinated biphenyls (PCBs) (sediment)⁶, sediment toxicity⁶, and trash⁷.
- b. **Los Angeles River Reach 1 (Estuary to Carson Street)** – Calwater Watershed 40512000 (Hydro. Unit No. 405.12 in Basin Plan)
Pollutants – Ammonia⁷, cadmium⁷, coliform bacteria⁶, copper (dissolved)⁷, cyanide⁶, diazinon⁶, lead⁷, nutrients (algae)⁷, trash⁷, zinc (dissolved)⁷, and pH⁷

⁶ This pollutant requires a TMDL.

⁷ This pollutant is being addressed by a USEPA-approved TMDL.

- c. **Los Angeles River Reach 2 (Carson Street to Figueroa Street)** – Calwater Watershed 40515010 (Hydro. Unit No. 405.15 in Basin Plan)

Pollutants – Ammonia⁷, coliform bacteria⁶, copper⁷, lead⁷, nutrients (algae)⁷, oil⁶, and trash⁷
 - d. **Angeles River Reach 3 (Figueroa Street to Riverside Drive)** – Calwater Watershed 40521000 (Hydro. Unit No. 405.21 in Basin Plan)

Pollutants – Ammonia⁷, copper⁷, lead⁷, nutrients (algae)⁷, and trash⁷
 - e. **Burbank Western Channel** - Calwater Watershed 40521000 (Hydro. Unit No. 405.21 in Basin Plan)

Pollutants- Copper⁷, cyanide⁶, indicator bacteria⁶, lead⁷, selenium⁶, and trash⁷.
4. **TMDL** - A TMDL is a determination of the amount of a pollutant from point, nonpoint, and natural background sources plus a margin of safety, which may be discharged to a water quality-limited water body. Section 303(d) of the CWA established the TMDL process. The statutory requirements are codified at 40 CFR part 130.7. TMDLs must be developed for the pollutants of concern which impact the water quality of water bodies on the 303(d) list. According to the TMDL schedule under an amended consent decree (Heal the Bay, Santa Monica Bay Keeper, et al. v. Browner, et al. (March 22, 1999)), all TMDLs for the Los Angeles River have been approved by the Regional Water Board.
- a. **Nitrogen Compounds TMDL** – On July 10, 2003, the Regional Water Board adopted Resolution No. 2003-009, *Amendment to the Basin Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in the Los Angeles River (LA River Nitrogen Compounds TMDL)*. On November 19, 2003, the State Water Board approved the *LA River Nitrogen Compounds TMDL*. On December 4, 2003, the Regional Water Board revised the *LA River Nitrogen Compounds TMDL* by adopting Resolution No. 2003-016, *Revision of Interim Effluent Limitations for Ammonia in the Amendment to the Water Quality Control Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in the Los Angeles River*. Resolution No. 2003-016 only revised the portion of the *LA River Nitrogen Compounds TMDL* containing interim limitations for total ammonia as nitrogen for the Los Angeles-Glendale and Donald C. Tillman WRPs. All other portions of the TMDL remained unchanged. The *LA River Nitrogen Compounds TMDL* went into effect on March 23, 2004, when the Regional Water Board filed the Certificate of Fee Exemption with the California Department of Fish and Game.
- On June 7, 2007, the Regional Water Board adopted Resolution No. 2007-005, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate Site-Specific Objectives in Select Waterbodies in the*

Santa Clara, Los Angeles and San Gabriel River Watersheds. This amendment to the Basin Plan incorporates site-specific 30-day average objectives for ammonia along with corresponding site-specific early life stage implementation provisions for select waterbody reaches and tributaries in the Santa Clara, Los Angeles, and San Gabriel River watersheds. In accordance with Implementation Table, Task 8 of the *LA River Nitrogen Compounds TMDL*, "...If a site specific objective is adopted by the Regional Board, and approved by relevant approving agencies, this TMDL will need to be revised, readopted, and reapproved to reflect the revised water quality objectives."

- b. **Trash TMDL** – On September 19, 2001, the Regional Water Board adopted Resolution No. 2001-013, *Amendment to the Basin Plan for the Los Angeles Region to Incorporate a TMDL for Trash in the Los Angeles River (LA River Trash TMDL)*.

The LA River Trash TMDL was subsequently approved by the State Water Board (Resolution No. 02-038) on February 19, 2002, and by OAL on July 16, 2002. However, the State Water Board and OAL failed to approve the *LA River Trash TMDL* in time to meet the relevant federal consent decree; therefore, USEPA promulgated its own Trash TMDL in order to meet the consent decree timeline of March 23, 2002. Then, upon approval of the Regional Water Board's *LA River Trash TMDL* by OAL, USEPA approved the Regional Water Board's *Los Angeles River Trash TMDL* on August 1, 2002, and deemed it to have superseded the Trash TMDL promulgated by USEPA.

The City and the County of Los Angeles both filed petitions and complaints in the Los Angeles Superior Court challenging the *LA River Trash TMDL*. Subsequent negotiations led to a settlement agreement, which became effective on September 23, 2003. Twenty-two other cities sued the Regional Water Board to set aside the TMDL, on several grounds. On January 26, 2006, the Court of Appeal rejected the claims litigated by the cities but found that the Regional Water Board did not adequately complete the environmental checklist. The Court therefore affirmed a writ of mandate issued by the trial court ordering the Regional Water Board to set aside and not implement the *LA River Trash TMDL* until it had been brought into compliance with CEQA.

On June 8, 2006, the Regional Water Board set aside the *LA River Trash TMDL* and Resolution No. 01-013 which established it, pursuant to the writ of mandate. On August 9, 2007, the Regional Water Board approved the *LA River Trash TMDL* based on a revised CEQA analysis as Resolution No. 2007-012. The *LA River Trash TMDL* was approved by the State Water Board on April 15, 2008, and USEPA on July 24, 2008. The *LA River Trash TMDL* became effective on September 23, 2008, when the Certificate of Fee Exemption was filed with the California Department of Fish and Game.

- c. **Metals TMDL** – On June 2, 2005, the Regional Water Board adopted Resolution No. R05-006, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for*

Metals for the Los Angeles River and its Tributaries (LA River Metals TMDL). The *LA River Metals TMDL* contains Waste Load Allocations (WLAs) for cadmium, copper, lead, and zinc. On October 20, 2005, the State Water Board approved the *LA River Metals TMDL* by adopting Resolution No. 2005-0077. On December 9, 2005 and December 22, 2005, respectively, OAL and USEPA approved the *LA River Metals TMDL*. It went into effect on January 11, 2006, when the Certificate of Fee Exemption was filed with the California Department of Fish and Game.

On February 16, 2006, the cities of Bellflower, Carson, Cerritos, Downey, Paramount, Santa Fe Springs, Signal Hill, and Whittier (Cities) filed a petition for a writ of mandate challenging many aspects of the *LA River Metals TMDL* and the *Ballona Creek Metals TMDL*. (*Cities of Bellflower et al v. SWRCB et al*, Los Angeles Superior Court No. BS101732.) On May 24, 2007, the Los Angeles County Superior Court adopted the third of three rulings with respect to the writ petition. Collectively, all challenges to the *LA River Metals TMDL* were rejected, except for one CEQA claim. The Court ruled that the State and Regional Water Boards (Water Boards) should have adopted and circulated an alternatives analysis that analyzed alternatives to the project. The Court issued its writ of mandate, directing the Water Boards to adopt an alternative analysis and to reconsider the *LA River Metals TMDL* accordingly.

After considering the alternative analysis, the Regional Water Board found that the *LA River Metals TMDL* as originally proposed and adopted was appropriate. The Regional Water Board further found that nothing in the alternatives analysis nor any of the evidence generated, presented basis for the Regional Water Board to conclude that it would have acted differently when it adopted the TMDLs had the alternative analysis been prepared and circulated at that time. Thus, on September 6, 2007, the Regional Water Board adopted Resolution No. R2007-014, which reestablished the *LA River Metals TMDL* in substantially its original form.

On May 7, 2009, the Regional Water Board adopted Resolution No. 09-003, which voided and set aside Resolution Nos. R05-006, as required by the writ of mandate in the matter of *Cities of Bellflower et al v. SWRCB*.

On May 6, 2010, the Regional Water Board adopted Resolution No. R10-003, an amendment to the Basin Plan to revise the *LA River Metals TMDL*. The amendment revises the TMDL to adjust the numeric targets for copper in Reaches 1-4 of the Los Angeles River and the Burbank Western Channel and the corresponding WLAs for the Donald C. Tillman, Los Angeles-Glendale and Burbank WRPs based on an approved water effect ratio (WER) study. The revision includes language stating that regardless of the WER, the WRPs must perform at a level that can be attained by existing treatment technologies at the time of permit issuance, reissuance or modification. On April 19, 2011, the State Water Board adopted Resolution No. 2011-0021, approving the revised *LA River Metals TMDL*. At this hearing, the State Water Board made it clear that should the performance of the facility's

treatment technologies change for reasons beyond the facility's control, the permit may be reopened to revise the effluent limitations considering the applicability of the copper WER or other performance-based measure such that the effluent limitations ensure that effluent concentrations and mass discharges do not exceed the levels of water quality that can be attained by performance of this facility's treatment technologies existing at the time of permit issuance, reissuance, or modification. On July 27, 2011, and November 3, 2011, the *LA River Metals TMDL* (Resolution No. R10-003) was approved by OAL, respectively.

- d. **Bacteria TMDL** – On July 8, 2010, the Regional Water Board adopted Resolution No. R10-007, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Indicator Bacteria in the Los Angeles River Watershed (LA River Bacteria TMDL)*. The *LA River Bacteria TMDL* contains WLAs for Donald C. Tillman, Los Angeles-Glendale, and Burbank WRPs, which are set equal to a 7-day median of 2.2 MPN/100 mL of *E. coli* and/or a daily max of 235 MPN/100mL to ensure zero days of allowable exceedances. No exceedances of the geometric mean TMDL numeric target of 126/100 mL *E.coli* are permitted. The *LA River Bacteria TMDL* must still be approved by the State Water Board, OAL, and USEPA before it becomes effective.
- I. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.
- J. **State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. **Compliance Schedules and Interim Requirements.** Section 2.1 of the SIP provides that, based on a Discharger's request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued,

nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation exceeds one year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised WQO. This Order does not include compliance schedules and interim effluent limitations.

- L. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes. (40 CFR. section 131.21; 65 Federal Register 24641 (April 27, 2000).) Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- M. Title 22 of the California Code of Regulations (Title 22).** The California Department of Public Health established primary and secondary maximum contaminant levels (MCLs) for inorganic, organic, and radioactive contaminants in drinking water. These MCLs are codified in Title 22. The Basin Plan (Chapter 3) incorporates Title 22 primary MCLs by reference. This incorporation by reference is prospective, including future changes to the incorporated provisions as the changes take effect. Title 22 primary MCLs have been used as the basis for effluent limitations in WDRs and NPDES permits to protect groundwater recharge beneficial use when that receiving groundwater is designated as municipal and domestic supply (MUN). Also, the Basin Plan specifies that "Groundwaters shall not contain taste or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses."
- N. Stringency of Requirements for Individual Pollutants.** This Order contains both TBELs and WQBELs for individual pollutants. The TBELs consist of restrictions on BOD, TSS, pH, and percent removal of BOD and TSS. Restrictions on BOD, TSS, and pH are discussed in section IV.B. of the Fact Sheet (Attachment F). This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements.

WQBELs have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal WQS. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR part 131.38. The scientific procedures for calculating the individual WQBELs for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that

date, are nonetheless “applicable WQS for purposes of the CWA” pursuant to 40 CFR part 131.21(c)(1).

This Order contains pollutant restrictions that are more stringent than applicable federal requirements and standards. Specifically, this Order includes effluent limitations for BOD and TSS that are more stringent than applicable federal standards, but that are nonetheless necessary to meet numeric objectives or protect beneficial uses. The rationale for including these limitations is explained in Section IV.B. of the Fact Sheet.

- O. Sources of Drinking Water Policy (SODW Policy).** On May 19, 1988, the State Water Board adopted Resolution No. 88-63, *Sources of Drinking Water Policy*, which established a policy that all surface and ground waters, with limited exemptions, are suitable or potentially suitable for municipal and domestic supply. To be consistent with State Water Board’s SODW policy, on March 27, 1989, the Regional Water Board adopted Resolution No. 89-03, *Incorporation of Sources of Drinking Water Policy into the Water Quality Control Plans (Basin Plans) – Santa Clara River Basin (4A)/ Los Angeles River Basin (4B)*.

Consistent with Regional Water Board Resolution No. 89-03 and State Water Board Resolution No. 88-63, in 1994 the Regional Water Board conditionally designated all inland surface waters in Table 2-1 of the 1994 Basin Plan as existing, intermittent, or potential for MUN. However, the conditional designation in the 1994 Basin Plan included the following implementation provision: “no new effluent limitations will be placed in WDRs as a result of these [potential MUN designations made pursuant to the SODW policy and the Regional Water Board’s enabling resolution] until the Regional Water Board adopts [a special Basin Plan Amendment that incorporates a detailed review of the waters in the Region that should be exempted from the potential MUN designations arising from SODW policy and the Regional Water Board’s enabling resolution].” On February 15, 2002, the USEPA clarified its partial approval (May 26, 2000) of the 1994 Basin Plan amendments and acknowledged that the conditional designations do not currently have a legal effect, do not reflect new water quality standards subject to USEPA review, and do not support new effluent limitations based on the conditional designations stemming from the SODW Policy until a subsequent review by the Regional Water Board finalizes the designations for these waters. This permit is designed to be consistent with the existing Basin Plan.

- P. Antidegradation Policy.** Section 131.12 requires that the state WQS include an antidegradation policy consistent with the federal policy. The State Water Board established California’s antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board’s Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet (Attachment F) the permitted discharge is consistent with the antidegradation provision of section 131.12 and State Water Board Resolution No. 68-16.

T
E
N
T
A
T
I
V
E

- Q. Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40 CFR part 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. Some effluent limitations in this Order are less stringent than those in the previous Order. As discussed in detail in the Fact Sheet this relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.
- R. Endangered Species Act (ESA).** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California ESA (Fish and Game Code sections 2050 to 2097) or the Federal ESA (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The discharger is responsible for meeting all requirements of the applicable ESA.
- S. Monitoring and Reporting.** 40 CFR part 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP) establishes monitoring and reporting requirements to implement federal and state requirements. This Monitoring and Reporting Program is provided in Attachment E.
- T. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR part 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR part 122.42 are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR part 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet (Attachment F).
- U. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections VI.C. of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- V. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet (Attachment F) of this Order.

W. Consideration of Public Comment. The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet (Attachment F) of this Order.

**T
E
N
T
A
T
I
V
E**

THEREFORE, IT IS HEREBY ORDERED, that this Order supercedes Order No. R4-2006-0085 as amended by Order No. R4-2010-0058 except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the CWC (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

III. DISCHARGE PROHIBITIONS

- A. Discharge of wastewater at a location different from that described in this Order is prohibited.
- B. The bypass or overflow of untreated wastewater or wastes to surface waters or surface water drainage courses is prohibited, except as allowed in Standard Provision I.G. of Attachment D, Standard Provisions.
- C. The monthly average effluent dry weather discharge flow rate from the facility shall not exceed the design capacity.
- D. The Discharger shall not cause degradation of any water supply, except as consistent with State Water Board Resolution No. 68-16.
- E. The treatment or disposal of wastes from the facility shall not cause pollution or nuisance as defined in section 13050, subdivision (l) and (m) of the CWC.
- F. The discharge of any substances in concentrations toxic to animal or plant is prohibited.
- G. The discharge of any radiological, chemical, or biological warfare agent or high level radiological waste is prohibited.

T
E
N
T
A
T
I
V
E

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations

1. Effluent Limitations Applicable to Discharge Point 002

- a. The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 002 into Burbank Western Channel, tributary to the Los Angeles River, with compliance measured at Monitoring Location EFF-002 as described in the attached Monitoring and Reporting Program (MRP) (Attachment E).

Table 6. Effluent Limitations Applicable to Discharge Point 001

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
BOD ₅ 20°C	mg/L	20	30	45	--	--
	lbs/day ⁸	2085	3130	4690	--	--
Total Suspended Solids (TSS)	mg/L	15	40	45	--	--
	lbs/day ⁸	1560	4170	4690	--	--
pH	standard units	--	--	--	6.5	8.5
Oil and Grease	mg/L	10	--	15	--	--
	lbs/day ⁸	1040	--	1560	--	--
Settleable Solids	ml/L	0.1	--	0.3	--	--
Total Residual Chlorine	mg/L	--	--	0.1	--	--
	lbs/day ⁸	--	--	17	--	--
Total Dissolved Solids	mg/L	950	--	--	--	--
	lbs/day ⁸	99,040	--	--	--	--
Sulfate	mg/L	300	--	--	--	--
	lbs/day ⁸	31,300	--	--	--	--
Chloride	mg/L	190	--	--	--	--
	lbs/day ⁸	19,800	--	--	--	--
MBAS	mg/L	0.5	--	--	--	--
	lbs/day ⁸	52	--	--	--	--
Ammonia Nitrogen	mg/L	2.1 ⁹	--	9.1 ⁹	--	--
	lbs/day ⁸	--	--	--	--	--

⁸ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day, or Flow (MGD) x Concentration (µg/L) x 0.00834 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

⁹ This is the waste load allocation (WLA) according to the Nitrogen Compounds TMDL Resolution No. 2003-009, adopted by the Regional Board on July 10, 2003. The WLA serves as the effluent limitation for the discharge. It became effective on March 23, 2004.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Nitrate + Nitrite (as N)	mg/L	7.2 ⁹	--	--	--	--
	lbs/day ⁸	--	--	--	--	--
Nitrate (as N)	mg/L	7.2 ⁹	--	--	--	--
	lbs/day ⁸	--	--	--	--	--
Nitrite (as N)	mg/L	0.9 ⁹	--	--	--	--
	lbs/day ⁸	--	--	--	--	--
Antimony	µg/L	6	--	--	--	--
	lbs/day ⁸	0.6	--	--	--	--
Cadmium (Wet-weather)	µg/L	3.2 ¹⁰	--	8.3 ¹⁰	--	--
	lbs/day ⁸	0.33 ¹¹	--	0.87 ¹¹	--	--
Copper (Dry and Wet-weather)	µg/L	36 ^{10,12}	--	43 ^{10,12}	--	--
	lbs/day ⁸	3.8 ¹¹	--	4.5 ¹¹	--	--
Lead (Dry and Wet-weather)	µg/L	7.4 ^{10,12}	--	15 ^{10,12}	--	--
	lbs/day ⁸	0.77 ¹¹	--	1.6 ¹¹	--	--
Zinc (Wet-weather)	µg/L	159 ¹⁰	--	211 ¹⁰	--	--
	lbs/day ⁸	17 ¹¹	--	22 ¹¹	--	--
Cyanide	µg/L	4.2	--	8.5	--	--
	lbs/day ⁸	0.44	--	0.89	--	--
Dibromochloromethane	µg/L	34	--	94	--	--
	lbs/day ⁸	3.5	--	9.9	--	--
Benzo(a)anthracene	µg/L	0.049	--	0.098	--	--
	lbs/day ⁸	0.0051	--	0.010	--	--
Benzo(a)pyrene	µg/L	0.049	--	0.098	--	--
	lbs/day ⁸	0.0051	--	0.010	--	--
Benzo(b)fluoranthene	µg/L	0.049	--	0.098	--	--
	lbs/day ⁸	0.0051	--	0.010	--	--
Benzo(k)fluoranthene	µg/L	0.049	--	0.098	--	--
	lbs/day ⁸	0.0051	--	0.010	--	--
Bis(2-Ethylhexyl) Phthalate	µg/L	4	--	--	--	--
	lbs/day ⁸	0.4	--	--	--	--
Chrysene	µg/L	0.049	--	0.098	--	--
	lbs/day ⁸	0.0051	--	0.010	--	--
Dibenzo(a,h)Anthracene	µg/L	0.049	--	0.098	--	--
	lbs/day ⁸	0.0051	--	0.010	--	--

¹⁰ Wet-weather effluent limitations apply when the maximum daily flow measured at the Los Angeles River Wardlow station is equal to or greater than 500 cubic feet per second.

¹¹ According to *LA River Metals TMDL*, the mass-based effluent limitations for cadmium, copper, lead, and zinc do not apply during wet weather when the influent exceeds the plant design flow rate of 12.5 mgd.

¹² Dry-weather effluent limitations apply when the maximum daily flow measured at the Los Angeles River Wardlow station is less than 500 cubic feet per second.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Hexachlorobenzene	µg/L	0.00077	--	0.0015	--	--
	lbs/day ⁸	0.000080	--	0.000156	--	--
Indeno(1,2,3-cd)pyrene	µg/L	0.049	--	0.098	--	--
	lbs/day ⁸	0.0051		0.010		
Total trihalomethanes	µg/L	80	--	--	--	--
	lbs/day ⁸	8.3	--	--	--	--
Iron	µg/L	300	--	--	--	--
	lbs/day ⁸	31	--	--	--	--

2. Other Effluent Limitations Applicable to Discharge Point 002

- a. **Percent removal:** The average monthly removal of BOD 5-day 20°C and total suspended solids shall not be less than 85 percent.
- b. The temperature of wastes discharged shall not exceed 86°F except as a result of external ambient temperature.
- c. Radioactivity of the wastes discharged shall not exceed the limits specified in title 22, chapter 15, article 5, section 64443, of the California Code of Regulations (CCR), or subsequent revisions.
- d. The wastes discharged to water courses shall at all times be adequately disinfected. For the purpose of this requirement, the wastes shall be considered adequately disinfected if the median number of total coliform bacteria in the disinfected effluent does not exceed an MPN or CFU of 2.2 per 100 milliliters, and the number of total coliform bacteria does not exceed an MPN or CFU of 23 per 100 milliliters in more than one sample within any 30-day period. No sample shall exceed an MPN or CFU of 240 total coliform bacteria per 100 milliliters. The median value shall be determined from the bacteriological results of the last seven (7) days for which an analysis has been completed. Samples shall be collected at a time when wastewater flow and characteristics are most demanding on treatment facilities and disinfection processes.
- e. For the protection of the water contact recreation beneficial use, the wastes discharged to water courses shall have received adequate treatment, so that the turbidity of the wastewater does not exceed any of the following: (a) an average of 2 Nephelometric turbidity units (NTUs) within a 24-hour period; (b) 5 NTUs more than 5 percent of the time (72 minutes) within a 24-hour period; and (c) 10 NTU at any time.
- f. To protect the underlying ground water basins, pollutants shall not be present in the wastes discharged at concentrations that pose a threat to ground water quality.

g. Acute Toxicity Limitation

- a. The acute toxicity of the effluent shall be such that:
 - (i) the average survival in the undiluted effluent for any three (3) consecutive 96-hour static renewal bioassay tests shall be at least 90%, and
 - (ii) no single test producing less than 70% survival.
- b. If either of the above requirements IV.A.4.g.a.(i) or IV.A.4.g.a.(ii) is not met, the Discharger shall conduct six additional tests, taken approximately every two weeks, over a 12-week period. The Discharger shall ensure that results of a failing acute toxicity test are received by the Discharger within 24 hours of completion of the test and the additional tests shall begin within 5 business days of receipt of the result. If the additional tests indicate compliance with acute toxicity limitation, the Discharger may resume regular testing. However, if the results of any two of the six accelerated tests are less than 90% survival, then the Discharger shall begin a Toxicity Identification Evaluation (TIE). The TIE shall include all reasonable steps to identify the sources of toxicity. Once the sources are identified, the Discharger shall take all reasonable steps to reduce toxicity to meet the objective.
- c. If the initial test and any of the additional six acute toxicity bioassay tests results are less than 70% survival, the Discharger shall immediately implement Initial Investigation Toxicity Reduction Evaluation (TIRE) Workplan.
- d. The Discharger shall conduct acute toxicity monitoring as specified in Attachment E - MRP.

h. Chronic Toxicity Trigger and Requirements:

- a. The chronic toxicity of the effluent shall be expressed and reported in toxic units, where:

$$TU_c = \frac{100}{NOEC}$$

The No Observable Effect Concentration (NOEC) is expressed as the maximum percent effluent concentration that causes no observable effect on test organisms, as determined by the results of a critical life stage toxicity test.

- b. There shall be no chronic toxicity in the effluent discharge.
- c. If the chronic toxicity of the effluent exceeds the monthly median trigger of 1.0 TU_c , the Discharger shall immediately implement accelerated chronic toxicity testing according to Attachment E - MRP, Section V.B.3. If any three out of the initial test and the six accelerated tests results exceed 1.0 TU_c , the Discharger shall initiate a TIE and implement the Initial Investigation TRE Workplan, as specified in Attachment E – MRP, Section V.D.
- d. The Discharger shall conduct chronic toxicity monitoring as specified in Attachment E – MRP.

B. Reclamation Specifications – Discharge Point 002

- 1. The Discharger recycled 520 million gallons of tertiary-treated effluent in 2010 and plans to continue doing so. The production, distribution, and reuse of recycled water for direct, non-potable applications are presently regulated under Water Recycling Requirements contained in Order No. 91-101. The Public Works Department for the City of Burbank is the agency who distributes the recycled water. There are currently over 26 users of the recycled water produced by the Plant. Recycled water is used mainly in cooling towers at the Burbank Water and Power Plant and for landscape irrigation at a golf course, schools, parks, and medians located throughout the City.

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations are based on WQOs contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in Los Angeles River:

1. For waters designated with a warm freshwater habitat (WARM) beneficial use, the temperature of the receiving water at any time or place and within any given 24-hour period shall not be altered by more than 5°F above the natural temperature and shall not be raised above 86°F due to the discharge of effluent at the receiving water station located downstream of the discharge. Natural conditions shall be determined on a case-by-case basis.

If the receiving water temperature, downstream of the discharge, exceeds 86°F as a result of the following:

- a. High temperature in the ambient air; or,
- b. High temperature in the receiving water upstream of the discharge,

then the exceedance shall not be considered a violation.

2. The pH of inland surface waters shall not be depressed below 6.5 or raised above 8.5 as a result of wastes discharged. Ambient pH levels shall not be changed more than 0.5 units from natural conditions as a result of wastes discharged. Natural conditions shall be determined on a case-by-case basis.
3. The dissolved oxygen in the receiving water shall not be depressed below 5 mg/L as a result of the wastes discharged.
4. The fecal coliform concentration in the receiving water shall not exceed the following, as a result of wastes discharged:
 - a. Geometric Mean Limits
 - i. E.coli density shall not exceed 126/100 mL.
 - ii. Fecal coliform density shall not exceed 200/100 mL.
 - b. Single Sample Limits
 - i. E.coli density shall not exceed 235/100 mL.
 - ii. Fecal coliform density shall not exceed 400/100 mL.

5. Waters shall be free of changes in turbidity that cause nuisance or adversely affect beneficial uses. Increases in natural turbidity attributable to controllable water quality factors shall not exceed the following limits, as a result of wastes discharged:
 - a. Where natural turbidity is between 0 and 50 NTU, increases shall not exceed 20%, and
 - b. Where natural turbidity is greater than 50 NTU, increases shall not exceed 10%.
6. The wastes discharged shall not produce concentrations of toxic substances in the receiving water that are toxic to or cause detrimental physiological responses in human, animal, or aquatic life.
7. The wastes discharged shall not cause concentrations of contaminants to occur at levels that are harmful to human health in waters which are existing or potential sources of drinking water.
8. The concentrations of toxic pollutants in the water column, sediments, or biota shall not adversely affect beneficial uses as a result of the wastes discharged.
9. The wastes discharged shall not contain substances that result in increases in BOD, which adversely affect the beneficial uses of the receiving waters.
10. Waters shall not contain biostimulatory substances in concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses.
11. The wastes discharged shall not cause the receiving waters to contain any substance in concentrations that adversely affect any designated beneficial use.
12. The wastes discharged shall not alter the natural taste, odor, and color of fish, shellfish, or other surface water resources used for human consumption.
13. The wastes discharged shall not result in problems due to breeding of mosquitoes, gnats, black flies, midges, or other pests.
14. The wastes discharged shall not result in visible floating particulates, foams, and oil and grease in the receiving waters.
15. The wastes discharged shall not alter the color of the receiving waters; create a visual contrast with the natural appearance of the water; nor cause aesthetically undesirable discoloration of the receiving waters.
16. The wastes discharged shall not contain any individual pesticide or combination of pesticides in concentrations that adversely affect beneficial uses of the receiving

waters. There shall be no increase in pesticide concentrations found in bottom sediments or aquatic life as a result of the wastes discharged.

17. Acute Toxicity Receiving WQO

- a. There shall be no acute toxicity in ambient waters as a result of wastes discharged.
- b. Receiving water and effluent toxicity testing shall be performed on the same day as close to concurrently as possible.
- c. The acute toxicity of the receiving water, at monitoring location RSW-001D (formerly referred to as R-2) located immediately downstream of the discharge, shall be such that: (i) the average survival in the undiluted receiving water for any three (3) consecutive 96-hour static, static-renewal, or continuous flow bioassay tests shall be at least 90%, and (ii) no single test producing less than 70% survival. Static-renewal bioassay tests may be used, as allowed by the most current USEPA test method for measuring acute toxicity.
- d. If the upstream acute toxicity of the receiving water is greater than the downstream acute toxicity but the effluent acute toxicity is in compliance, acute toxicity accelerated monitoring in the receiving water according to MRP Section V.A.2.d does not apply.

18. Chronic Toxicity Receiving WQO

- a. There shall be no chronic toxicity in ambient waters as a result of wastes discharged.
- b. Receiving water and effluent toxicity testing shall be performed on the same day as close to concurrently as possible.
- c. If the chronic toxicity in the receiving water at the monitoring station immediately downstream of the discharge, exceeds the monthly median of 1.0 TU_c trigger in a critical life stage test and the toxicity cannot be attributed to upstream toxicity, as assessed by the Discharger, then the Discharger shall immediately implement an accelerated chronic toxicity testing according to MRP CI No. 4424, section V.B.3. If two of the six tests exceed a 1.0 TU_c trigger, the Discharger shall initiate a TIE and implement the Initial Investigation TRE Workplan.
- d. If the chronic toxicity of the receiving water upstream of the discharge is greater than the downstream and the TU_c of the effluent chronic toxicity test is less than or equal to a monthly median of 1 TU_c trigger, then accelerated monitoring need not be implemented.

B. Groundwater Limitations

1. The discharge shall not cause the underlying groundwater to be degraded, exceed water quality objectives, unreasonably affect beneficial uses, or cause a condition of pollution or nuisance.

VI. PROVISIONS

A. Standard Provisions

1. Standard Provisions

The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.

2. Regional Water Board Standard Provisions

The Discharger shall comply with the Regional Water Board-specific Standard Provisions as follows:

- a. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or nuisance as defined by Section 13050 of the CWC.
- b. Odors, vectors, and other nuisances of sewage or sludge origin beyond the limits of the treatment plant site or the sewage collection system due to improper operation of facilities, as determined by the Regional Water Board, are prohibited.
- c. All facilities used for collection, transport, treatment, or disposal of "wastes" shall be adequately protected against damage resulting from overflow, washout, or inundation from a storm or flood having a recurrence interval of once in 100 years.
- d. Collection, treatment, and disposal systems shall be operated in a manner that precludes public contact with wastewater.
- e. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer of the Regional Water Board.
- f. The provisions of this order are severable. If any provision of this order is found invalid, the remainder of this Order shall not be affected.
- g. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the discharger from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation under authority preserved by section 510 of the CWA.

- h. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the discharger from any responsibilities, liabilities or penalties to which the discharger is or may be subject to under section 311 of the CWA.
- i. The Discharger must comply with the lawful requirements of municipalities, counties, drainage districts, and other local agencies regarding discharges of storm water to storm drain systems or other water courses under their jurisdiction, including applicable requirements in municipal storm water management program developed to comply with NPDES permits issued by the Regional Water Board to local agencies.
- j. Discharge of wastes to any point other than specifically described in this Order is prohibited, and constitutes a violation thereof.
- k. The Discharger shall comply with all applicable effluent limitations, national standards of performance, toxic effluent standards, and all federal regulations established pursuant to sections 301, 302, 303(d), 304, 306, 307, 316, 403, and 405 of the CWA and amendments thereto.
- l. These requirements do not exempt the operator of the waste disposal facility from compliance with any other laws, regulations, or ordinances which may be applicable; they do not legalize this waste disposal facility, and they leave unaffected any further restraints on the disposal of wastes at this site which may be contained in other statutes or required by other agencies.
- m. Oil or oily material, chemicals, refuse, or other pollutionable materials shall not be stored or deposited in areas where they may be picked up by rainfall and carried off of the property and/or discharged to surface waters. Any such spill of such materials shall be contained and removed immediately.
- n. A copy of these waste discharge specifications shall be maintained at the discharge facility so as to be available at all times to operating personnel.
- o. If there is any storage of hazardous or toxic materials or hydrocarbons at this facility and if the facility is not manned at all times, a 24-hour emergency response telephone number shall be prominently posted where it can easily be read from the outside.
- p. The Discharger shall file with the Regional Water Board a report of waste discharge at least 120 days before making any material change or proposed change in the character, location or volume of the discharge.
- q. In the event of any change in name, ownership, or control of these waste disposal facilities, the discharger shall notify the Regional Water Board of such change and shall notify the succeeding owner or operator of the existence of this Order by letter, copy of which shall be forwarded to the Regional Water Board.

- r. The CWC provides that any person who violates a waste discharge requirement or a provision of the CWC is subject to civil penalties of up to \$5,000 per day, \$10,000 per day, or \$25,000 per day of violation, or when the violation involves the discharge of pollutants, is subject to civil penalties of up to \$10 per gallon per day or \$25 per gallon per day of violation; or some combination thereof, depending on the violation, or upon the combination of violations. Violation of any of the provisions of the NPDES program or of any of the provisions of this Order may subject the violator to any of the penalties described herein, or any combination thereof, at the discretion of the prosecuting authority; except that only one kind of penalty may be applied for each kind of violation.
- s. Under CWC 13387, any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this order, including monitoring reports or reports of compliance or noncompliance, or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained in this order and is subject to a fine of not more than \$25,000 or imprisonment of not more than two years, or both. For a second conviction, such a person shall be punished by a fine of not more than \$25,000 per day of violation, or by imprisonment of not more than four years, or by both.
- t. The discharge of any waste resulting from the combustion of toxic or hazardous wastes to any waste stream that ultimately discharges to waters of the United States is prohibited, unless specifically authorized elsewhere in this permit.
- u. The Discharger shall notify the Executive Officer in writing no later than 6 months prior to planned discharge of any chemical, other than the products previously reported to the Executive Officer, which may be toxic to aquatic life. Such notification shall include:
 - (1) Name and general composition of the chemical,
 - (2) Frequency of use,
 - (3) Quantities to be used,
 - (4) Proposed discharge concentrations, and
 - (5) USEPA registration number, if applicable.
- v. Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this facility, may subject the Discharger to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Discharger to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
- w. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition, maximum daily effluent limitation, or receiving water limitation of this Order, the Discharger shall notify Watershed Regulatory Section Chief at the Regional Water Board by telephone (213) 576-6616, or electronically dhung@waterboards.ca.gov within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days,

unless the Regional Water Board waives confirmation. The written notification shall state the nature, time, duration, and cause of noncompliance, and shall describe the measures being taken to remedy the current noncompliance and, prevent recurrence including, where applicable, a schedule of implementation. Other noncompliance requires written notification as above at the time of the normal monitoring report.

- x. Prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a watercourse, the Discharger must file a petition with the State Water Board, Division of Water Rights, and receive approval for such a change. (CWC section 1211)

B. Monitoring and Reporting Program (MRP) Requirements

The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E of this Order.

C. Special Provisions

1. Reopener Provisions

- a. This Order may be modified, revoked and reissued, or terminated for cause, including, but not limited to:
 - (1) Violation of any term or condition contained in this Order;
 - (2) Obtaining this Order by misrepresentation, or by failure to disclose fully all relevant facts; and,
 - (3) A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.

The filing of a request by the Discharger for an Order modification, revocation, and issuance or termination, or a notification of planned changes or anticipated noncompliances does not stay any condition of this Order.

- b. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.
- c. This Order may be modified, in accordance with the provisions set forth in 40 CFR, parts 122 and 124 to include requirements for the implementation of the watershed protection management approach.

- d. The Regional Water Board may modify, or revoke and reissue this Order if present or future investigations demonstrate that the discharge(s) governed by this Order will cause, have the potential to cause, or will contribute to adverse impacts on water quality and/or beneficial uses of the receiving waters.
- e. This Order may also be modified, revoked and reissued, or terminated in accordance with the provisions of 40 CFR parts 122.44, 122.62 to 122.64, 125.62, and 125.64. Causes for taking such actions include, but are not limited to, failure to comply with any condition of this Order, endangerment to human health or the environment resulting from the permitted activity, or acquisition of newly obtained information which would have justified the application of different conditions if known at the time of Order adoption. The filing of a request by the Discharger for an Order modification, revocation and issuance or termination, or a notification of planned changes or anticipated noncompliance does not stay any condition of this Order.
- f. This Order may be modified, in accordance with the provisions set forth in 40 CFR parts 122 to 124, to include new Minimum Levels.
- g. This Order may be reopened and modified, to revise effluent limitations as a result of future Basin Plan Amendments, such as an update of a water quality objective, or the adoption of a TMDL for the Los Angeles River Watershed.
- h. This Order may be reopened and modified, to revise effluent limitations as a result of the delisting of a pollutant from the 303(d) list.
- i. This Order may be reopened and modified to revise the chronic toxicity effluent limitation, and/or total residual chlorine limitations, to the extent necessary, to be consistent with State Water Board precedential decisions, new policies, new laws, or new regulations.
- j. This Order may be reopened to modify final effluent limits, if at the conclusion of necessary studies conducted by the Discharger, the Regional Water Board determines that dilution credits, attenuation factors, water effects ratio, site specific objectives, or metal translators are warranted.
- k. This Order may be reopened to modify copper effluent limitations consistent with the *LA River Metals TMDL* and its implementation plan.

2. Special Studies, Technical Reports, and Additional Monitoring Requirements

a. Special Study – Constituents of Emerging Concern (CECs) in the Effluent

- i. The Discharger shall conduct a special study to investigate the CECs in the effluent discharge. Within six months of the effective date of this Order, the Discharger shall submit to the Executive Officer a CECs Special Study Work Plan (Work Plan) for approval. Upon approval, the Discharger shall implement the Work Plan.
- ii. The Discharger shall follow the requirements of the Special Study Work Plan as discussed in the MRP and the Fact Sheet.

b. Toxicity Reduction Requirements

The Discharger shall update its existing initial investigation Toxicity Reduction Evaluation (TRE) workplan and submit a copy of the revised initial investigation TRE workplan to the Executive Officer of the Regional Water Board for approval within 90 days of the effective date of this permit. If the Executive Officer does not disapprove the workplan within 60 days from the date in which it was received, the workplan shall become effective. The Discharger shall use USEPA manual EPA/833B-99/002 (municipal) or most current version as guidance. At a minimum, the initial investigation TRE workplan must contain the provisions in Attachment G. This workplan shall describe the steps the Discharger intends to follow if toxicity is detected, and should include, at a minimum:

- (1) A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
- (2) A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in the operation of the facility; and,
- (3) If a toxicity identification evaluation (TIE) is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor).

If the effluent toxicity test result exceeds the limitation, then the Discharger shall immediately implement accelerated toxicity testing that consists of six additional tests, each test done approximately every two weeks, over a 12-week period. Effluent sampling for the first test of the six additional tests shall commence within 5 days of receipt of the test results exceeding the toxicity limitation.

If the results of any two of the six tests (any two tests in a 12-week period) exceed the limitation, the Discharger shall initiate a Toxicity Reduction Evaluation (TRE).

If results of the implementation of the facility's initial investigation TRE workplan (as described above) indicate the need to continue the TRE/TIE, the Discharger shall expeditiously develop a more detailed TRE workplan for submittal to the Executive Officer within 15 days of completion of the initial investigation TRE.

Detailed toxicity testing and reporting requirements are contained in Section V of the MRP, (Attachment E).

b. Treatment Plant Capacity

The Discharger shall submit a written report to the Executive Officer of the Regional Water Board within 90 days after the "30-day (monthly) average" daily dry-weather flow equals or exceeds 75 percent of the design capacity of waste treatment and/or disposal facilities. The Discharger's senior administrative officer shall sign a letter, which transmits that report and certifies that the discharger's policy-making body is adequately informed of the report's contents. The report shall include the following:

- (1) The average daily flow for the month, the date on which the peak flow occurred, the rate of that peak flow, and the total flow for the day;
- (2) The best estimate of when the monthly average daily dry-weather flow rate will equal or exceed the design capacity of the facilities; and
- (3) A schedule for studies, design, and other steps needed to provide additional capacity for waste treatment and/or disposal facilities before the waste flow rate equals the capacity of present units.

This requirement is applicable to those facilities which have not reached 75 percent of capacity as of the effective date of this Order. For those facilities that have reached 75 percent of capacity by that date but for which no such report has been previously submitted, such report shall be filed within 90 days of the issuance of this Order.

3. Best Management Practices and Pollution Prevention

a. Storm Water Pollution Prevention Plan (SWPPP) Not Applicable

b. Spill Clean-up Contingency Plan (SCCP)

Within 90 days, the Discharger is required to submit a Spill Clean-up Contingency Plan, which describes the activities and protocols, to address clean-up of spills, overflows, and bypasses of untreated or partially treated wastewater from the Discharger's collection system or treatment facilities, that reach water bodies, including dry channels and beach sands. At a minimum, the interim Plan shall include sections on spill clean-up and containment measures, public notification, and monitoring. The Discharger shall review and amend the Plan as appropriate after each spill from the facility or in the service area of the facility.

The Discharger shall include a discussion in the annual summary report of any modifications to the Plan and the application of the Plan to all spills during the year.

c. Pollutant Minimization Program (PMP)

Reporting protocols in the MRP, Attachment E, section X.B.4 describe sample results that are to be reported as Detected but Not Quantified (DNQ) or Not Detected (ND). Definitions for a reported Minimum Level (ML) and Method Detection Limit (MDL) are provided in Attachment A. These reporting protocols and definitions are used in determining the need to conduct a Pollution Minimization Program (PMP) as follows:

The Discharger shall be required to develop and conduct a PMP as further described below when there is evidence (e.g., sample results reported as DNQ when the effluent limitation is less than the MDL, sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, results of benthic or aquatic organism tissue sampling) that a pollutant is present in the effluent above an effluent limitation and either:

- (1) The concentration of the pollutant is reported as DNQ and the effluent limitation is less than the reported ML; or
- (2) The concentration of the pollutant is reported as ND and the effluent limitation is less than the MDL.

The goal of the PMP shall be to reduce all potential sources of a pollutant through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost-effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to CWC Section 13263.3(d), shall be considered to fulfill the PMP requirements.

The PMP shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:

- (1) An annual review and semi-annual monitoring of potential sources of the reportable pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling;
- (2) Quarterly monitoring for the reportable pollutant(s) in the influent to the wastewater treatment system;

- (3) Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable pollutant(s) in the effluent at or below the effluent limitation;
- (4) Implementation of appropriate cost-effective control measures for the reportable pollutant(s), consistent with the control strategy; and
- (5) An annual status report that shall be sent to the Regional Water Board including:
 - (a) All PMP monitoring results for the previous year;
 - (b) A list of potential sources of the reportable pollutant(s);
 - (c) A summary of all actions undertaken pursuant to the control strategy; and
 - (d) A description of actions to be taken in the following year.

4. Construction, Operation and Maintenance Specifications

- a. Wastewater treatment facilities subject to this Order shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to chapter 3, subchapter 14, title 23 of the CCR (section 13625 of the CWC).
- b. The Discharger shall maintain in good working order a sufficient alternate power source for operating the wastewater treatment and disposal facilities. All equipment shall be located to minimize failure due to moisture, liquid spray, flooding, and other physical phenomena. The alternate power source shall be designed to permit inspection and maintenance and shall provide for periodic testing. If such alternate power source is not in existence, the discharger shall halt, reduce, or otherwise control all discharges upon the reduction, loss, or failure of the primary source of power.

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Sludge Disposal Requirements (Not Applicable)

- (1) All sludge generated at the wastewater treatment plant is returned back to the sewer for transport and processing at the Hyperion Treatment Plant.

b. Pretreatment Requirements

- (1) This Order includes the Discharger's Pretreatment Program as previously submitted to this Regional Water Board. Any change to the Program shall be reported to the Regional Water Board in writing and shall not become effective until approved by the Executive Officer in accordance with procedures established in 40 CFR part 403.18.

- (2) The Discharger shall enforce the requirements promulgated under sections 307(b), 307(c), 307(d), and 402(b) of the Federal Clean Water Act with timely, appropriate, and effective enforcement actions. The Discharger shall require industrial users to comply with Federal Categorical Standards and shall initiate enforcement actions against those users who do not comply with the standards. The Discharger shall require industrial users subject to the Federal Categorical Standards to achieve compliance no later than the date specified in those requirements or, in the case of a new industrial user, upon commencement of the discharge.
- (3) The Discharger shall perform the pretreatment functions as required in Federal Regulations 40 CFR part 403 including, but not limited to:
 - A. Implement the necessary legal authorities as provided in 40 CFR part 403.8(f)(1);
 - B. Enforce the pretreatment requirements under 40 CFR part 403.5 and 403.6;
 - C. Implement the programmatic functions as provided in 40 CFR part 403.8(f)(2); and
 - D. Provide the requisite funding of personnel to implement the Pretreatment Program as provided in 40 CFR part 403.8(f)(3).
- (4) The Discharger shall submit semiannual and annual reports to the Regional Water Board, with copies to the State Water Board, and USEPA Region 9, describing the Discharger's pretreatment activities over the period. The annual and semiannual reports shall contain, but not be limited to, the information required in the attached *Pretreatment Reporting Requirements* (Attachment J), or an approved revised version thereof. If the Discharger is not in compliance with any conditions or requirements of this Order, the Discharger shall include the reasons for noncompliance and shall state how and when the Discharger will comply with such conditions and requirements.
- (5) The Discharger shall be responsible and liable for the performance of all control authority pretreatment requirements contained in 40 CFR part 403, including subsequent regulatory revisions thereof. Where 40 CFR part 403 or subsequent revision places mandatory actions upon the Discharger as Control Authority but does not specify a timetable for completion of the actions, the Discharger shall complete the required actions within six months from the effective date of this Order or the effective date of 40 CFR part 403 revisions, whichever comes later. For violations of pretreatment requirements, the Discharger shall be subject to enforcement actions, penalties, fines, and other remedies by the Regional Water Board, USEPA, or other appropriate parties, as provided in the Federal Clean Water Act. The Regional Water Board or USEPA may initiate enforcement action against an industrial user for

noncompliance with acceptable standards and requirements as provided in the Federal Clean Water Act and/or the CWC.

- c. The Discharger's collection system is part of the system that is subject to this Order. As such, the Discharger must properly operate and maintain its collection system (40 CFR part 122.41(e)). The Discharger must report any non-compliance (40 CFR part 122.41(l)(6) and (7)) and mitigate any discharge from the collection system in violation of this Order (40 CFR part 122.41(d)). See Attachment D, subsections I.D, V.E, V.H, and I.C., and the following section (Spill Reporting Requirements) of this Order.

6. Spill Reporting Requirements

1. Initial Notification

Although State and Regional Water Board staff do not have duties as first responders, this requirement is an appropriate mechanism to ensure that the agencies that do have first responder duties are notified in a timely manner in order to protect public health and beneficial uses. For certain spills, overflows and bypasses, the Discharger shall make notifications as required below:

- a. In accordance with the requirements of Health and Safety Code section 5411.5, the Discharger shall provide notification to the local health officer or the director of environmental health with jurisdiction over the affected water body of any unauthorized release of sewage or other waste that causes, or probably will cause, a discharge to any waters of the State as soon as possible, but no later than two (2) hours after becoming aware of the release.
- b. In accordance with the requirements of CWC section 13271, the Discharger shall provide notification to the California Emergency Management Agency (Cal EMA) of the release of reportable amounts of hazardous substances or sewage that causes, or probably will cause, a discharge to any waters of the State as soon as possible, but not later than two (2) hours after becoming aware of the release. The California Code of Regulations, Title 23, section 2250, defines a reportable amount of sewage as being 1,000 gallons. The phone number for reporting these releases to the Cal EMA is (800)852-7550.
- c. The Discharger shall notify the Regional Water Board of any unauthorized release of sewage from its POTWs that causes, or probably will cause, a discharge to a water of the State as soon as possible, but not later than **two (2)** hours after becoming aware of the release. This initial notification does not need to be made if the Discharger has notified Cal EMA and the local health officer or the director of environmental health with jurisdiction over the affected waterbody. The phone number for reporting these releases of sewage to the Regional Water Board is (213) 576-6657. The phone numbers for after hours and weekend reporting of releases of sewage to the Regional Water Board are (213) 305-2284 and (213) 305-2253.

At a minimum, the following information shall be provided to the Regional Water Board:

- (i) The location, date, and time of the release.
- (ii) The water body that received or will receive the discharge.
- (iii) An estimate of the amount of sewage or other waste released and the amount that reached a surface water at the time of notification.
- (iv) If ongoing, the estimated flow rate of the release at the time of the notification.
- (v) The name, organization, phone number and email address of the reporting representative.

2. Monitoring

For spills, overflows and bypasses reported under section VI.C.6.1.c., the Discharger shall monitor as required below:

- a. To define the geographical extent of spill's impact the Discharger shall obtain grab samples (if feasible, accessible, and safe) for spills, overflows or bypasses of any volume that reach receiving waters. The Discharger shall analyze the samples for total and fecal coliforms or E. coli, and enterococcus, and relevant pollutants of concern, upstream and downstream of the point of entry of the spill (if feasible, accessible and safe). This monitoring shall be done on a daily basis from time the spill is known until the results of two consecutive sets of bacteriological monitoring indicate the return to the background level or the County Department of Public Health authorizes cessation of monitoring.
- b. The Discharger shall obtain a grab sample (if feasible, accessible, and safe) for spills, overflows or bypasses of any volume that flowed to receiving waters, entered a shallow ground water aquifer, or have the potential for public exposure; and for all spills, overflows or bypasses of 1,000 gallons or more. The Discharger shall characterize the sample for total and fecal coliforms or E. coli, and enterococcus, and analyze relevant pollutants of concern depending on the area and nature of spills or overflows if feasible, accessible and safe.

3. Reporting

The Regional Water Board initial notification required under section VI.C.6.1.a. shall be followed by:

- a. As soon as possible, but **not later than twenty four (24) hours** after becoming aware of an unauthorized discharge of sewage or other waste from

its wastewater treatment plant to a water of the state, the discharger shall submit a statement to the Regional Water Board by email at aanijelo@waterboards.ca.gov. If the discharge is 1,000 gallons or more, this statement shall certify that Cal EMA has been notified of the discharge in accordance with CWC section 13271. The statement shall also certify that the local health officer or director of environmental health with jurisdiction over the affected water bodies has been notified of the discharge in accordance with Health and Safety Code section 5411.5. The statement shall also include at a minimum the following information:

- (i) Agency, NPDES No., Order No., and MRP CI No., if applicable.
 - (ii) The location, date, and time of the discharge.
 - (iii) The water body that received the discharge.
 - (iv) A description of the level of treatment of the sewage or other waste discharged.
 - (v) An initial estimate of the amount of sewage or other waste released and the amount that reached a surface water.
 - (vi) The Cal EMA control number and the date and time that notification of the incident was provided to Cal EMA.
 - (vii) The name of the local health officer or director of environmental health representative notified (if contacted directly); the date and time of notification; and the method of notification (e.g., phone, fax, email).
- b. A written preliminary report five working days after disclosure of the incident (submission to the Regional Water Board of the California Integrated Water Quality System (CIWQS) Sanitary Sewer Overflow (SSO) event number shall satisfy this requirement). Within 30 days after submitting the preliminary report, the Discharger shall submit the final written report to this Regional Water Board. (A copy of the final written report, for a given incident, already submitted pursuant to a Statewide General Waste Discharge Requirements for Wastewater Collection System Agencies, may be submitted to the Regional Water Board to satisfy this requirement.) The written report shall document the information required in paragraph D below, monitoring results and any other information required in provisions of the Standard Provisions document including corrective measures implemented or proposed to be implemented to prevent/minimize future occurrences. The Executive Officer for just cause can grant an extension for submittal of the final written report.
- c. The Discharger shall include a certification in the annual summary report (due according to the schedule in the MRP) that states—the sewer system emergency equipment, including alarm systems, backup pumps, standby power generators, and other critical emergency pump station components

were maintained and tested in accordance with the Discharger's Preventive Maintenance Plan. Any deviations from or modifications to the Plan shall be discussed.

4. Records

The Discharger shall develop and maintain a record of all spills, overflows or bypasses of raw or partially treated sewage from its collection system or treatment plant. This record shall be made available to the Regional Water Board upon request and a spill summary shall be included in the annual summary report. The records shall contain:

- a. The date and time of each spill, overflow or bypass;
- b. The location of each spill, overflow or bypass;
- c. The estimated volume of each spill, overflow or bypass including gross volume, amount recovered and amount not recovered, monitoring results as required by section VI.C.6.2;
- d. The cause of each spill, overflow or bypass;
- e. Whether each spill, overflow or bypass entered a receiving water and, if so, the name of the water body and whether it entered via storm drains or other man-made conveyances;
- f. Mitigation measures implemented;
- g. Corrective measures implemented or proposed to be implemented to prevent/minimize future occurrences; and,
- h. The mandatory information included in SSO online reporting for finalizing and certifying the SSO report for each spill, overflow, or bypass under the SSO WDR.

5. Activities Coordination

In addition, Regional Water Board expects that the POTW's owners/operators will coordinate their compliance activities for consistency and efficiency with other entities that have responsibilities to implement: (i) this NPDES permit, including the Pretreatment Program, (ii) a MS4 NPDES permit that may contain spill prevention, sewer maintenance, reporting requirements and (iii) the SSO WDR.

6. Consistency with Sanitary Sewer Overflows WDRs

The Clean Water Act prohibits the discharge of pollutants from point sources to surface waters of the United States unless authorized under an NPDES permit. (33 U.S.C. §§1311, 1342). The State Water Board adopted General Waste

Discharge Requirements (WDRs) for Sanitary Sewer Systems, (WQ Order No. 2006-0003) on May 2, 2006, to provide a consistent, statewide regulatory approach to address Sanitary Sewer Overflows (SSOs). The SSOs WDR requires public agencies that own or operate sanitary sewer systems to develop and implement sewer system management plans and report all SSOs to the State Water Board's online SSOs database.

The requirements contained in this Order in sections VI.C.3.b. (Spill Contingency Plan Section), VI.C.4. (Construction, Operation and Maintenance Specifications Section), and VI.C.6. (Spill Reporting Requirements) are intended to be consistent with the requirements of the SSOs WDR. The Regional Water Board recognizes that there may be some overlap between the NPDES permit provisions and SSOs WDR requirements, at least as related to the collection systems. The requirements of the SSOs WDR are considered the minimum thresholds (see Finding 11 of State Board Order No. 2006-0003-DWQ). To encourage efficiency, the Regional Water Board will accept the documentation prepared by the Permittees under the SSOs WDR for compliance purposes, as satisfying the requirements in sections VI.C.3.b., VI.C.4., and VI.C.6. provided the monitoring requirements contained in this Order in sections IV.9.B.d. and IV.9.B.e. are also addressed. Pursuant to the SSO WDR, State Board Order No. 2006-0003-DWQ, section D., provision 2.(iii) and (iv), the provisions of this NPDES permit supercede the SSO WDR, for all purposes, including enforcement, to the extent the requirements may be deemed duplicative.

7. The Discharger shall provide standby or emergency power facilities and/or storage capacity or other means so that in the event of plant upset or outage due to power failure or other cause, discharge of raw or inadequately treated sewage does not occur.

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

A. General.

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the MRP and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

B. Multiple Sample Data

When determining compliance with a measure of central tendency (arithmetic mean, geometric mean, median, etc.) of multiple sample analyses and the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not

Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

C. Average Monthly Effluent Limitation (AMEL)

If the average (or when applicable, the median determined by subsection B above for multiple sample data) of daily discharges over a calendar month exceeds the AMEL for a given parameter, this will represent a single violation, though the Discharger may be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AMEL, the Discharger may be considered out of compliance for that calendar month. The Discharger will only be considered out of compliance for days when the discharge occurs. For any one calendar month during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar month with respect to the AMEL.

If the analytical result of a single sample, monitored monthly, quarterly, semiannually, or annually, does not exceed the AMEL for a given parameter, the Discharger will have demonstrated compliance with the AMEL for each day of that month for that parameter.

If the analytical result of any single sample, monitored monthly, quarterly, semiannually, or annually, exceeds the AMEL for any parameter, the Discharger may collect up to four additional samples within the same calendar month. All analytical results shall be reported in the monitoring report for that month. The concentration of pollutant (an arithmetic mean or a median) in these samples estimated from the "Multiple Sample Data Reduction" Section above, will be used for compliance determination.

In the event of noncompliance with an AMEL, the sampling frequency for that parameter shall be increased to weekly and shall continue at this level until compliance with the AMEL has been demonstrated.

D. Average Weekly Effluent Limitation (AWEL)

If the average of daily discharges over a calendar week exceeds the AWEL for a given parameter, an alleged violation will be flagged and the discharger will be considered out of compliance for each day of that week for that parameter, resulting in 7 days of non-compliance. The average of daily discharges over the calendar week that exceeds the AWEL for a parameter will be considered out of compliance for that week only. If only a single sample is taken during the calendar week and the analytical result for that sample exceeds the AWEL, the discharger will be considered out of compliance for that calendar week. For any one calendar week during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar week with respect to the AWEL.

A calendar week will begin on Sunday and end on Saturday. Partial calendar weeks at the end of the calendar month will be carried forward to the next month in order to calculate and report a consecutive seven-day average value on Saturday.

E. Maximum Daily Effluent Limitation (MDEL)

If a daily discharge exceeds the MDEL for a given parameter, an alleged violation will be flagged and the discharger will be considered out of compliance for that parameter for that 1 day only within the reporting period. For any 1 day during which no sample is taken, no compliance determination can be made for that day with respect to the MDEL.

F. Instantaneous Minimum Effluent Limitation.

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

G. Instantaneous Maximum Effluent Limitation.

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

H. Six-month Median Effluent Limitation.

If the median of daily discharges over any 180-day period exceeds the six-month median effluent limitation for a given parameter, an alleged violation will be flagged and the discharger will be considered out of compliance for each day of that 180-day

period for that parameter. The next assessment of compliance will occur after the next sample is taken. If only a single sample is taken during a given 180-day period and the analytical result for that sample exceeds the six-month median, the discharger will be considered out of compliance for the 180-day period. For any 180-period during which no sample is taken, no compliance determination can be made for the six-month median effluent limitation.

I. Percent Removal.

The average monthly percent removal is the removal efficiency expressed in percentage across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of pollutant concentrations (C in mg/L) of influent and effluent samples collected at about the same time using the following equation:

$$\text{Percent Removal (\%)} = [1 - (C_{\text{Effluent}}/C_{\text{Influent}})] \times 100 \%$$

When preferred, the Discharger may substitute mass loadings and mass emissions for the concentrations.

J. Mass and Concentration Limitations

Compliance with mass and concentration effluent limitations for the same parameter shall be determined separately with their respective limitations. When the concentration of a constituent in an effluent sample is determined to be ND or DNQ, the corresponding mass emission rate determined from that sample concentration shall also be reported as ND or DNQ.

K. Compliance with single constituent effluent limitations

Dischargers may be considered out of compliance with the effluent limitation if the concentration of the pollutant (see Section B “Multiple Sample Data Reduction” above) in the monitoring sample is greater than the effluent limitation and greater than or equal to the Reporting Level (RL).

L. Compliance with effluent limitations expressed as a sum of several constituents

Dischargers are out of compliance with an effluent limitation which applies to the sum of a group of chemicals (e.g., PCB's) if the sum of the individual pollutant concentrations is greater than the effluent limitation. Individual pollutants of the group will be considered to have a concentration of zero if the constituent is reported as ND or DNQ.

M. Mass Emission Rate.

The mass emission rate shall be obtained from the following calculation for any calendar day:

$$\text{Mass emission rate (lb/day)} = \frac{8.34}{N} \sum_{i=1}^N Q_i C_i$$

$$\text{Mass emission rate (kg/day)} = \frac{3.79}{N} \sum_{i=1}^N Q_i C_i$$

in which 'N' is the number of samples analyzed in any calendar day. 'Q_i' and 'C_i' are the flow rate (MGD) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' grab samples, which may be taken in any calendar day. If a composite sample is taken, 'C_i' is the concentration measured in the composite sample and 'Q_i' is the average flow rate occurring during the period over which samples are composited.

The daily concentration of all constituents shall be determined from the flow-weighted average of the same constituents in the combined waste streams as follows:

$$\text{Daily concentration} = \frac{1}{Q_t} \sum_{i=1}^N Q_i C_i$$

in which 'N' is the number of component waste streams. 'Q_i' and 'C_i' are the flow rate (MGD) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' waste streams. 'Q_t' is the total flow rate of the combined waste streams.

N. Bacterial Standards and Analysis.

1. The geometric mean used for determining compliance with bacterial standards is calculated with the following equation:

$$\text{Geometric Mean} = (C_1 \times C_2 \times \dots \times C_n)^{1/n}$$

where n is the number of days samples were collected during the period and C is the concentration of bacteria (MPN/100 mL or CFU/100 mL) found on each day of sampling.

2. For bacterial analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliform, at a minimum, and 1 to 1000 per 100 ml for enterococcus). The detection methods used for each analysis shall be reported with the results of the analyses.
3. Detection methods used for coliforms (total and fecal) shall be those presented in Table 1A of 40 CFR part 136 (revised March 12, 2007), unless alternate methods have been approved by USEPA pursuant to 40 CFR part 136, or improved methods have been determined by the Executive Officer and/or USEPA.
4. Detection methods used for enterococcus shall be those presented in Table 1A of 40 CFR part 136 (revised March 12, 2007) or in the USEPA publication EPA

600/4-85/076, *Test Methods for Escherichia coli and Enterococci in Water By Membrane Filter Procedure* or any improved method determined by the Executive Officer and/or USEPA to be appropriate.

O. Single Operational Upset

A single operational upset (SOU) that leads to simultaneous violations of more than one pollutant parameter shall be treated as a single violation and limits the Discharger's liability in accordance with the following conditions:

1. A single operational upset is broadly defined as a single unusual event that temporarily disrupts the usually satisfactory operation of a system in such a way that it results in violation of multiple pollutant parameters.
2. A Discharger may assert SOU to limit liability only for those violations which the Discharger submitted notice of the upset as required in Provision V.E.2(b) of Attachment D – Standard Provisions.
3. For purpose outside of CWC section 13385 (h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Dischargers to assert the SOU limitation of liability, and the manner of counting violations) shall be in accordance with USEPA Memorandum "Issuance of Guidance Interpreting Single Operational Upset" (September 27, 1989).
4. For purpose of CWC section 13385 (h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Dischargers to assert the SOU limitation of liability, and the manner of counting violations) shall be in accordance with CWC section 13385 (f)(2).

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ), also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

Arithmetic mean = $\mu = \Sigma x / n$ where: Σx is the sum of the measured ambient water concentrations, and n is the number of samples.

Average Monthly Effluent Limitation (AMEL): the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL): the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative pollutants are those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV) is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ) are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA) is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration is the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in California Water Code (CWC) section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters are all surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL) is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND) are those sample results less than the laboratory's MDL.

Ocean Waters are the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP) means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to CWC section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in CWC section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Reporting Level (RL) is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System is the portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water is any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ) is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:


x is the observed value;

μ is the arithmetic mean of the observed values; and


n is the number of samples.

Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT B – MAP



ATTACHMENT C – FLOW SCHEMATIC



ATTACHMENT D –STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (CWC) and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 CFR part 122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 CFR part 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR part 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR part 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 CFR part 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR part 122.41(g).)

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 CFR part 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR part 122.41(i); CWC section 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 CFR part 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 CFR part 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 CFR part 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the CWC, any substances or parameters at any location. (40 CFR part 122.41(i)(4).)

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR part 122.41(m)(1)(i).)
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR part 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 CFR part 122.41(m)(2).)

3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 CFR part 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR part 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR part 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR part 122.41(m)(4)(i)(C).)
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 CFR part 122.41(m)(4)(ii).)
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR part 122.41(m)(3)(i).)
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR part 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR part 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was

caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR part 122.41(n)(2).).

2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR part 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 CFR part 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 CFR part 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR part 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR part 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 CFR part 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR part 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 CFR part 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such

other requirements as may be necessary under the CWA and the CWC. (40 CFR part 122.41(l)(3); part 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR part 122.41(j)(1).)
- B.** Monitoring results must be conducted according to test procedures under 40 CFR part 136 or, in the case of sludge use or disposal, approved under 40 CFR part 136 unless otherwise specified in 40 CFR part 503 unless other test procedures have been specified in this Order. (40 CFR part 122.41(j)(4); part 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A.** Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 CFR part 122.41(j)(2).)

B. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements (40 CFR part 122.41(j)(3)(i));
2. The individual(s) who performed the sampling or measurements (40 CFR part 122.41(j)(3)(ii));
3. The date(s) analyses were performed (40 CFR part 122.41(j)(3)(iii));
4. The individual(s) who performed the analyses (40 CFR part 122.41(j)(3)(iv));
5. The analytical techniques or methods used (40 CFR part 122.41(j)(3)(v)); and
6. The results of such analyses. (40 CFR part 122.41(j)(3)(vi).)

C. Claims of confidentiality for the following information will be denied (40 CFR part 122.7(b)):

1. The name and address of any permit applicant or Discharger (40 CFR part 122.7(b)(1)); and
2. Permit applications and attachments, permits and effluent data. (40 CFR part 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR part 122.41(h); CWC § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR part 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR part 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR part 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative

may thus be either a named individual or any individual occupying a named position.) (40 CFR part 122.22(b)(2)); and

- c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 CFR part 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR part 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR part 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR part 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 CFR part 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 CFR part 136 or, in the case of sludge use or disposal, approved under 40 CFR part 136 unless otherwise specified in 40 CFR part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 CFR part 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR part 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR part 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR part 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR part 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR part 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR part 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR part 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR part 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 CFR part 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 CFR part 122.41(l)(1)(ii).)

3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR part 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 CFR part 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR part 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 CFR part 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A.** The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 CFR part 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR part 122.42(b)(1)); and

2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 CFR part 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR part 122.42(b)(3).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Table of Contents

Attachment E – Monitoring and Reporting Program (MRP), CI-4424	E-2
I. General Monitoring Provisions.....	E-2
II. Monitoring Locations	E-5
III. Influent Monitoring Requirements.....	E-7
A. Monitoring Location INF-001.....	E-7
IV. Effluent Monitoring Requirements	E-8
A. Monitoring Location EFF-002.....	E-8
V. Whole Effluent Toxicity Testing Requirements	E-12
A. Acute Toxicity	E-12
B. Chronic Toxicity Testing.....	E-13
C. Quality Assurance.....	E-15
D. Preparation of an Initial Investigation TRE Workplan.....	E-15
E. Steps in TRE and TIE	E-16
F. Ammonia Removal.....	E-17
G. Reporting	E-18
VI. Reclamation Monitoring Requirements.....	E-19
VII. Receiving Water Monitoring Requirements – Surface Water.....	E-19
A. Monitoring Location RSW-001U and RSW-002D	E-19
B. Bioassessment Monitoring Program	E-22
C. Monitoring Location RSW-003D, Los Angeles River Wardlow Station.....	E-23
VIII. Other Monitoring Requirements	E-23
A. Special Study – Constituents of Emerging Concern in Effluent	E-23
B. Los Angeles River Watershed Monitoring Program (LARWMP)	E-26
IX. Reporting Requirements.....	E-28
A. General Monitoring and Reporting Requirements.....	E-28
B. Self-Monitoring Reports (SMRs)	E-28
C. Discharge Monitoring Reports (DMRs)	E-30
D. Other Reports	E-31

List of Tables

Table 1. Monitoring Station Locations.....	E-5
Table 2. Influent Monitoring	E-7
Table 3. Effluent Monitoring.....	E-8
Table 4a. Receiving Water Monitoring Requirements.....	E-19
Table 4b. TMDL Receiving Water Monitoring Requirements.....	E-23
Table 5. Effluent Monitoring of CECs.....	E-24
Table 6. Monitoring Periods and Reporting Schedule.....	E-29

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP), CI-4424

The Code of Federal Regulations title 40, section 122.48 requires that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A. All samples shall be representative of the waste discharge under conditions of peak load. Quarterly effluent analyses shall be performed during the months of February, May, August, and November. Semiannual analyses shall be performed during the months of February and August. Annual analyses shall be performed during the month of August with the exception of bioassessments. Should there be instances when monitoring could not be done during these specified months, the Discharger must notify the Regional Water Board, state the reason why monitoring could not be conducted, and obtain approval from the Executive Officer for an alternate schedule. Results of quarterly, semiannual, and annual analyses shall be reported in the monthly monitoring report following the analysis.
- B. Pollutants shall be analyzed using the analytical methods described in 40 CFR parts 136.3, 136.4, and 136.5 (revised March 12, 2007); or where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. Laboratories analyzing effluent samples and receiving water samples shall be certified by the California Department of Public Health Environmental Laboratory Accreditation Program (ELAP) or approved by the Executive Officer and must include quality assurance/quality control (QA/QC) data in their reports. A copy of the laboratory certification shall be provided each time a new certification and/or renewal of the certification is obtained from ELAP.
- C. Water/wastewater samples must be analyzed within allowable holding time limits as specified in 40 CFR part 136.3 (revised March 12, 2007). All QA/QC analyses must be run on the same dates that samples are actually analyzed. The Discharger shall retain the QA/QC documentation in its files and make available for inspection and/or submit them when requested by the Regional Water Board. Proper chain of custody procedures must be followed and a copy of that documentation shall be submitted with the monthly report.
- D. The Discharger shall calibrate and perform maintenance procedures on all monitoring instruments and to ensure accuracy of measurements, or shall ensure that both equipment activities will be conducted.
- E. For any analyses performed for which no procedure is specified in the USEPA guidelines, or in the MRP, the constituent or parameter analyzed and the method or procedure used must be specified in the monitoring report.

- F. Each monitoring report must affirm in writing that “all analyses were conducted at a laboratory certified for such analyses by the California Department of Public Health or approved by the Executive Officer and in accordance with current USEPA guideline procedures or as specified in this MRP.”
- G. The monitoring report shall specify the USEPA analytical method used, the Method Detection Limit (MDL), and the Reporting Level (RL) [the applicable minimum level (ML) or reported Minimum Level (RML)] for each pollutant. The MLs are those published by the State Water Board in the *Policy for the Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California*, (SIP) February 9, 2005, Appendix 4. The ML represents the lowest quantifiable concentration in a sample based on the proper application of all method-based analytical procedures and the absence of any matrix interference. When all specific analytical steps are followed and after appropriate application of method specific factors, the ML also represents the lowest standard in the calibration curve for that specific analytical technique. When there is deviation from the method analytical procedures, such as dilution or concentration of samples, other factors may be applied to the ML depending on the sample preparation. The resulting value is the reported minimum level.
- H. The Discharger shall select the analytical method that provides a ML lower than the permit limit established for a given parameter, unless the Discharger can demonstrate that a particular ML is not attainable and obtains approval for a higher ML from the Executive Officer, as provided for in section J, below. If the effluent limitation is lower than all the MLs in Appendix 4 of the SIP, the Discharge must select the method with the lowest ML for compliance purposes. The Discharger shall include in the Annual Summary Report a list of the analytical methods employed for each test.
- I. The Discharger shall instruct its laboratories to establish calibration standards so that the ML (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve. In accordance with section J, below, the Discharger’s laboratory may employ a calibration standard lower than the ML in Appendix 4 of the SIP.
- J. In accordance with section 2.4.3 of the SIP, the Regional Water Board Executive Officer, in consultation with the State Water Board’s Quality Assurance Program Manager, may establish an ML that is not contained in Appendix 4 of the SIP to be included in the discharger’s permit in any of the following situations:
 - a. When the pollutant under consideration is not included in Appendix 4 of the SIP;
 - b. When the discharger and the Regional Water Board agree to include in the permit a test method that is more sensitive than those specified in 40 CFR part 136 (revised as of March 12, 2007);
 - c. When a discharger agrees to use an ML that is lower than those listed in Appendix 4;

- d. When a discharger demonstrates that the calibration standard matrix is sufficiently different from that used to establish the ML in Appendix 4 and proposes an appropriate ML for the matrix; or,
- e. When the discharger uses a method, which quantification practices are not consistent with the definition of the ML. Examples of such methods are USEPA-approved method 1613 for dioxins, and furans, method 1624 for volatile organic substances, and method 1625 for semi-volatile organic substances. In such cases, the discharger, the Regional Water Board, and the State Water Resources Control Board shall agree on a lowest quantifiable limit and that limit will substitute for the ML for reporting and compliance determination purposes.

If there is any conflict between foregoing provisions and the State Implementation Policy (SIP), the provisions stated in the SIP (section 2.4) shall prevail.

- K. If the Discharger samples and performs analyses (other than for process/operational control, startup, research, or equipment testing) on any influent, effluent, or receiving water constituent more frequently than required by this Program using approved analytical methods, the results of those analyses shall be included in the report. These results shall be reflected in the calculation of the average used in demonstrating compliance with average effluent, receiving water, etc., limitations.
- L. The Discharger shall develop and maintain a record of all spills or bypasses of raw or partially treated sewage from its collection system or treatment plant according to the requirements in the WDR section of this Order. This record shall be made available to the Regional Water Board upon request and a spill summary shall be included in the annual summary report.
- M. For all bacteriological analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliform, at a minimum, and 1 to 1000 per 100 ml for enterococcus). The detection methods used for each analysis shall be reported with the results of the analyses.
 - a. Detection methods used for coliforms (total and fecal) shall be those presented in Table 1A of 40 CFR part 136 (revised March 12, 2007), unless alternate methods have been approved in advance by the USEPA pursuant to 40 CFR part 136.
 - b. Detection methods used for enterococcus shall be those presented in Table 1A of 40 CFR part 136 (revised March 12, 2007) or in the USEPA publication EPA 600/4-85/076, *Test Methods for Escherichia coli and Enterococci in Water By Membrane Filter Procedure*, or any improved method determined by the Regional Water Board to be appropriate.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table 1. Monitoring Station Locations

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
Influent Monitoring Station		
--	INF-001	Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained.
Effluent Monitoring Stations		
002	EFF-002	The effluent sampling station for all constituents shall be located downstream of the dechlorination process and inside the plant, where representative samples can be obtained.
Receiving Water Monitoring Stations		
--	RSW-001U	Burbank Western Channel, approximately 300 feet upstream of the Burbank WRP. (Previously designated as R-1)
--	RSW-002D	Burbank Western Channel at Verdugo Wash (downstream of Discharge Point 002). (Previously designated as R-2)
TMDL Wet-Weather Flow Monitoring Station		
--	RSW-003D	TMDL Wet-weather Flow Monitoring Station at the County of Los Angeles Department of Public Works' Wardlow Gage Station No. F319-R, in Los Angeles River, just below Wardlow River Road.

Burbank WRP Receiving Water Stations



III. INFLUENT MONITORING REQUIREMENTS

Influent monitoring is required to:

- Determine compliance with NPDES permit conditions.
- Assess treatment plant performance.
- Assess effectiveness of the Pretreatment Program.

A. Monitoring Location INF-001

1. The Discharger shall monitor influent to the facility at INF-001 as follows:

Table 2. Influent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	mgd	recorder	continuous ¹	¹
pH	pH unit	grab	weekly	²
Total suspended solids	mg/L	24-hour composite	weekly	²
BOD ₅ 20 °C	mg/L	24-hour composite	weekly	²
Antimony	µg/L	24-hour composite	quarterly	²
Cadmium	µg/L	24-hour composite	quarterly	²
Copper	µg/L	24-hour composite	quarterly	²
Lead	µg/L	24-hour composite	quarterly	²
Zinc	µg/L	24-hour composite	quarterly	²
Cyanide	µg/L	grab	quarterly	²
Dibromochloromethane	µg/L	grab	quarterly	²
Benzo(a)anthracene	µg/L	24-hour composite	quarterly	²
Benzo(a)pyrene	µg/L	24-hour composite	quarterly	²
Benzo(b)pyrene	µg/L	24-hour composite	quarterly	²
Benzo(k)fluoranthene	µg/L	24-hour composite	quarterly	²
Bis(2-Ethylhexyl)Phthalate	µg/L	24-hour composite	quarterly	²
Dibenzo(a,h)Anthracene	µg/L	24-hour composite	quarterly	²
Hexachlorobenzene	µg/L	24-hour composite	quarterly	²
Indeno(1,2,3-cd)pyrene	µg/L	24-hour composite	quarterly	²
Total trihalomethanes	µg/L	grab	quarterly	²
Iron	µg/L	24-hour composite	quarterly	²
Remaining EPA priority pollutants ³ excluding asbestos	µg/L	24-hour composite/grab for VOCs and Chromium VI	semiannually	²

¹ Total daily flow and instantaneous peak daily flow (24-hr basis). Actual monitored flow shall be reported (not the maximum flow, i.e., design capacity).

² Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Resources Control Board. For any pollutant whose effluent limitation is lower than all the MLs specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

IV. EFFLUENT MONITORING REQUIREMENTS

Effluent monitoring is required to:

- Determine compliance with NPDES permit conditions and water quality standards.
- Assess plant performance, identify operational problems and improve plant performance.
- Provide information on wastewater characteristics and flows for use in interpreting water quality and biological data.
- Determine reasonable potential analysis for toxic pollutants.
- Determine TMDL effectiveness in waste load allocation compliance.

A. Monitoring Location EFF-002

1. The Discharger shall monitor the discharge of tertiary-treated effluent at EFF-002. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding ML.

Table 3. Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and Minimum Level, units, respectively
Total waste flow	mgd	recorder	continuous ⁴	⁴
Turbidity	NTU	recorder	continuous ⁴	⁵
Total residual chlorine	mg/L	recorder	continuous ⁶	--
Total residual chlorine	mg/L	grab	daily ⁷	⁵
Total coliform	MPN/ 100mL or CFU/100ml	grab	weekly	⁵

³ Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423.

⁴ Where continuous monitoring of a constituent is required, the following shall be reported:
Total waste flow – total daily and peak daily flow (24-hr basis);
Turbidity – maximum daily value, total amount of time each day the turbidity exceeded five turbidity units, flow-proportioned average daily value. A grab sample can be used to determine compliance with the 5 NTU limit.

⁵ Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Resources Control Board. For any pollutant whose effluent limitation is lower than all the minimum levels (MLs) specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

⁶ Total residual chlorine shall be recorded continuously. The recorded data shall be maintained by the Permittee for at least five years. The Permittee shall extract the maximum daily peak, minimum daily peak, and average daily from the recorded media and shall be made available upon request of the Regional Water Board. The continuous monitoring data are not intended to be used for compliance determination purposes.

⁷ Daily samples shall be collected during peak flow at monitoring location EFF-002, Monday through Friday only, except for holidays. Analytical results of daily grab samples will be used to determine compliance with total residual chlorine effluent limitation. Furthermore, additional monitoring requirements specified in section IV.A.2. shall be followed.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and Minimum Level, units, respectively
Fecal coliform	MPN/ 100mL or CFU/100ml	grab	weekly	⁵
E.coli	MPN/ 100mL or CFU/100ml	grab	weekly ⁸	⁵
Temperature ⁹	°F	grab	daily ¹⁰	⁵
pH ⁹	pH units	grab	daily ¹⁰	⁵
Settleable solids	mL/L	grab	weekly	⁵
Suspended solids	mg/L	24-hour composite	weekly	⁵
BOD ₅ 20 °C	mg/L	24-hour composite	weekly	⁵
Oil and grease	mg/L	grab	monthly	⁵
Dissolved oxygen	mg/L	grab	monthly	⁵
Total Dissolved Solids	mg/L	24-hour composite	monthly	⁵
Sulfate	mg/L	24-hour composite	monthly	⁵
Chloride	mg/L	24-hour composite	monthly	⁵
Ammonia Nitrogen ⁹	mg/L	24-hour composite	monthly	⁵
Nitrite nitrogen ⁹	mg/L	24-hour composite	monthly	⁵
Nitrate nitrogen ⁹	mg/L	24-hour composite	monthly	⁵
Organic nitrogen ⁹	mg/L	24-hour composite	monthly	⁵
Total nitrogen ⁹	mg/L	24-hour composite	monthly	⁵
Surfactants (MBAS)	mg/L	24-hour composite	monthly	⁵
Surfactants (CTAS)	mg/L	24-hour composite	monthly	⁵
Total hardness (CaCO ₃)	mg/L	24-hour composite	monthly	⁵
Chronic toxicity	TUc	24-hour composite	monthly	⁵
Chronic toxicity (narrative effluent limit reporting) ¹¹	Passed/ Triggered	24-hour composite	monthly	⁵
Acute toxicity	% Survival	24-hour composite	quarterly	⁵
Radioactivity (Including gross alpha, gross beta, combined radium-226 and radium-228, tritium,	PCi/L	24-hour composite	semiannually	¹²

⁸ E. coli testing shall be conducted only if fecal coliform testing is positive. If the fecal coliform analysis results in no detection, a result of less than (<) the reporting limit for fecal coliform will be reported for E. coli.

⁹ Temperature, pH, nitrate nitrogen, nitrite nitrogen, ammonia nitrogen, and organic nitrogen shall be conducted concurrently.

¹⁰ Daily grab samples shall be collected Monday through Friday, except, for holidays; and not on weekends.

¹¹ For narrative chronic toxicity effluent limit reporting, "Passed" is reported when chronic toxicity effluent results do not trigger accelerated testing by exceeding the monthly median trigger of 1.0 TUc = 100/NOEC. "Triggered" is reported when chronic toxicity effluent results trigger accelerated testing by exceeding the monthly median trigger of 1.0 TUc = 100/NOEC.

¹² Analyze these radiochemicals by the following USEPA methods: method 900.0 for gross alpha and gross beta, method 903.0 or 903.1 for radium-226, method 904.0 for radium-228, method 906.0 for tritium, method 905.0 for strontium-90, and method 908.0 for uranium. Analysis for combined Radium-226 & 228 shall be conducted only if gross alpha results for the same sample exceed 15 pCi/L or beta greater than 50 pCi/L. If Radium-226 & 228 exceeds the stipulated criteria, analyze for Tritium, Strontium-90 and uranium.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and Minimum Level, units, respectively
strontium-90 and uranium)				
Antimony	µg/L	24-hour composite	monthly	5
Arsenic	µg/L	24-hour composite	quarterly	5
Beryllium	µg/L	24-hour composite	quarterly	5
Cadmium	µg/L	24-hour composite	monthly	5
Copper	µg/L	24-hour composite	monthly	5
Lead	µg/L	24-hour composite	monthly	5
Zinc	µg/L	24-hour composite	monthly	5
Mercury	µg/L	24-hour composite	quarterly	5
Cyanide	µg/L	grab	monthly	5
Iron	µg/L	24-hour composite	monthly	5
Dibromochloromethane	µg/L	grab	monthly	5
Total trihalomethanes	µg/L	grab	monthly	5
Manganese	µg/L	24-hour composite	quarterly	
Benzo(a)anthracene	µg/L	grab	quarterly	5
Benzo(a)pyrene	µg/L	24-hour composite	quarterly	5
Benzo(b)pyrene	µg/L	24-hour composite	quarterly	5
Benzo(k)fluoranthene	µg/L	24-hour composite	quarterly	5
Bis(2-Ethylhexyl) Phthalate	µg/L	24-hour composite	monthly	5
Chrysene	µg/L	24-hour composite	quarterly	5
Dibenzo(a,h)Anthracene	µg/L	24-hour composite	quarterly	5
Indeno(1,2,3-cd)pyrene	µg/L	24-hour composite	quarterly	5
Hexachlorobenzene	µg/L	24-hour composite	quarterly	5
Total Chromium	µg/L	grab	quarterly	5
Chromium III	µg/L	calculation	quarterly	5
Chromium VI	µg/L	grab	quarterly	5
Nickel	µg/L	24-hour composite	quarterly	5
Selenium	µg/L	24-hour composite	quarterly	5
Silver	µg/L	24-hour composite	quarterly	5
Thallium	µg/L	24-hour composite	semiannually	5
Diazinon	µg/L	24-hour composite	semiannually	5
2,3,7,8-TCDD ¹³	pg/L	24-hour composite	semiannually	5
Perchlorate	µg/L	grab	semiannually	14

¹³ In accordance with the SIP, the Discharger shall conduct effluent monitoring for the seventeen 2,3,7,8-tetrachlorodibenzo-p-dioxin (2,3,7,8-TCDD or dioxin) congeners in the effluent and in the receiving water Station RSW-001U, located upstream of the discharge point 002. The Discharger shall use the appropriate Toxicity Equivalence Factor (TEF) to determine Toxic Equivalence (TEQ). Where TEQ equals the product between each of the 17 individual congeners' (i) concentration analytical result (C_i) and their corresponding Toxicity Equivalence Factor (TEF_i), (i.e., TEQ_i = C_i x TEF_i). Compliance with the Dioxin limitation shall be determined by the summation of the seventeen individual TEQs, or the following equation:

$$\text{Dioxin concentration in effluent} = \sum_{i=1}^{17} (\text{TEQ}_i) = \sum_{i=1}^{17} (C_i)(\text{TEF}_i)$$

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and Minimum Level, units, respectively
1,4-Dioxane	µg/L	grab	semiannually	¹⁴
1,2,3-Trichloropropane	µg/L	grab	semiannually	¹⁴
Methyl tert-butyl-ether (MTBE)	µg/L	grab	semiannually	¹⁴
Boron	mg/L	24-hour composite	quarterly	⁵
Fluoride	mg/L	24-hour composite	quarterly	⁵
Pesticide ¹⁵	µg/L	24-hour composite	annually	⁵
Remaining EPA priority pollutants ¹⁶ excluding asbestos	µg/L	24-hour composite; grab for VOCs	semiannually	⁵

2. Total Residual Chlorine Additional Monitoring

Continuous monitoring of total residual chlorine at the current location shall serve as an internal trigger for the increased grab sampling at EFF-002 if either of the following occurs, except as noted in item c:

- Total residual chlorine concentration excursions of up to 0.3 mg/L lasting greater than 15 minutes; or
- Total residual chlorine concentration peaks in excess of 0.3 mg/L lasting greater than 1 minute.
- Additional grab samples need not be taken if it can be demonstrated that a stoichiometrically appropriate amount of dechlorination chemical has been added to effectively dechlorinate the effluent to 0.1 mg/L or less for peaks in excess of 0.3 mg/L lasting more than 1 minute, but not for more than five minutes.

¹⁴ Emerging chemicals include 1,4-dioxane (USEPA 8270M test method), perchlorate (USEPA 314 test method, or USEPA method 331 if a detection limit of less than 6 µg/L is achieved), 1,2,3-trichloropropane (USEPA 504.1, 8260B test method, or USEPA 524.2 in SIM mode), and methyl tert-butyl ether (USEPA 8260B test method or USEPA method 624 if a detection level of less than 5 µg/L is achieved, and if the Discharger received ELAP certification to run USEPA method 624).

¹⁵ Pesticides are, for the purposes of this Order, those six constituent referred in 40 CFR part 125.58(p), (demeton, guthion, malathion, mirex, methoxychlor, parathion).

¹⁶ Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Acute Toxicity

1. Definition of Acute Toxicity

Acute toxicity is a measure of primarily lethal effects that occur over a 96-hour period. Acute toxicity shall be measured in percent survival measured in undiluted (100%) effluent.

- a. The average survival in the undiluted effluent for any three (3) consecutive 96-hour static renewal bioassay tests shall be at least 90%, and
- b. No single test shall produce less than 70% survival.

2. Acute Toxicity Effluent Monitoring Program

- a. **Method.** The Discharger shall conduct acute toxicity tests on 24-hr composite 100% effluent and receiving water grab samples by methods specified in 40 CFR part 136, which cites USEPA's *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, October, 2002 (EPA-821-R-02-012) or a more recent edition to ensure compliance.
- b. **Test Species.** The fathead minnow, *Pimephales promelas*, shall be used as the test species for fresh water discharges and the topmelt, *Atherinopsaffinis*, shall be used as the test species for brackish discharges. However, if the salinity of the receiving water is between 1 to 32 parts per thousand (ppt), the Discharger may have the option of using the inland silverside, *Menidiaberyllina*, instead of the topmelt. The method for topmelt is found in USEPA's *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, October, 2002 (EPA-821-R-02-012).
- c. **Alternate Reporting.** In lieu of conducting the standard acute toxicity testing with the fathead minnow, the Discharger may elect to report the results or endpoint from the first 96 hours of the chronic toxicity test as the results of the acute toxicity test, but only if the Discharger uses USEPA's October 2002 protocol (EPA-821-R-02-013) and fathead minnow is used to conduct the chronic toxicity test.
- d. **Acute Toxicity Accelerated Monitoring.** If either of the effluent or receiving water acute toxicity requirements in Section IV.A.4.g.a.(i) and (ii), and Section V.A.17.c., respectively, of this Order is not met, the Discharger shall conduct six additional tests, approximately every two weeks, over a 12-week period. The Discharger shall ensure that results of a failing acute toxicity test are received by the Discharger within 24 hours of completion of the test and the additional tests shall begin within 5 business days of receipt of the result. If

the additional tests indicate compliance with acute toxicity limitation, the Discharger may resume regular testing.

However, if the extent of the acute toxicity of the receiving water upstream of the discharge is greater than the downstream and the results of the effluent acute toxicity test comply with acute toxicity limitation, the accelerated monitoring need not be implemented for the receiving water.

e. Toxicity Identification Evaluation (TIE).

1. If the results of any two of the six accelerated tests are less than 90% survival, then the Discharger shall begin a Toxicity Identification Evaluation (TIE). The TIE shall include all reasonable steps to identify the sources of toxicity. Once the sources are identified, the Discharger shall take all reasonable steps to reduce toxicity to meet the objective.
2. If the initial test and any of the additional six acute toxicity bioassay tests results are less than 70% survival, the Discharger shall immediately implement Initial Investigation Toxicity Reduction Evaluation (TRE) Workplan. Once the sources are identified the Discharger shall take all reasonable steps to reduce toxicity to meet the requirements.

B. Chronic Toxicity Testing

1. Definition of Chronic Toxicity

Chronic toxicity is a measure of adverse sub-lethal effects in plants, animals, or invertebrates in a long-term test. The effects measured may include lethality or decreases in fertilization, growth, and reproduction.

2. Chronic Toxicity Effluent Monitoring Program

- a. **Test Methods.** The Discharger shall conduct critical life stage chronic toxicity tests on 24-hour composite 100 % effluent samples and receiving water grab samples in accordance with EPA's *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, October 2002 (EPA-821-R-02-013) or EPA's *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, October 2002 (EPA-821-R-02-014), or current version. The Discharger shall conduct static renewal tests in accordance with the 2002 freshwater chronic methods manual for water flea and fathead minnow. For *Selenastrum*, use a static non-renewal test protocol.
- b. **Frequency**
 1. **Screening and Monitoring.** - The Discharger shall conduct the first chronic toxicity test screening for three consecutive months in 2012. The Discharger shall conduct short-term tests with the cladoceran, water flea (*Ceriodaphnia dubia* - survival and reproduction test), the fathead minnow

(*Pimephales promelas* - larval survival and growth test), and the green algae (*Selenastrum capricornutum* - growth test) as an initial screening process for a minimum of three, but not to exceed, five suites of tests to account for potential variability of the effluent/receiving water. After this screening period, monitoring shall be conducted using the most sensitive species.

2. **Re-screening** is required every 24 months. The Discharger shall re-screen with the three species listed above and continue to monitor with the most sensitive species. If the first suite of re-screening tests demonstrates that the same species is the most sensitive then the re-screening does not need to include more than one suite of tests. If a different species is the most sensitive or if there is ambiguity, then the Discharger shall proceed with suites of screening tests for a minimum of three, but not to exceed five suites.
3. Regular toxicity tests - After the screening period, monitoring shall be conducted monthly using the most sensitive species.
- c. **Toxicity Units.** The chronic toxicity of the effluent shall be expressed and reported in Chronic Toxic Units, TUC, where,

$$TUC = \frac{100}{NOEC}$$

The No Observable Effect Concentration (NOEC) is expressed as the maximum percent effluent concentration that causes no observable effect on test organisms, as determined by the results of a critical life stage toxicity test.

3. Accelerated Monitoring

If the chronic toxicity of the effluent or the receiving water downstream the discharge exceeds the monthly trigger median of 1.0 TUC, the Discharger shall conduct six additional tests, approximately every two weeks, over a 12-week period. The Discharger shall ensure that they receive results of a failing chronic toxicity test within 24 hours of the completion of the test and the additional tests shall begin within 5 business days of the receipt of the result. However, if the chronic toxicity of the receiving water upstream of the discharge is greater than the downstream and the TUC of the effluent chronic toxicity test is less than or equal to a monthly median of 1.0 TUC trigger, then accelerated monitoring need not be implemented for the receiving water.

- a. If any three out of the initial test and the six additional tests results exceed 1.0 TUC the Discharger shall immediately implement the Initial Investigation TRE workplan.
- b. If implementation of the initial investigation TRE workplan indicates the source of toxicity (e.g., a temporary plant upset, etc.), then the Discharger

shall return to the normal sampling frequency required in Table 3 and Table 4a of this MRP.

- c. If all of the six additional tests required above do not exceed 1.0 TUc, then the Discharger may return to the normal sampling frequency.
- d. If a TRE/TIE is initiated prior to completion of the accelerated testing schedule required, then the accelerated testing schedule may be terminated, or used as necessary in performing the TRE/TIE, as determined by the Executive Officer.

C. Quality Assurance

1. Concurrent testing with a reference toxicant shall be conducted. Reference toxicant tests shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc).
2. If either the reference toxicant test or effluent test does not meet all test acceptability criteria (TAC) as specified in the test methods manual (EPA-821-R-02-012 and/or EPA-821-R-02-013), then the Discharger must re-sample and re-test within 14 days.
3. Control and dilution water should be receiving water or laboratory water, as appropriate, as described in the manual. If the dilution water used is different from the culture water, a second control using culture water shall be used.

D. Preparation of an Initial Investigation TRE Workplan

The Discharger shall prepare and submit a copy of the Discharger's initial investigation TRE workplan to the Executive Officer of the Regional Water Board for approval within 90 days of the effective date of this permit. If the Executive Officer does not disapprove the workplan within 60 days, the workplan shall become effective. The Discharger shall use USEPA manual EPA/833B-99/002 (municipal) as guidance, or most current version. At a minimum, the TRE Workplan must contain the provisions in Attachment G. This workplan shall describe the steps the Discharger intends to follow if toxicity is detected, and should include, at a minimum:

1. A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
2. A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in the operation of the facility; and,
3. If a toxicity identification evaluation (TIE) is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor). See MRP Section V.E.3. for guidance manuals.

E. Steps in TRE and TIE

1. If results of the implementation of the facility's initial investigation TRE workplan indicate the need to continue the TRE/TIE, the Discharger shall expeditiously develop a more detailed TRE workplan for submittal to the Executive Officer within 15 days of completion of the initial investigation TRE. The detailed workplan shall include, but not be limited to:
 - a. Further actions to investigate and identify the cause of toxicity;
 - b. Actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
 - c. A schedule for these actions.
2. The following section summarizes the stepwise approach used in conducting the TRE:
 - a. Step 1 includes basic data collection.
 - b. Step 2 evaluates optimization of the treatment system operation, facility housekeeping, and selection and use of in-plant process chemicals.
 - c. If Steps 1 and 2 are unsuccessful, Step 3 implements a Toxicity Identification Evaluation (TIE) and employment of all reasonable efforts using currently available TIE methodologies. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity.
 - d. Assuming successful identification or characterization of the toxicant(s), Step 4 evaluates final effluent treatment options.
 - e. Step 5 evaluates in-plant treatment options.
 - f. Step 6 consists of confirmation once a toxicity control method has been implemented.

Many recommended TRE elements parallel source control, pollution prevention, and storm water control program best management practices (BMPs). To prevent duplication of efforts, evidence of compliance with those requirements may be sufficient to comply with TRE requirements. By requiring the first steps of a TRE to be accelerated testing and review of the facility's TRE workplan, a TRE may be ended in its early stages. All reasonable steps shall be taken to reduce toxicity to the required level. The TRE may be ended at any stage if monitoring indicates there are no longer toxicity violations.

3. The Discharger shall initiate a TIE as part of the TRE process to identify the cause(s) of toxicity. The Discharger shall use the USEPA acute manual, chronic

manual, EPA/600/R-96-054 (Phase I), EPA/600/R-92/080 (Phase II), and EPA-600/R-92/081 (Phase III), as guidance.

4. If a TRE/TIE is initiated prior to completion of the accelerated testing required in Section V.D. of this program, then the accelerated testing schedule may be terminated, or used as necessary in performing the TRE/TIE, as determined by the Executive Officer .
5. Toxicity tests conducted as part of a TRE/TIE may also be used for compliance, if appropriate.
6. The Regional Water Board recognizes that toxicity may be episodic and identification of causes of and reduction of sources of toxicity may not be successful in all cases. Consideration of enforcement action by the Board will be based, in part, on the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.
 - a. If all the results of the six additional tests are in compliance with the chronic toxicity limitation, the Discharger may resume regular monthly testing.
 - b. If the results of any of the six accelerated tests exceeds the limitation, the Discharger shall continue to monitor until six additional tests, taken approximately every two weeks, over a 12-week period are in compliance. At that time, the Discharger may resume regular monthly testing.
 - c. If the results of two of the six tests exceed the $1TU_C$ trigger, the Discharger shall initiate a TRE.
 - d. If implementation of the initial investigation TRE workplan (see item D.3, above) indicates the source of toxicity (e.g., a temporary plant upset, etc.), then the Discharger shall return to the regular testing frequency.

F. Ammonia Removal

1. Except with prior approval from the Executive Officer of the Regional Water Board, ammonia shall not be removed from bioassay samples. The Discharger must demonstrate the effluent toxicity is caused by ammonia because of increasing test pH when conducting the toxicity test. It is important to distinguish the potential toxic effects of ammonia from other pH sensitive chemicals, such as certain heavy metals, sulfide, and cyanide. The following may be steps to demonstrate that the toxicity is caused by ammonia and not other toxicants before the Executive Officer would allow for control of pH in the test.
 - a. There is consistent toxicity in the effluent and the maximum pH in the toxicity test is in the range to cause toxicity due to increased pH.
 - b. Chronic ammonia concentrations in the effluent are greater than 4 mg/L total ammonia.

- c. Conduct graduated pH tests as specified in the toxicity identification evaluation methods. For example, mortality should be higher at pH 8 and lower at pH 6.
 - d. Treat the effluent with a zeolite column to remove ammonia. Mortality in the zeolite treated effluent should be lower than the non-zeolite treated effluent. Then add ammonia back to the zeolite-treated samples to confirm toxicity due to ammonia.
2. When it has been demonstrated that toxicity is due to ammonia because of increasing test pH, pH may be controlled using appropriate procedures which do not significantly alter the nature of the effluent, after submitting a written request to the Regional Water Board, and receiving written permission expressing approval from the Executive Officer of the Regional Water Board.

G. Reporting

The Discharger shall submit a full report of the toxicity test results, including any accelerated testing conducted during the month, as required by this permit. Test results shall be reported in Acute Toxicity Units (TUa) or Chronic Toxicity Units (TUc), as required, with the self-monitoring report (SMR) for the month in which the test is conducted. If an initial investigation indicates the source of toxicity and accelerated testing is unnecessary, pursuant to Section V.A.2.d. and V.B.3., then those results also shall be submitted with the SMR for the period in which the Investigation occurred.

1. The full report shall be received by the Regional Water Board by the 15th day of the third month following sampling.
2. The full report shall consist of (1) the results; (2) the dates of sample collection and initiation of each toxicity test; (3) the toxicity limit; and, (4) printout of the toxicity program (ToxCalc or CETIS).
3. Test results for toxicity tests also shall be reported according to the appropriate manual chapter on Report Preparation and shall be attached to the SMR. Routine reporting shall include, at a minimum, as applicable, for each test, as appropriate:
 - a. sample date(s)
 - b. test initiation date
 - c. test species
 - d. end point value(s) for each dilution (e.g. number of young, growth rate, percent survival)
 - e. NOEC values in percent effluent

- f. TU_c value(s), where $TU_c = \frac{100}{NOEC}$
 - g. Mean percent mortality (+standard deviation) after 96 hours in 100% effluent (if applicable)
 - h. NOEC and LOEC (Lowest Observable Effect Concentration) values for reference toxicant test(s)
 - i. Available water quality measurements for each test (e.g., pH, D.O., temperature, conductivity, hardness, salinity, ammonia).
4. The Discharger shall provide a compliance summary that includes a summary table of toxicity data from at least eleven of the most recent samples.
 5. The Discharger shall notify this Regional Water Board immediately of any toxicity exceedance and in writing 14 days after the receipt of the results of an effluent limit. The notification will describe actions the Discharger has taken or will take to investigate and correct the cause(s) of toxicity. It may also include a status report on any actions required by the permit, with a schedule for actions not yet completed. If no actions have been taken, the reasons shall be given.

VI. RECLAMATION MONITORING REQUIREMENTS

The Discharger recycled 520 million gallons of tertiary-treated effluent in 2010 and plans to continue doing so. The production, distribution, and reuse of recycled water for direct, non-potable applications are presently regulated under Water Recycling Requirements contained in Order No. 91-101. The Department of Public Works for the City of Burbank is the agency who distributes the recycled water. There are currently 26 users of the recycled water produced by the Burbank WRP. Recycled water is used mainly in cooling towers at the City of Burbank's Department of Water and Power's Power Plant and is also used for landscape irrigation at various sites throughout the city.

VII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER

A. Monitoring Location RSW-001U and RSW-002D

1. The Discharger shall monitor Burbank Western Channel at RSW-001U and RSW-002D as follows:

Table 4a. Receiving Water Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Total flow	cfs	calculation	monthly	--
Turbidity	NTU	grab	monthly	¹⁷

¹⁷ Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Total residual chlorine	mg/L	grab	weekly	17
Total coliform	MPN/100ml or CFU/100ml	grab	monthly	17
Fecal coliform	MPN/100ml or CFU/100ml	grab	monthly	17
E.coli	MPN/100ml or CFU/100ml	grab	monthly ¹⁸	17
Temperature ¹⁹	°F	grab	weekly	17
pH	pH units	grab	weekly	17
Settleable solids	mL/L	grab	quarterly	17
Suspended solids	mg/L	grab	quarterly	17
BOD ₅ 20 °C	mg/L	grab	quarterly	17
Total organic carbon	mg/L	grab	quarterly	17
Oil and grease	mg/L	grab	quarterly	17
Dissolved oxygen	mg/L	grab	weekly	17
Total Dissolved Solids	mg/L	grab	quarterly	17
Conductivity	µmhos/cm	grab	quarterly	17
Sulfate	mg/L	grab	quarterly	17
Chloride	mg/L	grab	quarterly	17
Ammonia nitrogen	mg/L	grab	weekly ²⁰	17
Nitrate nitrogen	mg/L	grab	weekly ²⁰	17
Nitrite nitrogen	mg/L	grab	weekly ²⁰	17
Organic nitrogen	mg/L	grab	weekly ²⁰	17
Total nitrogen	mg/L	grab	weekly ²⁰	17
Total kjeldahl nitrogen (TKN)	mg/L	grab	weekly ²⁰	17
Total phosphorus	mg/L	grab	quarterly	17
Orthophosphate-P	mg/L	grab	quarterly	17
Surfactants (MBAS)	mg/L	grab	quarterly	17
Surfactants (CTAS)	mg/L	grab	quarterly	17
Total hardness (CaCO ₃)	mg/L	grab	quarterly	17
Chronic toxicity	TUc	grab	quarterly	17
Acute toxicity	% Survival	grab	quarterly	17
Cadmium	µg/L	grab	monthly	17
Copper	µg/L	grab	monthly	17

Resources Control Board. For any pollutant whose effluent limitation is lower than all the MLs specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

¹⁸ E. coli testing shall be conducted only if fecal coliform testing is positive. If fecal coliform analysis results in no detection, a result of less than (<) the reporting limit for fecal coliform will be reported for E. coli.

¹⁹ Temperature, pH, nitrate nitrogen, nitrite nitrogen, ammonia nitrogen, organic nitrogen sampling shall be conducted concurrently.

²⁰ Regional Water Board Resolution No. 2003-009, Amendment to the Basin Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in the Los Angeles River (*LA River Nitrogen Compounds TMDL*), requires weekly receiving water monitoring to ensure compliance with the water quality objective.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Lead	µg/L	grab	monthly	17
Zinc	µg/L	grab	monthly	17
Mercury	µg/L	grab	quarterly	17
Cyanide	µg/L	grab	monthly	17
Dibromochloromethane	µg/L	grab	monthly	17
Benzo(a)pyrene	µg/L	grab	quarterly	17
Benzo(b)fluoranthene	µg/L	grab	quarterly	17
Benzo(k)fluoranthene	µg/L	grab	quarterly	17
Bis(2-Ethylhexyl)Phthalate	µg/L	grab	monthly	17
Dibenzo(a,h)Anthracene	µg/L	grab	quarterly	17
Hexachlorobenzene	µg/L	grab	quarterly	17
Indeno(1,2,3-cd)pyrene	µg/L	grab	quarterly	17
Halomethanes	µg/L	grab	monthly	17
Benzo(a)anthracene	µg/L	grab	quarterly	174
Chrysene	µg/L	grab	quarterly	17
Antimony	µg/L	grab	monthly	17
Arsenic	µg/L	grab	quarterly	17
Beryllium	µg/L	grab	quarterly	17
Chromium III	µg/L	calculation	quarterly	17
Chromium VI	µg/L	grab	quarterly	17
Total Chromium	µg/L	grab	quarterly	17
Nickel	µg/L	grab	quarterly	17
Selenium	µg/L	grab	quarterly	17
Silver	µg/L	grab	quarterly	17
Thallium	µg/L	grab	quarterly	17
Fluoride	mg/L	grab	quarterly	17
Boron	mg/L	grab	quarterly	17
Methyl tert-butyl-ether (MTBE)	µg/L	grab	semiannually	21
Perchlorate	µg/L	grab	semiannually	21
1,2,3-Trichloropropane	µg/L	grab	semiannually	21
1,4-Dioxane	µg/L	grab	semiannually	21
Diazinon ²²	µg/L	grab	quarterly	17
2,3,7,8-TCDD ²³	pg/L	grab	semiannually	17

²¹ Emerging chemicals include 1,4-dioxane (USEPA 8270M test method), perchlorate (USEPA 314 test method, or USEPA method 331 if a detection limit of less than 6 µg/L is achieved), 1,2,3-trichloropropane (USEPA 504.1, 8260B test method, or USEPA 524.2 in SIM mode), and methyl tert-butyl ether (USEPA 8260B test method or USEPA method 624 if a detection level of less than 5 µg/L is achieved, and if the Discharger received ELAP certification to run USEPA method 624).

²² Diazinon sampling shall be conducted concurrently with the receiving water chronic toxicity sampling.

²³ In accordance with the SIP, the Discharger shall conduct effluent monitoring for the seventeen 2,3,7,8-tetrachlorodibenzo-p-dioxin (2,3,7,8-TCDD or dioxin) congeners in the effluent and in the receiving water Station RSW-001U located upstream of the discharge point 002. The Discharger shall use the appropriate Toxicity Equivalence Factor (TEF) to determine Toxic Equivalence (TEQ). Where TEQ equals the product between each of the 17 individual congeners' (i) concentration analytical result (C_i) and their corresponding

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Chemical oxygen demand (COD)	mg/L	grab	quarterly	¹⁷
Pesticide ²⁴	µg/L	grab	annually	¹⁷
Remaining EPA priority pollutants ²⁵ excluding asbestos	µg/L	grab	semiannually	¹⁷

B. Bioassessment Monitoring Program

1. The .

This program shall be implemented by appropriately trained staff. Alternatively, a professional subcontractor qualified to conduct bioassessments may be selected to perform the bioassessment work for the Discharger. Analyses of the results of the bioassessment monitoring program, along with photographs of the monitoring site locations taken during sample collection, shall be submitted in the corresponding annual report. If another stakeholder, or interested party in the watershed subcontracts a qualified professional to conduct bioassessment monitoring during the same season and at the same location as specified in the MRP, then the Discharger may, in lieu of duplicative sampling, submit the data, a report interpreting the data, photographs of the site, and related QA/QC documentation in the corresponding annual report.

- The Discharger must provide a copy of their Standard Operation Procedures (SOPs) for the Bioassessment Monitoring Program to the Regional Board upon request. The document must contain step-by-step field, laboratory and data entry procedures, as well as, related QA/QC procedures. The SOP must also include specific information about each bioassessment program including: assessment program description, its organization and the responsibilities of all its personnel; assessment project description and objectives; qualifications of all personnel; and the type of training each member has received.
- Field sampling must conform to the SOP established for the California Stream Bioassessment Procedure (CSBP) or more recently established sampling protocols, such as used by the Surface Water Ambient Monitoring Program (SWAMP). Field crews shall be trained on aspects of the protocol and appropriate safety issues. All field data and sample Chain of Custody (COC) forms must be examined for completion and gross errors. Field inspections shall

Toxicity Equivalence Factor (TEF_i), (i.e., TEQ_i = C_i x TEF_i). Compliance with the Dioxin limitation shall be determined by the summation of the seventeen individual TEQs, or the following equation:

$$\text{Dioxin concentration in effluent} = \sum_{i=1}^{17} (\text{TEQ}_i) = \sum_{i=1}^{17} (C_i)(\text{TEF}_i)$$

²⁴ Pesticides are, for purposes of this Order, those six constituents referred in 40CFR part 125.58(p), (demeton, guthion, malathion, mirex, methoxychlor, and parathion).

²⁵ Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423.

be planned with random visits and shall be performed by the Discharger or an independent auditor. These visits shall report on all aspects of the field procedure with corrective action occurring immediately.

4. A taxonomic identification laboratory shall process the biological samples that usually consist of subsampling organisms, enumerating and identifying taxonomic groups and entering the information into an electronic format. The Regional Board may require QA/QC documents from the taxonomic laboratories and examine their records regularly. Intra-laboratory QA/QC for subsampling, taxonomic validation and corrective actions shall be conducted and documented. Biological laboratories shall also maintain reference collections, vouchered specimens (the Discharger may request the return of their sample voucher collections) and remnant collections. The laboratory should participate in an (external) laboratory taxonomic validation program at a recommended level of 10% or 20%. External QA/QC can be arranged through the California Department of Fish and Game's Aquatic Bioassessment Laboratory located in Rancho Cordova, California.

C. Monitoring Location RSW-003D, Los Angeles River Wardlow Station

1. The Discharger shall report the maximum daily flow at Los Angeles River, downstream of the discharge, at the LA County Department of Public Works' Gage Station No. F319-R Los Angeles River below Wardlow. For the purposes of this permit, this station is also known as RSW-003D. This information is necessary to determine the wet-weather and dry-weather conditions of the river as defined by *Los Angeles River Metals TMDL*. If the gauging station is not operational, an estimated maximum daily flow may be submitted.

Table 4b. TMDL Receiving Water Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Maximum Daily Flow	cfs	recorder	daily	N/A

VIII. OTHER MONITORING REQUIREMENTS

A. Special Study – Constituents of Emerging Concern in Effluent

CECs Special Study Requirements

1. The Discharger shall conduct a special study to investigate the CECs in the effluent discharge. Within six months of the effective date of this Order, the Discharger shall submit to the Executive Officer a CECs Special Study Work Plan (Work Plan) for approval. Upon approval, the Discharger shall implement the Work Plan.

This Special Study Work Plan shall include, but not limited to be, the following:

- a. Identification of CECs to be monitored in the effluent, sample type (e.g. 24-hour composite), sampling frequency, proposed sampling month, and

sampling methodology. Table 5 identifies the minimum parameters to be monitored.

Table 5. Effluent Monitoring of CECs

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
17 α -Ethinyl Estradiol	ng/L	To be proposed	Annually	To be proposed
17 β -Estradiol	ng/L	To be proposed	Annually	To be proposed
Estrone	ng/L	To be proposed	Annually	To be proposed
Bisphenol A	ng/L	To be proposed	Annually	To be proposed
Nonylphenol and nonylphenolpolyethoxylates	ng/L	To be proposed	Annually	To be proposed
Octylphenol and octylphenolpolyethoxylates	ng/L	To be proposed	Annually	To be proposed
Polybrominateddiphenyl ethers	ng/L	To be proposed	Annually	To be proposed
Acetaminophen	ng/L	To be proposed	Annually	To be proposed
Amoxicillin	ng/L	To be proposed	Annually	To be proposed
Azithromycin	ng/L	To be proposed	Annually	To be proposed
Carbamazepine	ng/L	To be proposed	Annually	To be proposed
Caffeine	ng/L	To be proposed	Annually	To be proposed
Ciprofloxacin	ng/L	To be proposed	Annually	To be proposed
DEET	ng/L	To be proposed	Annually	To be proposed
Dilantin	ng/L	To be proposed	Annually	To be proposed
Gemfibrozil	ng/L	To be proposed	Annually	To be proposed
Ibuprofen	ng/L	To be proposed	Annually	To be proposed
Lipitor (Atorvastatin)	ng/L	To be proposed	Annually	To be proposed
Iodinated contrast media (i.e., iopromide)	ng/L	To be proposed	Annually	To be proposed
Sulfamethoxazole	ng/L	To be proposed	Annually	To be proposed
Trimethoprim	ng/L	To be proposed	Annually	To be proposed
Salicylic acid	ng/L	To be proposed	Annually	To be proposed
TCEP	ng/L	To be proposed	Annually	To be proposed
Triclosan	ng/L	To be proposed	Annually	To be proposed

Once the Southern California Coastal Water Research Project's (SCCWRP's) recommended list of CECs monitoring in ambient waters, including ocean waters, is finalized, the above list of minimum parameters to be monitored by the Discharger and the sampling frequency may be re-evaluated and modified by the Executive Officer. At such time, upon request by the Executive Officer, the Discharger shall monitor the requested CECs parameters at the specified frequency. In the Special Study Work Plan, the Discharger may also propose, for consideration and approval by the Executive Officer, surrogate or indicator CECs that may contribute towards a better understanding of CECs in its effluent.

Sample Type – The Discharger shall propose in the Work Plan the appropriate sample type (e.g. grab or composite) for each constituent.

Sampling Period – At minimum, the Discharger shall monitor the specified CECs once per year. The Work Plan shall propose the appropriate sampling month or quarter for each year, consistent with the goals of the

analyses. The rationale for selecting the particular sampling month or quarter shall be explained in the Work Plan.

Proposed Sampling Month- The Discharger may choose a fixed month for sampling or vary the sampling month over the duration of the special study in order to examine possible temporal associations.

Analytical Test Methodology – The Discharger shall review and consider all available analytical test methodologies, including but not limited to those listed in USEPA Methods 1694 and 1698, and methodologies approved or utilized by U.S. Geologic Survey, California Department of Public Health, and other federal or State agencies. Based on its review, the Discharger shall propose the most appropriate analytical methodology, considering sensitivity, accuracy, availability, and cost.

- b. Characterization of existing CECs data (data collected previous to Special Study). The Discharger shall propose a characterization of all existing CECs data (associated with its effluent or receiving water) that have been collected for various purposes in the past. At a minimum, the characterization shall include:
- an identification of all CECs monitored to date (outside of this Special Study);
 - monitoring duration, frequency, and date(s) (for example, from 2000-present, annually);
 - analytical methodologies employed;
 - RL, MLs and MDLs achieved for each methodology used; and,
 - If detected, temporal/seasonal trend analyses (using both statistical and graphical demonstration) of CECs.
- c. Evaluation of CECs data collected as part of this Special Study. The Discharger shall propose an evaluation of CECs data (associated with its effluent) to be collected as part of this special study. At a minimum, the characterization shall include:
- an identification of CECs that have been monitored;
 - monitoring duration, frequency, and date(s);
 - RL, MLs and MDLs achieved for each methodology used;
 - a brief update on any improvements (or change) in the analytical methodologies and associated RL, MLs and MDLs achieved for each methodology used; and,
 - If detected, temporal/seasonal trend analyses (using both statistical and graphical demonstration) of cumulative CECs data collected as part of this special study.
2. Reporting – By April 15th of each year (starting April 15, 2013), the Discharger shall submit to the Executive Officer of this Regional Water Board, an annual report summarizing the monitoring results from the previous year. For example,

the annual report due April 15, 2013, shall include CECs monitoring data from January to December 2012. Each annual report shall include a compilation of effluent monitoring data of CECs listed in the approved Work Plan, MLs, sample type, analytical methodology used, sampling date/time, QA/QC information, and an evaluation of cumulative CECs data collected to date as part of this special study (see above for further details on CECs data evaluation). In addition, the first annual report due April 15, 2013, shall include a characterization of existing CECs data, i.e., all data collected outside of this special study (see above for further details on existing CECs data characterization).

B. Los Angeles River Watershed Monitoring Program (LARWMP)

1. Pursuant to the 40 CFR section 122.41(j) and section 122.48(b), the monitoring program for a discharger receiving an NPDES permit must be designed to determine compliance with NPDES permit terms and conditions, and demonstrate that State water quality standards are met.

Since compliance monitoring focuses on the effects of a point source discharge, it is not designed to assess impacts from other sources of pollution (e.g., non-point source run-off, aerial fallout) or to evaluate the current status of important ecological resources on a regional basis.

The LARWMP was developed for the Los Angeles River Watershed by the City of Burbank in cooperation with Los Angeles Regional Water Quality Control Board and USEPA staff, as well as several other local stakeholders. The LARWMP was approved by the Executive Officer on August 8, 2008. The Discharger shall participate in the implementation of the LARWMP as indicated in that plan.

The goals of the comprehensive watershed-wide monitoring program include evaluating or assessing: compliance with receiving water objectives, trends in surface water quality, impacts to beneficial uses, the health of the biological community, data needs for modeling contaminants of concern, and attaining the goals of the TMDLs under implementation in the Los Angeles River.

2. In coordination with interested stakeholders in the Los Angeles River Watershed, the Discharger shall conduct the bioassessment program annually in the spring/summer period and include an analysis of the community structure of the instream macroinvertebrate assemblages, the community structure of the instream algal assemblages (benthic diatoms and soft-bodied algae), chlorophyll a and biomass for instream algae, and physical habitat assessment at the 10 random monitoring stations designated by the Los Angeles River Watershed Monitoring Program.

This program shall be implemented by appropriately trained staff. Alternatively, a professional subcontractor qualified to conduct bioassessments may be selected to perform the bioassessment work for the Discharger. Analyses of the results of the bioassessment monitoring program, along with photographs of the monitoring site locations taken during sample collection, shall be submitted in the

corresponding annual report. If another stakeholder, or interested party in the watershed subcontracts a qualified professional to conduct bioassessment monitoring during the same season and at the same location as specified in the MRP, then the Discharger may, in lieu of duplicative sampling, submit the data, a report interpreting the data, photographs of the site, and related QA/QC documentation in the corresponding annual report.

3. The Discharger must provide a copy of their Standard Operation Procedures (SOPs) for the Bioassessment Monitoring Program to the Regional Board upon request. The document must contain step-by-step field, laboratory and data entry procedures, as well as, related QA/QC procedures. The SOP must also include specific information about each bioassessment program including: assessment program description, its organization and the responsibilities of all its personnel; assessment project description and objectives; qualifications of all personnel; and the type of training each member has received.
4. Field sampling must conform to the SOP established for the California Stream Bioassessment Procedure (CSBP) or more recently established sampling protocols, such as used by the Surface Water Ambient Monitoring Program (SWAMP). Field crews shall be trained on aspects of the protocol and appropriate safety issues. All field data and sample Chain of Custody (COC) forms must be examined for completion and gross errors. Field inspections shall be planned with random visits and shall be performed by the Discharger or an independent auditor. These visits shall report on all aspects of the field procedure with corrective action occurring immediately.
5. A taxonomic identification laboratory shall process the biological samples that usually consist of subsampling organisms, enumerating and identifying taxonomic groups and entering the information into an electronic format. The Regional Board may require QA/QC documents from the taxonomic laboratories and examine their records regularly. Intra-laboratory QA/QC for subsampling, taxonomic validation and corrective actions shall be conducted and documented. Biological laboratories shall also maintain reference collections, vouchered specimens (the Discharger may request the return of their sample voucher collections) and remnant collections. The laboratory should participate in an (external) laboratory taxonomic validation program at a recommended level of 10% or 20%. External QA/QC can be arranged through the California Department of Fish and Game's Aquatic Bioassessment Laboratory located in Rancho Cordova, California.

C. Tertiary Filter Treatment Bypasses

1. During any day that filters are bypassed, the Discharger shall monitor the effluent for BOD, suspended solids, settleable solids, and oil and grease, on daily basis, until it is demonstrated that the filter "bypass" has not caused an adverse impact on the receiving water.

2. The Discharger shall maintain chronological log of tertiary filter treatment process bypasses, to include the following:
 - a. Date and time of bypass start and end;
 - b. Total duration time; and,
 - c. Estimated total volume bypassed
3. The Discharger shall notify Regional Water Board staff by telephone within 24 hours of the filter bypass event.
4. The Discharger shall submit a written report to the Regional Water Board, according to the corresponding monthly self-monitoring report schedule. The report shall include, at a minimum, the information from the chronological log. Results from the daily effluent monitoring, required by VII.C.1. above, shall be submitted to the Regional Water Board as the results become available.

IX. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. If there is no discharge during any reporting period, the report shall so state.
3. Each monitoring report shall contain a separate section titled "Summary of Non-Compliance" which discusses the compliance record and the corrective actions taken or planned that may be needed to bring the discharge into full compliance with waste discharge requirements. This section shall clearly list all non-compliance with discharge requirements, as well as all excursions of effluent limitations.
4. The Discharger shall inform the Regional Water Board well in advance of any proposed construction activity that could potentially affect compliance with applicable requirements.

B. Self-Monitoring Reports (SMRs)

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. The Discharger shall report in the SMR the results for all monitoring specified in this MRP under sections III through VIII. The Discharger shall submit monthly, quarterly, semiannual, annual SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. If the Discharger monitors any pollutant more frequently than required by this Order (other

than for process/operational control, startup, research, or equipment testing), the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.

3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table 6. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	Submit with monthly SMR
Daily	Permit effective date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	Submit with monthly SMR
Weekly	Sunday following permit effective date or on permit effective date if on a Sunday	Sunday through Saturday	Submit with monthly SMR
Monthly	First day of calendar month following permit effective date or on permit effective date if that date is first day of the month	1 st day of calendar month through last day of calendar month	By the 15 th day of the third month after the month of sampling
Quarterly	Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31	June 15 September 15 December 15 March 15
Semiannually	Closest of January 1 or July 1 following (or on) permit effective date	January 1 through June 30 July 1 through December 31	September 15 March 15
Annually	January 1 following (or on) permit effective date	January 1 through December 31	April 15

4. Reporting Protocols. The Discharger shall report with each sample result the applicable reported Minimum Level (ML), for those constituents where the SIP specifies MLs, and the applicable reported Reporting Level (RL), for all other constituents as appropriate, and the current Method Detection Limit (MDL), as determined by the procedure in Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the

reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
 - d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.
5. The Discharger shall submit SMRs in accordance with the following requirements:
- a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations.
 - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
 - c. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D). Paper SMRs should be converted to a Portable Document Format (PDF). Documents that are less than 10 megabytes (MB) should be emailed to losangeles@waterboards.ca.gov. Documents that are 10 MB or larger should be transferred to a disk and mailed to the address listed below: (Reference the reports to Compliance File No. 4424 to facilitate routing to the appropriate staff and file.)

California Regional Water Quality Control Board
320 West 4th Street, Suite 200
Los Angeles, CA 90013
Attention: Information Technology Unit

However, Dischargers who have been certified to only submit electronic SMRs to CIWQS should continue doing so, as previously required.

C. Discharge Monitoring Reports (DMRs)

- 1. As described in Section X.B.1 above, at any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.

2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharger shall submit the original DMR and one copy of the DMR to the address listed below:

STANDARD MAIL	FEDEX/UPS/ OTHER PRIVATE CARRIERS
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA95814

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated will not be accepted unless they follow the exact same format of EPA Form 3320-1.

D. Other Reports

1. Annual Summary Report

By April 15 of each year, the Discharger shall submit an annual report containing a discussion of the previous year's influent/effluent analytical results and receiving water bacterial monitoring data. The annual report shall also contain an overview of any plans for upgrades to the treatment plant's collection system, the treatment processes, or the outfall system. The Discharger shall submit a hard copy annual report to the Regional Water Board in accordance with the requirements described in subsection IX.B.5 above.

Each annual monitoring report shall contain a separate section titled "Reasonable Potential Analysis" which discusses whether or not reasonable potential was triggered for pollutants which do not have a final effluent limitation in the NPDES permit. This section shall contain the following statement: "The analytical results for this sampling period did/ did not trigger reasonable potential." If reasonable potential was triggered, then the following information should also be provided:

- a. A list of the pollutant(s) that triggered reasonable potential;
 - b. The Basin Plan or CTR criteria that was exceeded for each given pollutant;
 - c. The concentration of the pollutant(s);
 - d. The test method used to analyze the sample; and,
 - e. The date and time of sample collection.
2. The Discharger shall submit to the Regional Water Board, together with the first monitoring report required by this permit, a list of all chemicals and proprietary additives which could affect this waste discharge, including quantities of each. Any subsequent changes in types and/or quantities shall be reported promptly.

3. The Regional Water Board requires the Discharger to file with the Regional Water Board, within 90 days after the effective date of this Order, a technical report on his preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. The technical report should:
 - a. Identify the possible sources of accidental loss, untreated waste bypass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks, and pipes should be considered.
 - b. Evaluate the effectiveness of present facilities and procedures and state when they become operational.
 - c. Describe facilities and procedures needed for effective preventive and contingency plans.
 - d. Describe facilities and procedures needed for effective preventive and contingency plans.
 - e. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule contingent interim and final dates when they will be constructed, implemented, or operational.

ATTACHMENT F – FACT SHEET

Table of Contents

Attachment F – Fact Sheet	F-3
I. Permit Information	F-3
II. Facility Description	F-4
A. Description of Wastewater and Biosolids Treatment or Controls	F-4
B. Discharge Points and Receiving Waters.....	F-5
C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data	F-6
D. Compliance Summary.....	F-11
E. Planned Changes	F-11
III. Applicable Plans, Policies, and Regulations.....	F-11
A. Legal Authorities	F-11
B. California Environmental Quality Act (CEQA)	F-12
C. State and Federal Regulations, Policies, and Plans	F-12
D. Integrated Report on Impaired Water Bodies CWA 303(d) List	F-16
E. Other Plans, Policies and Regulations.....	F-16
IV. Rationale For Effluent Limitations and Discharge Specifications.....	F-22
A. Discharge Prohibitions	F-22
B. Technology-Based Effluent Limitations (TBELs).....	F-22
1. Scope and Authority.....	F-22
2. Applicable TBELs.....	F-22
C. Water Quality-Based Effluent Limitations (WQBELs).....	F-24
1. Scope and Authority.....	F-24
2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	F-24
3. Determining the Need for WQBELs	F-34
4. WQBEL Calculations	F-40
5. Whole Effluent Toxicity (WET)	F-46
D. Final Effluent Limitations.....	F-48
E. Reclamation Specifications.....	F-52
V. Rationale for Receiving Water Limitations	F-52
A. Surface Water	F-52
B. Groundwater	F-52
VI. Rationale for Monitoring and Reporting Requirements.....	F-53
A. Influent Monitoring	F-53
B. Effluent Monitoring	F-53
C. Whole Effluent Toxicity Testing Requirements	F-55
D. Receiving Water Monitoring.....	F-55
1. Surface Water	F-55
VII. Rationale for Provisions.....	F-56
A. Standard Provisions.....	F-56
B. Special Provisions.....	F-56
1. Reopener Provisions.....	F-56
2. Special Studies and Additional Monitoring Requirements.....	F-56
3. Best Management Practices and Pollution Prevention	F-60
4. Construction, Operation, and Maintenance Specifications.....	F-60

5. Special Provisions for Municipal Facilities (POTWs Only)	F-61
VIII. Public Participation	F-61
A. Notification of Interested Parties	F-61
B. Written Comments	F-62
C. Public Hearing	F-62
D. Nature of Hearing.....	F-62
E. Parties to the Hearing	F-63
F. Public Comments and Submittal of Evidence	F-63
G. Hearing Procedure.....	F-63
H. Waste Discharge Requirements Petitions.....	F-64
I. Information and Copying.....	F-64
J. Register of Interested Persons	F-64
K. Additional Information	F-64

List of Tables

Table 1. Facility Information.....	F-3
Table 2. Historic Effluent Limitations and Monitoring Data	F-6
Table 3a. Basin Plan Beneficial Uses – Receiving Waters.....	F-12
Table 3b. Basin Plan Beneficial Uses – Ground Waters.....	F-13
Table 4. Summary of Technology-based Effluent Limitations.....	F-23
Table 5. Summary of Reasonable Potential Analysis	F-36
Table 6. Summary of Water Quality-based Effluent Limitations for Discharge Point 002	F-45
Table 7. Summary of Final Effluent Limitations	F-50
Table 8. Effluent Monitoring Program Comparison Table.....	F-54
Table 9. CECs Monitoring in the Effluent.....	F-58

ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to the City of Burbank (City or Discharger). Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table 1. Facility Information

WDID	4B190101001
Discharger	City of Burbank
Name of Facility	Burbank Water Reclamation Plant
Facility Address	740 N. Lake Street
	Burbank, CA91502
	Los Angeles County
Facility Contact, Title and Phone	Daniel Rynn, Principal Civil Engineer, (818) 238-3940
Authorized Person to Sign and Submit Reports	Bonnie Teafor, Public Works Director
Mailing Address	275 East Olive Avenue, Burbank, CA 91502
Billing Address	SAME
Type of Facility	POTW
Major or Minor Facility	Major
Threat to Water Quality	1
Complexity	A
Pretreatment Program	Y
Reclamation Requirements	Producer
Facility Permitted Flow	12.5 million gallons per day
Facility Design Flow	12.5 million gallons per day
Watershed	Los Angeles River
Receiving Water	Burbank Western Channel
Receiving Water Type	Inland surface water

- A.** The City of Burbank (hereinafter Discharger) is the owner of the Burbank Water Reclamation Plant (Burbank WRP, hereinafter Facility), a Publicly-Owned Treatment Works and United Water Services is contracted to operate it.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The Facility discharges wastewater to Burbank Western Channel, a water of the United States, and is currently regulated by Order No. R4-2006-0085 adopted on November 9, 2006. This Order was subsequently amended by Order No. R4-2010-0058 adopted on April 1, 2010, and expired on October 10, 2011. The terms and conditions of the current Order have been automatically continued and remain in effect until new Waste Discharge Requirements and NPDES permit are adopted pursuant to this Order.
- C.** The Discharger filed a report of waste discharge and submitted an application for renewal of its Waste Discharge Requirements (WDRs) and National Pollutant Discharge Elimination System (NPDES) permit on April 18, 2011. A site visit was conducted on December 12, 2011, to observe operations and collect additional data to develop permit limitations and conditions.

II. FACILITY DESCRIPTION

The Discharger owns and United Water Services operates the Burbank WRP, a tertiary wastewater treatment plant located at 740 N. Lake Street, Burbank, California. Attachment B shows the location of the plant. The Burbank WRP currently receives wastewater from the City of Burbank. The wastewater is a mixture of domestic and industrial wastewater that is pre-treated pursuant to 40 CFR Part 403. Burbank WRP has a design capacity of 12.5 mgd and serves an estimated population of 105,000 people.

The Burbank WRP is part of the City of Los Angeles' integrated network of facilities, known as the North Outfall Sewer (NOS), which includes four treatment plants. The upstream treatment plants (Donald C. Tillman WRP, Los Angeles-Glendale WRP, and Burbank WRP) discharge solids to the Hyperion Treatment Plant. This system also allows biosolids, solids, and excess flows to be diverted from the upstream plants to the Hyperion Wastewater Treatment Plant for treatment and disposal. All solids removed from the Burbank WRP treatment process are returned untreated to the NOS for downstream treatment at the Hyperion Treatment Plant.

A. Description of Wastewater and Biosolids Treatment or Controls

1. Treatment at the Burbank WRP consists of barscreen removal of large solids, flow equalization, primary sedimentation, activated sludge biological treatment with nitrification and denitrification, secondary sedimentation with coagulation, single media deep bed sand filtration, chlorination, and dechlorination. Treated wastewater discharged to Burbank Western Channel is dechlorinated but the effluent delivered for reuse is not dechlorinated.
2. Sodium hypochlorite is used as a disinfectant in the Burbank WRP. The disinfecting agent is added to the treated effluent prior to the filters to destroy bacteria, pathogens and viruses, and to minimize algal growth in the filters. Prior to discharge, sodium bisulfite is added to the treated effluent to remove residual chlorine.

3. No facilities are provided for solids processed at the plant. Sewage solids separated from the wastewater are returned to the trunk sewer for conveyance to NOS, where treatment and disposal occur, under Hyperion Wastewater Treatment Plant's NPDES permit. Attachment C is a schematic of the Burbank WRP wastewater flow.
4. City of Burbank has constructed a biological nutrient removal system with nitrogen de-nitrification process (NDN) in order to achieve compliance with the ammonia Basin Plan objectives. The system was completed and has been in operation since March 18, 2003.

B. Discharge Points and Receiving Waters

The Burbank WRP discharges tertiary-treated municipal to the Burbank Western Channel, a water of the United States, above the Estuary. Treated effluents are discharged from the plant to surface waters at the following discharge point:

Discharge Point 001 is abandoned and has not been used since June 14, 2005.

Discharge Point 002: Discharge to Burbank Western Channel near Burbank Boulevard (approximate coordinates: Latitude 34° 10' 58", Longitude 118° 18' 58").

During dry weather (May 1 – October 31), the Burbank WRP's effluent is the primary source of water flow in the Burbank Western Channel and is a significant source of water flow in the Los Angeles River together with urban runoff conveyed through the municipal separate storm sewer systems (MS4). Storm water and dry weather urban runoff from MS4s are regulated under an NPDES permit, *Waste Discharge Requirements for Municipal Storm Water and Urban Runoff Discharges within the County of Los Angeles* (LA Municipal Permit), NPDES Permit No. CAS004001.

The Los Angeles County Flood Control District channelized Burbank Western Channel and portions of the Los Angeles River to convey and control floodwater, and to prevent damage to homes located adjacent to the river. Although not its main purpose, the Los Angeles River conveys treated wastewater along with floodwater, and urban runoff. The Los Angeles River is unlined further downstream of its confluence with the Burbank Western Channel, in what is known as the Glendale Narrows. Groundwater recharge occurs incidentally, in these unlined areas of the Los Angeles River. At times when the groundwater table is high, groundwater rises and contributes flow to the Los Angeles River. Natural springs feed the river and support willows, sycamores, and cottonwood trees. South of the Glendale Narrows, the Los Angeles River is concrete-lined down to Willow Street, in Long Beach.

The Los Angeles (LA) River watershed is one of the largest in the Region. It is also one of the most diverse in terms of land use patterns. The LA River drains an 824 square mile area. Approximately 324 square miles of the watershed are covered by forest or open space land including the area near the headwaters which originate in the Santa Monica, Santa Susana, and San Gabriel Mountains. The rest of the watershed is highly developed. The river flows through the San Fernando Valley past heavily developed residential and commercial areas. From the Arroyo Seco, north of downtown Los

Angeles, to the confluence with the Rio Hondo, the river flows through industrial and commercial areas and is bordered by railyards, freeways, and major commercial and government buildings. From the Rio Hondo to the Pacific Ocean, the river flows through industrial, residential, and commercial areas, including major refineries and petroleum products storage facilities, major freeways, rail lines, and railyards serving the Ports of Los Angeles and Long Beach.

Major tributaries to the river in the San Fernando Valley are the Pacoima Wash, Tujunga Wash (both drain portions of the Angeles National Forest in the San Gabriel Mountains), the Burbank Western Channel and the Verdugo Wash (both drain the Verdugo Mountains). Due to major flood events at the beginning of the century, by the 1950's most of the river was lined with concrete. In the San Fernando Valley, there is a section of the river with a soft bottom at the Sepulveda Flood Control Basin. The Basin is a 2,150-acre open space upstream of the Sepulveda Dam designed to collect flood waters during major storms. Because the area is periodically inundated, it remains in a semi-natural condition and supports a variety of low-intensity uses as well as supplying habitat. At the eastern end of the San Fernando Valley, the river bends around the Hollywood Hills and flows through Griffith and Elysian Parks, in an area known as the Glendale Narrows. Since the water table was too high to allow laying of concrete, the river in this area has a rocky, unlined bottom with concrete-lined or rip-rap sides. This stretch of the river is fed by natural springs and supports stands of willows, sycamores, and cottonwoods. The many trails and paths along the river in this area are heavily used by the public for hiking, horseback riding, and bird watching.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in the existing Order for discharges from Discharge Point 002 (Monitoring Location EFF-002) and representative monitoring data summarized in the Report of Waste Discharge (ROWD) from the term of the previous Order are as follows:

Table 2. Historic Effluent Limitations and Monitoring Data

Parameter	Units	Effluent Limitation			Monitoring Data (From 12/01/2007 to 08/31/2011)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
BOD ₅ 20°C	mg/L	20	30	45	<3.0	--	5.0
Suspended Solids	mg/L	15	40	45	<1.0	--	5.0
Oil and Grease	mg/L	10	--	15	<1.2	--	45
Settleable Solids	ml/L	0.1	--	0.3	< 0.1	--	< 0.1
Residual Chlorine	mg/L	--	--	0.1	< 0.1	--	<0.01
Total Dissolved Solids	mg/L	950	--	--	655	--	860
MBAS	mg/L	0.5	--	--	0.058	--	0.13
Chloride	mg/L	190	--	--	130	--	173
Sulfate	mg/L	300	--	--	127	--	252

Parameter	Units	Effluent Limitation			Monitoring Data (From 12/01/2007 to 08/31/2011)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Turbidity	NTU	2 Daily Ave	--	5	0.43	--	6.6
Nitrate as N	mg/L	7.2	--	--	6.74	--	7.27
Nitrite as N	mg/L	0.9	--	--	<0.01	--	0.04
Nitrate + Nitrite as N	mg/L	7.2	--	--	4.67	--	7.27
Ammonia as N	mg/L	2.1	--	9.1	0.69	--	1.2
Total Phosphorus	mg/L	--	--	--	4.6	--	7.6
Antimony	µg/L	--	--	--	0.73	--	1.4
Arsenic	µg/L	--	--	--	2.0	--	2.9
Beryllium	µg/L	--	--	--	<0.11	--	<0.11
Cadmium	µg/L	4.4	--	5.8	0.18	--	1.5
Chromium III	µg/L	--	--	--	2.1	--	6.0
Chromium VI	µg/L	9.7	--	16	0.11	--	0.99
Copper	µg/L	16	--	30	21	--	44
Iron	µg/L	--	--	--	72	--	190
Lead	µg/L	8	--	13	0.87	--	2.4
Mercury	µg/L	0.051		0.10	0.0082	--	0.0022
Nickel	µg/L	--	--	--	2.5	--	3.4
Selenium	µg/L	4.2	--	7.8	3.6	--	3.9
Silver	µg/L	--	--	--	0.54	--	2.5
Thallium	µg/L	--	--	--	<0.05	--	0.08
Zinc	µg/L	178	--	236	71	--	105
Cyanide	µg/L	3.4	--	9.6	<2.5	--	8
Asbestos	µg/L	--	--	--	--	--	--
2,3,7,8-TCDD (Dioxin)	pg/L	--	--	--	<0.655	--	<0.532
Acrolein	µg/L	--	--	--	<0.43	--	<0.43
Acrylonitrile	µg/L	--	--	--	<0.22	--	<0.22
Benzene	µg/L	--	--	--	<0.24	--	<0.24
Bromoform	µg/L	--	--	--	8.2	--	17
Carbon Tetrachloride	µg/L	--	--	--	<0.25	--	<0.25
Chlorobenzene	µg/L	--	--	--	<0.33	--	<0.33
Dibromochloro- methane	µg/L	--	--	--	26	--	60
Chloroethane	µg/L	--	--	--	<0.20	--	<0.20
2-chloroethylvinyl- ether	µg/L	--	--	--	<0.29	--	<0.29
Chloroform	µg/L	--	--	--	12	--	74
Dichlorobromo- methane	µg/L	--	--	--	23	--	43
Total trihalomethanes	µg/L	80	--	--	69	---	216

Parameter	Units	Effluent Limitation			Monitoring Data (From 12/01/2007 to 08/31/2011)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
1,1-dichloroethane	µg/L	--	--	--	<0.26	--	<0.26
1,2-dichloroethane	µg/L	--	--	--	<0.22	--	<0.22
1,1-dichloroethylene	µg/L	--	--	--	<0.25	--	<0.25
1,2-dichloropropane	µg/L	--	--	--	<0.23	--	<0.23
1,3-dichloropropylene	µg/L	--	--	--	<0.30	--	<0.30
Ethylbenzene	µg/L	--	--	--	<0.31	--	<0.31
Methyl bromide	µg/L	--	--	--	<0.14	--	<0.14
Methyl chloride	µg/L	--	--	--	<0.21	--	<0.21
Methylene chloride	µg/L	--	--	--	<0.28	--	1.2
1,1,2,2-tetrachloroethane	µg/L	--	--	--	<0.27	--	<0.27
Tetrachloroethylene	µg/L	--	--	--	<0.37	--	3.1
Toluene	µg/L	--	--	--	<0.32	--	<0.32
Trans 1,2-Dichloroethylene	µg/L	--	--	--	<0.25	--	<0.25
1,1,1-Trichloroethane	µg/L	--	--	--	<0.30	--	0.77
1,1,2-Trichloroethane	µg/L	--	--	--	<0.25	--	<0.25
Trichloroethylene	µg/L	--	--	--	<0.25	--	<0.25
Vinyl Chloride	µg/L	--	--	--	<0.25	--	<0.25
2-chlorophenol	µg/L	--	--	--	<0.72	--	<0.72
2,4-dichlorophenol	µg/L	--	--	--	<0.77	--	<0.77
2,4-dimethylphenol	µg/L	--	--	--	<0.83	--	<0.83
4,6-dinitro-o-resol(aka 2-methyl-4,6-Dinitrophenol)	µg/L	--	--	--	<0.41	--	<0.41
2,4-dinitrophenol	µg/L	--	--	--	<4.3	--	<7.3
2-nitrophenol	µg/L	--	--	--	<0.81	--	<0.81
4-nitrophenol	µg/L	--	--	--	<5.7	--	<5.7
3-Methyl-4-Chlorophenol (aka P-chloro-m-cresol)	µg/L	--	--	--	<0.36	--	0.59
Pentachlorophenol	µg/L	--	--	--	<0.59	--	0.95
Phenol	µg/L	--	--	--	<0.36	--	<0.36
2,4,6-trichlorophenol	µg/L	--	--	--	<0.88	--	<0.88
Acenaphthene	µg/L	--	--	--	<0.35	--	<0.35
Acenaphthylene	µg/L	--	--	--	<0.32	--	<0.32
Anthracene	µg/L	--	--	--	<0.30	--	0.28
Benzidine	µg/L	--	--	--	<1.1	--	<1.1
Benzo(a)Anthracene	µg/L	--	--	--	<0.23	--	0.45
Benzo(a)Pyrene	µg/L	--	--	--	<0.25	--	0.23

Parameter	Units	Effluent Limitation			Monitoring Data (From 12/01/2007 to 08/31/2011)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Benzo(b) Fluoranthene	µg/L	--	--	--	<0.21	--	0.25
Benzo(ghi)Perylene	µg/L	--	--	--	<0.33	--	0.5
Benzo(k) Fluoranthene	µg/L	--	--	--	<0.28	--	0.32
Bis(2-Chloroethoxy) methane	µg/L	--	--	--	<0.45	--	<0.45
Bis(2-Chloroethyl)Ether	µg/L	--	--	--	<0.53	--	<0.53
Bis(2-Chloroisopropyl) Ether	µg/L	--	--	--	<0.52	--	<0.52
Bis(2-Ethylhexyl) Phthalate	µg/L	4	--	--	3.6	--	85
4-Bromophenyl Phenyl Ether	µg/L	--	--	--	<0.35	--	0.28
Butylbenzyl Phthalate	µg/L	--	--	--	<0.60	--	0.94
2-Chloronaphthalene	µg/L	--	--	--	<0.38	--	<0.38
4-Chlorophenyl Phenyl Ether	µg/L	--	--	--	<0.46	--	<0.46
Chrysene	µg/L	--	--	--	<0.28	--	0.33
Dibenzo(a,h) Anthracene	µg/L	--	--	--	<0.58	--	0.49
1,2-Dichlorobenzene	µg/L	--	--	--	<0.27	--	<0.27
1,3-Dichlorobenzene	µg/L	--	--	--	<0.27	--	<0.27
1,4-Dichlorobenzene	µg/L	--	--	--	<0.27	--	<0.27
3,3'-Dichlorobenzidine	µg/L	--	--	--	<0.39	--	<0.39
Diethyl Phthalate	µg/L	--	--	--	<1.0	--	1.3
Dimethyl Phthalate	µg/L	--	--	--	<0.36	--	<0.36
Di-n-Butyl Phthalate	µg/L	--	--	--	<0.58	--	0.83
2,4-Dinitrotoluene	µg/L	--	--	--	<0.46	--	<0.46
2,6-Dinitrotoluene	µg/L	--	--	--	<0.34	--	1.4
Di-n-Octyl Phthalate	µg/L	--	--	--	<0.35	--	<0.35
1,2-Diphenylhydrazine	µg/L	--	--	--	<0.41	--	<0.41
Fluoranthene	µg/L	--	--	--	<0.20	--	0.39
Fluorene	µg/L	--	--	--	<0.33	--	0.32
Hexachlorobenzene	µg/L	--	--	--	<0.27	--	0.26
Hexachlorobutadiene	µg/L	--	--	--	<0.49	--	<0.49
Hexachlorocyclopentadiene	µg/L	--	--	--	<4.3	--	<4.3

Parameter	Units	Effluent Limitation			Monitoring Data (From 12/01/2007 to 08/31/2011)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Hexachloroethane	µg/L	--	--	--	<0.44	--	<0.44
Indeno(1,2,3-cd)Pyrene	µg/L	--	--	--	<0.33	--	0.42
Isophorone	µg/L	--	--	--	<0.40	--	<0.40
Naphthalene	µg/L	--	--	--	<0.38	--	0.43
Nitrobenzene	µg/L	--	--	--	<0.44	--	<0.44
N-Nitrosodimethyl-amine	µg/L	--	--	--	<0.44	--	<0.44
N-Nitrosodi-n-Propylamine	µg/L	--	--	--	<0.47	--	<0.47
N-Nitrosodiphenyl-amine	µg/L	--	--	--	<0.32	--	0.31
Phenanthrene	µg/L	--	--	--	<0.29	--	0.51
Pyrene	µg/L	--	--	--	<0.22	--	0.34
1,2,4-Trichlorobenzene	µg/L	--	--	--	<0.46	--	<0.46
Aldrin	µg/L	--	--	--	<0.005	--	<0.005
Alpha-BHC	µg/L	--	--	--	<0.01	--	<0.01
Beta-BHC	µg/L	--	--	--	<0.005	--	<0.005
Gamma-BHC (aka Lindane)	µg/L	0.063	--	0.13	<0.02	--	<0.02
delta-BHC	µg/L	--	--	--	<0.0025	--	<0.0025
Chlordane	µg/L	--	--	--	<0.1	--	<0.1
4,4'-DDT	µg/L	--	--	--	<0.0031	--	<0.0031
4,4'-DDE	µg/L	--	--	--	<0.0025	--	<0.0025
4,4'-DDD	µg/L	--	--	--	<0.003	--	<0.003
Dieldrin	µg/L	--	--	--	<0.0021	--	<0.0021
Alpha-Endosulfan	µg/L	--	--	--	<0.0017	--	<0.0017
Beta-Endosulfan	µg/L	--	--	--	<0.0019	--	<0.0019
Endosulfan Sulfate	µg/L	--	--	--	<0.008	--	<0.008
Endrin	µg/L	--	--	--	<0.0028	--	<0.0028
Endrin Aldehyde	µg/L	--	--	--	<0.003	--	<0.003
Heptachlor	µg/L	--	--	--	<0.0017	--	<0.0017
Heptachlor Epoxide	µg/L	--	--	--	<0.0019	--	<0.0019
PCB 1016	µg/L	--	--	--	<0.08	--	<0.08
PCB 1221	µg/L	--	--	--	<0.06	--	<0.06
PCB 1232	µg/L	--	--	--	<0.15	--	<0.15
PCB 1242	µg/L	--	--	--	<0.07	--	<0.07
PCB 1248	µg/L	--	--	--	<0.06	--	<0.06
PCB 1254	µg/L	--	--	--	<0.04	--	<0.04
PCB 1260	µg/L	--	--	--	<0.04	--	<0.04
Toxaphene	µg/L	--	--	--	<0.12	--	<0.12
1,4-Dioxane	µg/L	--	--	--	1.8	--	2

Parameter	Units	Effluent Limitation			Monitoring Data (From 12/01/2007 to 08/31/2011)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
MTBE	µg/L	--	--	--	<0.25	--	<0.25
Perchlorate	µg/L	--	--	--	<0.45	--	<8.2
1,2,3-Trichloropropane	µg/L	--	--	--	<0.031	--	0.77
Methoxychlor	µg/L	--	--	--	<0.0054	--	<0.0054
2,4-D	µg/L	--	--	--	<0.21	--	<0.21
2,4,5-TP (Sylvex)	µg/L	--	--	--	<0.11	--	<0.11
Alpha Radioactivity	pCi/mL	--	--	--	4.9	--	14.5
Beta Radioactivity	pCi/mL	--	--	--	21	--	24

D. Compliance Summary

Monitoring data from December 2007 to August 2011 indicate that the Discharger has consistently complied with the effluent limitations of Order No. R4-2006-0085 as amended by Order No. R4-2010-0058 except for three reporting violations and the following effluent violations: four total residual chlorine, two turbidity, eleven total coliform, three oil and grease, nineteen temperature, and one bis(2-ethylhexyl)phthalate.

Interim Effluent Limitations:

Order No. R4-2006-0085 as amended by Order No. R4-2010-0058 provided interim effluent limitations for mercury, selenium, gamma-BHC (lindane), and total trihalomethanes. The Discharger met all the interim effluent limitations by the October 10, 2011 compliance schedule deadline. Time Schedule Order (TSO) No. R4-2011-0038, adopted by the Regional Water Board on February 3, 2011, provided a one-year compliance schedule with interim effluent limitations for copper, subject to an extension by the Regional Water Board. Consistent with language contained in TSO No. R4-2011-0038, the Regional Water Board has extend the time schedule so that it expires on the effective date of this NPDES permit.

E. Planned Changes

The Discharger is not planning any upgrades to the Burbank WRP in the near future.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the proposed Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (CWC) (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the CWC (commencing with section 13260).

B. California Environmental Quality Act (CEQA)

Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100 through 21177.

C. State and Federal Regulations, Policies, and Plans

1. **Water Quality Control Plans.** The Regional Water Quality Control Board (Regional Water Board) adopted a Water Quality Control Plan for the Los Angeles Region (hereinafter Basin Plan) on June 13, 1994 that designates beneficial uses, establishes water quality objectives (WQOs), and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which establishes state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to Los Angeles River are as follows:

Table 3a. Basin Plan Beneficial Uses – Receiving Waters

Discharge Point	Receiving Water Name	Beneficial Use(s)
002	Burbank Western Channel (Hydro. Unit No. 405.21)	<u>Intermittent:</u> <u>non-contact water recreation (REC-2).</u> <u>Potential:</u> <u>Municipal and domestic water supply (MUN¹), water contact recreation (REC-1²), warm freshwater habitat (WARM) and wildlife habitat (WILD).</u>
002	Los Angeles River (Hydro. Unit No. 405.21)	<u>Existing:</u> Ground water recharge (GWR); REC-1; REC-2; WARM; WILD; and wetland habitat (WET). <u>Potential:</u> MUN ¹ and industrial service supply (IND).

¹ The potential municipal and domestic supply (p*MUN) beneficial use for the water body is consistent with the State Water Resources Control Board Resolution 88-63 and Regional Water Board Resolution No. 89-003; however, the Regional Water Board has only conditionally designated the MUN beneficial use of the surface water and at this time cannot establish effluent limitation designed to protect the conditional designation.

Discharge Point	Receiving Water Name	Beneficial Use(s)
002	Los Angeles River (Hydro. Unit No. 405.15)	<u>Existing:</u> GWR; REC-1 ² ; REC-2; and WARM. <u>Potential:</u> MUN ¹ ; IND; and WILD.
002	Los Angeles River to Estuary (Hydro. Unit No. 405.12)	<u>Existing:</u> GWR; REC-1 ² ; REC-2; WARM; marine habitat (MAR); WILD; and rare, threatened, or endangered species (RARE). <u>Potential:</u> MUN ¹ ; IND; industrial process supply (PROC); migration of aquatic organisms (MIGR); spawning, reproduction, and/or early development (SPWN); and shellfish harvesting (SHELL ²).
002	Los Angeles River Estuary (Hydro. Unit No. 405.12)	<u>Existing:</u> IND; navigation (NAV); REC-1; REC-2; commercial and sport fishing (COMM); estuarine habitat (EST); MAR; WILD; RARE ³ ; MIGR ⁴ ; and SPWN ⁴ ; and WET. <u>Potential:</u> SHELL.

Beneficial uses of the receiving ground waters are as follows:

Table 3b. Basin Plan Beneficial Uses – Ground Waters

Discharge Point	Basin Name	Beneficial Use(s)
002	San Fernando Basin East of Highway 405 (overall) DWR Basin No. 4-12	<u>Existing:</u> Municipal and domestic water supply (MUN); industrial service supply (IND); industrial process supply (PROC); and agricultural supply (AGR)
002	Los Angeles Coastal Plain Central Basin DWR Basin No. 4-11	<u>Existing:</u> Municipal and domestic water supply (MUN); industrial service supply (IND); industrial process supply (PROC); and agricultural supply (AGR)
002	Los Angeles Coastal Plain West Coast Basin DWR Basin No. 4-11	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR)

² Access prohibited by Los Angeles County DPW.

³ One or more rare species utilize all ocean, bays, estuaries, and coastal wetlands for foraging and/or nesting.

⁴ Aquatic organisms utilize all bays, estuaries, lagoons and coastal wetlands, to a certain extent, for spawning and early development. This may include migration into areas which are heavily influenced by freshwater inputs.

Requirements of this Order implement the Basin Plan and subsequent amendments.

- a. **Ammonia WQOs** –Table 3-1 through Table 3-4 of the 1994 Basin Plan provided WQOs for ammonia to protect aquatic life. However, those ammonia WQOs were revised on April 25, 2002, by the Regional Water Board with the adoption of Resolution No. 2002-011, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Update the Ammonia Objectives for Inland Surface Waters (Including Enclosed Bays, Estuaries and Wetlands) with Beneficial Use Designations for Protection of Aquatic Life*. The ammonia Basin Plan amendment was approved by the State Water Board, Office of Administrative Law (OAL), and USEPA on April 30, 2003, June 5, 2003, and June 19, 2003, respectively. On December 1, 2005, Resolution No. 2005-014, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Revise the Early Life Stage Implementation Provision of the Freshwater Ammonia Objectives for Inland Surface Waters (including enclosed bays, estuaries and wetlands) for Protection of Aquatic Life*, was adopted by the Regional Water Board. Resolution No. 2005-014 was approved by the State Water Board, OAL, and USEPA on July 19, 2006, August 31, 2006, and April 5, 2007, respectively. On June 7, 2007, the Regional Water Board adopted Resolution No. 2007-005, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate Site-Specific Objectives in Select Waterbodies in the Santa Clara, Los Angeles and San Gabriel River Watersheds*. This amendment to the Basin Plan incorporates site-specific 30-day average objectives for ammonia along with corresponding site-specific early life stage implementation provisions for select waterbody reaches and tributaries in the Santa Clara, Los Angeles, and San Gabriel River watersheds. The State Water Board, OAL, and USEPA approved this Basin Plan amendment on January 15, 2008, May 12, 2008, and March 30, 2009, respectively.
 - b. **Chloride WQOs** – Table 3-8 of the 1994 Basin Plan contained WQOs for chloride. However, the chloride WQOs for some waterbodies were revised by the Regional Water Board on January 27, 1997, with the adoption of Resolution No. 97-02, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Policy for Addressing Levels of Chloride in Discharges of Wastewaters*. Resolution No. 97-02 was approved by the State Water Board, OAL, and USEPA on October 23, 1997, January 9, 1998, and February 5, 1998, respectively, and is now in effect. The chloride WQO was revised from 150 mg/L to 190 mg/L, for the Los Angeles River between Figueroa Street and Los Angeles River Estuary (Willow Street) and between Sepulveda Flood Control Basin and Figueroa Street (including Burbank Western Channel). The final effluent limitation for chloride prescribed in this Order is based on the revised chloride WQO and is applied at the end of pipe.
2. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for

California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.

- 3. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- 4. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes (40 CFR part 131.21, 65 Fed. Reg. 24641 (April 27, 2000)). Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- 5. Antidegradation Policy.** 40 CFR part 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. The permitted discharge must be consistent with the antidegradation provision of 40 CFR part 131.12 and State Water Board Resolution No. 68-16.
- 6. Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40 CFR part 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. All conventional and non-conventional pollutants effluent limitations in the Order are at least as stringent as the effluent limitations in the previous Order. As discussed in this Fact Sheet, this relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

D. Integrated Report on Impaired Water Bodies CWA 303(d) List

The State Water Board proposed the California 2008-2010 Integrated Report from a compilation of the adopted Regional Water Boards' Integrated Reports containing 303(d) List of Impaired Waters and 305(b) Reports following recommendations from the Regional Water Boards and information solicited from the public and other interested parties. The Regional Water Boards' Integrated Reports were used to revise their 2006 303(d) List. On August 4, 2010, the State Water Board adopted the California 2008-2010 Integrated Report. On November 12, 2010, the USEPA approved California 2008-2010 Integrated Report Section 303(d) List of Impaired Waters requiring TMDLs for the Los Angeles Region.

Los Angeles River and their tributaries are in the California 2008-2010 Integrated Report. The following pollutants were identified as impacting the receiving waters:

- a. **Los Angeles River Estuary (Queensway Bay)** – Calwater Watershed 40512000 (Hydro. Unit No. 405.12 in Basin Plan)

Pollutants – Chlordane (sediment)⁵, DDT (sediment)⁵, polychlorinated biphenyls (PCBs) (sediment)⁵, sediment toxicity⁵, and trash⁶

- b. **Los Angeles River Reach 1 (Estuary to Carson Street)** – Calwater Watershed 40512000 (Hydro. Unit No. 405.12 in Basin Plan)

Pollutants – Ammonia⁶, cadmium⁶, coliform bacteria⁵, copper⁶, cyanide⁵, diazinon⁵, lead⁶, nutrients (algae)⁶, trash⁶, zinc⁶, and pH⁶

- c. **Los Angeles River Reach 2 (Carson Street to Figueroa Street)** – Calwater Watershed 40515010 (Hydro. Unit No. 405.15 in Basin Plan)

Pollutants – Ammonia⁶, coliform bacteria⁵, copper⁶, lead⁶, nutrients (algae)⁶, oil⁵, and trash⁶

- d. **Angeles River Reach 3 (Figueroa Street to Riverside Drive)** – Calwater Watershed 40521000 (Hydro. Unit No. 405.21 in Basin Plan)

Pollutants - Ammonia⁶, copper⁶, lead⁶, nutrients (algae)⁶, and trash⁶

- e. **Burbank Western Channel** - Calwater Watershed 40521000 (Hydro. Unit No. 405.21 in Basin Plan)

Pollutants- Copper⁷, cyanide⁶, indicator bacteria⁶, lead⁷, selenium⁶, and trash⁷.

E. Other Plans, Policies and Regulations

⁵ This pollutant requires TMDL.

⁶ TMDL has been approved for this pollutant, which has being addressed by USEPA.

- 1. Sources of Drinking Water Policy.** On May 19, 1988, the State Water Board adopted Resolution No. 88-63, *Sources of Drinking Water (SODW) Policy*, which established a policy that all surface and ground waters, with limited exemptions, are suitable or potentially suitable for municipal and domestic supply. To be consistent with State Water Board's SODW policy, on March 27, 1989, the Regional Water Board adopted Resolution No. 89-03, *Incorporation of Sources of Drinking Water Policy into the Water Quality Control Plans (Basin Plans) – Santa Clara River Basin (4A)/ Los Angeles River Basin (4B)*.

Consistent with Regional Water Board Resolution No. 89-03 and State Water Board Resolution No. 88-63, in 1994 the Regional Water Board conditionally designated all inland surface waters in Table 2-1 of the 1994 Basin Plan as existing, intermittent, or potential for Municipal and Domestic Supply (MUN). However, the conditional designation in the 1994 Basin Plan included the following implementation provision: "no new effluent limitations will be placed in Waste Discharge Requirements as a result of these [potential MUN designations made pursuant to the SODW policy and the Regional Water Board's enabling resolution] until the Regional Water Board adopts [a special Basin Plan Amendment that incorporates a detailed review of the waters in the Region that should be exempted from the potential MUN designations arising from SODW policy and the Regional Water Board's enabling resolution]." On February 15, 2002, the USEPA clarified its partial approval (May 26, 2000) of the 1994 Basin Plan amendments and acknowledged that the conditional designations do not currently have a legal effect, do not reflect new water quality standards subject to USEPA review, and do not support new effluent limitations based on the conditional designations stemming from the SODW Policy until a subsequent review by the Regional Water Board finalizes the designations for these waters. This permit is designed to be consistent with the existing Basin Plan.

- 2. Secondary Treatment Regulations.** 40 CFR part 133 establishes the minimum levels of effluent quality to be achieved by secondary treatment. These limitations, established by USEPA, are incorporated into this Order, except where more stringent limitations are required by other applicable plans, policies, or regulations or to prevent backsliding.
- 3. Storm Water.** CWA section 402(p), as amended by the Water Quality Act of 1987, requires NPDES permits for storm water discharges. Pursuant to this requirement, in 1990, USEPA promulgated 40 CFR part 122.26 that established requirements for storm water discharges under an NPDES program. To facilitate compliance with federal regulations, on November 1991, the State Water Board issued a statewide general permit, *General NPDES Permit No. CAS000001 and Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities*. This permit was amended in September 1992 and reissued on April 17, 1997 in State Water Board Order No. 97-03-DWQ to regulate storm water discharges associated with industrial activity.

General NPDES permit No. CAS000001 is applicable to storm water discharges from the Burbank WRP's premises. On March 19, 1992, City filed a Notice of Intent to comply with the requirements of the general permit. City developed and currently

implements a Storm Water Pollution Prevention Plan (SWPPP), to comply with the State Water Board's (Order No. 97-03-DWQ).

- 4. Sanitary Sewer Overflows.** The Clean Water Act prohibits the discharge of pollutants from point sources to surface waters of the United States unless authorized under an NPDES permit (33 U.S.C. §§1311, 1342). The State Water Board adopted Statewide General Waste Discharge Requirements (WDRs) for Sanitary Sewer Systems, Water Quality Order No. 2006-0003 on May 2, 2006, to provide a consistent, statewide regulatory framework to address Sanitary Sewer Overflows (SSOs). The WDR requires public agencies that own or operate sanitary sewer systems to develop and implement sewer system management plans and report all SSOs to the State Water Board's online SSO database.

The requirements contained in this Order in Sections VI.C.3.b. (Spill Contingency Plan Section), VI.C.4. (Construction, Operation and Maintenance Specifications Section), and VI.C.6. (Spill Reporting Requirements) are intended to be consistent with the requirements of the SSOs WDR. The Regional Water Board recognizes that there may be some overlap between the NPDES permit provisions and SSOs WDR requirements, at least as related to the collection systems. The requirements of the SSOs WDR are considered the minimum thresholds (see Finding 11 of State Board Order No. 2006-0003-DWQ). To encourage efficiency, the Regional Water Board will accept the documentation prepared by the Permittee under the SSOs WDR for compliance purposes, as satisfying the requirements in Sections VI.C.3.b., VI.C.4., and VI.C.6. provided the monitoring requirements contained in this Order in sections IV.9.B.d. and IV.9.B.e. are also addressed. Pursuant to the SSO WDR, State Board Order No. 2006-0003-DWQ, Section D., Provision 2.(iii) and (iv), the provisions of this NPDES permit supercede the SSO WDR, for all purposes, including enforcement, to the extent the requirements may be deemed duplicative.

- 5. Watershed Management** - This Regional Water Board has been implementing a Watershed Management Approach (WMA) to address water quality protection in the Los Angeles Region following the USEPA guidance in *Watershed Protection: A Project Focus* (EPA841-R-95-003, August 1995). The objective of the WMA is to provide a more comprehensive and integrated strategy resulting in water resource protection, enhancement, and restoration while balancing economic and environmental impacts within a hydrologically-defined drainage basin or watershed. The WMA emphasizes cooperative relationships between regulatory agencies, the regulated community, environmental groups, and other stakeholders in the watershed to achieve the greatest environmental improvements with the resources available. The accompanying Order fosters the implementation of this approach by protecting beneficial uses in the watershed and requiring the Discharger to participate in the development and implementation of the watershed-wide monitoring program. On August 8, 2008, the Los Angeles River Regional Monitoring Program was approved by this Regional Water Board to implement the goal of the watershed-wide monitoring program.

- 6. Relevant TMDLs** - Section 303(d) of the Clean Water Act requires states to identify water bodies that do not meet water quality standards and then to establish TMDLs

for each waterbody for each pollutant of concern. TMDLs identify the maximum amount of pollutants that can be discharged to waterbodies without causing violations of water quality standards.

- a. Nitrogen Compounds TMDL** – On July 10, 2003, the Regional Water Board adopted Resolution No. 2003-009, *Amendment to the Basin Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in the Los Angeles River (LA River Nitrogen Compounds TMDL)*. On November 19, 2003, the State Water Board approved the *Nitrogen Compounds TMDL*. However, on December 4, 2003, the Regional Water Board revised the Nitrogen Compound TMDL by adopting Resolution No. 2003-016, *Revision of Interim Effluent Limitations for Ammonia in the Amendment to the Water Quality Control Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in the Los Angeles River*. Resolution No. 2003-016 only revised the portion of the Nitrogen Compounds TMDL containing interim limitations for total ammonia as nitrogen, for the Los Angeles-Glendale and Donald C. Tillman WRPs. All other portions of the TMDL remained unchanged. The *Nitrogen Compounds TMDL* went into effect on March 23, 2004, when the Regional Water Board filed the Certificate of Fee Exemption with the California Department of Fish and Game.

On June 7, 2007, the Regional Water Board adopted Resolution No. 2007-005, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate Site-Specific Objectives in Select Waterbodies in the Santa Clara, Los Angeles and San Gabriel River Watersheds*. This amendment to the Basin Plan incorporates site-specific 30-day average objectives for ammonia along with corresponding site-specific early life stage implementation provisions for select waterbody reaches and tributaries in the Santa Clara, Los Angeles, and San Gabriel River watersheds. In accordance with Implementation Table, Task 8 of the *LA River Nitrogen Compounds TMDL*, "...If a site specific objective is adopted by the Regional Board, and approved by relevant approving agencies, this TMDL will need to be revised, readopted, and reapproved to reflect the revised water quality objectives."

- b. Trash TMDL** – On September 19, 2001, the Regional Water Board adopted Resolution No. 2001-013, *Amendment to the Basin Plan for the Los Angeles Region to Incorporate a TMDL for Trash in the Los Angeles River (LA River Trash TMDL)*.

The TMDL was subsequently approved by the State Water Board on February 19, 2002 and by OAL on July 16, 2002. Since the State Water Board and OAL failed to approve the TMDL in time to meet the relevant federal consent decree; therefore, USEPA promulgated its own Trash TMDL in order to meet the consent decree timeline of March 23, 2002. Then, upon approval of the Regional Water Board's TMDL by OAL, USEPA approved the Regional Water Board's LA River Trash TMDL on August 1, 2002, and deemed it to have superseded the TMDL promulgated by USEPA.

The City and the County of Los Angeles both filed petitions and complaints in the Los Angeles Superior Court challenging the *LA River Trash TMDL*. Subsequent negotiations led to a settlement agreement, which became effective on September 23, 2003. Twenty-two other cities sued the Regional Water Board to set aside the TMDL, on several grounds. On January 26, 2006, the Court of Appeal rejected the claims litigated by the cities but found that the Regional Water Board did not adequately complete the environmental checklist. The Court therefore affirmed a writ of mandate issued by the trial court ordering the Regional Water Board to set aside and not implement the *LA River Trash TMDL* until it has been brought into compliance with CEQA.

On June 8, 2006, the Regional Water Board set aside the *LA River Trash TMDL* and Resolution No. 01-013 which established it, pursuant to the writ of mandate. On August 9, 2007, the Regional Water Board approved the *LA River Trash TMDL* based on a revised CEQA analysis as Resolution No. 2007-012. The *LA River Trash TMDL* was approved by the State Water Board on April 15, 2008 and USEPA on July 24, 2008. The *LA River Trash TMDL* became effective on September 23, 2008, when the Certificate of Fee Exemption was filed with the California Department of Fish and Game.

- c. Metals TMDL** – On June 2, 2005, the Regional Water Board adopted Resolution No. R05-006, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Metals for the Los Angeles River and its Tributaries (LA River Metals TMDL)*. The *LA River Metals TMDL* contains WLAs for cadmium, copper, lead, and zinc. On October 20, 2005, the State Water Board approved the *LA River Metals TMDL* by adopting Resolution No. 2005-0077. On December 9, 2005 and December 22, 2005, respectively, OAL and USEPA approved the *LA River Metals TMDL*. It went into effect on January 11, 2006, when the Certificate of Fee Exemption was filed with the California Department of Fish and Game.

On February 16, 2006, the cities of Bellflower, Carson, Cerritos, Downey, Paramount, Santa Fe Springs, Signal Hill, and Whittier (Cities) filed a petition for a writ of mandate challenging many aspects of the *LA River Metals TMDL* and the *Ballona Creek Metals TMDL*. (*Cities of Bellflower et al v. SWRCB et al*, Los Angeles Superior Court No. BS101732.) On May 24, 2007, the Los Angeles County Superior Court adopted the third of three rulings with respect to the writ petition. Collectively, all challenges to the *LA River Metals TMDL* were rejected, except for one CEQA claim. The Court ruled that the State and Regional Water Boards (Water Boards) should have adopted and circulated an alternatives analysis that analyzed alternatives to the project. The Court issued its writ of mandate, directing the Water Boards to adopt an alternative analysis and to reconsider the *LA River Metals TMDL* accordingly.

After considering the alternative analysis, the Regional Water Board found that the *LA River Metals TMDL* as originally proposed and adopted was appropriate. The Regional Water Board further found that nothing in the alternatives analysis nor any of the evidence generated, presented basis for the Regional Water

Board to conclude that it would have acted differently when it adopted the TMDLs had the alternative analysis been prepared and circulated at that time. Thus, on September 6, 2007, the Regional Water Board adopted Resolution No. R2007-014, which reestablished the *LA River Metals TMDL* in substantially its original form.

On May 7, 2009, the Regional Water Board adopted Resolution No. 09-003, which voided and set aside Resolution Nos. R05-006 as required by the writ of mandate in the matter of *Cities of Bellflower et al v. SWRCB*.

On May 6, 2010, the Regional Water Board adopted Resolution No. R10-003, an amendment to the Basin Plan to revise the *LA River Metals TMDL*. The amendment revises the TMDL to adjust the numeric targets for copper in Reaches 1-4 of the Los Angeles River and the Burbank Western Channel and the corresponding WLAs for the Donald C. Tillman, Los Angeles-Glendale and Burbank WRPs based on an approved water effect ratio (WER) study. The revision includes language stating that regardless of the WER, the WRPs must perform at a level that can be attained by existing treatment technologies at the time of permit issuance, reissuance or modification. On April 19, 2011, the State Water Board adopted Resolution No. 2011-0021, approving the revised *LA River Metals TMDL*. At this hearing, the State Water Board made it clear that should the performance of the facility's treatment technologies change for reasons beyond the facility's control, the permit may be reopened to revise the effluent limitations considering the applicability of the copper WER or other performance-based measure such that the effluent limitations ensure that effluent concentrations and mass discharges do not exceed the levels of water quality that can be attained by performance of this facility's treatment technologies existing at the time of permit issuance, reissuance, or modification. On July 27, 2011, and November 3, 2011, the *LA River Metals TMDL* (Resolution No. R10-003) was approved by OAL and USEPA, respectively.

- d. **Bacteria TMDL** – On July 8, 2010 the Regional Water Board adopted Resolution No. R10-007, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Indicator Bacteria in the Los Angeles River Watershed (LA River Bacteria TMDL)*. The *LA River Bacteria TMDL* contains WLAs for Donald C. Tillman, Los Angeles-Glendale, and Burbank WRPs, which are set equal to a 7-day median of 2.2 MPN/100 mL of *E. coli* and/or a daily max of 235 MPN/100mL to ensure zero days of allowable exceedances. No exceedances of the geometric mean TMDL numeric target of 126/100 mL *E.coli* are permitted. The *LA River Bacteria TMDL* must still be approved by the State Water Board, OAL, and USEPA before it becomes effective.

- 7. **Title 22 of the California Code of Regulations (Title 22).** The California Department of Public Health (CDPH) established primary and secondary maximum contaminant levels (MCLs) for inorganic, organic, and radioactive contaminants in drinking water. These MCLs are codified in Title 22. The Basin Plan (Chapter 3) incorporates Title 22 primary MCLs by reference. This incorporation by reference is

prospective, including future changes to the incorporated provisions as the changes take effect. Title 22 primary MCLs have been used as bases for effluent limitations in WDRs and NPDES permits to protect groundwater recharge beneficial use when that receiving groundwater is designated as MUN. Also, the Basin Plan specifies that “Ground waters shall not contain taste or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses.”

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the 40 CFR part 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 CFR part 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

A. Discharge Prohibitions

Effluent and receiving water limitations in this Board Order are based on the Federal Clean Water Act, Basin Plan, State Water Board’s plans and policies, U. S. Environmental Protection Agency guidance and regulations, and best practicable waste treatment technology. This order authorizes the discharge of tertiary-treated wastewater from Discharge Point 001 only. It does not authorize any other types of discharges.

B. Technology-Based Effluent Limitations (TBELs)

1. Scope and Authority

TBELs require a minimum level of treatment for industrial/municipal point sources based on currently available treatment technologies while allowing the discharger to use any available control techniques to meet the effluent limits. The 1972 CWA required POTWs to meet performance requirements based on available wastewater treatment technology. Section 301 of the CWA established a required performance level--referred to as “secondary treatment” --that all POTWs were required to meet by July 1, 1977. More specifically, Section 301(b)(1)(B) of the CWA required that EPA develop secondary treatment standards for POTWs as defined in Section 304(d)(1). Based on this statutory requirement, USEPA developed national secondary treatment regulations which are specified in 40 CFR part 133. These technology-based regulations apply to all POTWs and identify the minimum level of effluent quality to be attained by secondary treatment in terms of five-day biochemical oxygen demand, total suspended solids, and pH.

2. Applicable TBELs

This facility is subject to the technology-based regulations for the minimum level of effluent quality attainable by secondary treatment in terms of BOD₅20°C, TSS, and pH.

However, all TBELs from the previous Order R4-2006-0085 as amended by Order No. R4-2010-0058 are based on tertiary-treated wastewater treatment standards. These effluent limitations have been carried over from the previous Order to avoid backsliding. Further, mass-based effluent limitations are based on a design flow rate of 12.5 MGD. The following Table summarizes the TBELs applicable to the Facility:

Summary of Technology-based Effluent Limitations Discharge Point 002

Table 4. Summary of Technology-based Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
BOD ₅ 20°C	mg/L	20	30	45		
	lbs/day ⁷	2085	3130	4690		
Total Suspended Solids (TSS)	mg/L	15	40	45		
	lbs/day ¹	1560	4170	4690		
pH	standard units	--	--	--	6.5	8.5
Removal Efficiency for BOD and TSS	%	85	--	--		

However, this Facility is also subject to technology-based effluent limitations contained in similar NPDES permits, for similar facilities, based on the treatment level achievable by tertiary-treated wastewater treatment systems. These effluent limitations are consistent with the State Water Board precedential decision, State Water Board Order No. WQ 2004-0010 for the City of Woodland.

⁷ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

Section 301(b) of the CWA and 40 CFR part 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements, expressed as a technology equivalence requirement, more stringent than secondary treatment requirements that are necessary to meet applicable water quality standards. The rationale for these requirements, which consist of tertiary treatment or equivalent requirements or other provisions, is discussed starting from Section IV.C.2.

40 CFR part 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR part 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

- a. The Basin Plan establishes the beneficial uses for surface water bodies in the Los Angeles region. The beneficial uses of the Burbank Western Channel and the Los Angeles River affected by the discharge have been described previously in this Fact Sheet.
- b. The Basin Plan also specifies narrative and numeric water quality objectives applicable to surface water as shown in the following discussions.

i. **BOD₅20°C and TSS**

BOD₅20°C is a measure of the quantity of the organic matter in the water and, therefore, the water's potential for becoming depleted in dissolved oxygen. As organic degradation takes place, bacteria and other decomposers use the

T
E
N
T
A
T
I
V
E

oxygen in the water for respiration. Unless there is a steady resupply of oxygen to the system, the water will quickly become depleted of oxygen. Adequate dissolved oxygen levels are required to support aquatic life. Depressions of dissolved oxygen can lead to anaerobic conditions resulting in odors, or, in extreme cases, in fish kills.

40 CFR part 133 describes the minimum level of effluent quality attainable by secondary treatment, for BOD₅20°C and TSS, as:

- The 30-day average shall not exceed 30 mg/L, and
- The 7-day average shall not exceed 45 mg/L.

The Burbank WRP permit provides tertiary treatment requirements, such as, the BOD₅20°C and TSS limits that are more stringent than secondary treatment requirements, based on best professional judgment (bpj). The Plant achieves solids removal that are better than secondary-treated wastewater by adding a polymer and Alum to enhance the precipitation of solids, and by filtering the effluent.

The monthly average, the 7-day average, and the daily maximum limits cannot be removed because none of the antidegradation exceptions apply. Those limits were all included in the previous permit (Order R4-2006-0085 as amended by R4-2010-0058) and the Burbank WRP has been able to meet all three limits (monthly average, the 7-day average, and the daily maximum) for both BOD₅20°C and TSS.

In addition to having mass-based and concentration-based effluent limitations for BOD₅20°C and suspended solids, the Order also contains a percent removal requirement for these two constituents. In accordance with 40 CFR parts 133.102(a)(3) and 133.102(b)(3), the 30-day average percent removal shall not be less than 85 percent. Percent removal is defined as a percentage expression of the removal efficiency across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of the raw wastewater influent pollutant concentrations to the facility and the 30-day average values of the effluent pollutant concentrations for a given time period.

ii. pH

The hydrogen ion activity of water (pH) is measured on a logarithmic scale, ranging from 0 to 14. Minor changes from natural conditions can harm aquatic life. In accordance with 40 CFR section 133.102(c), the effluent values for pH shall be maintained within the limits of 6.0 to 9.0 unless the POTW demonstrates that: (1) Inorganic chemicals are not added to the waste stream as part of the treatment process; and (2) contributions from industrial sources do not cause the pH of the effluent to be less than 6.0 or greater than 9.0. The effluent limitation for pH in this permit requiring that the wastes

T
E
N
T
A
T
I
V
E

discharged shall at all times be within the range of 6.5 to 8.5 is taken from the Basin Plan (page 3-15) which reads “the pH of inland surface waters shall not be depressed below 6.5 or raised above 8.5 as a result of waste discharge.”

iii. **Settleable solids**

Excessive deposition of sediments can destroy spawning habitat, blanket benthic (bottom dwelling) organisms, and abrade the gills of larval fish. The limits for settleable solids are based on the Basin Plan (page 3-16) narrative, “Waters shall not contain suspended or settleable material in concentrations that cause nuisance or adversely affect beneficial uses.” The numeric limits are empirically based on results obtained from the settleable solids 1-hour test, using an Imhoff cone.

It is impracticable to use a 7-day average limitation because short-term spikes of settleable solid levels that would be permissible under a 7-day average scheme would not be adequately protective of all beneficial uses. The monthly average and the daily maximum limits cannot be removed because none of the antibacksliding exceptions apply. The monthly average and daily maximum limits were both included in the previous permit (Order R4-2006-0085 as amended by R4-2010-0058) and the Burbank WRP has been able to meet both limits.

iv. **Oil and grease**

Oil and grease are not readily soluble in water and form a film on the water surface. Oily films can coat birds and aquatic organisms, impacting respiration and thermal regulation, and causing death. Oil and grease can also cause nuisance conditions (odors and taste), are aesthetically unpleasant, and can restrict a wide variety of beneficial uses. The limits for oil and grease are based on the Basin Plan (page 3-11) narrative, “Waters shall not contain oils, greases, waxes, or other materials in concentrations that result in a visible film or coating on the surface of the water or on objects in the water, that cause nuisance, or that otherwise adversely affect beneficial uses.”

The numeric limits are empirically based on concentrations at which an oily sheen becomes visible in water. It is impracticable to use a 7-day average limitation because spikes that occur under a 7-day average scheme could cause a visible oil sheen. A 7-day average scheme would not be sufficiently protective of beneficial uses. The monthly average and the daily maximum limits cannot be removed because none of the antibacksliding exceptions apply. Both limits were included in the previous permit (Order R4-2006-0085 as amended by R4-2010-0058) and the Burbank WRP has been able to meet both limits for the most part. Furthermore, the Discharger reported a daily maximum of 45 mg/L, therefore demonstrating that the discharge has reasonable potential to exceed the effluent limitations.

T
E
N
T
A
T
I
V
E

v. Residual Chlorine

Disinfection of wastewaters with chlorine produces a chlorine residual. Chlorine and its reaction products are toxic to aquatic life. The limit for residual chlorine is based on the Basin Plan (page 3-9) narrative, "Chlorine residual shall not be present in surface water discharges at concentrations that exceed 0.1 mg/L and shall not persist in receiving waters at any concentration that causes impairment of beneficial uses."

It is impracticable to use a 7-day average or a 30-day average limitation, because it is not as protective as of beneficial uses as a daily maximum limitation is. Chlorine is very toxic to aquatic life and short term exposures of chlorine may cause fish kills.

vi. Fluoride

The existing permit does not contain an effluent limitation for fluoride. Fluoride is not a priority pollutant. The discharge from the Burbank WRP does not exhibit reasonable potential to exceed the USEPA Quality Criteria for Water 1976 (EPA 440/9-76-023) of 2.0 mg/L. Therefore, the accompanying Order does not contain an effluent limitation for fluoride.

vii. Total Dissolved Solids, Chloride, Sulfate, and Boron

The limits for total dissolved solids, sulfate, and boron are based on Basin Plan Table 3-8 (page 3-13), for Los Angeles River watershed, above Figueroa Street. TDS is 950 mg/L and sulfate is 300 mg/L. There is no Boron water quality objective for that reach of the Los Angeles River. The chloride limit is no longer 150 mg/L, but 190 mg/L, which resulted from Regional Water Board Resolution No. 97-02, Amendment to the Water Quality Control Plan to incorporate a Policy for Addressing Levels of Chloride in Discharges of Wastewaters. Resolution 97-02 was adopted by Regional Water Board on January 27, 1997; approved by SWRCB (Resolution 97-94); and, approved by OAL on January 8, 1998; and served to revise the chloride water quality objective in the Los Angeles River and other surface waters. It is practicable to express these limits as monthly averages, since they are not expected to cause acute effects on beneficial uses.

Limits based upon the Basin Plan WQOs have been included in this Order because, based upon Best Professional Judgment, these constituents are always present in potable water which is the supply source of the wastewater entering the Treatment Plant. They may be present in concentrations which meet California drinking water standards but exceed the Basin Plan Objectives. Therefore, limitations are warranted to protect the beneficial uses of the receiving water.

viii. **Methylene Blue Activated Substances (MBAS)**

The MBAS procedure tests for the presence of anionic surfactants (detergents) in surface and ground waters. Surfactants disturb the water surface tension, which affects insects and can affect gills in aquatic life. The MBAS can also impart an unpleasant soapy taste to water, as well as cause scum and foaming in waters, which impact the aesthetic quality of both surface and ground waters.

The existing permit effluent limitation of 0.5 mg/l for MBAS was developed based on the Basin Plan incorporation of Title 22, Drinking Water Standards, by reference, to protect the surface water GWR beneficial use, as well as the groundwater MUN beneficial use. Given the nature of the facility which accepts domestic wastewater into the sewer system and treatment plant, and the characteristics of the wastes discharged, the discharge has reasonable potential to exceed both the numeric MBAS WQO and the narrative WQO for the prohibition of floating material such as foams and scums. Therefore an effluent limitation is required.

ix. **Nitrogen Compounds/Nutrient Compounds**

- (a). **Nitrate Nitrogen (NO_3^- -N), Nitrite Nitrogen (NO_2^- -N), Total inorganic Inorganic Nitrogen ($\text{NO}_2 + \text{NO}_3$ as N)** – Total inorganic nitrogen is the sum of Nitrate-nitrogen and Nitrite-nitrogen. High nitrate levels in drinking water can cause health problems in humans. Infants are particularly sensitive and can develop methemoglobinemia (blue-baby syndrome). Nitrogen is also considered a nutrient. Excessive amounts of nutrients can lead to other water quality impairments.
- (b). **Algae** - Excessive growth of algae and/or other aquatic plants can degrade water quality. Algal blooms sometimes occur naturally, but they are often the result of excess nutrients (i.e., nitrogen, phosphorus) from waste discharges or nonpoint sources. These algal blooms can lead to problems with tastes, odors, color, and increased turbidity and can depress the dissolved oxygen content of the water, leading to fish kills. Floating algal scum and algal mats are also an aesthetically unpleasant nuisance.

The WQO for biostimulatory substances are based on Basin Plan (page 3-8) narrative, "Waters shall not contain biostimulatory substances in concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses," and other relevant information to arrive at a mass based-limit intended to be protective of the beneficial uses, pursuant to 40 CFR part 122.44(d). Total inorganic nitrogen will be the indicator parameter intended to control algae, pursuant to 40 CFR part 122.44(d)(1)(vi)(C).

Nutrients are among 303(d) List in the *California 2008-2010 Integrated Report for the Los Angeles River*. Since nutrients have WLAs in the *LA River Nitrogen Compounds TMDL*, TMDL WLA-based effluent limitations for nutrients are required in order to implement the provisions of the TMDL and to try and restore the water quality in that section of the receiving water.

- (c). **Concentration-based limit.** The proposed effluent limitations of 7.2 mg/L, 0.9 mg/L, and 7.2 mg/L for nitrate nitrogen, nitrite nitrogen, and total inorganic nitrogen, respectively, are based on the Nutrient TMDL WLA. However, if the Los Angeles River is de-listed for nutrients, then the permit would be re-opened to include Basin Plan-based effluent limitations.

Watershed-wide monitoring will track concentration levels of phosphorus and all nitrogen series pollutants present in the effluent and receiving waters, pursuant to 40 CFR part 122.44(d)(1)(vi)(C)(3).

- (d). **Mass-based limit.** There are no mass emission rates for nitrogen compounds because the Nutrient TMDL did not specify mass-based WLA.

x. **Total Ammonia**

- (a). Ammonia is a pollutant routinely found in the wastewater effluent of Publicly Owned Treatment Works (POTWs), in landfill-leachate, as well as in run-off from agricultural fields where commercial fertilizers and animal manure are applied. Ammonia exists in two forms – un-ionized ammonia (NH_3) and the ammonium ion (NH_4^+). They are both toxic, but the neutral, un-ionized ammonia species (NH_3) is much more toxic, because it is able to diffuse across the epithelial membranes of aquatic organisms much more readily than the charged ammonium ion. The form of ammonia is primarily a function of pH, but it is also affected by temperature and other factors. Additional impacts can also occur as the oxidation of ammonia lowers the dissolved oxygen content of the water, further stressing aquatic organisms. Oxidation of ammonia to nitrate may lead to groundwater impacts in areas of recharge. There is groundwater recharge in the reaches of the Los Angeles River, downstream of the discharge point. Ammonia also combines with chlorine (often both are present in POTW treated effluent discharges) to form chloramines – persistent toxic compounds that extend the effects of ammonia and chlorine downstream.
- (b). Tables 3-1 through Tables 3-4 of the 1994 Basin Plan contain WQOs for ammonia to protect aquatic life. However, those ammonia objectives were revised on April 25, 2002, by the Regional Board, with the adoption of Resolution No. 2002-011, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Update the Ammonia Objectives for*

T
E
N
T
A
T
I
V
E

Inland Surface Waters (including enclosed bays, estuaries and wetlands) with Beneficial Use designations for protection of Aquatic Life. Resolution No. 2002-011 was approved by the State Water Board, the Office of Administrative Law, and USEPA on April 30, 2003, June 5, 2003, and June 19, 2003, respectively, and is now in effect. On December 1, 2005, Resolution No. 2005-014, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Revise the Early Life Stage Implementation Provision of the Freshwater Ammonia Objectives for Inland Surface Waters (including enclosed bays, estuaries and wetlands) for Protection of Aquatic Life*, was adopted by the Regional Water Board. Resolution No. 2005-014 was approved by the State Water Board, the Office of Administrative Law, and USEPA on July 19, 2006, August 31, 2006, and April 5, 2007, respectively. On June 7, 2007, the Regional Water Board adopted Resolution No. 2007-005, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate Site-Specific Objectives in Select Waterbodies in the Santa Clara, Los Angeles and San Gabriel River Watersheds*. This amendment to the Basin Plan incorporates site-specific 30-day average objectives for ammonia along with corresponding site-specific early life stage implementation provisions for select waterbody reaches and tributaries in the Santa Clara, Los Angeles, and San Gabriel River watersheds. The State Water Board, OAL, and USEPA approved this Basin Plan amendment on January 15, 2008, May 12, 2008, and March 30, 2009, respectively.

Ammonia is among the 303(d) List in the California 2008-2010 Integrated Report for the Los Angeles River. Since ammonia has a WLA in the *LA River Nitrogen Compounds TMDL*, a TMDL-based effluent limitation for total ammonia as nitrogen is required in order to implement the provisions of the TMDL and to try and restore the water quality in that section of the receiving water.

- (c). **Concentration-Based Limit** –The proposed ammonia effluent limitations of 2.1 mg/L for monthly average and 9.1 mg/L for daily maximum are based on the Nutrient TMDL WLA. However, if the Los Angeles River becomes de-listed for ammonia, then the permit would be re-opened to include Basin Plan-based effluent limitations for ammonia.
- (d). **Mass-Based Limit** –There is no mass emission rate for total ammonia because the Nutrient TMDL did not specify a mass-based WLA.

xi. **Coliform**

Total and fecal coliform bacteria are used to indicate the likelihood of pathogenic bacteria in surface waters. Given the nature of the facility, a wastewater treatment plant, pathogens are likely to be present in the effluent

in cases where the disinfection process is not operating adequately. As such, the permit contains the following filtration and disinfection TBELs for coliform:

(a). Effluent Limitations

- The 7-day median number of total coliform bacteria at some point in the disinfected effluent must not exceed an MPN or CFU of 2.2 per 100 milliliters;
- The number of total coliform bacteria must not exceed an MPN or CFU of 23 per 100 milliliters in more than one sample within any 30-day period; and
- No sample shall exceed an MPN or CFU of 240 total coliform bacteria per 100 milliliters.

These limits for coliform must be met at the point of the treatment train immediately following disinfection. Coliform is 303(d) listed in the Los Angeles River. The disinfection and filtration processes reduce the likelihood of having pathogens in the discharger's effluent. Most of the time the coliform analyses results are reported as less than 1 MPN/100 mL. It is not likely that the 303(d) listing of coliform is due to the discharge of treated effluent from the Discharger. Therefore, the TBEL is also protective of water quality.

(b). Receiving Water Limitations

- Geometric Mean Limitations
 - * E.coli density shall not exceed 126/100 mL.
 - * Fecal coliform density shall not exceed 200/100 mL.
- Single Sample Limitations
 - * E.coli density shall not exceed 235/100 mL.
 - * Fecal coliform density shall not exceed 400/100 mL.

These receiving water limitations are based on Resolution No. 01-018, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Update the Bacteria Objectives for Water Bodies Designated for Water Contact Recreation*, adopted by the Regional Board on October 25, 2001. The Resolution was approved by State Water Board, OAL, and USEPA, on July 18, 2002, September 19, 2002, and September 25, 2002, respectively.

T
E
N
T
A
T
I
V
E

xii. **Turbidity**

Turbidity is an expression of the optical property that causes light to be scattered in water due to particulate matter such as clay, silt, organic matter, and microscopic organisms. Turbidity can result in a variety of water quality impairments. The effluent limitation for turbidity which reads, “For the protection of the water contact recreation beneficial use, the wastes discharged to water courses shall have received adequate treatment, so that the turbidity of the wastewater does not exceed: (a) a daily average of 2 Nephelometric turbidity units (NTU); (b) 5 NTU more than 5 percent of the time (72 minutes) during any 24 hour period; and (c) 10 NTU at any time” is based on the Basin Plan (page 3-17) and Section 60301.320 of Title 22, Chapter 3, “Filtered Wastewater” of the California Code of Regulations.

xiii. **Radioactivity**

Radioactive substances are generally present in natural waters in extremely low concentrations. Mining or industrial activities increase the amount of radioactive substances in waters to levels that are harmful to aquatic life, wildlife, or humans. Section 301(f) of the CWA contains the following statement with respect to effluent limitations for radioactive substances: “Notwithstanding any other provisions of this Act it shall be unlawful to discharge any radiological, chemical, or biological warfare agent, any high-level radioactive waste, or any medical waste, into the navigable waters.” Chapter 5.5 of the CWC contains a similar prohibition under Section 13375, which reads as follows: “The discharge of any radiological, chemical, or biological warfare agent into the waters of the state is hereby prohibited.” However, rather than give a hard and fast absolute prohibition on radioactive substances, Regional Water Board staff have set the following effluent limit for radioactivity: “Radioactivity of the wastes discharged shall not exceed the limits specified in Title 22, Chapter 15, Article 5, Section 64443, of the California Code of Regulations, or subsequent revisions.” The limit is based on the Basin Plan incorporation of Title 22, *Drinking Water Standards*, by reference, to protect the surface water GWR beneficial use and the groundwater MUN beneficial use. However, the Regional Water Board has new information about the appropriate designated uses for the water body, and based on the current designated uses, a limit for Radioactivity is unnecessary and inappropriate unless discharge is to a reach used for groundwater recharge, where Title 22-based limits apply. Therefore, the accompanying Order will contain a limit for radioactivity to protect the GWR beneficial use.

xiv. Temperature

USEPA document, *Quality Criteria for Water 1986* [EPA 440/5-86-001, May 1, 1986], also referred to as the *Gold Book*, discusses temperature and its effects on beneficial uses, such as recreation and aquatic life.

- (a). The Federal Water Pollution Control Administration in 1967 called temperature “a catalyst, a depressant, an activator, a restrictor, a stimulator, a controller, a killer, and one of the most important water quality characteristics to life in water.” The suitability of water for total body immersion is greatly affected by temperature. Depending on the amount of activity by the swimmer, comfortable temperatures range from 20°C to 30°C (68 °F to 86 °F).
- (b). Temperature also affects the self-purification phenomenon in water bodies and therefore the aesthetic and sanitary qualities that exist. Increased temperatures accelerate the biodegradation of organic material both in the overlying water and in bottom deposits which makes increased demands on the dissolved oxygen resources of a given system. The typical situation is exacerbated by the fact that oxygen becomes less soluble as water temperature increases. Thus, greater demands are exerted on an increasingly scarce resource which may lead to total oxygen depletion and obnoxious septic conditions. Increased temperature may increase the odor of water because of the increased volatility of odor-causing compounds. Odor problems associated with plankton may also be aggravated.
- (c). Temperature changes in water bodies can alter the existing aquatic community. Coutant (1972) has reviewed the effects of temperature on aquatic life reproduction and development. Reproductive elements are noted as perhaps the most thermally restricted of all life phases, assuming other factors are at or near optimum levels. Natural short-term temperature fluctuations appear to cause reduced reproduction of fish and invertebrates.

The Basin Plan lists temperature requirements for the receiving waters. Based on the requirements of the Basin Plan and a white paper developed by Regional Board staff entitled *Temperature and Dissolved Oxygen Impacts on Biota in Tidal Estuaries and Enclosed Bays in the Los Angeles Region*, a maximum effluent temperature limitation of 86 °F is included in the Order. The white paper evaluated the optimum temperatures for steelhead, topsmelt, ghost shrimp, brown rock crab, jackknife clam, and blue mussel. The new temperature effluent limitation is reflective of new information available that indicates that the 100 °F temperature is not protective of aquatic organisms. A survey was completed for several kinds of fish and the 86 °F temperature was found to be protective. It is impracticable to use a 7-day average or a 30-day

T
E
N
T
A
T
I
V
E

average limitation for temperature, because it is not as protective as of beneficial uses as a daily maximum limitation is. A daily maximum limitation is necessary to protect aquatic life and is consistent with the fishable/swimmable goals of the CWA.

Section IV.A.2.b. of the Order contains the following effluent limitation for temperature:

“The temperature of wastes discharged shall not exceed 86°F, except as a result of external ambient temperature.”

The above effluent limitation for temperature has been quoted in all recent NPDES permits adopted by this Regional Water Board.

Section V.A.1. of the Order explains how compliance with the receiving water temperature limitation will be determined.

xv. **Iron**

The USEPA document, *Quality Criteria for Water 1986* [EPA 440/5-86-001, May 1, 1986], also referred to as the *Gold Book*, contains criteria for iron: 300 µg/L for the protection of domestic water supply and 1000 µg/L for the protection of freshwater aquatic life. The secondary MCL for iron is also 300 µg/L. Since the discharge had reasonable potential to cause to contribute to an exceedance, a limit for iron, based on the 300 µg/L criteria, is prescribed for the protection of the GWR beneficial use in the surface water and for the protection of the MUN beneficial use in the underlying groundwater basins. The highest receiving water concentration was 1200 µg/L and the highest effluent concentration was 190 µg/L.

c. **CTR and SIP**

The California Toxic Rule (CTR) and State Implementation Policy (SIP) specify numeric objectives for toxic substances and the procedures whereby these objectives are to be implemented. The procedures include those used to conduct a reasonable potential analysis (RPA) to determine the need for effluent limitations for priority and non-priority pollutants.

3. Determining the Need for WQBELs

The Regional Water Board developed WQBELs for cadmium, lead, and zinc consistent with available WLAs under the *LA River Metals TMDL* which was approved by USEPA on October 29, 2008. The effluent limitations for these pollutants were established regardless of whether or not there is reasonable potential for the pollutants to be present in the discharge at levels that would cause or contribute to a violation of water quality standards. Regional Water Board staff developed WQBELs for these three metals in this Order pursuant to the “Implementation” section specified in Page 12 of the revised *LA River Metals TMDL*. The “Implementation” states:

T
E
N
T
A
T
I
V
E

“Permit writers may translate applicable waste load allocations into effluent limits for the major, minor and general NPDES permits by applying the effluent limitation procedures in Section 1.4 of the State Water Resources Control Board’s Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (2000)...”

Therefore, the Regional Water Board calculated final WQBELs for these three metals, based on Section 1.4 of the SIP.

The WQBELs for copper were developed consistent with the WLA and Water Effect Ratio (WER) footnote under the revised *LA River Metals TMDL*, approved by USEPA on November 3, 2011.

In accordance with Section 1.3 of the SIP, the Regional Water Board conducted an RPA for each priority pollutant, when necessary, with an applicable criterion or objective to determine if a WQBEL is required in the permit. The Regional Water Board analyzed effluent data to determine if a pollutant in a discharge has reasonable potential to cause or contribute to an excursion above a state water quality standard. For all parameters that demonstrate reasonable potential, numeric WQBELs are required. The RPA considers water quality criteria from the CTR and NTR, and when applicable, WQOs specified in the Basin Plan. To conduct the RPA, the Regional Water Board staff identified the maximum effluent concentration (MEC) and maximum background concentration in the receiving water for each constituent, based on data provided by the Discharger. The monitoring data cover the period from December 2007, when the Discharger has completed the NDN process upgrade, up to August 2011.

Section 1.3 of the SIP provides the procedures for determining if a discharge has reasonable potential to cause or contribute to an exceedance of applicable water quality criteria and objectives. The SIP specifies three tiers that may trigger RP:

- Tier 1 – If the Maximum Effluent Concentration (MEC) is greater than or equal to the CTR water quality criteria or applicable objective (C), a limitation is needed.
- Tier 2 – If background water quality (B) > C and the pollutant is detected in the effluent, a limitation is needed.
- Tier 3 – If other related information such as CWA 303(d) listing for a pollutant, discharge type, compliance history, then best professional judgment is used to determine that a limitation is needed.

Sufficient effluent and ambient data are needed to conduct a complete RPA. If data are not sufficient, the Discharger will be required to gather the appropriate data for the Regional Water Board to conduct the RPA. Upon review of the data, and if the

T
E
N
T
A
T
I
V
E

Regional Water Board determines that WQBELs are needed to protect the beneficial uses, the permit will be reopened for appropriate modification.

The RPA was performed for the priority pollutants regulated in the Basin Plan and the CTR; and, for iron and total trihalomethanes regulated in the Basin Plan, for which data are available. Based on the RPA, pollutants that demonstrate reasonable potential are cadmium, copper, lead, and zinc because TMDLs are adopted for these metals. Copper also shows reasonable potential because the MEC was greater than C, and because the receiving water concentration (B) is greater than the criteria (C) and it was detected in the effluent. Antimony, cyanide, dibromochloromethane, benzo(a)anthracene, benzo(a)pyrene, benzo(b)fluoranthene, benzo(k) fluoranthene, bis(2-ethylhexyl)phthalate, chrysene, dibenzo(a,h)anthracene, hexachlorobenzene, indeno(1,2,3-cd)pyrene, and total trihalomethanes show reasonable potential because the (MEC) is greater than (C). The following Table summarizes results from RPA.

Table 5. Summary of Reasonable Potential Analysis

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation ?	Reason
1	Antimony	6	1.4	21	Yes	B>C & detected in effluent
2	Arsenic	10	2.9	7.5	No	C>B, C>MEC
3	Beryllium	4	<0.18	<0.18	No	C>B, C>MEC
4	Cadmium	4.5	1.5	2.2	Yes	Metals TMDL
5a	Chromium III	524	6	6	No	C>B, C>MEC
5b	Chromium VI	11	0.99	8	No	C>B, C>MEC
6	Copper	19	30.2	99	Yes	Revised Metals TMDL; B>C & detected at effluent
7	Lead	9.1	2.4	4.6	Yes	Metals TMDL
8	Mercury	0.051	0.0022	0.024	No	C>B, C>MEC
9	Nickel	100	3.4	17.1	No	C>B, C>MEC
10	Selenium	5	3.9	3.1	No	C>B, C>MEC
11	Silver	29	2.5	1.2	No	C>B, C>MEC
12	Thallium	2	<0.1	<0.14	No	C>B, C>MEC
13	Zinc	212	105	260	Yes	Metals TMDL
14	Cyanide	5.2	8	5.8	Yes	B>C & detected at effluent, MEC>C
15	Asbestos	7x10 ⁶ fibers/L	No sample	No sample	No	N/A
16	2,3,7,8-TCDD (Dioxin)	1.4x10 ⁻⁰⁸	ND	2.44	No	C>MEC
17	Acrolein	780	<0.27	<0.44	No	C>B, C>MEC
18	Acrylonitrile	0.66	<0.11	<0.27	No	C>B, C>MEC
19	Benzene	1	<0.15	<0.3	No	C>B, C>MEC

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation ?	Reason
20	Bromoform	360	17	59	No	C>B, C>MEC
21	Carbon Tetrachloride	0.5	<0.16	<0.16	No	C>B, C>MEC
22	Chlorobenzene	21,000	<0.15	<0.15	No	C>B, C>MEC
23	Dibromochloromethane	34	60	37	Yes	MEC>C
24	Chloroethane	No criteria	<0.18	<0.18	No	No criteria
25	2-chloroethyl vinyl ether	No criteria	<0.24	<0.24	No	No criteria
26	Chloroform	No criteria	74	2.6	No	No criteria
27	Dichlorobromomethane	46	43	8.9	No	C>B, C>MEC
28	1,1-dichloroethane	No criteria	<0.18	<0.18	No	No criteria
29	1,2-dichloroethane	0.5	<0.14	<0.14	No	C>B, C>MEC
30	1,1-dichloroethylene	3.2	<0.18	<0.18	No	C>B, C>MEC
31	1,2-dichloropropane	5	<0.16	<0.16	No	C>B, C>MEC
32	1,3-dichloropropylene	0.5	<0.24	<0.05	No	C>B, C>MEC
33	Ethylbenzene	0.7	<0.14	<0.14	No	C>B, C>MEC
34	Methyl bromide	4,000	<0.12	<0.12	No	C>B, C>MEC
35	Methyl chloride	No criteria	<0.12	<0.12	No	No criteria
36	Methylene chloride	1,600	1.2	0.9	No	C>B, C>MEC
37	1,1,2,2-tetrachloroethane	1	<0.17	<0.17	No	C>B, C>MEC
38	Tetrachloroethylene	5	3.1	<0.18	No	C>B, C>MEC
39	Toluene	150	<0.13	0.87	No	C>B, C>MEC
40	Trans 1,2-Dichloroethylene	10	<0.16	<0.16	No	C>B, C>MEC
41	1,1,1-Trichloroethane	No criteria	0.77	<0.18	No	C>B, C>MEC
42	1,1,2-Trichloroethane	5	<0.19	<0.19	No	C>B, C>MEC
43	Trichloroethylene	5	<0.11	<0.11	No	C>B, C>MEC
44	Vinyl Chloride	0.5	<0.14	<0.14	No	C>B, C>MEC
45	2-chlorophenol	400	<0.71	<0.71	No	C>B, C>MEC
46	2,4-dichlorophenol	790	<0.77	<0.77	No	C>B, C>MEC
47	2,4-dimethylphenol	2,300	<0.8	<0.8	No	C>B, C>MEC
48	4,6-dinitro-o-cresol(aka 2-methyl-4,6-Dinitrophenol)	765	<0.33	<0.33	No	C>B, C>MEC
49	2,4-dinitrophenol	14,000	<5	<5	No	C>B, C>MEC
50	2-nitrophenol	No criteria	<0.84	<0.84	No	No criteria
51	4-nitrophenol	No criteria	<0.67	<0.67	No	No criteria
52	3-Methyl-4-Chlorophenol (aka P-chloro-m-cresol)	No criteria	0.59	0.52	No	No criteria
53	Pentachlorophenol	8.2	0.95	2.1	No	C>B, C>MEC
54	Phenol	4,600,000	<0.3	<0.3	No	C>B, C>MEC
55	2,4,6-trichlorophenol	6.5	<0.88	<0.88	No	C>B, C>MEC

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation ?	Reason
56	Acenaphthene	2,700	<0.31	<0.31	No	C>B, C>MEC
57	Acenaphthylene	No criteria	<0.26	<0.26	No	No criteria
58	Anthracene	110,000	0.28	<0.28	No	C>B, C>MEC
59	Benzidine	0.00054	<0.7	<0.7	No	C>B, C>MEC
60	Benzo(a)Anthracene	0.049	0.45	<0.19	Yes	MEC>C
61	Benzo(a)Pyrene	0.049	0.23	0.41	Yes	MEC>C, B>C
62	Benzo(b)Fluoranthene	0.049	0.25	0.28	Yes	MEC>C, B>C
63	Benzo(ghi)Perylene	No criteria	0.5	<0.31	No	No criteria
64	Benzo(k)Fluoranthene	0.049	0.32	<0.23	Yes	MEC>C, B>C
65	Bis(2-Chloroethoxy) methane	No criteria	<0.4	2	No	No criteria
66	Bis(2-Chloroethyl)Ether	1.4	<0.46	<0.46	No	C>B, C>MEC
67	Bis(2-Chloroisopropyl) Ether	170,000	<0.48	<0.48	No	C>B, C>MEC
68	Bis(2-Ethylhexyl)Phthalate	4.0	85	96	Yes	MEC>C, B>C
69	4-Bromophenyl Phenyl Ether	No criteria	0.28	<0.23	No	No criteria
70	Butylbenzyl Phthalate	5,200	94	5.2	No	C>B, C>MEC
71	2-Chloronaphthalene	4,300	<0.26	<0.26	No	C>B, C>MEC
72	4-Chlorophenyl Phenyl Ether	No criteria	<0.24	0.33	No	No criteria
73	Chrysene	0.049	0.33	<0.25	Yes	MEC>C
74	Dibenzo(a,h) Anthracene	0.049	0.33	<0.25	Yes	MEC>C
75	1,2-Dichlorobenzene	17,000	<0.18	<0.18	No	C>B, C>MEC
76	1,3-Dichlorobenzene	2,600	<0.16	<0.35	No	C>B, C>MEC
77	1,4-Dichlorobenzene	5	<0.13	<0.13	No	C>B, C>MEC
78	3-3'-Dichlorobenzidine	0.077	<0.3	<0.3	No	C>B, C>MEC
79	Diethyl Phthalate	120,000	1.3	1.3	No	C>B, C>MEC
80	Dimethyl Phthalate	2,900,000	<0.26	0.29	No	C>B, C>MEC
81	Di-n-Butyl Phthalate	12,000	0.83	0.68	No	C>B, C>MEC
82	2-4-Dinitrotoluene	9.1	<0.4	<0.4	No	C>B, C>MEC
83	2-6-Dinitrotoluene	No criteria	1.4	0.58	No	No criteria
84	Di-n-Octyl Phthalate	No criteria	<0.28	<0.28	No	No criteria
85	1,2-Diphenylhydrazine	0.54	<0.35	<0.35	No	C>B, C>MEC
86	Fluoranthene	370	0.39	<0.16	No	C>B, C>MEC
87	Fluorene	14,000	0.32	0.63	No	C>B, C>MEC
88	Hexachlorobenzene	0.00077	0.26	<0.15	Yes	MEC>C
89	Hexachlorobutadiene	50	<0.41	<0.41	No	C>B, C>MEC
90	Hexachlorocyclopentadiene	17,000	<5	<5	No	C>B, C>MEC

T
E
N
T
A
T
I
V
E

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation ?	Reason
91	Hexachloroethane	8.9	<0.36	<0.36	No	C>B, C>MEC
92	Indeno(1,2,3-cd)Pyrene	0.049	<0.42	<0.32	Yes	MEC>C
93	Isophorone	600	<0.33	<0.33	No	C>B, C>MEC
94	Naphthalene	No criteria	<0.43	<0.35	No	No criteria
95	Nitrobenzene	1,900	<0.37	<0.37	No	C>B, C>MEC
96	N-Nitrosodimethylamine	8.1	<0.36	0.5	No	C>B, C>MEC
97	N-Nitrosodi-n-Propylamine	1.4	<0.41	<0.41	No	C>B, C>MEC
98	N-Nitrosodiphenylamine	16	0.31	<0.23	No	C>B, C>MEC
99	Phenanthrene	No criteria	0.51	<0.25	No	No criteria
100	Pyrene	11,000	0.34	<0.16	No	C>B, C>MEC
101	1,2,4-Trichlorobenzene	No criteria	<0.26	<0.26	No	No criteria
102	Aldrin	0.00014	<0.0015	<0.0015	No	C>B, C>MEC
103	Alpha-BHC	0.013	<0.0018	<0.0018	No	C>B, C>MEC
104	Beta-BHC	0.046	<0.0031	<0.0031	No	C>B, C>MEC
105	Gamma-BHC (aka Lindane)	0.063	<0.0021	<0.0021	No	C>B, C>MEC
106	delta-BHC	No criteria	<0.0025	<0.0025	No	No criteria
107	Chlordane	0.00059	<0.08	<0.08	No	C>B, C>MEC
108	4,4'-DDT	0.00059	<0.0031	<0.0031	No	C>B, C>MEC
109	4,4'-DDE	0.00059	<0.0025	<0.0025	No	C>B, C>MEC
110	4,4'-DDD	0.00084	<0.003	<0.003	No	C>B, C>MEC
111	Dieldrin	0.00014	<0.0021	<0.0021	No	C>B, C>MEC
112	Alpha-Endosulfan	0.056	<0.0017	<0.0017	No	C>B, C>MEC
113	Beta-Endosulfan	0.056	<0.0019	<0.0019	No	C>B, C>MEC
114	Endosulfan Sulfate	240	<0.008	<0.008	No	C>B, C>MEC
115	Endrin	0.036	<0.0028	<0.0028	No	C>B, C>MEC
116	Endrin Aldehyde	0.81	<0.003	<0.003	No	C>B, C>MEC
117	Heptachlor	0.00021	<0.0017	<0.0017	No	C>B, C>MEC
118	Heptachlor Epoxide	0.00011	<0.0019	<0.0019	No	C>B, C>MEC
119	PCB 1016	0.00017	<0.08	<0.05	No	C>B, C>MEC
120	PCB 1221	0.00017	<0.06	<0.06	No	C>B, C>MEC
121	PCB 1232	0.00017	<0.15	<0.15	No	C>B, C>MEC
122	PCB 1242	0.00017	<0.07	<0.07	No	C>B, C>MEC
123	PCB 1248	0.00017	<0.06	<0.06	No	C>B, C>MEC
124	PCB 1254	0.00017	<0.04	<0.04	No	C>B, C>MEC
125	PCB 1260	0.00017	<0.04	<0.04	No	C>B, C>MEC
126	Toxaphene	0.0002	<0.12	<0.12	No	C>B, C>MEC

T
E
N
T
A
T
I
V
E

4. WQBEL Calculations

- a. **Calculation Options.** Once RPA has been conducted using either the TSD or the SIP methodologies, WQBELs are calculated. Alternative procedures for calculating WQBELs include:
 - i. Use WLA from applicable TMDL.
 - ii. Use a steady-state model to derive Maximum Daily Effluent Limits and Average Monthly Effluent Limits.
 - iii. Where sufficient data exist, use a dynamic model which has been approved by the State Water Board.
 - iv. Use revised *LA River Metals TMDL* WLA WER footnote to establish performance-based limitations for copper.
- b. **Los Angeles River Metals TMDL Calculation Procedure.**

Discharge Point 002 discharges into the Burbank Western Channel, as described by the *LA River Metals TMDL*. Burbank Western Channel has wet-weather WLAs for cadmium, copper, lead, and zinc (4.5 µg/L, 19 µg/L, 9.1 µg/L, and 212 µg/L, respectively). Burbank Western Channel has dry-weather WLAs only for copper and lead (19 µg/L and 9.1 µg/L, respectively). Wet-weather allocations are based on dry-weather in-stream numeric targets because the POTWs exert the greatest influence over in-stream water quality during dry weather, and collectively they contribute minimally to the total wet-weather loading. During dry-weather, the concentration-based and mass-based waste load allocations apply. In wet weather, the mass-based WLAs do not apply when the influent flows exceed the design capacity of the treatment plants.

According to the *LA River Metals TMDL* implementation section, permit writers may translate applicable waste load allocations into effluent limits by applying the effluent limitation procedures in Section 1.4 of the SIP or other applicable engineering practices authorized under federal regulations.

1. Copper: Tiers 1 and 2 of the SIP triggered RP for copper because the maximum effluent concentration exceeded the criteria ($MEC > C$), there was an exceedance of water quality objectives in the receiving water ($B > C$) and the pollutant is detected in the effluent. Tier 3 of the SIP also triggered RP because this constituent has established WLAs described in the revised *LA River Metals TMDL*. Therefore, final effluent limitations have been prescribed for copper.

The revised *LA River Metals TMDL* incorporated a 3.96 WER for copper. However, language contained in the revised *LA River Metals TMDL* precludes the direct application of the full copper WER for the derivation of final effluent limitations. The relevant TMDL WLA footnote reads, "The WER for this constituent is 3.96. Regardless of the WER, effluent limitations shall ensure that effluent concentrations and mass discharges do not exceed the levels of

T
E
N
T
A
T
I
V
E

water quality that can be attained by performance of this facility's treatment technologies existing at the time of permit issuance, reissuance, or modification." Therefore, the copper final effluent limitations will be performance-based, such that they do not exceed the levels of water quality that can be attained by of this facility's treatment technologies existing at the time of permit reissuance. The 36 µg/L Monthly Average effluent limitation was set at the 95th percentile of effluent data from December 2007 to August 2011, and was derived statistically from a probability plot using the MINITAB statistical software, Release 14. The 43 µg/L Daily Maximum final effluent limitation was set at the 99th percentile of effluent data from December 2007 to August 2011, and was derived statistically from a probability plot using the MINITAB statistical software, Release 14. These final effluent limitations for copper apply to both wet and dry weather conditions. Therefore, the effluent limitations for copper apply all-year round.

2. Lead: Tier 1 and Tier 2 of the SIP RPA procedures were not triggered for lead. However, Tier 3 was triggered because this constituent has established WLAs described in *LA River Metals TMDL*. In this permit, the TMDL-established WLAs for lead (9.1 µg/L), the USEPA default conversion factors, the median receiving water TMDL hardness of 229 mg/L, and a 0.6 coefficient of variation (CV) were used to calculate the WQBELs based on SIP/CTR procedures. The final effluent limitations for lead apply to both wet and dry weather conditions and shall apply all-year round.
3. Cadmium: Tier 1 and Tier 2 of the SIP RPA procedures were not triggered for cadmium. However, Tier 3 was triggered because this constituent has established WLAs described in *LA River Metals TMDL*. In this permit, the TMDL-established WLA for cadmium (4.5 µg/L), the USEPA default conversion factors, the TMDL hardness, and a 1.1 coefficient of variation were used to calculate the WQBELs based on SIP/CTR procedures. The final effluent limitations for cadmium apply to wet weather conditions only.
4. Zinc: Tier 1 of the SIP did not trigger RP for zinc. Tier 2 triggered RP for zinc because $B > C$ and zinc was detected in the effluent and Tier 3 triggered RP because this constituent has established waste load allocations described in the *LA River Metals TMDL*. In this permit, the TMDL-established WLA for zinc (212 µg/L), the USEPA default conversion factors, the TMDL hardness, and a 0.2 coefficient of variation were used to calculate the WQBELs based on SIP/CTR procedures. The final effluent limitations for zinc apply to wet weather conditions only.

The metals effluent limitations prescribed in this Order are consistent with the SIP Procedures, TMDL WLAs, and TMDL Implementation Sections.

- c. **SIP Calculation Procedure.** Section 1.4 of the SIP (2005) requires the step-by-step procedure to "adjust" or convert CTR numeric criteria into Average Monthly

Effluent Limitations (AMELs) and Maximum Daily Effluent Limitations (MDELs), for toxics.

Step 3 of Section 1.4 of the SIP (starting on page 8) lists the statistical equations that adjust CTR criteria for effluent variability.

Step 5 of Section 1.4 of the SIP (starting on page 10) lists the statistical equations that adjust CTR criteria for averaging periods and exceedance frequencies of the criteria/objectives. This section also reads, "For this method only, maximum daily effluent limitations shall be used for publicly-owned treatment works (POTWs) in place of average weekly limitations."

Sample calculation for Cyanide:

Step 1: Identify applicable water quality criteria.

From California Toxics Rule (CTR), we can obtain the Criterion Maximum Concentration (CMC) and the Criterion Continuous Concentration (CCC).

Freshwater Aquatic Life Criteria:

CMC = 22 µg/L (CTR page 31712, column B1) and

CCC = 5.2 µg/L (CTR page 31712, column B1); and

Human Health Criteria for Organisms only = 220,000 µg/L (CTR page 31712, column D2).

Step 2: Calculate effluent concentration allowance (ECA)

ECA = Criteria in CTR, since no dilution is allowed.

Step 3: Determine long-term average (LTA) discharge condition

i. Calculate CV:

CV = Standard Deviation/Mean

= 0.6 since more than 80% of data was non-detect

Find the ECA Multipliers from SIP Table 1 (page 9), or by calculating them using equations on SIP page 8. When CV = 0.6, then:

ECA Multiplier acute = 0.321 and

ECA Multiplier chronic = 0.527

LTA acute = ECA acute x ECA Multiplier acute

= 22 µg/L x 0.0871 = 7.062 µg/L

LTA chronic = ECA chronic x ECA Multiplier chronic

= 5.2 µg/L x 0.527 = 2.7404 µg/L

T
E
N
T
A
T
I
V
E

Step 4: Select the lowest LTA

In this case, the lowest LTA is 2.740 µg/L.

Step 5: Calculate the Average Monthly Effluent Limitation (AMEL) & Maximum Daily Effluent Limitation (MDEL) for AQUATIC LIFE

- i. Find the multipliers. You need to know CV and n (frequency of sample collection per month). If effluent samples are collected 4 times a month or less, then n = 4. CV was determined to be 0.6 in the previous step.

AMEL Multiplier = 1.55

MDEL Multiplier = 3.11

- ii. AMEL aquatic life = lowest LTA (from Step 4) x AMEL Multiplier
= 2.740 µg/L x 1.55 = 4.24762 µg/L
- iii. MDEL aquatic life = lowest LTA (from Step 4) x AMEL Multiplier
= 2.740 µg/L x 3.11 = 8.5226 µg/L

Step 6: Find the Average Monthly Effluent Limitation (AMEL) & Maximum Daily Effluent Limitation (MDEL) for HUMAN HEALTH

- i. Find factors. Given CV = 0.6 and n = 4.

For AMEL human health limit, there is no factor.

The MDEL/AMEL human health factor = 2.01

- ii. AMEL human health = ECA = 220,000 µg/L
- iii. MDEL human health = ECA x MDEL/AMEL factor
= 2.01 µg/L x 220,000 = 442,200 µg/L

Step 7: Compare the AMELs for Aquatic life and Human health and select the lowest. Compare the MDELs for Aquatic life and Human health and select the lowest

- i. Lowest AMEL = 4.2 µg/L (Based on Aquatic Life protection)
- ii. Lowest MDEL = 8.5 µg/L (Based on Aquatic Life protection)

d. Impracticability Analysis

Federal NPDES regulations contained in 40 CFR part 122.45 continuous dischargers states that all permit limitations, standards, and prohibitions, including those to achieve water quality standards, shall, unless impracticable, be

T
E
N
T
A
T
I
V
E

stated as maximum daily and average monthly discharge limitations for all dischargers other than POTWs.

As stated by USEPA in its long-standing guidance for developing WQBELs, average alone limitations are not practical for limiting acute, chronic, and human health toxic effects.

For example, a POTW sampling for a toxicant to evaluate compliance with a 7-day average limitation could fully comply with this average limit but still be discharging toxic effluent on one, two, three, or up to four of these seven days and not be meeting 1-hour average acute criteria or 4-day average chronic criteria. For these reason, USEPA recommends daily maximum and 30-day average limits for regulating toxics in all NPDES discharges. For the purposes of protecting the acute effects of discharges containing toxicants (CTR human health for the ingestion of fish), daily maximum limitations have been established in this NPDES permit for mercury because it is considered to be a carcinogen, endocrine disruptor, and is bioaccumulative.

A 7-day average alone would not protect one, two, three, or four days of discharging pollutants in excess of the acute and chronic criteria. Fish exposed to these endocrine disrupting chemicals will be passed on to the human consumer. Endocrine disrupters alter hormonal functions by several means. These substances can:

- mimic or partly mimic the sex steroid hormones estrogens and androgens (the male sex hormone) by binding to hormone receptors or influencing cell signaling pathways.
 - block, prevent and alter hormonal binding to hormone receptors or influencing cell signaling pathways.
 - alter production and breakdown of natural hormones.
 - modify the making and function of hormone receptors.
- e. **Mass based limits.** 40 CFR part 122.45(f)(1) requires that except under certain conditions, all permit limits, standards, or prohibitions be expressed in terms of mass units. 40 CFR part 122.45(f)(2) allows the permit writer, at its discretion, to express limits in additional units (e.g., concentration units). The regulations mandate that, where limits are expressed in more than one unit, the permittee must comply with both.

T
E
N
T
A
T
I
V
E

Generally, mass-based limits ensure that proper treatment, and not dilution, is employed to comply with the final effluent concentration limits. Concentration-based effluent limits, on the other hand, discourage the reduction in treatment efficiency during low-flow periods and require proper operation of the treatment units at all times. In the absence of concentration-based effluent limits, a permittee would be able to increase its effluent concentration (i.e., reduce its level of treatment) during low-flow periods and still meet its mass-based limits. To account for this, this permit includes mass and concentration limits for some constituents.

Summary of Water Quality-based Effluent Limitations Discharge Point 002

Table 6. Summary of Water Quality-based Effluent Limitations for Discharge Point 002

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Antimony	µg/L	6				
	lbs/day ¹	0.6				
Cadmium (wet-weather)	µg/L	3.2 ²	--	8.3 ²		
	lbs/day ¹	0.33 ³	--	0.87 ³		
Copper (dry- and wet-weather)	µg/L	36 ^{2,4}	--	43 ^{2,4}		
	lbs/day ¹	3.8 ³	--	4.5 ³		
Lead (dry- and wet-weather)	µg/L	7.4 ^{2,4}	--	15 ^{2,4}		
	lbs/day ¹	0.77 ³	--	1.6 ³		
Zinc (wet-weather)	µg/L	159 ²	--	211 ²		
	lbs/day ¹	17 ³	--	22 ³		
Cyanide	µg/L	4.2	--	8.5		
	lbs/day ¹	0.44	--	0.89		
Dibromochloromethane	µg/L	34	--	94		
	lbs/day ¹	3.5	--	9.8		
Benzo(a)anthracene	µg/L	0.049	--	0.098		

¹ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day, or Flow (MGD) x Concentration (µg/L) x 0.00834 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

² Wet-weather effluent limitations apply when the maximum daily flow measured at the Los Angeles River Wardlow station is equal to or greater than 500 cubic feet per second.

³ The mass-based effluent limitations for cadmium, copper, lead, and zinc do not apply during wet weather when the influent exceeds the plant design flow rate of 12.5 mgd.

⁴ Dry-weather effluent limitations apply when the maximum daily flow at the Los Angeles River Wardlow station is less than 500 cubic feet per second.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
	lbs/day ¹	0.0051	--	0.010		
Benzo(a)pyrene	µg/L	0.049	--	0.098		
	lbs/day ¹	0.0051	--	0.010		
Benzo(b)fluoranthene	µg/L	0.049	--	0.098		
	lbs/day ¹	0.0051	--	0.010		
Benzo(k)fluoranthene	µg/L	0.049	--	0.098		
	lbs/day ¹	0.0051	--	0.010		
Bis(2-Ethylhexyl) Phthalate	µg/L	4	--	--		
	lbs/day ¹	0.67	--	--		
Chrysene	µg/L	0.049	--	0.098		
	lbs/day ¹	0.0051	--	0.010		
Dibenzo(a,h)Anthracene	µg/L	0.049	--	0.098		
	lbs/day ¹	0.0082	--	0.016		
Hexachlorobenzene	µg/L	0.00077	--	0.0015	--	--
	lbs/day ¹	0.000080	--	0.000156	--	--
Indeno(1,2,3-cd)pyrene	µg/L	0.049	--	0.098	--	--
	lbs/day ¹	0.0051		0.010		
Total trihalomethanes	µg/L	80	--	--	--	--
	lbs/day ¹	8.3	--	--	--	--
Iron	µg/L	300	--	--	--	--
	lbs/day ¹	31	--	--	--	--

T
E
N
T
A
T
I
V
E

5. Whole Effluent Toxicity (WET)

Because of the nature of industrial discharges into the POTW sewershed, it is possible that other toxic constituents could be present in the Burbank WRP effluent or could have synergistic or additive effects. Also, because numeric limits for certain toxic constituents that did not show RP have been removed, the acute toxicity limit may provide a backstop to preventing the discharge of toxic pollutants in toxic amounts. In spite of the addition of nitrification/denitrification (NDN) process to the treatment train, from December 2007 to October 2010, the chronic toxicity narrative effluent limitation and 1.0 monthly median trigger were exceeded for twenty months, triggering an extensive Toxicity Identification Evaluation (TIE) and Toxicity Reduction Evaluation (TRE) on the part of the City of Burbank. The TIE researched whether the toxicity was due to zinc and copper presence, nutrient starved-effluent, or ion imbalance. The TRE results concluded that the reported test endpoint for the *Selenastrum* test species had not captured the true algal growth percentage because the contract lab had omitted a step in the analytical test procedure. Section 14.6.16.3.3 of *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition (EPA-821-R-02-013)* calls for the *Selenastrum* stock cultures to be shaken continuously at 100 cpm or shaken twice daily by hand. In February 2011 the City of Burbank's contract lab began following the additional

protocol called for in the USEPA test method. The algae which had been adhering to the walls of the lab glassware was reintroduced into suspension following the shaking procedure. Therefore, when the cell density per mL measurement was taken, the percentage of algae growth was at acceptable levels. Since then, the toxicity monthly median trigger has been met. Although all acute toxicity testing results reported during the term of the previous Order (post NDN) exhibited survival rates greater than 90% and thus did not exceed any acute toxicity requirements, Regional Water Board staff determined that, pursuant to the SIP, reasonable potential exists for toxicity. As such, the permit contains effluent limitations for both acute and chronic toxicity.

The toxicity numeric effluent limitations are based on:

- a. 40 CFR part 122.44(d)(v) – limits on whole effluent toxicity are necessary when chemical-specific limits are not sufficient to attain and maintain applicable numeric or narrative water quality standards;
- b. 40 CFR part 122.44(d)(vi)(A) – where a State has not developed a water quality criterion for a specific pollutant that is present in the effluent and has reasonable potential, the permitting authority can establish effluent limits using numeric water quality criterion;
- c. Basin Plan objectives and implementation provisions for toxicity;
- d. Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity Programs Final May 31, 1996;
- e. Whole Effluent Toxicity (WET) Control Policy July 1994; and,
- f. Technical Support Document (several chapters and Appendix B).

The circumstances warranting a numeric chronic toxicity effluent limitation when there is reasonable potential were under review by the State Water Resources Control Board (State Water Board) in SWRCB/OCC Files A-1496 & A-1496(a) [Los Coyotes/Long Beach Petitions]. On September 16, 2003, at a public hearing, the State Water Board adopted Order No. 2003-0012 deferring the issue of numeric chronic toxicity effluent limitations until a subsequent Phase of the SIP is adopted. In the meantime, the State Water Board replaced the numeric chronic toxicity limit with a narrative effluent limitation and a 1.0 TUc trigger, in the Long Beach and Los Coyotes WRP NPDES permits. This permit contains a similar narrative chronic toxicity effluent limitation, with a numeric trigger for accelerated monitoring. Phase II of the SIP has been adopted; however, the toxicity control provisions were not revised.

On January 17, 2006, the State Water Board Division of Water Quality held a CEQA scoping meeting to seek input on the scope and content of the environmental information that should be considered in the planned revisions of the Toxicity Control

T
E
N
T
A
T
I
V
E

Provisions of the SIP. However, the Toxicity Control Provisions of the SIP continue unchanged.

This Order contains a reopener to allow the Regional Water Board to modify the permit, if necessary, consistent with any new policy, law, or regulation. Until such time, this Order will have toxicity limitations that are consistent with the State Water Board's precedential decision.

a. Acute Toxicity Limitation:

The Dischargers may test for acute toxicity by using USEPA's *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, October 2002 (EPA-821-R-02-012). Acute toxicity provisions in the accompanying Order are derived from the Basin Plan's toxicity standards (Basin Plan 3-16 and 3-17). The provisions require the Discharger to accelerate acute toxicity monitoring and take further actions to identify the source of toxicity and to reduce acute toxicity.

b. Chronic Toxicity Limitation and Requirements:

Chronic toxicity provisions in the accompanying Order are derived from the Basin Plan's toxicity standards (Basin Plan 3-16 and 3-17). The provisions require the Discharger to accelerate chronic toxicity monitoring and take further actions to identify the source of toxicity and to reduce chronic toxicity. The monthly median trigger of 1.0 TU_c for chronic toxicity is based on *USEPA Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity (WET) Programs* Final May 31, 1996 (Chapter 2 – Developing WET Permitting Conditions, page 2-8). In cases where effluent receives no dilution or where mixing zones are not allowed, the 1.0 TU_c chronic criterion should be expressed as a monthly median. The "median" is defined as the middle value in a distribution, above which and below which lie an equal number of values. For example, if the results of the WET testing for a month were 1.5, 1.0, and 1.0 TU_c, the median would be 1.0 TU_c.

The *USEPA Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity (WET) Programs* Final May 31, 1996 (Chapter 2 – Developing WET Permitting Conditions, page 2-8) recommends two alternatives for setting up maximum daily limit: using 2.0 TU_c as the maximum daily limit; or using a statistical approach outlined in the TSD to develop a maximum daily effluent limitation. In this permit, a maximum daily limitation is not prescribed. However, a trigger for chronic toxicity is prescribed.

D. Final Effluent Limitations

1. Satisfaction of Anti-Backsliding Requirements

The effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order, with the exception of effluent limitation for fluoride.

The effluent limitation for fluoride was deleted because it did not show reasonable potential to be in the effluent water. This relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

2. Satisfaction of Antidegradation Policy

On October 28, 1968, the State Water Board adopted Resolution No. 68-16, *Maintaining High Quality Water*, which established an antidegradation policy for State and Regional Water Boards. The State Water Board has, in State Water Board Order No. 86-17 and an October 7, 1987 guidance memorandum, interpreted Resolution No. 68-16 to be fully consistent with the federal antidegradation policy. Similarly, the CWA (section 304(d)(4)(B)) and USEPA regulations (40 CFR part 131.12) require that all permitting actions be consistent with the federal antidegradation policy. Together, the state and federal policies are designed to ensure that a water body will not be degraded resulting from the permitted discharge. Discharges in conformance with the provisions of this Order will not result in a lowering of water quality and therefore conform to the antidegradation policies.

3. Stringency of Requirements for Individual Pollutants

This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The TBELs consist of restrictions on BOD, TSS, pH, and percent removal of BOD and TSS. Restrictions on BOD, TSS and pH are discussed in Section IV.B. of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements that are necessary to meet water quality standards.

WQBELs have been scientifically derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and WQOs contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to section 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA and the applicable water quality standards for purposes of the CWA.

T
E
N
T
A
T
I
V
E

Summary of Final Effluent Limitations Discharge Point 002

Table 7. Summary of Final Effluent Limitations

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
BOD ₅ 20°C	mg/L	20	30	45			Existing
	lbs/day ⁵	2085	3130	4690			
Total Suspended Solids (TSS)	mg/L	15	40	45			Existing
	lbs/day ⁵	1560	4170	4690			
pH	standard units	--	--	--	6.5	8.5	Existing
Removal Efficiency for BOD and TSS	%	85	--	--			Existing
Oil and Grease	mg/L	10	--	15			Existing
	lbs/day ⁵	1040	--	1560			
Settleable Solids	ml/L	0.1	--	0.3			Existing
Total Residual Chlorine	mg/L	--	--	0.1			Existing
	lbs/day ⁵	--	--	17			
Total Dissolved Solids	mg/L	950	--	--			Existing
	lbs/day ⁵	99,040	--	--			
Sulfate	mg/L	300	--	--			Existing
	lbs/day ⁵	31,300	--	--			
Chloride	mg/L	190	--	--			Existing
	lbs/day ⁵	19,800	--	--			
MBAS	mg/L	0.5	--	--			Existing
	lbs/day ⁵	52	--	--			
Ammonia Nitrogen	mg/L	2.1 ⁶	--	9.1 ⁶			TMDL
	lbs/day ⁵	--	--	--			
Nitrate + Nitrite (as N)	mg/L	7.2 ⁶	--	--			TMDL
	lbs/day ⁵	--	--	--			
Nitrate (as N)	mg/L	7.2 ⁶	--	--			TMDL
	lbs/day ⁵	--	--	--			
Nitrite (as N)	mg/L	0.9 ⁶	--	--			TMDL

⁵ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day, or Flow (MGD) x Concentration (µg/L) x 0.00834 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

⁶ This is the waste load allocation (WLA), according to the *LA River Nitrogen Compounds TMDL* Resolution No. 2003-009, adopted by the Regional Board on July 10, 2003. The WLA serves as the effluent limitation for the discharge. It became effective on March 23, 2004.

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
	lbs/day ⁵	--	--	--			
Antimony	µg/L	6	--	--			Basin Plan
	lbs/day ⁵	0.6	--	--			
Cadmium (wet-weather)	µg/L	3.2 ⁷	--	8.3 ⁷			TMDL
	lbs/day ⁵	0.33 ⁸	--	0.87 ⁸			
Copper (Dry- and wet-weather)	µg/L	36 ^{7,9}	--	43 ^{7,9}			TMDL
	lbs/day ⁵	3.8 ⁸	--	4.5 ⁸			
Lead (Dry- and wet-weather)	µg/L	7.4 ^{7,9}	--	15 ^{7,9}			TMDL
	lbs/day ⁵	0.77 ⁸	--	1.6 ⁸			
Zinc (wet-weather)	µg/L	159 ⁷	--	211 ⁷			TMDL
	lbs/day ⁵	17 ⁸	--	22 ⁸			
Cyanide	µg/L	4.2	--	8.5			SIP/CTR
	lbs/day ⁵	0.44	--	0.89			
Dibromochloromethane	µg/L	34	--	94			SIP/CTR
	lbs/day ⁵	3.5	--	9.9			
Benzo(a)anthracene	µg/L	0.049	--	0.098			SIP/CTR
	lbs/day ⁵	0.0051	--	0.010			
Benzo(a)pyrene	µg/L	0.049	--	0.098			SIP/CTR
	lbs/day ⁵	0.0051	--	0.010			
Benzo(b)fluoranthene	µg/L	0.049	--	0.098			SIP/CTR
	lbs/day ⁵	0.0051	--	0.010			
Benzo(k)fluoranthene	µg/L	0.049	--	0.098			SIP/CTR
	lbs/day ⁵	0.0051	--	0.010			
Bis(2-Ethylhexyl) Phthalate	µg/L	4	--	--			SIP/CTR
	lbs/day ⁵	0.67	--	--			
Chrysene	µg/L	0.049	--	0.098			SIP/CTR
	lbs/day ⁵	0.0051	--	0.010			
Dibenzo(a,h) Anthracene	µg/L	0.049	--	0.098			SIP/CTR
	lbs/day ⁵	0.0082	--	0.016			
Hexachlorobenzene	µg/L	0.00077	--	0.0015			SIP/CTR
	lbs/day ⁵	0.000080	--	0.000156			
Indeno(1,2,3-cd)pyrene	µg/L	0.049	--	0.098			SIP/CTR

⁷ Wet-weather effluent limitations apply when the maximum daily flow measured at the Los Angeles River Wardlow station is equal to or greater than 500 cubic feet per second.

⁸ The mass-based effluent limitations for cadmium, copper, lead, and zinc do not apply during wet weather when the influent exceeds the plant design flow rate of 12.5 mgd.

⁹ Dry-weather effluent limitations apply when the maximum daily flow measured at the Los Angeles River Wardlow station is less than 500 cubic feet per second.

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
		lbs/day ⁵		0.010			
Total trihalomethanes	µg/L	80	--	--	--	--	Basin Plan
	lbs/day ⁵	8.3	--	--	--	--	
Iron	µg/L	300	--	--	--	--	Basin Plan
	lbs/day ⁵	31	--	--	--	--	

E. Reclamation Specifications

The Discharger recycled 520 million gallons of the tertiary-treated effluent in 2010 and plans to continue doing so. The production, distribution, and reuse of recycled water for direct, non-potable applications are presently regulated under Water Recycling Requirements contained in Order No. 91-101. The Public Works Department for the City of Burbank is the agency who distributes the recycled water. There are currently over 26 users of the recycled water produced by the Plant. Recycled water is used mainly in cooling towers at the Burbank Power Plant and for landscape irrigation at a golf course, schools, parks, and medians located throughout the City.

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order.

B. Groundwater

Limitations in this Order must protect not only surface receiving water beneficial uses, but also, the beneficial uses of underlying groundwater where there is a recharge beneficial use of the surface water. In addition to a discharge to surface water, there is discharge that can impact groundwater. Sections of the Los Angeles River, near Burbank WRP discharge points, are designated as GWR beneficial use. Surface water from the Los Angeles River percolates into the Central/West Coast Los Angeles Coastal Plain Groundwater Basins. Since groundwater from these Basins is used to provide drinking water to the community, the groundwater aquifers should be protected.

T
E
N
T
A
T
I
V
E

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

40 CFR part 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order, establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

A. Influent Monitoring

This Order carries forward the treatment plant's influent monitoring requirements with the inclusion of cyanide.

B. Effluent Monitoring

The Discharger is required to conduct monitoring of the permitted discharges in order to evaluate compliance with permit conditions. Monitoring requirements are given in the proposed Monitoring and Reporting Program (Attachment E). This provision requires compliance with the Monitoring and Reporting Program, and is based on 40 CFR parts 122.44(i), 122.62, 122.63, and 124.5. The Monitoring and Reporting Program is a standard requirement in almost all NPDES permits (including the proposed Order) issued by the Regional Water Board. In addition to containing definition of terms, it specifies general sampling/analytical protocols and the requirements of reporting spills, violation, and routine monitoring data in accordance with NPDES regulations, the CWC, and Regional Water Board policies. The Monitoring and Reporting Program also contains sampling program specific for the Discharger's wastewater treatment plant. It defines the sampling stations and frequency, pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all pollutants for which effluent limitations are specified. Further, in accordance with Section 1.3 of the SIP, a periodic monitoring is required for all priority pollutants defined by the CTR, for which criteria apply and for which no effluent limitations have been established, to evaluate reasonable potential to cause or contribute to an excursion above a water quality standard.

Monitoring for those pollutants expected to be present in the discharge from the facility, will be required as shown on the proposed Monitoring and Reporting Program (Attachment E) and as required in the SIP. Monitoring requirements are largely unchanged from the previous Order. Annual monitoring for priority pollutants in the effluent is required in accordance with the SIP.

The changes in the effluent monitoring are summarized in the following table.

T
E
N
T
A
T
I
V
E

Table 8. Effluent Monitoring Program Comparison Table

Parameter	Monitoring Frequency (2006 Permit)	Monitoring Frequency (2011 Permit)
pH	daily	no change
Settleable solids	daily	weekly
Suspended solids	daily	weekly
BOD	weekly	no change
Oil and grease	monthly	no change
Total dissolved solids	monthly	no change
Chloride	monthly	no change
Sulfate	monthly	no change
Ammonia nitrogen	monthly	no change
Nitrate nitrogen	monthly	no change
Nitrite nitrogen	monthly	no change
Organic nitrogen	monthly	no change
Total nitrogen	monthly	no change
Surfactants (MBAS)	monthly	no change
Chronic Toxicity	monthly	no change
Acute Toxicity	quarterly	no change
Fluoride	quarterly	no change
Boron	monthly	quarterly
Antimony	quarterly	monthly
Arsenic	quarterly	no change
Beryllium	semiannually	no change
Cadmium	monthly	no change
Chromium III	monthly	quarterly
Chromium VI	monthly	quarterly
Copper	monthly	no change
Iron	quarterly	monthly
Lead	monthly	no change
Manganese	monthly	quarterly
Mercury	monthly	quarterly
Nickel	quarterly	no change
Selenium	monthly	quarterly
Silver	quarterly	no change
Thallium	semiannually	no change
Zinc	monthly	no change
Cyanide	quarterly	monthly
2,3,7,8-TCDD (Dioxin)	semiannually	no change
Total trihalomethanes	monthly	no change
Bromoform	monthly	semiannually
Bromodichloromethane	monthly	semiannually
Carbon Tetrachloride	quarterly	semiannually
Dibromochloromethane	monthly	no change
Tetrachloroethylene	quarterly	semiannually

**T
E
N
T
A
T
I
V
E**

Parameter	Monitoring Frequency (2006 Permit)	Monitoring Frequency (2011 Permit)
Benzo(a)anthracene	quarterly	no change
Benzo(a)pyrene		quarterly
Benzo(b)pyrene		quarterly
Benzo(k)fluoranthene		quarterly
Bis(2-ethylhexyl)phthalate	monthly	no change
Chrysene	quarterly	no change
Dibenzo(a,h)Anthracene	monthly	quarterly
N-Nitrosodi-n-propylamine	quarterly	semiannually
Indeno(1,2,3-cd)pyrene	semiannually	quarterly
Hexachlorobenzene	semiannually	quarterly
Lindane	monthly	semiannually
Diazinon	--	semiannually
Pesticide	semi-annually	no change
2,4-D	annually	--
2,4,5-TP (Silvex)	annually	--
Perchlorate	semiannually	no change
1,4-Dioxane	semiannually	no change
1,2,3-Trichloropropane	semiannually	no change
Methyl-tert-butyl-ether (MTBE)	semiannually	no change
Hardness (CaCo)	monthly	no change

**T
E
N
T
A
T
I
V
E**

The reduction of monitoring frequencies for priority pollutants listed in the above Table is warranted because the previous monitoring data for these pollutants indicate that the discharge did not demonstrate reasonable potential to exceed water quality standards.

C. Whole Effluent Toxicity Testing Requirements

Whole effluent toxicity (WET) protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth.

This requirement establishes conditions and protocol by which compliance with the Basin Plan narrative water quality objective for toxicity will be demonstrated and in accordance with Section 4.0 of the SIP. Conditions include required monitoring and evaluation of the effluent for acute and chronic toxicity and numerical values for chronic toxicity evaluation to be used as 'triggers' for initiating accelerated monitoring and toxicity reduction evaluation(s).

D. Receiving Water Monitoring

1. Surface Water

- Receiving water monitoring is required to determine compliance with receiving water limitations and to characterize the water quality of the receiving water.

Requirements are based on the Basin Plan. Flow monitoring is required at the Los Angeles River Wardlow station to determine the dry- and wet-weather condition of the receiving water.

- The proposed receiving water monitoring program will improve coordination and efficiency of receiving water monitoring for existing discharges in the Los Angeles River watershed by streamlining monitoring efforts and reducing redundancies throughout the watershed and will provide more useful water quality data on both watershed and site-specific scales.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR part 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR part 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR part 122.42.

40 CFR parts 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. 40 CFR part 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with section 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR parts 122.41(j)(5) and (k)(2) because the enforcement authority under the CWC is more stringent. In lieu of these conditions, this Order incorporates by reference CWC section 13387(e).

B. Special Provisions

1. Reopener Provisions

This provision is based on 40 CFR part 123. The Regional Water Board may reopen the permit to modify permit conditions and requirements. Causes for modifications include the promulgation of new regulations, modification in sludge use or disposal practices, or adoption of new regulations by the State Water Board or Regional Water Board, including revisions to the Basin Plan.

2. Special Studies and Additional Monitoring Requirements

a. Special Study – Constituents of Emerging Concern in the Effluent

Background

Advancements in analytical technology over the last decade have dramatically increased the number of chemicals that can be detected and greatly decreased

**T
E
N
T
A
T
I
V
E**

the concentrations at which chemicals can be detected. This new ability to detect trace levels of chemical concentrations has expanded the existing understanding of the kinds of contaminants present in the water and wastewater. Many man-made chemicals, particularly pesticides, pharmaceuticals and personal care products, have been found in waters across the United States.

Collectively, these compounds are referred to as Emerging Constituents (ECs) or Constituents of Emerging Concern (CECs) because their presence is starting to be revealed by rapid advances in analytical technology. Despite recent improvements in analytical science, there is still scarcity of data and lack of robust methodologies for measuring most CECs. CECs are part of the unregulated chemicals, for which no water quality standards have been established.

Recent publications and media reports on CECs have increased public awareness of the issue, providing an impetus for CECs investigations around the country, including local efforts by the City of Los Angeles and Southern California Coastal Water Research Project (SCCWRP). For instance, starting in 2005 the City of Los Angeles has been conducting a special study as part of the Order No. 2005-0020, whose results suggest that the presence of natural and synthetic estrogen hormones has caused feminization of male fish (hornyhead turbot) in Santa Monica Bay, especially near the Hyperion Treatment Plant outfall. In January 2010, SCCWRP convened a workshop where 50 scientists, water quality managers, and stakeholders discussed and collaborated on developing an effective CEC monitoring and management strategy that is protective of water quality. Anticipated outcomes of this workshop include recommended lists of CECs for monitoring in recycled water (for groundwater concerns) and for monitoring in ambient waters, including ocean waters.

In recent years, this Regional Water Board has incorporated monitoring of a select group of CECs into the NPDES permits issued to POTWs.

CEC Special Study Requirements

1. The Discharger shall conduct a special study to investigate the CECs in the effluent discharge. Within six months of the effective date of this Order, the Discharger shall submit to the Executive Officer a CECs Special Study Work Plan (Work Plan) for approval. Upon approval, the Discharger shall implement the Work Plan.

This Special Study Work Plan shall include, but not limited to, the following:

- (1) Identification of CECs to be monitored in the effluent, sample type (e.g. 24-hour composite), sampling frequency, proposed sampling month, and sampling methodology. Table 9 identifies the minimum parameters to be monitored.

Table 9. CECs Monitoring in the Effluent

Parameter	Units	Sample Type	Minimum Sampling Frequency	Analytical Test Method and (Minimum Level, units)
17 α -Ethinyl Estradiol	ng/L	To be proposed	Annually	To be proposed
17 β -Estradiol	ng/L	To be proposed	Annually	To be proposed
Estrone	ng/L	To be proposed	Annually	To be proposed
Bisphenol A	ng/L	To be proposed	Annually	To be proposed
Nonylphenol and nonylphenolpolyethoxylates	ng/L	To be proposed	Annually	To be proposed
Octylphenol and octylphenolpolyethoxylates	ng/L	To be proposed	Annually	To be proposed
Polybrominateddiphenyl ethers	ng/L	To be proposed	Annually	To be proposed
Acetaminophen	ng/L	To be proposed	Annually	To be proposed
Amoxicillin	ng/L	To be proposed	Annually	To be proposed
Azithromycin	ng/L	To be proposed	Annually	To be proposed
Carbamazepine	ng/L	To be proposed	Annually	To be proposed
Caffeine	ng/L	To be proposed	Annually	To be proposed
Ciprofloxacin	ng/L	To be proposed	Annually	To be proposed
DEET	ng/L	To be proposed	Annually	To be proposed
Dilantin	ng/L	To be proposed	Annually	To be proposed
Gemfibrozil	ng/L	To be proposed	Annually	To be proposed
Ibuprofen	ng/L	To be proposed	Annually	To be proposed
Lipitor (Atorvastatin)	ng/L	To be proposed	Annually	To be proposed
Iodinated contrast media (i.e., iopromide)	ng/L	To be proposed	Annually	To be proposed
Sulfamethoxazole	ng/L	To be proposed	Annually	To be proposed
Trimethoprim	ng/L	To be proposed	Annually	To be proposed
Salicylic acid	ng/L	To be proposed	Annually	To be proposed
TCEP	ng/L	To be proposed	Annually	To be proposed
Triclosan	ng/L	To be proposed	Annually	To be proposed

**T
E
N
T
A
T
I
V
E**

Once the Southern California Coastal Water Research Project's (SCCWRP's) recommended list of CECs monitoring in ambient waters, including ocean waters, is finalized, the above list of minimum parameters to be monitored by the Discharger and the sampling frequency may be re-evaluated and modified by the Executive Officer. At such time, upon request by the Executive Officer, the Discharger shall monitor the requested CECs parameters at the specified frequency. In the Special Study Work Plan, the Discharger may also propose, for consideration and approval by the Executive Officer, surrogate or indicator CECs that may contribute towards a better understanding of CECs in its effluent.

Sample Type– The Discharger shall propose in the Work Plan the appropriate sample type (e.g. grab or composite) for each constituent.

Sampling Period– At minimum, the Discharger shall monitor the specified CECs once per year. The Work Plan shall propose the appropriate sampling month or quarter for each year, consistent with the goals of the analyses.

The rationale for selecting the particular sampling month or quarter shall be explained in the Work Plan.

Proposed Sampling Month- The Discharger may choose a fixed month for sampling or vary the sampling month over the duration of the special study in order to examine possible temporal associations.

Analytical Test Methodology – The Discharger shall review and consider all available analytical test methodologies, including but not limited to those listed in USEPA Methods 1694 and 1698, and methodologies approved or utilized by U.S. Geologic Survey, California Department of Public Health, and other federal or State agencies. Based on its review, the Discharger shall propose the most appropriate analytical methodology, considering sensitivity, accuracy, availability, and cost.

(2) Characterization of existing CECs data (data collected previous to Special Study). The Discharger shall propose a characterization of all existing CECs data (associated with its effluent or receiving water) that have been collected for various purposes in the past. At a minimum, the characterization shall include:

- an identification of all CECs monitored to date (outside of this Special Study);
- monitoring duration, frequency, and date(s) (for example, from 2000-present, annually);
- analytical methodologies employed;
- RL, MLs and MDLs achieved for each methodology used; and
- If detected, temporal/seasonal trend analyses (using both statistical and graphical demonstration) of CECs.

(3) Evaluation of CECs data collected as part of this Special Study. The Discharger shall propose an evaluation of CECs data (associated with its effluent) to be collected as part of this special study. At a minimum, the characterization shall include:

- an identification of CECs that have been monitored;
- monitoring duration, frequency, and date(s);
- RL, MLs and MDLs achieved for each methodology used;
- a brief update on any improvements (or change) in the analytical methodologies and associated RL, MLs and MDLs achieved for each methodology used; and
- If detected, temporal/seasonal trend analyses (using both statistical and graphical demonstration) of cumulative CECs data collected as part of this special study.

T
E
N
T
A
T
I
V
E

2. Reporting – By April 15th of each year (starting April 15, 2013), the Discharger shall submit to the Executive Officer of this Regional Water Board, an annual report summarizing the monitoring results from the previous year. For example, the annual report due April 15, 2013, shall include CECs monitoring data from January to December 2012. Each annual report shall include a compilation of effluent monitoring data of CECs listed in the approved Work Plan, MLs, sample type, analytical methodology used, sampling date/time, QA/QC information, and an evaluation of cumulative CECs data collected to date as part of this special study (see above for further details on CECs data evaluation). In addition, the first annual report (due April 15, 2013) shall include a characterization of existing CECs data, i.e., all data collected outside of this special study (see above for further details on existing CECs data characterization).
 - b. **Antidegradation Analysis and Engineering Report for Proposed Plant Expansion.** This provision is based on the State Water Resources Control Board Resolution No. 68-16, which requires the Regional Water Board in regulation the discharge of waste to maintain high quality waters of the State, the Discharger must demonstrate that it has implemented adequate controls (e.g., adequate treatment capacity) to ensure that high quality waters will be maintained. This provision requires the Discharger to clarify it has increase plant capacity through the addition of new treatment system(s) to obtain alternative effluent limitations for the discharge from the treatment system(s). This provision requires the Discharger to report specific time schedules for the plants projects. This provision requires the Discharger to submit report to the Regional Water Board for approval.
 - c. **Operations Plan for Proposed Expansion.** This provision is based on Section 13385(j)(1)(D) of the CWC and allows a time period not to exceed 90 days in which the Discharger may adjust and test the treatment system(s). This provision requires the Discharger to submit an Operations Plan describing the actions the Discharger will take during the period of adjusting and testing to prevent violations.
 - d. **Treatment Plant Capacity.** The treatment plant capacity study required by this Order shall serve as an indicator for the Regional Water Board regarding Facility's increasing hydraulic capacity and growth in the service area.
3. **Best Management Practices and Pollution Prevention**
 - a. **Pollutant Minimization Program.** This provision is based on the requirements of section 2.4.5 of the SIP.
 4. **Construction, Operation, and Maintenance Specifications**

This provision is based on the requirements of 40 CFR part 122.41(e) and the previous Order.

5. Special Provisions for Municipal Facilities (POTWs Only)

- a. **Biosolids Requirements.(Not Applicable)** The Burbank WRP returns the sludge generated by the treatment process back to the sewer for transport and treatment at the Hyperion Treatment Plant.
- b. **Pretreatment Requirements.** This permit contains pretreatment requirements consistent with applicable effluent limitations, national standards of performance, and toxic and performance effluent standards established pursuant to sections 208(b), 301, 302, 303(d), 304, 306, 307, 403, 404, 405, and 501 of the CWA, and amendments thereto. This permit contains requirements for the implementation of an effective pretreatment program pursuant to section 307 of the CWA; 40 CFR 35 and 403; and/or section 2233, title 23, California Code of Regulations.
- c. **Spill Reporting Requirements.** This Order established a reporting protocol for how different types of spills, overflow or bypasses of raw or partially treated sewage from its collection system or treatment plant covered by this Order shall be reported to regulatory agencies.

The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order No. 2006-0003-DWQ (General Order) on May 2, 2006. The General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans (SSMPs) and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions.

Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. The Discharger must comply with both the General Order and this Order.

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, Los Angeles Region (Regional Water Board) is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for Burbank Water Reclamation Plant. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

T
E
N
T
A
T
I
V
E

The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided by posting notices at the Burbank WRP.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted to the Executive Office in a Portable Document Format (PDF). Documents that are less than 10 megabytes (MB) should be emailed to losangeles@waterboards.ca.gov. Documents that are 10 MB or larger should be transferred to a disk and mailed to the address listed below:

California Regional Water Quality Control Board
320 West 4th Street, Suite 200
Los Angeles, CA 90013

To be fully responded to by staff and considered by the Regional Water Board, written comments must be received at the Regional Water Board offices by **12:00 p.m. (noon) on January 23, 2012.**

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: March 1, 2012
Time: 9:00 AM
Location: Metropolitan Water District of Southern California, Board Room
700 N. Alameda Street
Los Angeles, California

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/losangeles/> where you can access the current agenda for changes in dates and locations.

D. Nature of Hearing

This proceeding will be a formal adjudicatory proceeding. For such proceedings, the Regional Water Board follows procedures established by the State Water Resources Control Board. These procedures are set forth in regulations commencing with section 647 of title 23 of CCR, in particular, Article 2, commencing with section 648.

**T
E
N
T
A
T
I
V
E**

E. Parties to the Hearing

The following are the parties to this proceeding:

- City of Burbank/permittee

Any other persons requesting party status must submit a written or electronic request to staff not later than 20 business days before the hearing. All parties will be notified if other persons are so designated.

F. Public Comments and Submittal of Evidence

Persons wishing to comment upon or object to the tentative waste discharge requirements, or submit evidence for the Board to consider, are invited to submit them in writing to the above address. To be evaluated and responded to by staff, included in the Board's agenda folder, and fully considered by the Board, written comments regarding the Tentative Order dated December 22, 2011, must be received no later than **12:00 p.m. (noon) on January 23, 2012.**

Comments or evidence received after that date will be submitted, ex agenda, to the Board for consideration, but only included in administrative record with express approval of the Chair during the hearing. Additionally, if the Board receives only supportive comments, the permit may be placed on the Board's consent calendar, and approved without an oral testimony.

G. Hearing Procedure

The Board meeting, of which this hearing is a part, will start at 9:00 a.m. Interested persons are invited to attend. When the agenda item is called, staff will present the matter under consideration, after which oral statements from parties or interested persons will be heard. For accuracy of the record, all important testimony should be in writing. The Board will include in the administrative record written transcriptions of oral testimony that is actually presented at the hearing. Oral testimony may be limited to three minutes or less for each interested person, depending on the number of interested persons wishing to be heard.

Parties or interested persons with similar concerns or opinions are encouraged to choose one representative to speak and are encouraged to coordinate their presentations with each other. Parties will be advised after the receipt of public comments, but prior to the date of the hearing, of the amount of time each is allocated for presentations. That decision will be based upon the complexity and number of issues under consideration, the extent to which the parties have coordinated, the number of parties and interested persons anticipated, and the time available for the hearing. The parties are invited to contact staff not later than February 16, 2012, (two weeks prior to the hearing) to discuss how much time they believe is necessary for their presentations, and staff will endeavor to accommodate reasonable requests. At the conclusion of testimony, the Board will deliberate in open or close session, and render a decision.

T
E
N
T
A
T
I
V
E

The Board does not generally require the prior identification of witnesses, the cross examination of witnesses, or other procedures not specified in this notice. Parties or persons with special procedural requests or requests for alternative hearing procedures should contact staff, who will endeavor to accommodate reasonable requests. Objections to any procedure to be used during this hearing must be submitted in writing no later than close of business 15 business days prior to the date of the hearing. (Any objections related to the amount of time allocated for parties' presentations must be submitted within two business days of notice thereof, if that date is less than 15 business days before the hearing.) Absent such objections, any procedure not specified in this hearing notice will be waived pursuant to section 648(d) of title 23 of the CCR. Procedural objections will not be entertained at the hearing.

If there should not be a quorum on the scheduled date of this meeting, this matter will be automatically continued to the next scheduled meeting in April 2012. A continuance will not extend any time set forth herein.

H. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA95812-0100

I. Information and Copying

The ROWD, related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (213) 576-6600.

J. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

K. Additional Information

Requests for additional information or questions regarding this order should be directed to Veronica Cuevas at (213)576-6662.