

Response to Comments
City of Oxnard
Groundwater, Recharge, Enhancement, and Treatment (GREAT) Program
Tentative Waste Discharge Requirements and Water Reclamation Requirements

This table describes all significant comments received from interested persons regarding the tentative permit described above. Each comment has a corresponding response and action taken.

Comments received from the State Water Resources Control Board, Division of Drinking Water on March 10, 2020

#	Comment	Response	Action Taken
1	<p>Page A-5 of Attachment A - Definitions</p> <p>The Division recommends changing the definition for Running Four-Week Average to the following text:</p> <p>“The arithmetic mean, calculated weekly, of the monitoring results from the previous four consecutive weekly samples results.”</p>	<p>The Regional Water Board agrees. Similar language was also removed from the running annual average definition. No confirmation sample is collected for those pollutants for which a running annual average applies. The text was changed as follows:</p> <p>Running Annual Average</p> <p>The arithmetic mean, calculated quarterly, of the monitoring results from the previous four consecutive quarters. If a confirmation sample is collected due to an exceedance of the initial sample, the arithmetic mean of the initial sample and the confirmation sample shall be used as the monitoring result for the quarter. If no sample was collected during a quarter or a result for a quarter is not available, only available data shall be used in the calculation of the running annual average.</p>	<p>Revisions were made to the permit.</p>

#	Comment	Response	Action Taken
		<p>Running Four-Week Average The arithmetic mean, calculated weekly, of the monitoring results from the previous four <u>consecutive</u> weekly samples <u>results</u>. If a confirmation sample is collected due to an exceedance of the initial sample, the first weekly sample is the arithmetic mean of the initial sample and the confirmation sample.</p>	

Miscellaneous Minor Modifications

1. Page 17, Section E. Added the word “preliminary” to the fourth sentence.
2. Page 24, Table 5. Modified the final effluent limitations for turbidity to be consistent with the footnote and with the turbidity requirements for water used for nonpotable uses.
3. Page 28, Section XI.A. Removed “(b)” from the reference to Title 22 of the California Code of Regulations.