



**PERMIT TO OPERATE**

This initial permit must be renewed ANNUALLY unless the equipment is moved, or changes ownership  
If the billing for the annual renewal fee (Rule 301 f) is not received by the expiration date, contact the District

Legal Owner  
or Operator

P & M OIL CO  
2109 GUNDRY AVE  
SIGNAL HILL, CA 90806

ID 9391

**Equipment Location** 28TH/CALIFORNIA AVE, SIGNAL HILL, CA 90806

**Equipment Description**

EL CAM KIRKPATRICK LEASE CRUDE OIL/WATER/GAS SEPARATION AND TANK TRUCK LOADING SYSTEM CONSISTING OF

- 1 WASH TANK, KP-26, 16' DIA X 16' H , K25, CAPACITY 500 BBL FIXED ROOF, VENTED TO THE GAS SCRUBBER AND INTO SIGNAL HILL'S GAS COLLECTION SYSTEM (COMMON TO ITEMS 3, 4, 5, & 6)
- 2 WASH TANK, KP-25, 16' DIA X 16' H , K26, CAPACITY 500 BBL FIXED ROOF, VENTED TO THE GAS SCRUBBER AND INTO SIGNAL HILL'S GAS COLLECTION SYSTEM (COMMON TO ITEMS 2, 4, 5, & 6)
- 3 SHIPPING TANK, NO 1282, 21' DIA X 16' H , CAPACITY 1,000 BBL, FIXED ROOF, VENTED TO THE GAS SCRUBBER AND INTO SIGNAL HILL'S GAS COLLECTION SYSTEM (COMMON TO ITEMS 2, 3, 5, & 6)
- 4 PRODUCE WATER TANK, 10' - 6" DIA X 16' H , CAPACITY 250 BBL, FIXED ROOF, VENTED TO THE GAS SCRUBBER AND INTO SIGNAL HILL'S GAS COLLECTION SYSTEM (COMMON TO ITEMS 2, 3, 4, & 6)
- 5 RAIN WATER SUMP TANK, 6' L X 6' W X 3' D, COVERED, VENTED TO THE GAS SCRUBBER AND INTO SIGNAL HILL'S GAS COLLECTION SYSTEM (COMMON TO ITEMS 2, 3, 4, & 5)
- 6 WELL GAS SCRUBBER, 14" DIA X 5'H , PRESSURE VESSEL VENTED TO THE SIGNAL HILL'S SUCTION LINE
- 7 TANK TRUCK LOADING STAND PIPE, 3" DIA
- 8 TWO WASTEWATER INLINE PUMPS, EACH WITH A 10 H P MOTOR (ONE STANDBY)

**Conditions**

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW

**FILE COPY**



**PERMIT TO OPERATE**

CONTINUATION OF PERMIT TO OPERATE

- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
- 3 THE OPERATOR SHALL COMPLY WITH RULE 1113 DURING PAINTING OF TANKS
- 4 TANKS' GAUGING AND SAMPLING HATCHES SHALL BE CLOSED AT ALL TIMES EXCEPT DURING GAUGING & SAMPLING OPERATION
- 5 THROUGHPUT RECORDS, AS REQUIRED BY RULES 463 AND 1173, AND PAINTING OPERATION RECORDS SHALL BE MAINTAINED IN A FORMAT APPROVED BY THE EXECUTIVE OFFICER, KEPT ON FILE FOR A MINIMUM OF TWO YEARS, AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
- 6 THE SHIPPING, WASTEWATER, BOTH THE WASH TANKS AND TANK TRUCK LOADING SHALL NOT BE OPERATED UNLESS THEY ARE VENTED ONLY TO THE VAPOR RECOVERY SYSTEM WHICH IS IN OPERATION AT ALL TIMES
- 7 THE OPERATOR SHALL NOT LOAD MORE THAN 20,000 GALLONS IN ANY GIVEN DAY
- 8 THE OPERATOR SHALL NOT HOLD THE CRUDE OIL IN THE SHIPPING TANK FOR MORE THAN 72 HRS

**NOTICE**

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR COPY SHALL BE POSTED ON OR WITHIN 8 METERS OF THE EQUIPMENT

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE AIR QUALITY MANAGEMENT DISTRICT THIS PERMIT CANNOT BE CONSIDERED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUES OF OTHER GOVERNMENT AGENCIES

EXECUTIVE OFFICER

*Dorris M Bailey*

By Dorris M Bailey/HD01  
6/22/2004

**FILE COPY**