

Attachment A to Resolution No. 03-016

Revision of interim effluent limits for ammonia in the Amendment to the Water Quality Control Plan for the Los Angeles Region to include a TMDL for Nitrogen Compounds and Related Effects in the Los Angeles River, Resolution 03-009

Adopted by the California Regional Water Quality Control Board, Los Angeles Region on December 4, 2003.

Amendments

Tables

7-8.1 Los Angeles River Nitrogen Compounds and Related Effects TMDL: Elements

This TMDL was adopted by:

The Regional Water Quality Control Board on December 4, 2003.

This TMDL was approved by:

The State Water Resources Control Board on March 24, 2004.

The Office of Administrative Law on September 27, 2004.

The U.S. Environmental Protection Agency on [Insert Date].

Table 7-8.1. LOS ANGELES RIVER NITROGEN COMPOUNDS AND RELATED EFFECTS TMDL: Elements

| Element | Los Angeles River Nitrogen Compounds and Related Effects TMDL |
|-----------------------|---|
| <i>Implementation</i> | <p>2. The Implementation Plan includes upgrades to the WRPs discharging to Los Angeles River for removal of ammonia, nitrate, and nitrite. At the discretion of the Regional Board, the following interim limits for ammonia, and nitrate plus nitrite will be allowed for major point sources for a period not to exceed 3.5 years from the effective date of this TMDL. Effluent limits for the individual compounds $\text{NO}_3\text{-N}$, and $\text{NO}_2\text{-N}$ are not required during the interim period.</p> <p style="text-align: center;"><u><i>Interim Limits for $\text{NH}_3\text{-N}$ and $\text{NO}_3\text{-N} + \text{NO}_2\text{-N}$</i></u></p> <p style="text-align: center;"><i>Total ammonia as Nitrogen</i> <i>POTW</i> <i>Daily Maximum*</i> <i>Monthly Average*</i></p> <p>Donald C. Tillman WRP 21.7 24.7 mg/L 21.0 20.5 mg/L</p> <p>Los Angeles-Glendale WRP 19.4 24.2 mg/L 16.5 18.8 mg/L</p> <p>Burbank WRP 24.1 mg/L 22.7 mg/L</p> <p>*The monthly average and daily maximum interim limits are based on the 95th and 99th percentiles of effluent performance data reported by dischargers.</p> <p style="text-align: center;"><i>Nitrite-nitrogen + Nitrate-nitrogen</i> <i>Monthly Average</i></p> <p style="text-align: center;">8.0 mg/L</p> |