

Eureka City

Eureka City Elk River WWTP

WDID No. 1B82151OHUM NPDES No. CA0024449

Effluent Limitation Violations Requiring Mandatory Minimum Penalties - January 1-September 30, 2015

#	Violation Number	Violation Date	Constituent	Pollutant Group	Limitation Period	Limit	Result/Average	Units	Exempted from MMP?	Exempt Reason or otherwise not subject to MMPs	% Over Limit	Date 180 Days Prior	Serious or Chronic Violation?	No. of Violations within 180 days (a)	Mandatory Fine?	Water Code	Penalty
1	987005	01/12/2015	Copper, Total	Group II	6-Month Median	33	36	ug/L	N		9%	07/16/2014	Chronic	>Ct.3	Y	13385(i)	\$ 3,000
2	988226	02/09/2015	Copper, Total	Group II	6-Month Median	33	34	ug/L	N		3%	08/13/2014	Chronic	>Ct.3	Y	13385(i)	\$ 3,000
3	989591	03/09/2015	Copper, Total	Group II	6-Month Median	33	34	ug/L	N		3%	09/10/2014	Chronic	>Ct.3	Y	13385(i)	\$ 3,000
4	991143	04/13/2015	Copper, Total	Group II	6-Month Median	33	35	ug/L	N		6%	10/15/2014	Chronic	>Ct.3	Y	13385(i)	\$ 3,000
5	992535	05/11/2015	Copper, Total	Group II	6-Month Median	33	41	ug/L	N		24%	11/12/2014	Serious	>Ct.3	Y	13385(i)	\$ 3,000
6	993669	06/08/2015	Copper, Total	Group II	6-Month Median	33	44	ug/L	N		33%	12/10/2014	Serious	>Ct.3	Y	13385(i)	\$ 3,000
7	994889	07/13/2015	Copper, Total	Group II	6-Month Median	33	38	ug/L	N		15%	01/14/2015	Chronic	>Ct.3	Y	13385(i)	\$ 3,000
8	996034	08/10/2015	Copper, Total	Group II	6-Month Median	33	38	ug/L	N		15%	02/11/2015	Chronic	>Ct.3	Y	13385(i)	\$ 3,000
9	998135	09/07/2015	Copper, Total	Group II	6-Month Median	33	38	ug/L	N		15%	03/11/2015	Chronic	>Ct.3	Y	13385(i)	\$ 3,000
																Total Penalty:	\$ 27,000

Table Legend:

a The first three violations in a six month period shall not receive MMP assessment unless it is serious

Ct. Count - Number of exceedances in the past 180 days, including this violation. A count >Ct.3 means that a penalty under Water Code section 13385 (i) applies.

1 - Violation occurs on sample date or last date of averaging period.

2 - For Group I pollutants, a violation is serious when the limit is exceeded by more than 40%

- For Group II pollutants, a violation is serious when the limit is exceeded by more than 20%

Violation period January 1 through September 30, 2015

Group I Violations Assessed MMP: 0

Group II Violations Assessed MMP: 9

Other Effluent Violations Assessed MMP: 0

Violations Exempt from MMP: 0

Total Violations Assessed MMP: 9

Mandatory Minimum Penalty = (0 Serious Violations + 9 Non-Serious Violations) x \$3,000 = \$27,000