

California Regional Water Quality Control Board
North Coast Region

Monitoring and Reporting Program No. R1-2000-58

For

GARBERVILLE SANITARY DISTRICT

Humboldt County

MONITORING

A staff gauge shall be installed in the final treatment pond and calibrated with respect to overflow elevation from that pond. Pond freeboard (the vertical difference between pond level and overflow level) shall be recorded daily.

Grab samples shall be collected from effluent discharging over the V-notch weir at the end of the chlorine contact chamber and shall be analyzed as follows:

<u>Constituent</u>	<u>Units</u>	<u>Sample Frequency</u>
BOD (20°C, 5-day)	mg/l	monthly
Suspended Solids	mg/l	monthly
Settleable Solids	ml/l	weekly
Coliform Organisms	MPN/100ml	weekly
pH	---	weekly
Daily Flow	gpd	continuous

The discharger shall record facility maintenance activities (such as weed removal and primary pond cleaning) and the results of weekly observations which describe the percolation beds and document the appearance, if any, of surface runoff, ponded areas, or unusual conditions.

Reporting

Monitoring reports shall be submitted to the Regional Water Board each month on a form similar to the attached example. Monitoring reports are due in the Regional Water Board office by the 15th day of the following month. The monitoring and any necessary narrative reports shall be properly titled, with a reference to this Order and signed by the responsible official or other authorized representative of the discharger.

Ordered by _____

Lee A. Michlin
Executive Officer

August 25, 2000