
North Coast Regional Water Quality Control Board

Notice of Proposed No Further Action

For

Eel River Fuels Point Arena
43451 Eureka Hill Road
Point Arena, California

Case Number 1NMC633

Mendocino County

Notice Posting Date: June 10, 2026

End of Comment Period: August 10, 2026

A spill of red-dyed diesel to soil and groundwater was investigated and remediated at the above-referenced site. Although some contamination remains, this site meets the conditions for closure under the State Water Resources Control Board's "Low-Threat Underground Storage Tank Case Closure Policy." Regional Water Board staff proposes that no further work be required. The purpose of this notice is to inform interested parties, including owners of nearby land, that the case is being considered for closure, and to invite public comment on this proposed decision.

Problem Description

An aboveground storage tank fuel system leaked red-dyed diesel to soil and groundwater at this site in 2015. Impacted soil was excavated and treated onsite, and free product and impacted groundwater was pumped and removed. Groundwater monitoring has shown minor contamination in the immediate vicinity of the site, but the contamination is not spreading. No water supply wells or surface water bodies were impacted by this contamination.

Proposed Action

Case closure is proposed. Although the spill was from an aboveground storage tank, the contamination characteristics are similar enough to use the State Water Resources Control Board's "[Low-Threat Underground Storage Tank Case Closure Policy](https://www.waterboards.ca.gov/water_issues/programs/ust/lt_cls_plcy.html)" (available on the internet at https://www.waterboards.ca.gov/water_issues/programs/ust/lt_cls_plcy.html). This site meets the conditions for closure under the Policy.

Unless significant comments are received or new information is presented regarding this site, Regional Water Board staff plans to proceed with the closure process upon conclusion of the comment period. Please contact Craig Hunt at (707) 576-2469 or craig.hunt@waterboards.ca.gov with any questions or comments. Written comments may also be submitted to:

North Coast Regional Water Quality Control Board
Attention: Craig Hunt
5550 Skylane Blvd, Suite A
Santa Rosa, CA 95403

All records for this case are available electronically on the [State Water Resources Control Board's GeoTracker website](#) at http://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T10000006526.