

1 CITY OF LIVE OAK
BRANT BORDSEN, ESQ. (SBN 101590)
2 City Attorney
Rich, Fuidge, Morris & Iverson
3 1129 D Street
P.O. Box "A"
4 Marysville, CA 95901
Telephone: (530) 742-7371
5 Facsimile: (530) 742-5982

6 SOMACH SIMMONS & DUNN
A Professional Corporation
7 THERESA A. DUNHAM, ESQ. (SBN 187644)
ROBERTA L. LARSON, ESQ. (SBN 191705)
8 500 Capitol Mall, Suite 1000
Sacramento, CA 95814
9 Telephone: (916) 446-7979
Facsimile: (916) 446-8199

10 Attorneys for Petitioner CITY OF LIVE OAK
11



12
13 BEFORE THE
14 CALIFORNIA STATE WATER RESOURCES CONTROL BOARD
15

16 In the Matter of the Petition of City of Live Oak
for Review of Action and Failure to Act by
17 Central Valley Regional Water Quality Control
Board.
18

SWRCB/OCC File No. _____

CITY OF LIVE OAK'S PETITION FOR
REVIEW AND STATEMENT OF POINTS
AND AUTHORITIES IN SUPPORT
THEREOF
[Wat. Code, § 13320]

19
20
21 The City of Live Oak (Live Oak or Petitioner) submits this Petition for Review and
22 Statement of Points and Authorities (Petition) to the State Water Resources Control Board (State
23 Water Board) in accordance with Water Code section 13320. Live Oak respectfully requests that
24 the State Water Board review the Central Valley Regional Water Quality Control Board's
25 (Regional Water Board) actions and inactions related to its adoption of Order No. R5-2011-0034,
26 NPDES¹ No. CA0079022 *Waste Discharge Requirements for City of Live Oak Wastewater*
27

28 ¹ National Pollutant Discharge Elimination System.

1 *Treatment Plant* (Permit) and associated provisions in Order No. R5-2011-0035 Amending Cease
2 and Desist Order No. R5-2009-0012-01 (CDO). Live Oak challenges the Permit's designation of
3 municipal and domestic supply (MUN) beneficial use to Reclamation District 777's constructed
4 Lateral Drain Nos. 1 and 2, and the adoption of effluent limitations, receiving water limitations,
5 and compliance schedule provisions based on the MUN beneficial use.

6 This Petition satisfies the requirements of title 23, section 2050 of the California Code of
7 Regulations. Live Oak requests the opportunity to file supplemental points and authorities in
8 support of this Petition once the administrative record becomes available. Live Oak also reserves
9 the right to submit additional argument and evidence in reply to the Regional Water Board or
10 other interested parties' responses to this Petition filed in accordance with title 23,
11 section 2050.5(a) of the California Code of Regulations.

12 **1. NAME, ADDRESS, TELEPHONE NUMBER, AND EMAIL ADDRESS OF THE**
13 **PETITIONER**

14 The Petitioner is the City of Live Oak, California, which operates and maintains the City
15 of Live Oak Wastewater Treatment Plant (Live Oak WWTP or WWTP). Petitioner's address is
16 as follows:

17 City of Live Oak
18 Attn: William P. Lewis
19 Public Works Director
20 9955 Live Oak Boulevard
21 Live Oak, CA 95953
22 Phone: (530) 695-2112
23 Email: blewis@liveoakcity.org

24 Brant Bordsen, City Attorney
25 Rich, Fuidge, Morris & Iverson
26 1129 D Street
27 P.O. Box "A"
28 Marysville, CA 95901
Phone: (530) 742-7371
Email: bbordsen@yubasutterlaw.com

1 In addition, Live Oak requests that all materials in connection with the Petition and
2 administrative record be provided to Live Oak's special counsel:

3 Theresa A. Dunham, Esquire
4 Roberta A. Larson, Esquire
5 Somach Simmons & Dunn
6 500 Capitol Mall, Suite 1000
7 Sacramento, CA 95814
8 Phone: (916) 446-7979
9 Email: tdunham@somachlaw.com
10 blarson@somachlaw.com

11 **2. THE SPECIFIC ACTION OR INACTION OF THE REGIONAL WATER BOARD
12 WHICH THE PETITIONER REQUESTS THE STATE WATER BOARD TO
13 REVIEW**

14 Live Oak petitions the State Water Board to review the Regional Water Board's adoption
15 of the Permit and CDO, and other action or inaction related thereto, as more fully described
16 herein. Live Oak is also requesting a stay of certain provisions of Order Nos. R5-2011-0034 and
17 R5-2011-0035 in their entirety. (See City of Live Oak's Request for Stay and Memorandum of
18 Points and Authorities in Support Thereof, filed concurrently herewith.) A copy of the Permit
19 (Order No. R5-2011-0034) is attached hereto as Exhibit A. A copy of the CDO (Order
20 No. R5-2011-0035) is attached hereto as Exhibit B.

21 The specific determinations, designations, and requirements of the Permit and CDO that
22 Live Oak requests the State Water Board to review are:

23 a. The determination or finding that the MUN beneficial use applies to Reclamation
24 District 777's constructed Lateral Drain Nos. 1 and 2 through the State Water Board's "Sources
25 of Drinking Water" Policy, Resolution No. 88-63 (Resolution 88-63), as incorporated into the
26 Water Quality Control Plan for the Sacramento and San Joaquin River Basins (Basin Plan);

27 b. The adoption of water quality-based effluent limitations for nitrate (as N), arsenic,
28 iron, manganese, total trihalomethanes, dibromochloromethane, dichlorobromomethane, and the
annual average water quality-based effluent limitation for aluminum based on the improper
determination or finding that MUN is a beneficial use in Reclamation District 777's constructed
Lateral Drain Nos. 1 and 2 under the Basin Plan;

1 c. The adoption of receiving water limitations prohibiting the discharge from causing
2 pesticides to be present in concentrations that exceed maximum contaminant levels (MCLs) set
3 forth in the California Code of Regulations, title 22, division 54, chapter 15, thiobencarb to be
4 present in excess of 1.0 µg/L, and radionuclides to be present in excess of the maximum
5 contaminant levels specified in Table 64443 (MCL Radioactivity) of section 64443 of title 22 of
6 the California Code of Regulations in surface water based on the improper determination that
7 MUN is a beneficial use in Reclamation District 777's constructed Lateral Drain Nos. 1 and 2
8 under the Basin Plan;

9 d. The adoption of interim effluent limitations and compliance schedule provisions
10 for arsenic and total trihalomethanes, which would not be required but for the improper
11 determination of finding that MUN is a beneficial use in Reclamation District 777's constructed
12 Lateral Drain Nos. 1 and 2 under the Basin Plan; and,

13 e. The adoption of amendments to the CDO to meet the final water quality-based
14 effluent limitations for nitrate (as N), iron, manganese, dibromochloromethane, and
15 dichlorobromomethane, which would not be required but for the improper determination of
16 finding that MUN is a beneficial use in Reclamation District 777's constructed Lateral Drain
17 Nos. 1 and 2 under the Basin Plan.

18 **3. THE DATE ON WHICH THE REGIONAL WATER BOARD ACTED OR**
19 **REFUSED TO ACT**

20 The Regional Water Board adopted Order No. R5-2011-0034, and Order
21 No. R5-2011-0035 on June 10, 2011. Unless otherwise provided, Live Oak contends that all
22 actions or inactions of the Regional Water Board challenged herein are not supported by adequate
23 findings or evidence in the record and/or are inconsistent with applicable law.

24 **4. A STATEMENT OF THE REASONS THE ACTION OR FAILURE TO ACT IS**
25 **INAPPROPRIATE OR IMPROPER**

26 As explained in more detail in the statement of points and authorities, the Permit applies
27 the MUN beneficial use designation to Reclamation District 777's constructed Lateral Drain
28 Nos. 1 and 2 (Lateral Drain Nos. 1 and 2) on the premise that they were so designated by the

1 Regional Water Board's incorporation of Resolution 88-63 into the Basin Plan. (See Permit,
2 pp. 6, F-16.) However, the State Water Board's policy includes a specific exception for systems
3 designed or modified for the primary purpose of conveying or holding agricultural drainage
4 waters. The Regional Water Board adopted the Permit with MUN being applied to Lateral Drain
5 Nos. 1 and 2 based on the erroneous finding that a Basin Plan amendment is required to apply the
6 exception contained in Resolution 88-63. Live Oak disagrees with the application of MUN to
7 Lateral Drain Nos. 1 and 2.

8 Application of the MUN beneficial use to Lateral Drain Nos. 1 and 2 is inappropriate for
9 the following reasons: (a) the State Water Board's adoption of Resolution 88-63 was invalidated
10 by the Office of Administrative Law (OAL) and is without legal effect; (b) the Regional Water
11 Board's incorporation of the invalidated policy is itself invalid because by its terms
12 Resolution 88-63, and the Regional Water Board's incorporation thereof, does not designate the
13 MUN use for agricultural drains; (c) in the alternative, if the Regional Water Board's
14 incorporation by reference is found to include the exceptions and the types of water bodies for
15 which the exceptions would apply, then the Regional Water Board's incorporation of
16 Resolution 88-63 must have included the exceptions as self-executing provisions; (d) the
17 implementation language in the Basin Plan contradicts the state's policy and is invalid; and
18 (e) alternatively, if a Basin Plan amendment is required, the Regional Water Board should refrain
19 from adopting MUN-based effluent limitations, receiving water limitations, and compliance
20 schedule provisions until a Basin Plan amendment is considered.

21 **5. THE MANNER IN WHICH THE PETITIONER IS AGGRIEVED**

22 The Permit provisions challenged place Live Oak in the untenable position of spending
23 significant public resources to comply with effluent limitations, receiving water limitations, and
24 compliance schedule provisions based on the attributed MUN beneficial use for Lateral Drain
25 Nos. 1 and 2 that are neither necessary, reasonable, nor supported by the evidence. The
26 provisions are more stringent and onerous than required by or provided for under current law.
27 The Regional Water Board's application of Resolution 88-63 to Lateral Drain Nos. 1 and 2 is
28 inconsistent with the express language of Resolution 88-63, which specifically directed the

1 regional water quality control boards to except surface water where “[t]he water is in systems
2 designed or modified for the primary purpose of conveying or holding agricultural drainage
3 waters, provided that discharge from such systems is monitored to assure compliance with all
4 relevant water quality objectives as required by the Regional Boards.” (Resolution 88-63,
5 pp. 1-2, at ¶ 2(b).) The Regional Water Board wrongly determined that such constructed drains
6 are designated as MUN, despite the plain language exception of Resolution 88-63 and the express
7 direction of the State Water Board’s Office of Chief Counsel. (See Memorandum to Dennis
8 Westcot from Elizabeth Miller Jennings (Mar. 3, 1994), pp. 2-3 [“The designation of beneficial
9 uses in constructed agricultural drains is not covered by either the tributary footnote or the
10 Sources of Drinking Water Policy.”].)

11 Petitioner estimates the cost to Live Oak’s ratepayers to correct the Regional Water
12 Board’s mistake in its application of Resolution 88-63 will be over \$4 million, on top of the
13 \$20 million already spent to comply with Order No. R5-2004-0096, Live Oak’s previous NPDES
14 permit. The Regional Water Board cannot justify the enormous burden that this approach would
15 place on Live Oak and its ratepayers in light of the nature of the facilities in question and the fact
16 that the State Water Board (as evinced by the plain language in Resolution 88-63) never intended
17 for such constructed facilities to be regulated as a drinking water source.

18 The Regional Water Board’s action is inconsistent with State Water Board’s express
19 policies and directives. Live Oak is aggrieved in having to spend additional increasingly scarce
20 public resources to comply with Permit requirements that are arbitrary, unnecessary, and not
21 required by law.

22 **6. THE SPECIFIC ACTION REQUESTED BY THE PETITIONER**

23 Based on the foregoing, Live Oak requests that the State Water Board modify, or order the
24 Regional Water Board to modify, Order Nos. R5-2011-0034 and R5-2011-0035 with direction for
25 revisions, as follows:

- 26 a. Delete the determination or findings that the MUN beneficial use applies to
27 Reclamation District 777’s constructed Lateral Drain Nos. 1 and 2, pursuant to the Basin Plan, as
28 set forth in Finding II.H;

1 b. Delete the water quality-based effluent limitations for nitrate (as N), arsenic, iron,
2 manganese, total trihalomethanes, dibromochloromethane, dichlorobromomethane, and annual
3 average limitation for aluminum, which are based on the finding that MUN is a beneficial use in
4 Reclamation District 777's constructed Lateral Drain Nos. 1 and 2 under the Basin Plan, which
5 are found in Effluent Limitations and Discharge Specifications IV.A.1;

6 c. Delete the following receiving water limitations for surface water prohibiting the
7 discharge from causing: pesticides to be present in concentrations that exceed MCLs set forth in
8 the California Code of Regulations, title 22, division 54, chapter 15; thiobencarb to be present in
9 excess of 1.0 µg/L; and, radionuclides to be present in excess of the MCLs specified in
10 Table 64443 (MCL Radioactivity) of section 64443 of title 22 of the California Code of
11 Regulations, which are based on the determination or finding that MUN is a beneficial use in
12 Reclamation District 777's constructed Lateral Drain Nos. 1 and 2 under the Basin Plan, which
13 are found in Receiving Water Limitations V.A.9.f, V.A.9.g, and V.A.10.b;

14 d. Delete the interim effluent limitations for arsenic and total trihalomethanes which
15 would not be required but for the inclusion of water quality-based effluent limitations based on
16 the finding that MUN is a beneficial use in Reclamation District 777's constructed Lateral Drain
17 Nos. 1 and 2 under the Basin Plan, which are found in Effluent Limitations and Discharge
18 Specifications IV.A.2;

19 e. Delete the compliance schedule provisions for final effluent limitations for arsenic
20 and total trihalomethanes which would not be required but for the inclusion of water quality-
21 based effluent limitations based on the finding that MUN is a beneficial use in Reclamation
22 District 777's constructed Lateral Drain Nos. 1 and 2 under the Basin Plan, which are found in
23 Provisions VI.C.7;

24 f. Delete the time schedule provisions in Order No. R5-2011-0035 for nitrate (as N),
25 iron, manganese, dibromochloromethane, and dichlorobromomethane, which require Live Oak to
26 meet the water quality-based effluent limitations for nitrate (as N), iron, and manganese by
27 June 10, 2016, and water quality-based effluent limitations for dibromochloromethane and
28 dichlorobromomethane by June 10, 2014; and

1 g. Make any necessary revisions consistent with the above terms and provisions of
2 this Petition.

3 **7. A STATEMENT OF POINTS AND AUTHORITIES IN SUPPORT OF LEGAL**
4 **ISSUES RAISED IN THIS PETITION**

5 As required by title 23, section 2050(a)(7) of the California Code of Regulations, Live
6 Oak includes a statement of points and authorities in support of this Petition beginning on page 9.

7 **8. A STATEMENT THAT THIS PETITION WAS SENT TO THE REGIONAL**
8 **WATER BOARD**

9 In accordance with title 23, section 2050(a)(8) of the California Code of Regulations, Live
10 Oak mailed true and correct copies of this Petition by First Class mail on July 11, 2011, to the
11 Regional Water Board. The address to which Live Oak mailed the copies to the Regional Water
12 Board is:


13 Pamela Creedon, Executive Officer
14 Central Valley Regional Water Quality Control Board
15 11020 Sun Center Drive, Suite 200
16 Rancho Cordova, CA 95670-6114

17 Petitioner is the discharger. Therefore, Live Oak did not mail a separate copy of this
18 Petition to the discharger.

19 **9. A STATEMENT AS TO WHETHER THE PETITIONER RAISED THE**
20 **SUBSTANTIVE ISSUES OR OBJECTIONS IN THE PETITION TO THE**
21 **REGIONAL WATER BOARD**

22 Live Oak timely raised the substantive issues and objections in this Petition before the
23 Regional Water Board in written comments dated August 26, 2010, and in testimony provided at
24 the February 3, 2011, and June 10, 2011, public hearings.

25 DATED: July 11, 2011

26 SOMACH SIMMONS & DUNN
27 A Professional Corporation
28 By: 
Theresa A. Dunham
Attorneys for Petitioner City of Live Oak

1 result of an "insane law."⁴ The Permit was adopted only after a second hearing on a rare
2 3-2 vote.⁵

3 Live Oak must commence immediately the expenditure of scarce resources to ensure
4 compliance with stringent effluent limitations even though Reclamation District 777's constructed
5 Lateral Drain Nos. 1 and 2 (Lateral Drain Nos. 1 and 2) have never been, and are unlikely to ever
6 be, used as source of drinking water. Further, the closest downstream water body that is actually
7 identified in the Basin Plan, and therefore specifically assigned beneficial uses, is the Sutter
8 Bypass. MUN is *not* an existing or potential beneficial use for the Sutter Bypass. (Basin Plan,
9 Table II-1.) Considering the facts (i.e., discharge to a constructed agricultural drain that is
10 upstream of a non-MUN water body), it is unreasonable to require the small, economically
11 disadvantaged community of Live Oak to treat its effluent to a level to protect the alleged MUN
12 beneficial use. As the state agency tasked to ensure the *reasonable* regulation of the state's water
13 quality given all the demands made upon the waters, it is imperative that the State Water Board
14 decide the issues in Live Oak's Petition.

15 More specifically, the Petition challenges whether the Regional Water Board acted
16 appropriately and reasonably when it adopted certain Permit provisions based on MUN for
17 Lateral Drain Nos. 1 and 2. Live Oak petitions the State Water Board to review the Regional
18 Water Board's application of MUN to the constructed agricultural drains, and the resulting
19 effluent limitations, receiving water limitations, and other Permit provisions resulting from the
20 application of MUN to Reclamation District 777's constructed Lateral Drain Nos. 1 and 2. These
21 Permit provisions dictate that Live Oak use its increasingly scarce public resources to comply
22 with potentially unnecessary requirements that are also unreasonable and not supported by the
23 evidence.

24 Accordingly, Live Oak respectfully requests that the State Water Board revise the permit
25 to delete the application of MUN to Reclamation District 777's constructed Lateral Drain Nos. 1

26 _____
27 ⁴ February Transcript, p. 75:21-22.

28 ⁵ Hearing Transcript for Meeting of the Central Valley Regional Water Quality Control Board (June 10, 2011)
(June Transcript), p. 144:3-12.

1 and 2, and delete all other Permit requirements associated with and/or necessitated by the
2 application of MUN to Reclamation District 777's constructed Lateral Drain Nos. 1 and 2. This
3 would render certain provisions of the CDO unnecessary, so Live Oak further requests that the
4 State Water Board revise the CDO accordingly. In the alternative, Live Oak respectfully requests
5 a remand of the Permit and CDO to the Regional Water Board for revisions as directed by the
6 State Water Board.

7 **II. FACTUAL BACKGROUND**

8 Live Oak owns and operates the Live Oak WWTP. The WWTP serves a total population
9 of approximately 8500 people in the Live Oak community. The WWTP currently produces
10 equivalent to secondary treated municipal effluent. The average dry weather flow capacity of the
11 facility is 1.4 million gallons per day (MGD). Wastewater is discharged from the Live Oak
12 facility at Discharge Point No. 001 to Reclamation District 777's constructed Lateral Drain No. 1
13 (a constructed agricultural drain), the use designation of which is at issue in this Petition. Lateral
14 Drain No. 1 flows to the East Interceptor Canal, then to Wadsworth Canal, and finally to Sutter
15 Bypass.

16 The Live Oak WWTP previously operated under Order No. R5-2004-0096 issued by the
17 Regional Water Board in 2004. (Order No. R5-2004-0096, NPDES No. CA0079022 *Waste*
18 *Discharge Requirements for City of Live Oak Wastewater Treatment Plant* (2004 Permit).) To
19 comply with the 2004 Permit, Live Oak is in the process of building major tertiary treatment plant
20 upgrades that include a lined equalization basin, an unlined emergency storage basin, and a
21 stormwater detention basin. Furthermore, the upgrade also includes nitrification and an odor
22 control system, secondary feed pump station, selector basin, two oxidation ditches, two secondary
23 clarifiers, cloth media filters, and an ultraviolet disinfection system. As part of the upgrade, the
24 discharge is being relocated to Reclamation District 777's constructed Lateral Drain No. 2, just
25 upstream of where Lateral Drain No. 2 joins Lateral Drain No. 1. Like with Lateral Drain No. 1,
26 Lateral Drain No. 2 is a constructed agricultural drain. The cost for the upgrade to comply with
27 the 2004 Permit is over \$20 million.

28

1 As the Mayor testified, Live Oak meets the definition of a distressed community.
2 (February Transcript, testimony of Mayor Baland, p. 27:20-21.) The unemployment rate is over
3 36%, and the median household income (MHI) is only \$31,663. (*Id.*, testimony of Mayor Baland,
4 pp. 27:24-28:4.) To comply with the water quality-based effluent limitations (WQBELs) for
5 nitrate (as N) included in Order No. R5-2011-0034, household sewer rates in Live Oak will be
6 over \$80 per month, which would exceed U.S. EPA's recommended guideline that sewer rates
7 not exceed two percent of the MHI. (*Id.*, testimony of William Lewis, p. 34:5-21.)

8 The Permit classifies Lateral Drain Nos. 1 and 2 for MUN beneficial use. (Permit,
9 pp. 6, F-16.) The Permit indicates that the Basin Plan does not specifically identify beneficial
10 uses for Lateral Drain Nos. 1 and 2. (*Id.*, p. 5.) Additionally, it states that the Basin Plan does not
11 designate the Sutter Bypass, downstream of Lateral Drain Nos. 1 and 2 for MUN use. (*Ibid.*)
12 The Permit applies Resolution 88-63, which established a state water policy that all waters, with
13 exceptions, must be considered suitable or potentially suitable for municipal and domestic use.
14 (*Ibid.*) According to the Permit, the Regional Water Board believes that it must adopt a Basin
15 Plan amendment, a resource-intensive process, to allow an exception to Resolution 88-63. (*Ibid.*)

16 III. ARGUMENT

17 A. Application of MUN Beneficial Use to Reclamation District 777's Constructed 18 Lateral Drain No. 1 Is Inappropriate

19 The Permit applies the MUN beneficial use designation to Reclamation District 777's
20 constructed Lateral Drain Nos. 1 and 2 based on the Regional Water Board's incorporation of
21 State Water Board Resolution 88-63 in the Basin Plan. Although the State Water Board's policy
22 includes a specific exception for systems designed or modified for the primary purpose of
23 conveying or holding agricultural drainage waters, the Regional Water Board contends that a
24 Basin Plan amendment is necessary to apply the exception contained in Resolution 88-63. The
25 application of Resolution 88-63 to Lateral Drain Nos. 1 and 2 and the conclusion in the Permit
26 that a Basin Plan amendment is required is arbitrary, unnecessary, and not required by law.
27
28

1 **1. The State Water Board's Adoption of Resolution 88-63 Was Invalidated by**
2 **the OAL and Therefore the Resolution Has No Legal Effect**

3 The State Water Board's adoption of Resolution 88-63 was invalidated by the OAL. The
4 Regional Water Board's subsequent incorporation of the invalidated policy is therefore also
5 invalid. In 1986, California voters passed Proposition 65, the Safe Drinking Water and Toxic
6 Enforcement Act of 1986. (Health & Saf. Code, § 25249.5 et seq.; Cal. Code Regs., tit. 27,
7 § 27001 et seq.) Among other things, Proposition 65 prohibits business activities releasing
8 certain chemicals that pass into a source of drinking water. (Health & Saf. Code, § 25249.5.)
9 Proposition 65 defines "source of drinking water" as "either a present source of drinking water or
10 water which is identified or designated in a water quality control plan adopted by a regional board
11 as being suitable for domestic or municipal uses." (*Id.*, § 25249.11(d).) The State Water Board
12 passed Resolution 88-63 in an effort to clarify Proposition 65's reference to "sources of drinking
13 water" for purposes of enforcement of that statute. Resolution 88-63 provides that, with the
14 exception of certain specified waters such as agricultural conveyance facilities, all surface and
15 ground waters of the state are considered to be suitable, or potentially suitable, for municipal or
16 domestic water supply.

17 Resolution 88-63, however, ran afoul of the California Administrative Procedure Act
18 (APA). (Gov. Code, §§ 11346-11346.8.) OAL Determination No. 8 held that Resolution 88-63
19 was a "regulation" subject to the APA, and its adoption violated Government Code
20 section 11347.5 (now § 11340.5) because the State Water Board failed to adopt this rule in
21 compliance with the APA.⁶ (OAL Determination No. 8 (May 17, 1989), California Regulatory
22 Notice Register, Register 89, No. 22-Z, pp. 1586, 1603.) Thus, Resolution 88-63 was invalid and
23 could not lawfully be applied by any agency. Nonetheless, the Regional Water Board

24
25 ⁶ Agency regulations must be submitted to the OAL. (Gov. Code, § 11349.1(a).) If the OAL disapproves the
26 regulation, it is sent back to the adopting agency. (*Id.*, § 11349.3(b).) It is unlawful for an agency to apply a
27 regulation that has not been approved by the OAL: "No state agency shall issue, utilize, enforce, or attempt to
28 enforce any guideline, criterion, bulletin, manual, instruction, order, standard of general application, or other rule,
which is a regulation as defined in Section 11342.600, unless the guideline, criterion, bulletin, manual, instruction,
order, standard of general application, or other rule has been adopted as a regulation and filed with the Secretary of
State pursuant to this chapter." (*Id.*, § 11340.5(a).)

1 incorporated that Resolution into the Basin Plan and the State Water Board approved that Basin
2 Plan amendment. Now, for the first time ever, the Regional Water Board has applied its
3 interpretation of Resolution 88-63 in Live Oak's Permit, finding MUN to be a regulatory
4 beneficial use of Lateral Drain Nos. 1 and 2, and imposing MUN-based effluent limits.

5 This was improper. It is unlawful for the Regional Water Board to use Resolution 88-63
6 in any fashion, and any MUN use based upon this designation pursuant to Resolution 88-63 is
7 legally infirm and invalid. (Gov. Code, § 11340.5(a).)

8 In other proceedings, the Regional Water Board has asserted it may use this unlawful
9 regulation by claiming Resolution 88-63 was exempted from the APA. The law provides that
10 basin plans or amendments enacted after June 1, 1992, must comply with the APA, but that then-
11 existing and uncontested plans were exempt from the APA. (Gov. Code, § 11353.) Of course,
12 OAL Determination No. 8 was issued on May 17, 1989, long before the 1992 APA amendments.
13 By 1992, the OAL had already held that Resolution 88-63 was invalid.

14 Thus, the Regional Water Board's incorporation of Resolution 88-63 cannot lawfully be
15 held to have designated the MUN beneficial use in otherwise undesignated constructed
16 agricultural drains like Lateral Drain Nos. 1 and 2. Because the Regional Water Board is relying
17 upon an invalidated regulation as the basis for its MUN designation of Lateral Drain Nos. 1 and 2,
18 any MUN use designated pursuant to Resolution 88-63 is similarly invalid.

19 **2. Agricultural Drains Are Not Designated by Resolution 88-63 or the Regional**
20 **Water Board's Incorporation Thereof**

21 Even assuming Resolution 88-63 were valid, constructed agricultural drains are not
22 designated by the policy. The language of Resolution 88-63 clearly states that regional boards
23 should designate:

24 All surface and ground waters of the State [] considered to be suitable, . . . for
25 municipal or domestic water supply . . . with the exception of: . . . 2. Surface
26 waters where: . . . b. [t]he water is in systems designed or modified for the primary
27 purpose of conveying or holding agricultural drainage waters, provided that the
28 discharge from such systems is monitored to assure compliance with all relevant
water quality objectives as required by the Regional Boards. (Resolution 88-63,
pp. 1-2.)

1 In other words, the State Water Board specifically directed the regional boards to
2 designate waters MUN, except for those waters of the state that fell within the exceptions of the
3 policy.

4 In a memorandum to Regional Water Board staff in 1994, Senior Staff Counsel from the
5 State Water Board advised Regional Water Board staff that constructed agricultural drains, "and
6 certain other collection and treatment systems which are described in the Policy," are excepted
7 from the MUN designation via Resolution 88-63, as incorporated into the Basin Plan.

8 (Memorandum to Dennis Westcot from Elizabeth Miller Jennings, p. 2.) The memorandum
9 specifically states, "[t]he designation of beneficial uses in constructed agricultural drains is not
10 covered by either the tributary footnote or the Sources of Drinking Water Policy." (*Id.*, p. 3.)

11 During the hearing, the Executive Officer stated that the Regional Water Board should have made
12 the changes, but for some reason did not. Now Live Oak is responsible to follow-up on their
13 inaction.

14 The State Water Board's Order WQO 2002-0015, "In the Matter of Review on Own
15 Motion . . . for Vacaville's Easterly Wastewater Treatment Plant" (Oct. 3, 2002) (Vacaville
16 Order), does not contradict the conclusions expressed by its counsel in the 1994 memorandum. In
17 the Vacaville Order, the State Water Board found Old Alamo Creek to be designated as MUN
18 through Resolution 88-63; however, it also found that the exception categories did not apply to
19 Old Alamo Creek. (Vacaville Order, p. 28.) Specifically, Old Alamo Creek was not designed or
20 modified to be an agricultural drain. (*Ibid.*) Thus, the State Water Board's Vacaville Order does
21 not opine on the issue now presented: whether the Basin Plan designates MUN for constructed
22 agricultural drains that do fit within the exception language of Resolution 88-63.

23 If the Regional Water Board was merely incorporating Resolution 88-63 into the Basin
24 Plan, the incorporation could not have altered or amended its terms. Because the language of
25 Resolution 88-63 provides specific exclusions for constructed agricultural drains, the Regional
26 Water Board's incorporation by reference thereof could not have designated such drains as MUN
27 because they were not in the class of water bodies to be considered for designation.
28

1 **3. Reclamation District 777's Constructed Lateral Drain Nos. 1 and 2 Are**
2 **Constructed Agricultural Drains That Fall Within the Exception in**
3 **Resolution 88-63**

4 As indicated, Resolution 88-63 includes an exception for surface waters where "the water
5 is in systems designed or modified for the primary purpose of conveying or holding agricultural
6 drainage waters, provided that the discharge from such systems is monitored to assure compliance
7 with all relevant water quality objectives as required by the Regional Boards."

8 (Resolution 88-63, pp. 1-2, at ¶ 2(b).) In this case, Reclamation District 777's constructed Lateral
9 Drain Nos. 1 and 2 were specifically designed for the primary purpose of conveying agricultural
10 drainage water. Historical documents indicate that both Lateral Drain Nos. 1 and 2 were
11 constructed prior to 1917. (See Letter to Mr. William Lewis, Public Works Director, from
12 Mr. Jeff Spence, Reclamation District 777 Engineer (Aug. 26, 2010) (Spence Letter).) Moreover,
13 there are no surface water streams, creeks, sloughs or other natural waterways that discharge into
14 Lateral Drain Nos. 1 and 2, and although Lateral Drain No. 1 crosses agricultural water supply
15 channels, water from Lateral Drain No. 1 cannot enter the agricultural water supply channels.
16 (*Ibid.*) Accordingly, the evidence in the record supports the contention that Reclamation
17 District 777's constructed Lateral Drain Nos. 1 and 2 are systems designed for the primary
18 purpose of conveying agricultural drainage water.

19 With respect to the issue of assuring that such systems are monitored to assure compliance
20 with all relevant water quality objectives, monitoring of the effluent in Live Oak provides the
21 necessary assurance. First, there is little to no flow in Reclamation District 777's constructed
22 Lateral Drain Nos. 1 and 2, except for Live Oak's effluent. (February Transcript, testimony of
23 William Lewis, pp. 36:6-25, 37:6-12.) Second, once the tertiary treatment upgrade is completed,
24 Live Oak's effluent will be of sufficient quality to comply with effluent limitations set to protect
25 all other applicable beneficial uses, which equates to complying with relevant water quality
26 objectives. Further, Live Oak's Permit requires it to monitor effluent quality as well as
27 downstream receiving water. (Permit, pp. E-4 - E-6, E-10 - E-11.)

28 Thus, Reclamation District 777's constructed Lateral Drain Nos. 1 and 2 fall squarely
within the "constructed agricultural drain" exception contained in Resolution 88-63.

1 Accordingly, the Regional Water Board's incorporation by reference of Resolution 88-63 did not
2 designate MUN to Lateral Drain Nos. 1 and 2 because they were not in the class of water bodies
3 to be considered for designation.

4 **4. If the Regional Water Board's Incorporation of Resolution 88-63 Includes the**
5 **Exceptions, the Exceptions are Self-Executing**

6 In the alternative, if the Regional Water Board's incorporation by reference is found to
7 include the exceptions and the types of water bodies for which the exceptions would apply, then
8 the incorporation must have included the exceptions as self-executing provisions. No Basin Plan
9 amendment is required to apply the exceptions. The Basin Plan specifically states:

10 Water Bodies within the basins that do not have beneficial uses designated in [the
11 Basin Plan] are assigned MUN designations in accordance with the provisions of
12 State Water Board Resolution No. 88-63 which is, by reference, a part of this
13 Basin Plan. . . . These MUN designations in no way affect the presence or absence
14 of other beneficial use designations in these water bodies. (Basin Plan, p. II-2.01.)

15 The Basin Plan further states, "[i]n making any exemptions to the beneficial use
16 designation of MUN, the Regional Board *will* apply the exceptions listed in Resolution 88-62[]." (Basin Plan, p. II-2.00, emphasis added.)

17 In the Vacaville Order, the State Water Board concluded that the Regional Water Board's
18 incorporation of Resolution 88-63, and in particular the "in accordance" language, meant that, in
19 the Basin Plan, the Regional Water Board actually assigned the MUN beneficial use to all
20 unidentified water bodies. (Vacaville Order, p. 27.) As discussed previously, the Vacaville Order
21 does not specifically state that the Regional Water Board's blanket designation included water
22 bodies that fell within the exceptions. If the Vacaville Order were given this reading, both the
23 Regional Water Board's interpretation and the State Water Board's conclusion fail to interpret the
24 Basin Plan according to the accepted rules of construction. A Basin Plan is a quasi-legislative
25 regulation (*State Water Resources Control Bd. v. Office of Administrative Law* (1993)
26 12 Cal.App.4th 697, 701-702) and, like any other regulation, must be interpreted according to the
27 standard rules of construction. Among those rules is the rule promoting an interpretation that will
28

1 give each word meaning and not render language superfluous. “Significance should be given, if
2 possible, to every word of an act. [Citations omitted.] Conversely, a construction that renders a
3 word surplusage should be avoided. [Citations omitted.]” (*Delaney v. Superior Court*
4 (*Kopetman*) (1990) 50 Cal.3d 785, 798-799.)

5 The relevant Basin Plan language in question consists of four paragraphs that must be read
6 collectively and harmonized. The first paragraph sets up the general application of beneficial use
7 designations through the tributary statement, but qualifies that statement’s application by stating
8 that the Regional Water Board’s judgment will be applied where the beneficial uses may not be
9 applicable. The second paragraph further explains that it is impractical to list every water body
10 and that “[f]or unidentified water bodies, the beneficial uses will be evaluated on a case-by-case
11 basis.” (Basin Plan, p. II-2.00.) Next, the language references the Regional Water Board’s
12 incorporation of Resolution 88-63 and assigns MUN beneficial uses “in accordance” with
13 Resolution 88-63. Finally, the last paragraph states, “[i]n making any exemptions to the
14 beneficial use designation of MUN, the Regional Board will apply the exceptions listed in
15 Resolution 88-63 [.]” (*Id.*, p. II-2.01.)

16 This language plainly establishes the Basin Plan’s intended process for designating
17 beneficial uses (e.g., “MUN” for drinking-water supplies) for water bodies not specifically
18 identified in the Basin Plan. This language explicitly requires the Regional Water Board to
19 evaluate the application of beneficial uses on a case-by-case basis for undesignated water bodies
20 and designate unidentified water bodies with the “MUN” beneficial use only in accordance with
21 Resolution 88-63. (Basin Plan, p. II-2.00.) Resolution 88-63, as adopted by the State Water
22 Board, directs the regional boards to consider all surface waters to be suitable for the MUN
23 beneficial use except where, “[t]he water is in systems designed or modified for the primary
24 purpose of conveying or holding agricultural drainage waters, provided that the discharge from
25 such systems is monitored to assure compliance with all relevant water quality objectives as
26 required by the Regional Boards.” (Resolution 88-63, p. 2, other exceptions omitted.) In
27 adopting Resolution 88-63, the State Water Board thus expressly recognized the problem later
28 created by the Vacaville Order and expressly directed the regional boards not to apply the

1 “MUN” beneficial use to agricultural drainage facilities. To comply with this direction, the
2 Regional Water Board explicitly incorporated language into the Basin Plan that states, “the
3 Regional Board will apply the exceptions listed in Resolution 88-63.” (Basin Plan, p. II-2.01.)

4 The Permit, however, ignores the impact and significance of this language. The Regional
5 Water Board members stated they were somehow compelled to apply the MUN designation,
6 despite the fact that the State Water Board’s Vacaville Order does not discuss at all the
7 application and meaning of the specific Basin Plan language that states the Regional Water Board
8 *will apply* the exceptions from Resolution 88-63. The Permit also fails to recognize that the
9 literal reading of “in accordance” with Resolution 88-63 means that the exceptions in the policy
10 were incorporated into the Basin Plan and thus preclude the Regional Water Board from
11 assigning the “MUN” beneficial use designation to water bodies that fit within
12 Resolution 88-63’s exceptions. As characterized by the Regional Water Board, the collective
13 interpretations of the Basin Plan render those exceptions surplusage in contradiction of standard
14 rules of construction.

15 As applied in the Permit, the Regional Water Board’s interpretation of the Basin Plan also
16 contradicts the rule of construction that interpretations of laws and rules not create absurd results.
17 (See, e.g., *People v. Valtakis* (2003) 105 Cal.App.4th 1066, 1076.) This consideration applies
18 particularly where an interpretation of law could cause institutions to be overburdened to the
19 point of breaking down. (See *City of Orange v. San Diego County Employees Retirement Assn.*
20 (2002) 103 Cal.App.4th 45, 55.) Based on the Regional Water Board’s interpretation of the Basin
21 Plan as applying the “MUN” beneficial use designation to all Central Valley water bodies, Live
22 Oak must now either pursue a Basin Plan amendment to apply the exception specifically
23 identified in the State Water Board’s policy, or install new treatment that will cost Live Oak’s
24 ratepayers over \$4 million on top of the \$20 million already spent to comply with the
25 2004 Permit. This is the very definition of an absurd result. In the words of Regional Water
26 Board Member Mulholland, “this is what makes us all look insane. What are the alternatives
27 besides saying this is drinkable water? I mean, its crazy . . . Are any . . . alternatives ones that we
28

1 can look at, rather than just pass this insane ruling on?"⁷ The enormous burden that this approach
2 would foist on Live Oak and its ratepayers is neither justified nor lawful.

3 **5. The Implementation Language in the Basin Plan Contradicts the State's**
4 **Policy and Is Invalid**

5 The Permit relies on language in the Implementation Chapter of the Basin Plan to support
6 the premise that the Regional Water Board must adopt a Basin Plan amendment to apply an
7 exception that is specifically identified in Resolution 88-63. (Permit, p. F-16; Basin Plan,
8 p. IV-9.00.) However, the cited language directly contradicts Resolution 88-63 and is therefore
9 invalid. As indicated previously, the Regional Water Board was required by Resolution 88-63 to
10 identify water bodies that are suitable for municipal use except for those that fell within the
11 categories identified in Resolution 88-63. Thus, the Regional Water Board's blanket designation
12 through its incorporation-by-reference was expressly constrained to exclude water bodies that fit
13 within the exceptions. In fact, the administrative record for the Basin Plan indicates that the
14 Regional Water Board did follow this direction when it first incorporated Resolution 88-63 into
15 the Basin Plan. However, as discussed below, the language was changed in 1994 for no specified
16 reason or purpose.

17 When the Regional Water Board first adopted Resolution 88-63 into the Basin Plan, the
18 language in the Implementation Chapter stated as follows: "This policy was adopted on 19 May
19 1988. It specifies which ground and surface waters are considered to be suitable or potentially
20 suitable for the beneficial use of water supply (MUN). It allows the Regional Board some
21 discretion in making MUN determinations." (*Water Quality Control Plan for the Sacramento*
22 *and San Joaquin River Basins* (2d ed., 3rd Printing, 1992), p. IV-7.) This original language
23 clearly defers to Resolution 88-63 for determining what waters are suitable or potentially suitable
24 for MUN. Thus, the exceptions and their implementation were included in the Regional Water
25 Board's incorporation of Resolution 88-63 into the Basin Plan.

26
27
28 ⁷ February Transcript, p. 41:17-24.

1 Subsequently, in 1994, the Regional Water Board amended the Basin Plan to include the
2 language that currently exists and is referred to in the Permit. However, the administrative record
3 for the 1994 amendments provides no rationale or basis for the changes made in 1994. It merely
4 states that, “[n]ew and/or updated summary paragraphs are provided for the following: 1. State
5 Water Board Resolution No. 88-63, Sources of Drinking Water” (See *Staff Report*
6 *Amendment of the Water Quality Control Plan for Sacramento River Basin, Sacramento-San*
7 *Joaquin Delta Basin, and the San Joaquin River Basin* (Staff Report), p. 7.) In the 74-page Staff
8 Report, there is no further mention of the new language except with respect to its application to
9 the designation of beneficial uses for groundwater. On this point, the Staff Report merely states
10 that “[w]here a discharger chooses to seek exemption from one or more beneficial use designation
11 based on the exception criteria, development of the case for consideration by the Regional Water
12 Board will involve the expenditure of both private and state resources.” (*Id.*, p. 28.) In its
13 discussion with respect to “one or more” beneficial use designations, the Staff Report references
14 the fact that the 1994 amendments provided blanket designations for agricultural and industrial
15 supply that did not previously apply to unidentified groundwater basins. The Staff Report
16 provides no further explanation as to why the language proposed in the Implementation Chapter
17 was proposed and for what purpose. Without support and appropriate findings, the
18 implementation language cannot implement a substantive change to the original beneficial use
19 language, which results in the need for a formal Basin Plan amendment where one was not
20 previously required. Thus, the changes to the Implementation Chapter in 1994 with respect to
21 Resolution 88-63 are invalid and cannot be used as the basis for requiring a Basin Plan
22 amendment today.

23 In sum, the MUN designation is inappropriately applied to the constructed agricultural
24 drains, Lateral Drain Nos. 1 and 2, and all WQBELs, receiving water limitations, and compliance
25 schedule provisions derived from this designation are invalid. Thus, all such effluent limits
26 should be removed.

27
28

1 **6. Alternatively, the Regional Water Board Should Have Refrained From**
2 **Adopting MUN-Based Effluent Limitations Until a Basin Plan Amendment Is**
3 **Considered**

4 At the very least, the Regional Water Board should have refrained from adopting
5 WQBELs, receiving water limitations, and compliance schedule provisions based on the MUN
6 beneficial use designation until after considering a Basin Plan amendment that applies the
7 constructed agricultural drain exception to Lateral Drain Nos. 1 and 2. This approach would be
8 consistent with that taken by the Regional Water Board when it adopted Waste Discharge
9 Requirements for the City of Biggs. (See Order No. R5-2007-0032 (Biggs Permit).)

10 In the Biggs Permit, the Regional Water Board recognizes that Lateral K (agricultural
11 drain for Reclamation District #833) is a constructed agricultural drain that potentially falls within
12 the exceptions of Resolution 88-63. (Biggs Permit, pp. 5, F-8.) To address this issue, the Biggs
13 Permit requires the discharger to conduct a study and provide sufficient information to the
14 Regional Water Board to process a Basin Plan amendment that would potentially remove MUN
15 from Lateral K. (*Id.*, p. 30.) In the meantime, the Biggs Permit does not identify MUN as an
16 existing use and does not include water quality-based effluent limitations on the discharge based
17 on the MUN designation. (See *id.*, pp. 9-11.)

18 This approach is appropriate because it allows time to process and consider a Basin Plan
19 amendment before requiring a discharger to comply with unnecessary and inappropriate effluent
20 limitations. Live Oak is in the process of completing a multi-year, multi-million dollar treatment
21 plant upgrade that will become insufficient if the State Water Board upholds the Permit as is. The
22 effluent limitations in the Permit would trigger the need for new upgrades to the not yet
23 completed treatment facility. Live Oak finds this to be unreasonable, and requests that the time
24 for the Regional Water Board to consider a Basin Plan amendment for applying the appropriate
25 exception from Resolution 88-63 to Lateral Drain Nos. 1 and 2 be provided by not adopting
26 permit provisions in the meantime.

27 This approach would also be consistent with that taken by the State Water Board in the
28 Vacaville case. The State Water Board stayed the effluent limitations associated with the
 improper MUN designation for Old Alamo Creek, and directed the Regional Water Board to


1 “expeditiously initiate basin plan amendments to consider dedesignating [. . .] MUN from Old
2 Alamo Creek.” (Vacaville Order, p. 76.) Otherwise, the small, disadvantaged community of
3 Live Oak must move forward with implementing actions to meet these WQBELs, including
4 planning for building de-nitrification facilities, while at the same time pursue a Basin Plan
5 amendment that would apply an exception already in existence. Further, for a small,
6 disadvantaged community such as Live Oak, it is imperative that the Regional Water Board move
7 forward with the Basin Plan amendment, including preparing all necessary information to support
8 the amendment, instead of placing that burden on the community of Live Oak itself.

9 **IV. CONCLUSION**

10 Based on this Petition and the evidence in the record, Live Oak respectfully requests that
11 the State Water Board revise the Permit to remove the MUN use designation for Lateral Drain
12 Nos. 1 and 2, and delete all associated Permit provisions. In the alternative, Live Oak
13 respectfully requests a remand of the Permit to the Regional Water Board with direction to revise
14 the MUN use designation for Lateral Drain Nos. 1 and 2, and a stay of the relevant effluent
15 limitations, receiving water limitations, and compliance schedule provisions until a Basin Plan
16 amendment has been considered.

17
18
19 DATED: July 11, 2011

SOMACH SIMMONS & DUNN
A Professional Corporation

By: 

Theresa A. Dunham
Attorneys for Petitioner City of Live Oak

EXHIBIT A

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION**

11020 Sun Center Drive, #200-Rancho Cordova, California 95670-6114
Phone (916) 464-3291 • Fax (916) 464-4645
<http://www.waterboards.ca.gov/centralvalley>

**ORDER NO. R5-2011-0034
NPDES NO. CA0079022
WASTE DISCHARGE REQUIREMENTS FOR THE
CITY OF LIVE OAK
WASTEWATER TREATMENT PLANT
SUTTER COUNTY**

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 1. Discharger Information

Discharger	City of Live Oak
Name of Facility	City of Live Oak Wastewater Treatment Plant
Facility Address	3450 Treatment Road
	Live Oak, CA 95953
	Sutter County
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a major discharge.	

The discharge by the City of Live Oak from the discharge points identified below is subject to waste discharge requirements as set forth in this Order:

Table 2. Discharge Location

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001	Domestic/Municipal Wastewater	39° 15' 48" N	121° 40' 42" W	Reclamation District 777 Lateral Drain No. 1 or 2

Table 3. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	10 June 2011
This Order shall become effective on:	30 July 2011
This Order shall expire on:	1 June 2016
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	4 December 2015

I, **Pamela C. Creedon**, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on **10 June 2011**.

Original Signed by

PAMELA C. CREEDON, Executive Officer

EXHIBIT A

Table of Contents

I.	Facility Information	3
II.	Findings	3
III.	Discharge Prohibitions	10
IV.	Effluent Limitations and Discharge Specifications	10
	A. Effluent Limitations – Discharge Point No. 001	10
	B. Land Discharge Specifications – NOT APPLICABLE	12
	C. Reclamation Specifications – NOT APPLICABLE	12
V.	Receiving Water Limitations	12
	A. Surface Water Limitations	12
	B. Groundwater Limitations	15
VI.	Provisions	15
	A. Standard Provisions	15
	B. Monitoring and Reporting Program Requirements	19
	C. Special Provisions	19
	1. Reopener Provisions	19
	2. Special Studies, Technical Reports and Additional Monitoring Requirements	21
	3. Best Management Practices and Pollution Prevention	24
	4. Construction, Operation and Maintenance Specifications	24
	5. Special Provisions for Municipal Facilities (POTWs Only)	25
	6. Other Special Provisions	27
VII.	Compliance Determination	28

List of Tables

Table 1.	Discharger Information	1
Table 2.	Discharge Location	1
Table 3.	Administrative Information	1
Table 4.	Facility Information	3
Table 5.	Basin Plan Beneficial Uses	6
Table 6.	Effluent Limitations	10

List of Attachments

Attachment A – Definitions	A-1
Attachment B – Map	B-1
Attachment C – Flow Schematic	C-1
Attachment D – Standard Provisions	D-1
Attachment E – Monitoring and Reporting Program	E-1
Attachment F – Fact Sheet	F-1
Attachment G – Summary of Reasonable Potential Analysis	G-1
Attachment H – Constituents to Be Monitored	H-1

I. FACILITY INFORMATION

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 4. Facility Information

Discharger	City of Live Oak
Name of Facility	City of Live Oak Wastewater Treatment Plant
Facility Address	3450 Treatment Road
	Live Oak, CA 95953
	Sutter County
Facility Contact, Title, and Phone	Mr. Jim Goodwin City Manager 530.695.2112
Mailing Address	9955 Live Oak Boulevard Live Oak, CA 95953
Type of Facility	Publicly Owned Treatment Works
Facility Permitted Flow	1.4 million gallons per day (MGD) average dry weather flow (ADWF)
Current Facility Design Flow	1.4 MGD

II. FINDINGS

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Central Valley Water Board), finds:

A. Background. The City of Live Oak (hereinafter Discharger) is currently discharging pursuant to Order No. R5-2004-0096 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0079022. The Discharger submitted a Report of Waste Discharge on 30 September 2008, and applied for a NPDES permit renewal to discharge up to 1.4 MGD of treated wastewater from the City of Live Oak Wastewater Treatment Plant, (hereinafter Facility).

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

B. Facility Description. The Discharger owns and operates the Publicly Owned Treatment Works. The Discharger provides sewerage service for the City of Live Oak and serves a population of approximately 8,000. The design daily average dry weather flow capacity of the Facility is 1.4 MGD. The Facility currently provides secondary treatment of domestic wastewater from within the City limits. The collection system consists of 25 miles of sewer lines and six pump stations. The Discharger’s potable water is supplied by five City-owned groundwater wells. The current Facility consists of aerated lagoons, oxidation ponds, disinfection by chlorine, and dechlorination. Wastewater is discharged from the Facility at Discharge Point No. 001 to the receiving water, Reclamation District 777 Lateral Drain No. 1 (a constructed agricultural drain), a

tributary to the East Interceptor Canal, then Wadsworth Canal, and then the Sutter Bypass.

The Discharger began construction of major tertiary treatment upgrades to the Facility in September 2009. The new tertiary treatment plant will include a lined equalization basin, an unlined emergency storage basin, and a stormwater detention basin. The upgraded treatment system will also include nitrification and will consist of an odor control system at the headworks, secondary feed pump station, selector basin, two oxidation ditches, two secondary clarifiers, cloth media filters, and ultraviolet disinfection system. Solids handling facilities will consist of storage basins and solar drying beds. Wastewater will be discharged from Discharge Point No. 001 and the plan for the new facility is to discharge to the Reclamation District 777 Lateral Drain No. 2 (a constructed agricultural drain). Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the new Facility.

- C. Legal Authorities.** This Order is issued pursuant to section 402 of the Clean Water Act (CWA) and implementing regulations adopted by USEPA and chapter 5.5, division 7 of the California Water Code (CWC; commencing with section 13370). It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the CWC (commencing with section 13260).
- D. Background and Rationale for Requirements.** The Central Valley Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through H are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100-21177.
- F. Technology-based Effluent Limitations.** Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations (40 CFR 122.44), require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at 40 CFR Part 133 in accordance with 40 CFR 125.3. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet.
- G. Water Quality-Based Effluent Limitations (WQBELs).** Section 301(b) of the CWA and 40 CFR 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements, expressed as a technology equivalence requirement, that are necessary to achieve water quality

standards. The Central Valley Water Board has considered the factors listed in CWC Section 13241 in establishing these requirements. The rationale for these requirements, which consist of tertiary treatment or equivalent requirements, is discussed in the Fact Sheet.

40 CFR 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

H. Water Quality Control Plans. The Central Valley Water Board adopted a *Water Quality Control Plan, Fourth Edition (Revised September 2009)*, for the Sacramento River and San Joaquin River Basins (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. The Basin Plan at page II-2.00 states that the "...beneficial uses of any specifically identified water body generally apply to its tributary streams." The Basin Plan does not specifically identify beneficial uses for Reclamation District 777 Lateral Drain No. 1 or for Lateral Drain No. 2, but does identify present and potential uses for the Sutter Bypass, to which Reclamation District 777 Lateral Drain No. 1 and Lateral Drain No. 2 are tributary. According to the Basin Plan, municipal and domestic supply is not a beneficial use of the Sutter Bypass.

However the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal and domestic supply. One exception is if the water is in systems designed or modified for the primary purpose of conveying or holding agricultural drainage waters, provided that the discharge from such systems is monitored to assure compliance with all relevant water quality objectives as required by the Regional Boards. In accordance with Chapter IV of the Basin Plan, the Central Valley Water Board must adopt a formal Basin Plan Amendment to grant an exception to Resolution No. 88-63. Therefore, until the Central Valley Water Board adopts a Basin Plan Amendment for an exception, and the State Water Board and Office of Administrative Law approve the Basin Plan Amendment, the receiving water is considered to be suitable or potentially suitable for municipal or domestic supply in accordance with State Water Board Resolution No. 88-63. Thus, as discussed in detail in the Fact Sheet, beneficial uses applicable to the receiving water are as follows:

Table 5. Basin Plan Beneficial Uses

Discharge Point	Receiving Water Name	Beneficial Use(s)
001	Reclamation District 777 Lateral Drain No. 1 and Reclamation District 777 Lateral Drain No. 2 (planned for new facility)	Municipal and domestic supply (MUN); Agricultural irrigation (AGR); Water contact recreation (REC-1); Warm freshwater habitat (WARM); Cold freshwater migration (MGR);
		Spawning, reproduction, and/or early development (SPWN); Wildlife habitat (WILD). Ground water recharge (GWR); Freshwater replenishment (FRSH).

The Basin Plan includes a list of Water Quality Limited Segments (WQLSs), which are defined as "...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 CFR 130, et seq.)." The Basin Plan also states, "Additional treatment beyond minimum federal standards will be imposed on dischargers to WQLSs. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment." Wadsworth Canal is listed as a WQLS for diazinon in the current final 303(d) list of impaired water bodies, but the Sutter Bypass and the East Interceptor Canal are not listed. However, on 11 June 2009, the Central Valley Water Board approved the updated 303(d) list (Integrated Report) for the Central Valley Region that, in part, identified Sutter Bypass as impaired for mercury and Wadsworth Canal also impaired for chlorpyrifos. The State Water Board approved the Integrated Report on 4 August 2010, and the Integrated Report to update the 303(d) list has been submitted to USEPA for final approval. The Discharger has been monitoring diazinon on a monthly basis according to Order No. R5-2004-0096 and the monitoring results show no reasonable potential, therefore, a final effluent limit for diazinon is not included in this Order. Monitoring results show no reasonable potential for mercury, but because mercury is bioaccumulative, a final mass-based effluent limit is included in this Order. Additionally, monitoring is included for diazinon, mercury, and chlorpyrifos in the Monitoring and Reporting Program (Attachment E) of this Order.

Requirements of this Order implement the Basin Plan.

- I. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on 22 December 1992, and later amended it on 4 May 1995 and 9 November 1999. About 40 criteria in the NTR applied in California. On 18 May 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on 13 February 2001. These rules contain water quality criteria for priority pollutants.
- J. **State Implementation Policy.** On 2 March 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on 28 April 2000 with respect to the priority pollutant criteria

promulgated for California by USEPA through the NTR and to the priority pollutant objectives established by the Central Valley Water Board in the Basin Plan. The SIP became effective on 18 May 2000 with respect to the priority pollutant criteria promulgated by USEPA through the CTR. The State Water Board adopted amendments to the SIP on 24 February 2005 that became effective on 13 July 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.

K. Compliance Schedules and Interim Requirements. In general, an NPDES permit must include final effluent limitations that are consistent with CWA section 301 and with 40 CFR 122.44(d). There are exceptions to this general rule. The State Water Board's *Policy for Compliance Schedules in National Pollutant Discharge Elimination System Permits* (Compliance Schedule Policy) allows compliance schedules for new, revised, or newly interpreted water quality objectives or criteria, or in accordance with a TMDL. All compliance schedules must be as short as possible, and may not exceed ten years from the effective date of the adoption, revision, or new interpretation of the applicable water quality objective or criterion, unless a TMDL allows a longer schedule. The Central Valley Water Board, however, is not required to include a compliance schedule, but may issue a Time Schedule Order pursuant to CWC section 13300 or a Cease and Desist Order pursuant to CWC section 13301 where it finds that the discharger is violating or threatening to violate the permit. The Central Valley Water Board will consider the merits of each case in determining whether it is appropriate to include a compliance schedule in a permit, and, consistent with the Compliance Schedule Policy, should consider feasibility of achieving compliance, and must impose a schedule that is as short as possible to achieve compliance with the effluent limit based on the objective or criteria.

The Compliance Schedule Policy and the SIP do not allow compliance schedules for priority pollutants beyond 18 May 2010, except for new or more stringent priority pollutant criteria adopted by USEPA after 17 December 2008.

Where a compliance schedule for a final effluent limitation exceeds one year, the Order must include interim numeric limitations for that constituent or parameter, interim milestones and compliance reporting within 14 days after each interim milestone. The permit may also include interim requirements to control the pollutant, such as pollutant minimization and source control measures.

L. Alaska Rule. On 30 March 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards become effective for CWA purposes. (40 CFR 131.21 and 65 FR 24641 (27 April 2000).) Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after 30 May 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by 30 May 2000 may be used for CWA purposes, whether or not approved by USEPA.

M. Stringency of Requirements for Individual Pollutants. This Order contains both technology-based effluent limitations and WQBELs for individual pollutants. The technology-based effluent limitations consist of restrictions on flow, percent removal requirements for 5-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), total coliform organisms, and pH. The WQBELs consist of restrictions on chlorine residual, aluminum, ammonia, BOD₅, TSS, copper, cadmium, and toxicity. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order includes new effluent limitations for nitrate, dibromochloromethane, dichlorobromomethane, total trihalomethanes (THMs), arsenic, iron, manganese, alpha BHC, 4,4'-DDE, alpha Endosulfan, Endrin Aldehyde, and electrical conductivity to meet numeric objectives or protect beneficial uses.

WQBELs have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR 131.38. The scientific procedures for calculating the individual WQBELs for priority pollutants are based on the CTR-SIP, which was approved by USEPA on 18 May 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to 30 May 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to 30 May 2000, but not approved by USEPA before that date, are nonetheless "*applicable water quality standards for purposes of the [Clean Water] Act*" pursuant to 40 CFR 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the technology-based requirements of the CWA and the applicable water quality standards for purposes of the CWA.

N. Antidegradation Policy. 40 CFR 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Central Valley Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet, the permitted discharge is consistent with the antidegradation provision of 40 CFR 131.12 and Resolution No. 68-16.

O. Anti-Backsliding Requirements. Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. Some effluent limitations in this Order are less stringent than those in Order No. R5-2004-0096. As discussed in detail in the Fact Sheet, this relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

- P. Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The discharger is responsible for meeting all requirements of the applicable Endangered Species Act.
- Q. Monitoring and Reporting.** 40 CFR 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Central Valley Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. The Monitoring and Reporting Program is provided in Attachment E.
- R. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR 122.42. The Central Valley Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the Fact Sheet.
- S. Provisions and Requirements Implementing State Law.** The provisions/requirements in sections V.B, and VI.C. 4.b. and 6.a. of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- T. Notification of Interested Parties.** The Central Valley Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- U. Consideration of Public Comment.** The Central Valley Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet.

THEREFORE, IT IS HEREBY ORDERED, that Order No. R5-2004-0096 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the CWC (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal CWA and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

III. DISCHARGE PROHIBITIONS

- A. Discharge of wastewater at a location or in a manner different from that described in the Findings is prohibited.
- B. The by-pass or overflow of wastes to surface waters is prohibited, except as allowed by Federal Standard Provisions I.G. and I.H. (Attachment D).
- C. Neither the discharge nor its treatment shall create a nuisance as defined in section 13050 of the CWC.
- D. The Discharger shall not allow pollutant-free wastewater to be discharged into the collection, treatment, and disposal system in amounts that significantly diminish the system's capability to comply with this Order. Pollutant-free wastewater means rainfall, groundwater, cooling waters, and condensates that are essentially free of pollutants.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Point No. 001

1. Final Effluent Limitations – Discharge Point No. 001

Effective immediately, the Discharger shall maintain compliance with the following effluent limitations at Discharge Point No. 001, with compliance measured at Monitoring Location EFF-001 and at Monitoring Location EFF-002 as described in the Monitoring and Reporting Program (Attachment E):

- a. The Discharger shall maintain compliance with the effluent limitations specified in Table 6:

Table 6. Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	10	15	20	--	--
	lbs/day ¹	120	180	230	--	--
Total Suspended Solids	mg/L	10	15	20	--	--
	lbs/day ¹	120	180	230	--	--
pH	standard units	--	--	--	6.5	8.3
Ammonia, Total (as N)	mg/L	1.4	--	2.8	--	--
	lbs/day ¹	16	--	33	--	--
Aluminum, Total Recoverable	µg/L	260	--	750	--	--
Arsenic	µg/L	10	--	20.1	--	--
Copper, Total Recoverable	µg/L	15	--	28	--	--

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Cadmium, Total Recoverable	µg/L	3.8	--	7.6	--	--
Dibromochloromethane	µg/L	0.41	--	0.82	--	--
Dichlorobromomethane	µg/L	0.56	--	1.2	--	--
Alpha BHC	µg/L	--	--	--	--	ND
4,4'-DDE	µg/L	--	--	--	--	ND
Alpha Endosulfan	µg/L	--	--	--	--	ND
Endrin Aldehyde	µg/L	--	--	--	--	ND
Nitrate (as N)	mg/L	10	--	--	--	--
Total Trihalomethanes	µg/L	80	--	--	--	--

1 Mass-based effluent limitations are based on a permitted average dry weather flow of 1.4 MGD.

- b. **Percent Removal.** The average monthly percent removal of 5-day biochemical oxygen demand (BOD₅) and total suspended solids (TSS) shall not be less than 85 percent.
- c. **Acute Whole Effluent Toxicity.** Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:
 - i. 70%, minimum for any one bioassay; and
 - ii. 90%, median for any three consecutive bioassays.
- d. **Chronic Whole Effluent Toxicity.** Effective 30 September 2012, there shall be no chronic toxicity in the effluent discharge.
- e. **Total Residual Chlorine.** Effluent total residual chlorine shall not exceed:
 - i. 0.011 mg/L, as a 4-day average; and
 - ii. 0.019 mg/L, as a 1-hour average.
- f. **Total Coliform Organisms.** Effluent total coliform organisms shall not exceed:
 - i. 2.2 most probable number (MPN) per 100 mL, as a 7-day median; and
 - ii. 23 MPN/100 mL, more than once in any 30-day period, and
 - iii. 240 MPN/100 mL, instantaneous maximum.
- g. **Average Dry Weather Flow.** The average dry weather discharge flow shall not exceed 1.4 MGD.
- h. **Iron.** For a calendar year, the annual average effluent total recoverable iron shall not exceed 300 µg/L.
- i. **Manganese.** For a calendar year, the annual average effluent total recoverable manganese shall not exceed 50 µg/L.

- j. **Aluminum.** For a calendar year, the annual average effluent total recoverable aluminum shall not exceed 200 µg/L.
- k. **Electrical Conductivity.** For a calendar year, the annual average effluent electrical conductivity shall not exceed 1100 µmhos/cm.
- l. **Mercury.** Effective immediately, the total calendar year annual mass discharge of total mercury shall not exceed 0.057 lbs. This performance-based limitation shall be in effect until the Central Valley Water Board establishes final effluent limitations after adoption of a mercury TMDL.

2. Interim Effluent Limitations

- a. **Total Trihalomethanes.** Effective immediately and ending by 3 years from the adoption date of this Order, or compliance with the final effluent limits, whichever is sooner, the Discharger shall maintain compliance with the interim effluent limitation at Discharge Point No. 001, with compliance measured at Monitoring Location EFF-001 as described in the Monitoring and Reporting Program (Attachment E). The interim effluent limitation for Total Trihalomethanes is 567.3 µg/L as a daily average. This interim effluent limitation shall apply in lieu of the final effluent limitation for Total Trihalomethanes specified in Table 6 of this Order during the time period specified in this provision.
- b. **Arsenic.** Effective immediately and ending by 5 years from the adoption date of this Order, or compliance with the final effluent limits, whichever is sooner, the Discharger shall maintain compliance with the interim effluent limitation at Discharge Point No. 001, with compliance measured at Monitoring Location EFF-001 as described in the Monitoring and Reporting Program (Attachment E). The interim effluent limitation for Arsenic is 88.9 µg/L as a daily average. This interim effluent limitation shall apply in lieu of all of the final effluent limitations for Arsenic specified in Table 6 of this Order during the time period specified in this provision.

B. Land Discharge Specifications – NOT APPLICABLE

C. Reclamation Specifications – NOT APPLICABLE

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in Reclamation District 777 Lateral Drain No. 1 or Lateral Drain No. 2:

1. **Bacteria.** The fecal coliform concentration, based on a minimum of not less than five samples for any 30-day period, to exceed a geometric mean of 200 MPN/100 mL, nor more than 10 percent of the total number of fecal coliform samples taken during any 30-day period to exceed 400 MPN/100 mL.
2. **Biostimulatory Substances.** Water to contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.
3. **Chemical Constituents.** Chemical constituents to be present in concentrations that adversely affect beneficial uses.
4. **Color.** Discoloration that causes nuisance or adversely affects beneficial uses.
5. **Dissolved Oxygen.** The dissolved oxygen concentration to be reduced below 7.0 mg/L at any time.
6. **Floating Material.** Floating material to be present in amounts that cause nuisance or adversely affect beneficial uses.
7. **Oil and Grease.** Oils, greases, waxes, or other materials to be present in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.
8. **pH.** The pH to be depressed below 6.5 nor raised above 8.5.
9. **Pesticides:**
 - a. Pesticides to be present, individually or in combination, in concentrations that adversely affect beneficial uses;
 - b. Pesticides to be present in bottom sediments or aquatic life in concentrations that adversely affect beneficial uses;
 - c. Total identifiable persistent chlorinated hydrocarbon pesticides to be present in the water column at concentrations detectable within the accuracy of analytical methods approved by USEPA or the Executive Officer;
 - d. Pesticide concentrations to exceed those allowable by applicable antidegradation policies (see State Water Board Resolution No. 68-16 and 40 CFR 131.12.);
 - e. Pesticide concentrations to exceed the lowest levels technically and economically achievable;
 - f. Pesticides to be present in concentration in excess of the maximum contaminant levels set forth in CCR, Title 22, division 4, chapter 15; nor
 - g. Thiobencarb to be present in excess of 1.0 µg/L.

10. Radioactivity:

- a. Radionuclides to be present in concentrations that are harmful to human, plant, animal, or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal, or aquatic life; nor
- b. Radionuclides to be present in excess of the maximum contaminant levels specified in Table 4 (MCL Radioactivity) of Section 64443 of Title 22 of the California Code of Regulations.

11. Suspended Sediments. The suspended sediment load and suspended sediment discharge rate of surface waters to be altered in such a manner as to cause nuisance or adversely affect beneficial uses.

12. Settleable Substances. Substances to be present in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.

13. Suspended Material. Suspended material to be present in concentrations that cause nuisance or adversely affect beneficial uses.

14. Taste and Odors. Taste- or odor-producing substances to be present in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.

15. Temperature. The instantaneous natural temperature to be increased by more than 5°F. Compliance to be determined based on the difference in temperature at RSW-001 and RSW-002.

16. Toxicity. Toxic substances to be present, individually or in combination, in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.

17. Turbidity.

- a. Turbidity to exceed 2 Nephelometric Turbidity Unit (NTU) where natural turbidity is less than 1 NTU;
- b. Turbidity to increase more than 1 NTU where natural turbidity is between 1 and 5 NTUs;
- c. Turbidity to increase more than 20 percent where natural turbidity is between 5 and 50 NTUs;
- d. Turbidity to increase more than 10 NTU where natural turbidity is between 50 and 100 NTUs; nor

- e. Turbidity to increase more than 10 percent where natural turbidity is greater than 100 NTUs.

Compliance to be determined based on the difference in turbidity at RSW-001 and RSW-002.

B. Groundwater Limitations

1. Release of waste constituents from any portion of the Facility shall not cause groundwater to contain waste constituents in concentrations greater than background water quality or water quality objectives, whichever is greater. The discharge shall not cause the groundwater to exceed water quality objectives, unreasonably affect beneficial uses, or cause a condition of pollution or nuisance.

VI. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
2. The Discharger shall comply with the following provisions:
 - a. If the Discharger's wastewater treatment plant is publicly owned or subject to regulation by California Public Utilities Commission, it shall be supervised and operated by persons possessing certificates of appropriate grade according to Title 23, CCR, division 3, chapter 26.
 - b. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
 - i. violation of any term or condition contained in this Order;
 - ii. obtaining this Order by misrepresentation or by failing to disclose fully all relevant facts;
 - iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; and
 - iv. a material change in the character, location, or volume of discharge.

The causes for modification include:

- *New regulations.* New regulations have been promulgated under section 405(d) of the CWA, or the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued.

- *Land application plans.* When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge, to revise an existing land application plan, or to add a land application plan.
- *Change in sludge use or disposal practice.* Under 40 CFR 122.62(a)(1), a change in the Discharger's sludge use or disposal practice is a cause for modification of the permit. It is cause for revocation and reissuance if the Discharger requests or agrees.

The Central Valley Water Board may review and revise this Order at any time upon application of any affected person or the Central Valley Water Board's own motion.

- c. If a toxic effluent standard or prohibition (including any scheduled compliance specified in such effluent standard or prohibition) is established under section 307(a) of the CWA, or amendments thereto, for a toxic pollutant that is present in the discharge authorized herein, and such standard or prohibition is more stringent than any limitation upon such pollutant in this Order, the Central Valley Water Board will revise or modify this Order in accordance with such toxic effluent standard or prohibition.

The Discharger shall comply with effluent standards and prohibitions within the time provided in the regulations that establish those standards or prohibitions, even if this Order has not yet been modified.

- d. This Order shall be modified, or alternately revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - i. contains different conditions or is otherwise more stringent than any effluent limitation in the Order; or
 - ii. controls any pollutant limited in the Order.

The Order, as modified or reissued under this paragraph, shall also contain any other requirements of the CWA then applicable.

- e. The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.

- g. The Discharger shall ensure compliance with any existing or future pretreatment standard promulgated by USEPA under section 307 of the CWA, or amendment thereto, for any discharge to the municipal system.
- h. A copy of this Order shall be maintained at the discharge facility and be available at all times to operating personnel. Key operating personnel shall be familiar with its content.
- i. Safeguard to electric power failure:

 - i. The Discharger shall provide safeguards to assure that, should there be reduction, loss, or failure of electric power, the discharge shall comply with the terms and conditions of this Order.
 - ii. Upon written request by the Central Valley Water Board the Discharger shall submit a written description of safeguards. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means. A description of the safeguards provided shall include an analysis of the frequency, duration, and impact of power failures experienced over the past 5 years on effluent quality and on the capability of the Discharger to comply with the terms and conditions of the Order. The adequacy of the safeguards is subject to the approval of the Central Valley Water Board.
 - iii. Should the treatment works not include safeguards against reduction, loss, or failure of electric power, or should the Central Valley Water Board not approve the existing safeguards, the Discharger shall, within 90 days of having been advised in writing by the Central Valley Water Board that the existing safeguards are inadequate, provide to the Central Valley Water Board and USEPA a schedule of compliance for providing safeguards such that in the event of reduction, loss, or failure of electric power, the Discharger shall comply with the terms and conditions of this Order. The schedule of compliance shall, upon approval of the Central Valley Water Board, become a condition of this Order.
- j. The Discharger, upon written request of the Central Valley Water Board, shall file with the Board a technical report on its preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. This report may be combined with that required under Central Valley Water Board Standard Provision contained in section VI.A.2.i. of this Order.

The technical report shall:

- i. Identify the possible sources of spills, leaks, untreated waste by-pass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.

- ii. Evaluate the effectiveness of present facilities and procedures and state when they became operational.
- iii. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

The Central Valley Water Board, after review of the technical report, may establish conditions which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions shall be incorporated as part of this Order, upon notice to the Discharger.

- k. A publicly owned treatment works whose waste flow has been increasing, or is projected to increase, shall estimate when flows will reach hydraulic and treatment capacities of its treatment and disposal facilities. The projections shall be made in January, based on the last 3 years' average dry weather flows, peak wet weather flows and total annual flows, as appropriate. When any projection shows that capacity of any part of the facilities may be exceeded in 4 years, the Discharger shall notify the Central Valley Water Board by 31 January. A copy of the notification shall be sent to appropriate local elected officials, local permitting agencies and the press. Within 120 days of the notification, the Discharger shall submit a technical report showing how it will prevent flow volumes from exceeding capacity or how it will increase capacity to handle the larger flows. The Central Valley Water Board may extend the time for submitting the report.
- l. The Discharger shall submit technical reports as directed by the Executive Officer. All technical reports required herein that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code, sections 6735, 7835, and 7835.1. To demonstrate compliance with Title 16, CCR, sections 415 and 3065, all technical reports must contain a statement of the qualifications of the responsible registered professional(s). As required by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in a manner such that all work can be clearly attributed to the professional responsible for the work.
- m. The Central Valley Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13385, 13386, and 13387.
- n. For publicly owned treatment works, prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a watercourse, the Discharger must file a petition with the State Water Board, Division of Water Rights, and receive approval for such a change. (CWC section 1211).

- o. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition, maximum daily effluent limitation, 1-hour average effluent limitation, or receiving water limitation contained in this Order, the Discharger shall notify the Central Valley Water Board by telephone (916) 464-3291 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within 5 days, unless the Central Valley Water Board waives confirmation. The written notification shall include the information required by the Standard Provision contained in Attachment D section V.E.1. [40 CFR 122.41(l)(6)(i)].
- p. Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this facility, may subject the Discharger to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Discharger to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
- q. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to the Central Valley Water Board.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the state of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Central Valley Water Board and a statement. The statement shall comply with the signatory and certification requirements in the federal Standard Provisions (Attachment D, section V.B) and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the CWC. Transfer shall be approved or disapproved in writing by the Executive Officer.

B. Monitoring and Reporting Program Requirements

The Discharger shall comply with the Monitoring and Reporting Program, and future revisions thereto, in Attachment E of this Order.

C. Special Provisions

1. Reopener Provisions

- a. Conditions that necessitate a major modification of a permit are described in 40 CFR 122.62, including:
 - i. If new or amended applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments thereto, this

permit may be reopened and modified in accordance with the new or amended standards.

- ii. When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.
- b. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.
- c. **Mercury.** If mercury is found to be causing toxicity based on acute or chronic toxicity test results, or if a TMDL program is adopted, this Order shall be reopened and the interim mass effluent limitation modified (higher or lower) or an effluent concentration limitation imposed. If the Central Valley Water Board determines that a mercury offset program is feasible for Dischargers subject to a NPDES permit, then this Order may be reopened to reevaluate the interim mercury mass loading limitation(s) and the need for a mercury offset program for the Discharger.
- d. **Whole Effluent Toxicity.** As a result of a Toxicity Reduction Evaluation (TRE), this Order may be reopened to include a new acute or chronic toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if the State Water Board revises the SIP's toxicity control provisions that would require the establishment of numeric chronic toxicity effluent limitations, this Order may be reopened to include a numeric chronic toxicity effluent limitation based on the new provisions.
- e. **Water Effects Ratios (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating CTR criteria for applicable priority pollutant inorganic constituents. In addition, default dissolved-to-total metal translators have been used to convert water quality objectives from dissolved to total recoverable when developing effluent limitations for aluminum, copper, and cadmium. If the Discharger performs studies to determine site-specific WERs and/or site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.
- f. **Salinity/EC Site-Specific Studies.** This Order requires the Discharger to complete and submit a report on the results of salinity/EC site-specific studies to determine appropriate salinity/EC levels necessary to protect downstream beneficial uses. The studies shall be completed and submitted to the Central Valley Water Board as specified in section VI.C.2.b of this Order. Based on a review of the results of the report on the salinity/EC site-specific studies this

Order may be reopened to modify the effluent limitation and requirements for salinity and/or EC.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. Chronic Whole Effluent Toxicity.** For compliance with the Basin Plan's narrative toxicity objective, this Order requires the Discharger to conduct chronic whole effluent toxicity (WET) testing, as specified in the Monitoring and Reporting Program (Attachment E, section V). Furthermore, this Provision requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity. If the discharge exhibits toxicity exceeding the numeric toxicity monitoring trigger during accelerated monitoring established in this Provision, the Discharger is required to initiate a TRE in accordance with an approved TRE Workplan, and take actions to mitigate the impact of the discharge and prevent recurrence of toxicity. A TRE is a site-specific study conducted in a stepwise process to identify the source(s) of toxicity and the effective control measures for effluent toxicity. TREs are designed to identify the causative agents and sources of effluent toxicity, evaluate the effectiveness of the toxicity control options, and confirm the reduction in effluent toxicity. This Provision includes requirements for the Discharger to develop and submit a TRE Workplan and includes procedures for accelerated chronic toxicity monitoring and TRE initiation.
- i. Initial Investigative TRE Workplan.** Within 90 days of the effective date of this Order, the Discharger shall submit to the Central Valley Water Board an Initial Investigative TRE Workplan for approval by the Executive Officer. This should be a one to two page document including, at a minimum:
- (a)** A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of effluent toxicity, effluent variability, and treatment system efficiency;
 - (b)** A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in operation of the facility; and
 - (c)** A discussion of who will conduct the Toxicity Identification Evaluation (TIE), if necessary (e.g., an in-house expert or outside contractor).
- ii. Accelerated Monitoring and TRE Initiation. Effective 1 October 2012,** when the numeric toxicity monitoring trigger is exceeded during regular chronic toxicity monitoring, and the testing meets all test acceptability criteria, the Discharger shall initiate accelerated monitoring as required in the Accelerated Monitoring Specifications. The Discharger shall initiate a TRE to address effluent toxicity if any WET testing results exceed the numeric toxicity monitoring trigger during accelerated monitoring.

iii. Numeric Toxicity Monitoring Trigger. Effective 1 October 2012, the numeric toxicity monitoring trigger to initiate a TRE is $> 1 TU_C$ (where $TU_C = 100/NOEC$). The monitoring trigger is not an effluent limitation; it is the toxicity threshold at which the Discharger is required to begin accelerated monitoring and initiate a TRE when the effluent exhibits toxicity.

iv. Accelerated Monitoring Specifications. Effective 1 October 2012, if the numeric toxicity monitoring trigger is exceeded during regular chronic toxicity testing, the Discharger shall initiate accelerated monitoring within 14 days of notification by the laboratory of the exceedance. Accelerated monitoring shall consist of four (4) chronic toxicity tests conducted once every 2 weeks using the species that exhibited toxicity. The following protocol shall be used for accelerated monitoring and TRE initiation:

- (a) If the results of four (4) consecutive accelerated monitoring tests do not exceed the monitoring trigger, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring. However, notwithstanding the accelerated monitoring results, if there is adequate evidence of effluent toxicity, the Executive Officer may require that the Discharger initiate a TRE.
- (b) If the source(s) of the toxicity is easily identified (e.g., temporary plant upset), the Discharger shall make necessary corrections to the facility and shall continue accelerated monitoring until four (4) consecutive accelerated tests do not exceed the monitoring trigger. Upon confirmation that the effluent toxicity has been removed, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring.
- (c) If the result of any accelerated toxicity test exceeds the monitoring trigger, the Discharger shall cease accelerated monitoring and begin a TRE to investigate the cause(s) of, and identify corrective actions to reduce or eliminate effluent toxicity. Within thirty (30) days of notification by the laboratory of any test result exceeding the monitoring trigger during accelerated monitoring, the Discharger shall submit a TRE Action Plan to the Central Valley Water Board including, at minimum:
 - (1) Specific actions the Discharger will take to investigate and identify the cause(s) of toxicity, including a TRE WET monitoring schedule;
 - (2) Specific actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
 - (3) A schedule for these actions.

Within sixty (60) days of notification by the laboratory of the test results, the Discharger shall submit to the Central Valley Water Board a detailed TRE Workplan for approval by the Executive Officer. The TRE Workplan shall outline the procedures for identifying the source(s) of, and reducing

or eliminating effluent toxicity. The TRE Workplan must be developed in accordance with USEPA guidance¹.

b. Salinity/EC Site-Specific Study. If, after one year following construction of the tertiary Facility, the effluent EC level is greater than 700 $\mu\text{mhos/cm}$ for the annual average EC discharge, the Discharger shall complete and submit to the Central Valley Water Board a report on the results of a site-specific investigation of appropriate EC levels to protect the beneficial uses of the receiving water (i.e. AGR and MUN). For protection of the AGR beneficial use the study must consider how climate, soil chemistry, background water quality (surface water and groundwater), rainfall, and flooding affect salinity (EC) requirements necessary to protect the AGR beneficial use. The study shall include, at minimum, the following:

- i. The most salt sensitive crops in areas irrigated with Reclamation District 777 Lateral Drain No. 1 or Lateral Drain No. 2 waters in the vicinity of the discharge under reasonable worst-case conditions.
- ii. The sodium adsorption ratio of soils in the affected area.
- iii. The alkalinity of soils to whether site specific conditions would reduce fluoride impacts.
- iv. The effects of rainfall and flood-induced leaching; and
- v. The background receiving water quality.

Based on these factors, as well as economic and environmental impacts (such as increased irrigation water usage, groundwater hydraulics and degraded water quality), the study shall recommend site-specific numeric values for EC that provide reasonable protection for the agricultural supply use designation in the receiving water.

<u>Task</u>	<u>Compliance Date</u>
i. Submit results and summary of EC monitoring from the tertiary Facility. If annual average effluent EC level is greater than 700 $\mu\text{mhos/cm}$, follow tasks ii. and iii. below.	Within 15 months following construction of the new tertiary Facility.
ii. Submit Site-Specific Study Workplan and Time Schedule, for approval by the Executive Officer.	Within 18 months following construction of the new tertiary Facility.
iii. Complete Site-Specific Study and submit Study Report.	Within 15 months following Executive Officer approval of the Workplan and Time Schedule.

¹ See the Fact Sheet (Attachment F section VII.B.2.a.) for a list of USEPA guidance documents that must be considered in development of the TRE Workplan.

3. Best Management Practices and Pollution Prevention

- a. **Salinity Evaluation and Minimization Plan.** The Discharger shall prepare and implement a salinity evaluation and minimization plan to address sources of salinity from the Facility. The salinity evaluation and minimization plan shall be completed and submitted to the Central Valley Water Board **within 14 months of the effective date of this Order** for approval by the Executive Officer, and progress reports shall be submitted annually in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1.).
- b. **Mercury Evaluation and Minimization Plan.** The Discharger shall prepare and implement a mercury evaluation and minimization plan to address sources of mercury from the Facility. The plan shall be completed and submitted to the Central Valley Water Board **within 14 months of the adoption date of this Order** for the approval by the Executive Officer, and progress reports shall be submitted annually in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1.).

4. Construction, Operation and Maintenance Specifications

- a. **Turbidity.** Effluent turbidity shall not exceed the following upon initiation of operation of the new tertiary treatment facility:
 - i. 2 NTU, as a daily average;
 - ii. 5 NTU, more than 5% of the time within a 24-hour period; and
 - iii. 10 NTU, at any time.
- b. **Emergency Pond Operating Requirements.**
 - i. The treatment facilities shall be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency.
 - ii. Public contact with wastewater shall be precluded through such means as fences, signs, and other acceptable alternatives.
 - iii. Ponds shall be managed to prevent breeding of mosquitoes. In particular,
 - (a) An erosion control program should assure that small coves and irregularities are not created around the perimeter of the water surface.
 - (b) Weeds shall be minimized.
 - (c) Dead algae, vegetation, and debris shall not accumulate on the water surface.
 - iv. Freeboard shall never be less than 2 feet (measured vertically to the lowest point of overflow).

- v. The discharge of waste classified as "hazardous" as defined in section 2521(a) of Title 23, California Code of Regulations (CCR), or "designated", as defined in section 13173 of the CWC, to the treatment ponds is prohibited.
- vi. Objectionable odors originating at this Facility shall not be perceivable beyond the limits of the wastewater treatment and disposal areas (or property owned by the Discharger).

c. Ultraviolet (UV) Disinfection System Operating Requirements. The Discharger shall operate the UV disinfection system to provide a minimum UV dose of 100 millijoules per square centimeter (mJ/cm^2) at peak daily flow, unless otherwise approved by the California Department of Public Health.

- i. The Discharger shall provide continuous, reliable monitoring of flow, UV transmittance, UV power, and turbidity.
- ii. The Discharger shall operate the treatment system to insure that turbidity prior to disinfection shall not exceed specifications in Provision VI.C.4.a. of this Order
- iii. The UV transmittance (at 254 nanometers) in the wastewater exiting the UV disinfection system shall not fall below 55 percent of maximum at any time.
- iv. The quartz sleeve and cleaning system components must be visually inspected per the manufacturer's operations manual for physical wear (scoring, solarization, seal leaks, cleaning fluid levels, etc.) and to check the efficacy of the cleaning system.
- v. The sleeves must be cleaned periodically as necessary to meet the requirements.
- vi. Lamps must be replaced per the manufacturer's operations manual, or sooner, if there are indications the lamps are failing to provide adequate disinfection. Lamp age and lamp replacement records must be maintained.
- vii. The Facility must be operated in accordance with an operations and maintenance program that assures adequate disinfection.

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Sludge/Biosolids Discharge Specifications

- i. Collected screenings, residual sludge, biosolids, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer, and consistent with Consolidated Regulations for Treatment, Storage, Processing, or Disposal of Solid Waste, as set forth in Title 27, CCR, division 2, subdivision 1, section 20005, et seq. Removal for further treatment, disposal, or reuse at sites (e.g., landfill, composting sites, soil amendment sites) that are operated in accordance with valid waste

discharge requirements issued by a Central Valley Water Board will satisfy these specifications.

- ii. Sludge and solid waste shall be removed from screens, sumps, ponds, clarifiers, etc. as needed to ensure optimal plant performance.
- iii. The treatment of sludge generated at the Facility shall be confined to the Facility property and conducted in a manner that precludes infiltration of waste constituents into soils in a mass or concentration that will violate groundwater limitations in section V.B. of this Order. In addition, the storage of residual sludge, solid waste, and biosolids on Facility property shall be temporary and controlled, and contained in a manner that minimizes leachate formation and precludes infiltration of waste constituents into soils in a mass or concentration that will violate groundwater limitations included in section V.B. of this Order.
- iv. The use and disposal of biosolids shall comply with existing federal and state laws and regulations, including permitting requirements and technical standards included in 40 CFR Part 503. If the State Water Board and the Central Valley Water Board are given the authority to implement regulations contained in 40 CFR Part 503, this Order may be reopened to incorporate appropriate time schedules and technical standards. The Discharger must comply with the standards and time schedules contained in 40 CFR Part 503 whether or not they have been incorporated into this Order.

b. Biosolids Disposal Requirements

- i. The Discharger shall comply with the Monitoring and Reporting Program for biosolids disposal contained in Attachment E.
- ii. Any proposed change in biosolids use or disposal practice from a previously approved practice shall be reported to the Executive Officer and USEPA Regional Administrator at least 90 days in advance of the change.
- iii. The Discharger is encouraged to comply with the "Manual of Good Practice for Agricultural Land Application of Biosolids" developed by the California Water Environment Association.

c. Biosolids Storage Requirements

- i. Facilities for the storage of Class B biosolids shall be located, designed and maintained to restrict public access to biosolids.
- ii. Biosolids storage facilities shall be designed and maintained to prevent washout or inundation from a storm or flood with a return frequency of 100 years.

- iii. Biosolids storage facilities, which contain biosolids, shall be designed and maintained to contain all storm water falling on the biosolids storage area during a rainfall year with a return frequency of 100 years.
- iv. Biosolids storage facilities shall be designed, maintained and operated to minimize the generation of leachate.

d. **Collection System.** On 2 May 2006, the State Water Board adopted State Water Board Order No. 2006-0003, a Statewide General WDR for Sanitary Sewer Systems. The Discharger shall be subject to the requirements of Order No. 2006-0003 and any future revisions thereto. Order No. 2006-0003 requires that all public agencies that currently own or operate sanitary sewer systems apply for coverage under the General WDR. The Discharger has applied for and has been approved for coverage under State Water Board Order 2006-0003 for operation of its wastewater collection system.

Regardless of the coverage obtained under Order No. 2006-0003, the Discharger's collection system is part of the treatment system that is subject to this Order. As such, pursuant to federal regulations, the Discharger must properly operate and maintain its collection system [40 CFR 122.41(e)], report any non-compliance [40 CFR 122.41(l)(6) and (7)], and mitigate any discharge from the collection system in violation of this Order [40 CFR 122.41(d)].

- e. This permit, and the Monitoring and Reporting Program which is a part of this permit, requires that certain parameters be monitored on a continuous basis. The wastewater treatment plant is not staffed on a full time basis. Permit violations or system upsets can go undetected during this period. The Discharger is required to establish an electronic system for operator notification for continuous recording device alarms. For existing continuous monitoring systems, the electronic notification system shall be installed within 6 months of adoption of this permit. For systems installed following permit adoption, the notification system shall be installed simultaneously.

6. Other Special Provisions

- a. Wastewater shall be oxidized, coagulated, filtered, and adequately disinfected pursuant to the Department of Public Health (DPH; formerly the Department of Health Services) reclamation criteria, CCR, Title 22, division 4, chapter 3, (Title 22), or equivalent. This Order does not include the requirements for unrestricted beneficial reuse contained in Chapter 3. For wastewater disposal, the Discharger is required to meet Title 22 tertiary numeric effluent quality (hence the use of "of equivalent"), but not the monitoring, alarm, process design, redundancy and storage requirements for beneficial reuse that is the full suite of Title 22 requirements.

7. Compliance Schedules

- a. Compliance Schedule for Final Effluent Limitations for Arsenic and Total Trihalomethanes. This Order requires compliance with the final effluent limitations for total trihalomethanes by 3 years from the adoption date of this Order, and for arsenic by 5 years from the adoption date of this Order. The Discharger shall comply with the following time schedule to ensure compliance with the final effluent limitations:**

<u>Task</u>	<u>Compliance Due</u>
i. Update and Implement Pollution Prevention Plan (PPP) ¹ for Total Trihalomethanes and Arsenic	<u>Ongoing</u>
ii. Progress Reports ²	1 March and 1 September of each year
iii. Achieve Full Compliance with the Effluent Limitations IV.A.1.a for Total Trihalomethanes.	3 years from the adoption date of this Order
iv. Achieve Full Compliance with the Effluent Limitations IV.A.1.a for Arsenic.	5 years from the adoption date of this Order
¹ The PPP for total trihalomethanes and arsenic shall be updated and implemented in accordance with CWC section 13263.3(d)(3) as outlined in the Fact Sheet (Attachment F, Section VII.B.7.b.).	
² The progress reports shall detail what steps have been implemented towards achieving compliance with waste discharge requirements, including studies, construction progress, evaluation of measures implemented, and recommendations for additional measures as necessary to achieve full compliance by the final compliance date.	

VII. COMPLIANCE DETERMINATION

- A. BOD₅ and TSS Effluent Limitations (Section IV.A.1.a. and b.).** Compliance with the final effluent limitations for BOD₅ and TSS required in Limitations and Discharge Requirements section IV.A.1.a., shall be ascertained by 24-hour composite samples. Compliance with effluent limitations required in Limitations and Discharge Requirements section IV.A.1.b., for percent removal shall be calculated using the arithmetic mean of BOD₅ and TSS in effluent samples collected over a monthly period as a percentage of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.
- B. Aluminum Effluent Limitations (Section IV.A.1.a. and k.).** Compliance with the final effluent limitations for aluminum can be demonstrated using either total or acid-soluble (inductively coupled plasma/atomic emission spectrometry or inductively coupled plasma/mass spectrometry) analysis methods, as supported by USEPA's Ambient Water Quality Criteria for Aluminum document (EPA 440/5-86-008), or other standard methods that exclude aluminum silicate particles as approved by the Executive Officer.
- C. Average Dry Weather Flow Effluent Limitations (Section IV.A.1.g.).** The average dry weather discharge flow represents the daily average flow when groundwater is at or near normal and runoff is not occurring. Compliance with the average dry weather flow

effluent limitations will be determined annually based on the average daily flow over three consecutive dry weather months (e.g., July, August, and September).

D. Total Coliform Organisms Effluent Limitations (Section IV.A.1.f.). For each day that an effluent sample is collected and analyzed for total coliform organisms, the 7-day median shall be determined by calculating the median concentration of total coliform bacteria in the effluent utilizing the bacteriological results of the last 7 days. For example, if a sample is collected on a Wednesday, the result from that sampling event and all results from the previous 6 days (i.e., Tuesday, Monday, Sunday, Saturday, Friday, and Thursday) are used to calculate the 7-day median. If the 7-day median of total coliform organisms exceeds a most probable number (MPN) of 2.2 per 100 milliliters, the Discharger will be considered out of compliance.

E. Total Residual Chlorine Effluent Limitations (Section IV.A.1.e.). Continuous monitoring analyzers for chlorine residual or for dechlorination agent residual in the effluent are appropriate methods for compliance determination. A positive residual dechlorination agent in the effluent indicates that chlorine is not present in the discharge, which demonstrates compliance with the effluent limitations. This type of monitoring can also be used to prove that some chlorine residual exceedances are false positives. Continuous monitoring data showing either a positive dechlorination agent residual or a chlorine residual at or below the prescribed limit are sufficient to show compliance with the total residual chlorine effluent limitations, as long as the instruments are maintained and calibrated in accordance with the manufacturer's recommendations.

Any excursion above the 1-hour average or 4-day average total residual chlorine effluent limitations is a violation. If the Discharger conducts continuous monitoring and the Discharger can demonstrate, through data collected from a back-up monitoring system, that a chlorine spike recorded by the continuous monitor was not actually due to chlorine, then any excursion resulting from the recorded spike will not be considered an exceedance, but rather reported as a false positive. Records supporting validation of false positives shall be maintained in accordance with Section IV Standard Provisions (Attachment D).

F. Chronic Whole Effluent Toxicity Effluent Limitation (Section IV.A.1.d.). Compliance with the accelerated monitoring and TRE/TIE provisions of Provision VI.C.2.a shall constitute compliance with the effluent limitation.

G. Total Mercury Mass Loading Effluent Limitations (Section IV.A.2.b.). The procedures for calculation mass loadings are as follows:

1. The total pollutant mass load for each individual quarter shall be determined using an average of all concentration data collected that quarter and the corresponding total quarterly flow. All effluent monitoring data collected under the monitoring and reporting program, pretreatment program and any special studies shall be used for these calculations. The total annual mass loading shall be the sum of the individual quarters.

2. In calculating compliance, the Discharger shall count all non-detect measures at one-half of the detection level. If compliance with the effluent limitation is not attained due to the non-detect contribution, the Discharger shall improve and implement available analytical capabilities and compliance shall be evaluated with consideration of the detection limits.

H. Mass Effluent Limitations. The mass effluent limitations contained in Final Effluent Limitations Section IV.A.1.a. and Interim Effluent Limitations Section IV.A.2.b. are based on the permitted average dry weather flow and calculated as follows:

$$\text{Mass (lbs/day)} = \text{Flow (MGD)} \times \text{Concentration (mg/L)} \times 8.34 \text{ (conversion factor)}$$

If the effluent flow exceeds the permitted average dry weather flow during wet-weather seasons, the effluent mass limitations contained in Final Effluent Limitations Section IV.A.1.a. and Interim Limitations Section IV.A.2.b. shall not apply. If the effluent flow is below the permitted average dry weather flow during wet-weather seasons, the effluent mass limitations do apply.

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ)

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

Arithmetic mean = $\mu = \Sigma x / n$ where: Σx is the sum of the measured ambient water concentrations, and n is the number of samples.

Average Monthly Effluent Limitation (AMEL)

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL)

The highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic

Pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV)

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge

Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of 1 day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ)

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA)

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in CWC section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters

All surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation

The highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

The lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL)

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL)

MDL is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in 40 CFR Part 136, Attachment B, revised as of 3 July 1999.

Minimum Level (ML)

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND)

Sample results which are less than the laboratory's MDL.

Ocean Waters

The territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent Pollutants

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP)

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Central Valley Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to CWC section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Central Valley Water Board.

Reporting Level (RL)

RL is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Central Valley Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System

The portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water

Any water designated as municipal or domestic supply (MUN) in a Central Valley Water Board Basin Plan.

Standard Deviation (σ)

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.

Toxicity Reduction Evaluation (TRE)

TRE is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT D – STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (CWC) and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 CFR 122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 CFR 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 CFR 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR 122.41(g).)

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 CFR 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Central Valley Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR 122.41(i); CWC section 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 CFR 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 CFR 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 CFR 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the CWC, any substances or parameters at any location. (40 CFR 122.41(i)(4).)

G. Bypass

1. Definitions

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR 122.41(m)(1)(i).)
- b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR 122.41(m)(1)(ii).)

2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 CFR 122.41(m)(2).)

3. Prohibition of bypass. Bypass is prohibited, and the Central Valley Water Board may take enforcement action against a Discharger for bypass, unless (40 CFR 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Central Valley Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR 122.41(m)(4)(i)(C).)
4. The Central Valley Water Board may approve an anticipated bypass, after considering its adverse effects, if the Central Valley Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 CFR 122.41(m)(4)(ii).)
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR 122.41(m)(3)(i).)
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was

caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR 122.41(n)(2).)

2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 CFR 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 CFR 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 CFR 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 CFR 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Central Valley Water Board. The Central Valley Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the CWC. (40 CFR 122.41(l)(3) and 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR 122.41(j)(1).)
- B. Monitoring results must be conducted according to test procedures under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503 unless other test procedures have been specified in this Order. (40 CFR 122.41(j)(4) and 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least 5 years (or longer as required by 40 CFR Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Central Valley Water Board Executive Officer at any time. (40 CFR 122.41(j)(2).)

B. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements (40 CFR 122.41(j)(3)(i));
2. The individual(s) who performed the sampling or measurements (40 CFR 122.41(j)(3)(ii));
3. The date(s) analyses were performed (40 CFR 122.41(j)(3)(iii));
4. The individual(s) who performed the analyses (40 CFR 122.41(j)(3)(iv));
5. The analytical techniques or methods used (40 CFR 122.41(j)(3)(v)); and
6. The results of such analyses. (40 CFR 122.41(j)(3)(vi).)

C. Claims of confidentiality for the following information will be denied (40 CFR 122.7(b)):

1. The name and address of any permit applicant or Discharger (40 CFR 122.7(b)(1)); and
2. Permit applications and attachments, permits and effluent data. (40 CFR 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Central Valley Water Board, State Water Board, or USEPA within a reasonable time, any information which the Central Valley Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Central Valley Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR 122.41(h); Wat. Code, § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Central Valley Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Central Valley Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR 122.22(b)(2)); and
 - c. The written authorization is submitted to the Central Valley Water Board and State Water Board. (40 CFR 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard

Provisions – Reporting V.B.3 above must be submitted to the Central Valley Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR 122.22(c).)

5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations." (40 CFR 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Central Valley Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 CFR 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Central Valley Water Board. (40 CFR 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time

the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR 122.41(l)(6)(i).)

2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR 122.41(l)(6)(ii)(B).)
3. The Central Valley Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Central Valley Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b) (40 CFR 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 CFR 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Central Valley Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 CFR 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Central Valley Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 CFR 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A.** The Central Valley Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13385, 13386, and 13387

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Central Valley Water Board of the following (40 CFR 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 CFR 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR 122.42(b)(3).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Table of Contents

I.	General Monitoring Provisions.....	E-2
II.	Monitoring Locations	E-3
III.	Influent Monitoring Requirements.....	E-4
	A. Monitoring Location INF-001.....	E-4
IV.	Effluent Monitoring Requirements	E-4
	A. Monitoring Location EFF-001.....	E-4
	B. Monitoring Location EFF-002.....	E-6
V.	Whole Effluent Toxicity Testing Requirements	E-7
VI.	Land Discharge Monitoring Requirements – NOT APPLICABLE	E-10
VII.	Reclamation Monitoring Requirements – NOT APPLICABLE	E-10
VIII.	Receiving Water Monitoring Requirements – Surface Water and Groundwater	E-10
	A. Monitoring Locations RSW-001 and RSW-002	E-10
	B. Groundwater Monitoring – NOT APPLICABLE	E-11
IX.	Other Monitoring Requirements.....	E-11
	A. Biosolids	E-11
	B. Pond/Lagoon Monitoring.....	E-12
	1. Monitoring Location PLG-001	E-12
	C. Equalization Basin and Emergency Storage Basin.....	E-12
	1. Monitoring Locations PND-001 and PND-002	E-12
	D. Ultraviolet Light (UV) Disinfection System	E-13
	1. Monitoring Location UVS-001.....	E-13
	E. Municipal Water Supply	E-13
X.	Reporting Requirements.....	E-14
	A. General Monitoring and Reporting Requirements.....	E-14
	B. Self Monitoring Reports (SMRs)	E-14
	C. Discharge Monitoring Reports (DMRs)	E-19
	D. Other Reports	E-19

List of Tables

Table E-1.	Monitoring Station Locations.....	E-3
Table E-2.	Influent Monitoring for INF-001.....	E-4
Table E-3.	Effluent Monitoring for EFF-001	E-4
Table E-4.	Effluent Monitoring for EFF-002	E-7
Table E-5.	Chronic Toxicity Testing Dilution Series	E-8
Table E-6.	Receiving Water Monitoring Requirements for RSW-001 and RSW-002.....	E-10
Table E-7.	Pond/Lagoon Monitoring Requirements.....	E-12
Table E-8.	Ultraviolet Disinfection System Monitoring Requirements.....	E-13
Table E-9.	Municipal Water Supply Monitoring Requirements for SPL-001.....	E-13
Table E-10.	Monitoring Periods and Reporting Schedule.....	E-16
Table E-11.	Reporting Requirements for Special Provisions Progress Reports	E-19

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Title 40 of the Code of Federal Regulations (CFR), section 122.48 (40 CFR 122.48) requires that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Central Valley Water Board) to require technical and monitoring reports. This Monitoring and Reporting Program establishes monitoring and reporting requirements, which implement the federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A.** Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring locations specified below and, unless otherwise specified, before the monitored flow joins or is diluted by any other waste stream, body of water, or substance. Monitoring locations shall not be changed without notification to and the approval of this Central Valley Water Board.
- B.** Effluent samples shall be taken downstream of the last addition of wastes to the treatment or discharge works where a representative sample may be obtained prior to mixing with the receiving waters. Samples shall be collected at such a point and in such a manner to ensure a representative sample of the discharge.
- C.** Chemical, bacteriological, and bioassay analyses shall be conducted at a laboratory certified for such analyses by the Department of Public Health (DPH; formerly the Department of Health Services). In the event a certified laboratory is not available to the Discharger, analyses performed by a noncertified laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory. A manual containing the steps followed in this program must be kept in the laboratory and shall be available for inspection by Central Valley Water Board staff. The Quality Assurance-Quality Control Program must conform to USEPA guidelines or to procedures approved by the Central Valley Water Board.
- D.** All analyses shall be performed in a laboratory certified to perform such analyses by DPH. Laboratories that perform sample analyses must be identified in all monitoring reports submitted to the Central Valley Water Board.
- E.** Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary, at least yearly, to ensure their continued accuracy. All flow measurement devices shall be calibrated at least once per year to ensure continued accuracy of the devices.
- F.** Monitoring results, including noncompliance, shall be reported at intervals and in a manner specified in this Monitoring and Reporting Program.

- G. Laboratories analyzing monitoring samples shall be certified by DPH, in accordance with the provision of CWC section 13176, and must include quality assurance/quality control data with their reports.
- H. The Discharger shall conduct analysis on any sample provided by USEPA as part of the Discharge Monitoring Quality Assurance (DMQA) program. The results of any such analysis shall be submitted to USEPA's DMQA manager.
- I. The Discharger shall file with the Central Valley Water Board technical reports on self-monitoring performed according to the detailed specifications contained in this Monitoring and Reporting Program.
- J. The results of all monitoring required by this Order shall be reported to the Central Valley Water Board, and shall be submitted in such a format as to allow direct comparison with the limitations and requirements of this Order. Unless otherwise specified, discharge flows shall be reported in terms of the monthly average and the daily maximum discharge flows.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
--	INF-001	Location where a representative sample of the facility's influent can be obtained, prior to any additives, treatment processes, and plant return flows.
001 ¹	EFF-001	Location where a representative sample of the facility's effluent can be obtained prior to discharge into the receiving water.
--	EFF-002	Location where a representative sample of the facility's effluent pH and turbidity can be obtained downstream of the facility's tertiary filters and upstream of the UV disinfection system. Note: New tertiary facility only.
	RSW-001 ¹	Approximately 50 feet upstream of Discharge Point No. 001 to the receiving water.
--	RSW-002 ¹	Approximately 200 feet downstream of Discharge Point No. 001 to the receiving water or upstream of the next ag drain.
--	BIO-001	Representative sample location for biosolids.
--	PLG-001	Representative sample location for pond/lagoon effluent. Note: Existing secondary facility only.
--	PND-001	Representative sample location for equalization pond effluent. Note: New tertiary facility only.
--	PND-002	Representative sample location for emergency storage pond effluent. Note: New tertiary facility only.
--	UVS-001	Representative sample location for the ultraviolet light disinfection system. Note: New tertiary facility only.

--	SPL-001	A location where a representative sample for the municipal water supply can be collected. If the water supply is from more than one source, a flow weighted average should be calculated.
----	---------	--

¹ Currently the Facility discharges from Discharge Point No. 001 into the receiving water, Reclamation District 777 Lateral Drain No. 1; however, following completion of the new tertiary treatment system, the Facility will discharge into Reclamation District 777 Lateral Drain No. 2.

III. INFLUENT MONITORING REQUIREMENTS

A. Monitoring Location INF-001

1. The Discharger shall monitor influent to the facility at INF-001 as follows:

Table E-2. Influent Monitoring for INF-001

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	MGD	Meter	Continuous	1
pH	Standard Units	Grab ²	1/Week	1
BOD 5-day @ 20°C	mg/L	24-hr Composite ³	1/Week	1
Total Suspended Solids	mg/L	24-hr Composite ³	1/Week	1
Electrical Conductivity @ 25°C	µmhos/cm	Grab ²	1/Month	1
Total Dissolved Solids	mg/L	Grab ²	1/Quarter	1

¹ Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; where no methods are specified for a given pollutant, method shall be approved by the Central Valley Water Board or the State Water Board.

² Grab samples shall not be collected at the same time each day to get a complete representation of variations in the influent.

³ 24-hour flow proportional composite.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location EFF-001

1. The Discharger shall monitor tertiary treated effluent at EFF-001 as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level:

Table E-3. Effluent Monitoring for EFF-001

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	MGD	Meter	Continuous	1
Chlorine, Total Residual	mg/L	Meter ⁸	Continuous ⁸	1,8
Turbidity ¹⁰	NTU	Grab ⁷	Daily	1

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Temperature	F (or as C)	Grab ⁷	1/Week ⁵	1
Total Coliform Organisms	MPN/100 mL	Grab ⁷	2/Week	1
Electrical Conductivity @ 25 C	µmhos/cm	24-hr Composite ²	1/Week	1
Biochemical Oxygen Demand 5-day @ 20 C	mg/L	24-hr Composite ²	1/Week	1
	lbs/day	Calculate	1/Week	
Total Suspended Solids	mg/L	24-hr Composite ²	1/Week	1
	lbs/day	Calculate	1/Week	
Ammonia, Total (as N)	mg/L	Grab ⁷	1/Week ^{4,5}	1
	lbs/day	Calculate	1/Week	
Dissolved Oxygen	mg/L & % saturation	Grab ⁷	1/Week	1
pH ¹⁰	Standard Units	Grab ⁷	1/Week	1
Aluminium, Total Recoverable	µg/L	24-hr Composite ²	1/Month	1,6
Arsenic	µg/L	24-hr Composite ²	1/Month	1,3
Nitrate (as N)	mg/L	Grab ⁷	1/Month	1
Hardness (as CaCO ₃)	mg/L	24-hr Composite ²	1/Month	1
Copper, Total Recoverable	µg/L	24-hr Composite ²	1/Month	1,3
Total Trihalomethanes	µg/L	24-hr Composite ²	1/Month	1,3
Dibromochloromethane	µg/L	Grab ⁷	1/Month	1,3
Dichlorobromomethane	µg/L	Grab ⁷	1/Month	1,3
Cadmium, Total Recoverable	µg/L	24-hr Composite ²	1/Quarter	1,3
Alpha BHC	µg/L	24-hr Composite ²	1/Quarter	1,3
4,4'-DDE	µg/L	24-hr Composite ²	1/Quarter	1,3
Alpha Endosulfan	µg/L	24-hr Composite ²	1/Quarter	1,3
Endrin Aldelhyde	µg/L	24-hr Composite ²	1/Quarter	1,3
Iron	µg/L	24-hr Composite ²	1/Quarter	1
Manganese	µg/L	24-hr Composite ²	1/Quarter	1
Total Dissolved Solids	mg/L	24-hr Composite ²	1/Quarter ⁹	1

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Mercury, Total Recoverable	µg/L	Grab ⁷	1/Quarter	9
Mercury, Methyl	µg/L	Grab ⁷	1/Quarter	9
Standard Minerals, Priority Pollutant, and Other Constituents of Concern (See Section X.D.5. below)	µg/L	Grab ⁷	Quarterly during 3 rd or 4 th year of permit term	1,3
Whole Effluent Toxicity (see Section V. below)	--	--	--	--

- ¹ Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; where no methods are specified for a given pollutant, method shall be approved by the Central Valley Water Board or the State Water Board.
- ² 24-hour flow proportioned composite.
- ³ For priority pollutant constituents with effluent limitations, detection limits shall be below the effluent limitations. If the lowest minimum level (ML) published in Appendix 4 of the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Plan or SIP) is not below the effluent limitation, the detection limit shall be the lowest ML. For priority pollutant constituents without effluent limitations, the detection limits shall be equal to or less than the lowest ML published in Appendix 4 of the SIP.
- ⁴ Concurrent with whole effluent toxicity monitoring.
- ⁵ pH and temperature shall be recorded at the time of ammonia sample collection.
- ⁶ Compliance with the final effluent limitations for aluminum can be demonstrated using either total or acid-soluble (inductively coupled plasma/atomic emission spectrometry or inductively coupled plasma/mass spectrometry) analysis methods, as supported by USEPA's Ambient Water Quality Criteria for Aluminum document (EPA 440/5-86-008), or other standard methods that exclude aluminum silicate particles as approved by the Executive Officer.
- ⁷ Grab samples shall not be collected at the same time each day to get a complete representation of variations in the effluent.
- ⁸ Total chlorine residual must be monitored with a method sensitive to and accurate at the permitted level of 0.01 mg/L. When effluent disinfection by chlorine is replaced by UV disinfection with the new Facility, total residual chlorine monitoring is required when the Facility uses chlorine for maintenance purposes and monitoring can be achieved by daily grab samples. Whenever chlorine is scheduled to be used for maintenance of the new Facility, the Discharger shall monitor chlorine residual one week prior to use and one week after the end of use. If chlorine is needed for an unforeseen operational or maintenance event, chlorine residual shall be monitored beginning the first day of use until one day after the end of use of chlorine.
- ⁹ Unfiltered methyl mercury and total mercury samples shall be taken using clean hands/dirty hands procedures, as described in U.S. EPA method 1669: Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels, for collection of equipment blanks (section 9.4.4.2), and shall be analyzed by U.S. EPA method 1630/1631 (Revision E) with a method detection limit of 0.02 ng/l for methylmercury and 0.2 ng/l for total mercury.
- ¹⁰ When the new Facility is completed, monitoring for turbidity and pH shall be conducted according to Section IV.B. of the Monitoring and Reporting Program. Upon initiation of operation of the new Facility, the Discharger shall indicate in the SMR that the monitoring location has changed.

B. Monitoring Location EFF-002

1. The Discharger shall monitor tertiary filtered effluent at EFF-002 as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level:

Table E-4. Effluent Monitoring for EFF-002

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Turbidity	NTU	Meter	Continuous	1
pH	Standard Units	Grab ²	1/Week	1

¹ Parameters shall be analyzed using the analytical methods described in 40 CFR Part 136; where no methods are specified for a given parameter, method shall be approved by the Central Valley Water Board or the State Water Board.

² Grab samples shall not be collected at the same time each day to get a complete representation of variations in the effluent.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Acute Toxicity Testing. The Discharger shall conduct acute toxicity testing to determine whether the effluent is contributing acute toxicity to the receiving water. The Discharger shall meet the following acute toxicity testing requirements:

1. Monitoring Frequency – The Discharger shall perform quarterly acute toxicity testing, concurrent with effluent ammonia sampling.
2. Sample Types – For static non-renewal and static renewal testing, the samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location EFF-001.
3. Test Species – Test species shall be fathead minnows (*Pimephales promelas*).
4. Methods – The acute toxicity testing samples shall be analyzed using EPA-821-R-02-012, Fifth Edition. Temperature, total residual chlorine, and pH shall be recorded at the time of sample collection. No pH adjustment may be made unless approved by the Executive Officer. In lieu of performing a separate acute bioassay, the Discharger may report the 96-hour percent survival of the fathead minnow species with the results from the chronic toxicity test procedure for determination of compliance with acute toxicity requirements. The results for acute and chronic testing must be reported separately.
5. Test Failure – If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger must re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.

B. Chronic Toxicity Testing. The Discharger shall conduct three species chronic toxicity testing to determine whether the effluent is contributing chronic toxicity to the receiving water. The Discharger shall meet the following chronic toxicity testing requirements:

1. Monitoring Frequency – The Discharger shall perform quarterly three species chronic toxicity testing.

2. Sample Types – Effluent samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location EFF-001. The receiving water control shall be a grab sample obtained from the RSW-001 sampling location, as identified in this Monitoring and Reporting Program.
3. Sample Volumes – Adequate sample volumes shall be collected to provide renewal water to complete the test in the event that the discharge is intermittent.
4. Test Species – Chronic toxicity testing measures sublethal (e.g., reduced growth, reproduction) and/or lethal effects to test organisms exposed to an effluent compared to that of the control organisms. The Discharger shall conduct chronic toxicity tests with:
 - The cladoceran, water flea, *Ceriodaphnia dubia* (survival and reproduction test);
 - The fathead minnow, *Pimephales promelas* (larval survival and growth test); and
 - The green alga, *Selenastrum capricornutum* (growth test).
5. Methods – The presence of chronic toxicity shall be estimated as specified in *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition*, EPA/821-R-02-013, October 2002.
6. Reference Toxicant – As required by the SIP, all chronic toxicity tests shall be conducted with concurrent testing with a reference toxicant and shall be reported with the chronic toxicity test results.
7. Dilutions – For regular and accelerated chronic toxicity testing it is not necessary to perform the test using a dilution series. The test may be performed using 100% effluent. If toxicity is found in any regular effluent test, the Discharger must immediately retest using the dilution series identified in Table E-5, below. For TRE monitoring, the chronic toxicity testing shall be performed using the full dilution series identified in Table E-5, below. The receiving water control shall be used as the diluent (unless the receiving water is toxic).

Table E-5. Chronic Toxicity Testing Dilution Series

Sample	Dilutions (%)					Controls	
	100	75	50	25	12.5	Receiving Water	Laboratory Water
% Effluent	100	75	50	25	12.5	0	0
% Receiving Water	0	25	50	75	87.5	100	0
% Laboratory Water	0	0	0	0	0	0	100

8. Test Failure – The Discharger must re-sample and re-test as soon as possible, but no later than fourteen (14) days after receiving notification of a test failure. A test failure is defined as follows:

- a. The reference toxicant test or the effluent test does not meet all test acceptability criteria as specified in the *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition*, EPA/821-R-02-013, October 2002 (Method Manual), and its subsequent amendments or revisions; or
 - b. The percent minimum significant difference (PMSD) measured for the test exceeds the upper PMSD bound variability criterion in Table 6 on page 52 of the Method Manual. (A retest is only required in this case if the test results do not exceed the monitoring trigger specified in the Special Provision at section VI. 2.a.iii. of the Order.)
- C. WET Testing Notification Requirements.** The Discharger shall notify the Central Valley Water Board within 24-hours after the receipt of test results exceeding the monitoring trigger during regular or accelerated monitoring, or an exceedance of the acute toxicity effluent limitation.
- D. WET Testing Reporting Requirements.** All toxicity test reports shall include the contracting laboratory's complete report provided to the Discharger and shall be in accordance with the appropriate "Report Preparation and Test Review" sections of the method manuals. At a minimum, whole effluent toxicity monitoring shall be reported as follows:
1. **Chronic WET Reporting.** Regular chronic toxicity monitoring results shall be reported to the Central Valley Water Board within 30 days following completion of the test, and shall contain, at minimum:
 - a. The results expressed in TU_c, measured as 100/NOEC, and also measured as 100/LC50, 100/EC25, 100/IC25, and 100/IC50, as appropriate.
 - b. The statistical methods used to calculate endpoints;
 - c. The statistical output page, which includes the calculation of the percent minimum significant difference (PMSD);
 - d. The dates of sample collection and initiation of each toxicity test; and
 - e. The results compared to the numeric toxicity monitoring trigger.

Additionally, the monthly discharger self-monitoring reports shall contain an updated chronology of chronic toxicity test results expressed in TU_c, and organized by test species, type of test (survival, growth or reproduction), and monitoring frequency, i.e., either quarterly, monthly, accelerated, or Toxicity Reduction Evaluation (TRE).
 2. **Acute WET Reporting.** Acute toxicity test results shall be submitted with the monthly discharger self-monitoring reports and reported as percent survival.
 3. **TRE Reporting.** Reports for TREs shall be submitted in accordance with the schedule contained in the Discharger's approved TRE Workplan.

4. Quality Assurance (QA). The Discharger must provide the following information for QA purposes *(if applicable)*:

- a. Results of the applicable reference toxicant data with the statistical output page giving the species, NOEC, LOEC, type of toxicant, dilution water used, concentrations used, PMSD, and dates tested.
- b. The reference toxicant control charts for each endpoint, which include summaries of reference toxicant tests performed by the contracting laboratory.
- c. Any information on deviations or problems encountered and how they were dealt with.

VI. LAND DISCHARGE MONITORING REQUIREMENTS – NOT APPLICABLE

VII. RECLAMATION MONITORING REQUIREMENTS – NOT APPLICABLE

VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER AND GROUNDWATER

A. Monitoring Locations RSW-001 and RSW-002

- 1. The Discharger currently discharges to Reclamation District 777 Lateral Drain No. 1 as the receiving water; however, the new tertiary treatment facility proposes to utilize a Reclamation District 777 Lateral Drain No. 2 as the receiving water. For either receiving water, the monitoring requirements for RSW-001 and RSW-002 apply. The Discharger shall monitor the receiving water at RSW-001 or RSW-002 as follows:

Table E-6. Receiving Water Monitoring Requirements for RSW-001 and RSW-002

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Dissolved Oxygen	mg/L ¹ % saturation ¹	Grab ²	1/Week ³	4
pH	standard units	Grab ²	1/Week ³	4
Turbidity	NTU	Grab ²	1/Week ³	4
Temperature	°F (or °C)	Grab ²	1/Week ³	4
Electrical Conductivity @ 25°C	µmhos/cm	Grab ²	1/Week ³	4
Hardness (as CaCO ₃)	mg/L	Grab ²	1/Month ³	4
Total Dissolved Solids	mg/L	Grab ²	1/Quarter ³	4
Standard Minerals, Priority Pollutant, and Other Constituents of Concern (See Section X.D.5. below)	µg/L	Grab ²	Quarterly during 3 rd or 4 th year of permit term	4

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
-----------	-------	-------------	----------------------------	---------------------------------

- ¹ Report both saturation concentration and percent saturation.
- ² Grab samples shall not be collected at the same time each day to get a complete representation of variations in the effluent. If there is no flow in the receiving water (RSW-001 or RSW-002, whichever is applicable) at time of sampling, no sample is required; however all reporting requirements for RSW-001 or RSW-002 still apply and reporting no-flow conditions is required. Flow is a downstream movement of water in sufficient volume to grab a reliable sample. Any receiving water limitation dependent upon available flow in the receiving water shall not be considered in violation, if no flow is available for sampling.
- ³ Monitoring must be concurrent with effluent discharge monitoring.
- ⁴ Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; where no methods are specified for a given pollutant, method shall be approved by the Central Valley Water Board or the State Water Board.

B. Groundwater Monitoring – NOT APPLICABLE

IX. OTHER MONITORING REQUIREMENTS

A. Biosolids

1. Monitoring Location BIO-001

- a. A composite sample of sludge shall be collected annually at Monitoring Location BIO-001 in accordance with USEPA's *POTW Sludge Sampling and Analysis Guidance Document*, August 1989, and tested for the metals listed in Title 22.
- b. Sampling records shall be retained for a minimum of 5 years. A log shall be maintained of sludge quantities generated and of handling and disposal activities. The frequency of entries is discretionary; however, the log must be complete enough to serve as a basis for part of the annual report.
- c. Upon removal of sludge, the Discharger shall submit characterization of sludge quality, including sludge percent solids and the most recent quantitative results of chemical analysis for the priority pollutants listed in 40 CFR Part 122, Appendix D, Tables II and III (excluding total phenols). In addition to USEPA's *POTW Sludge Sampling and Analysis Guidance Document*, August 1989, suggested methods for analysis of sludge are provided in USEPA publications titled *Test Methods for Evaluating Solid Waste: Physical/Chemical Methods* and *Test Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater*. Recommended analytical holding times for sludge samples should reflect those specified in 40 CFR 136.6.3(e). Other guidance is available.

B. Pond/Lagoon Monitoring

1. Monitoring Location PLG-001

- a. The Discharger shall monitor the wastewater impounded in the existing secondary facility's pond(s)/lagoon(s) at PLG-001 as follows. When the pond(s)/lagoons(s) are not in use, the monthly self-monitoring report shall so state.

Table E-7. Pond/Lagoon Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency
Freeboard	feet ¹	Grab	Weekly ³
Dissolved Oxygen ²	mg/L	Grab	Weekly ³
Odors	--	--	Weekly ³
pH ²	Standard Units	Grab	Weekly ³
Electrical Conductivity @ 25°C ²	µmhos/cm	Grab	Weekly ³

¹ To be measured vertically to the lowest point of overflow.

² A hand-held field meter may be used, provided the meter utilizes a U.S. EPA-approved algorithm method, and is calibrated and maintained in accordance with the manufacturer's instructions. A calibration and maintenance log for each meter used for monitoring required by this Monitoring and Reporting Program shall be maintained at the WWTP.

³ Sampling is not required when the depth of water covering the entire basin is less than one foot.

C. Equalization Basin and Emergency Storage Basin

1. Monitoring Locations PND-001 and PND-002

- a. The Discharger shall monitor the wastewater impounded in the Facility equalization basin at PND-001 and the emergency storage basin at PND-002 as follows. A sampling station shall be established where a representative sample of the wastewater in the basins can be obtained. Monitoring is required only when the depth of water covering the entire basin is more than one foot; however, the monthly self-monitoring report shall so state.
- b. The Discharger shall keep a log related to the use of each basin. In particular the Discharger shall record the following when any type of wastewater is directed to the basins;
- i. The date(s) when the wastewater is directed to the basin;
 - ii. The type(s) of wastewater (e.g., untreated due to plant upset, tertiary treated) directed to the basin;
 - iii. The total volume of wastewater directed to each basin;
 - iv. The duration of time wastewater is collected in the basin; prior to redirection back to the wastewater treatment plant; and
 - v. The date when all wastewater in the basin has been redirected to the wastewater treatment plant.

- vi. The freeboard available in the basin.
- c. The basin logs shall be submitted with the monthly self-monitoring reports required in Section X.B. of the Monitoring and Reporting Program (Attachment E).

D. Ultraviolet Light (UV) Disinfection System

1. Monitoring Location UVS-001

The Discharger shall monitor the UV disinfection system at UVS-001 when the system is operational, as follows:

Table E-8. Ultraviolet Disinfection System Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency
Flow rate	MGD	Meter	Continuous
Turbidity ¹	NTU	Meter	Continuous
Number of UV banks in operation	Number	Meter	Continuous
UV Transmittance ^{3,4}	Percent (%)	Meter	Continuous
UV Power Setting	Percent (%)	Meter	Continuous
UV Dose ²	mJ/cm ²	Calculated	Continuous

- ¹ Report daily average and maximum turbidity. If the influent exceeds 10 NTU, collect a sample for total coliform at EFF-001 and report the duration of the turbidity exceedance.
- ² Report daily minimum UV dose, daily average UV dose, and weekly average UV dose. If effluent discharge has received less than the minimum UV dose and is not diverted from discharging to the receiving water, report the duration associated with each incident.
- ³ The Discharger shall report documented routine meter maintenance activities, including date, time of day, duration, in which the UV transmittance analyzer(s) is not in operation to record monitoring information
- ⁴ The UV transmittance analyzer can be out of service for calibration no more than 2 hours. One UV transmittance sample shall be collected and analyzed. Grab sample results will then be entered into the UV control system as the value used for UV dose calculation.

E. Municipal Water Supply

1. Monitoring Location SPL-001

The Discharger shall monitor the municipal water supply at SPL-001 as follows. A sampling station shall be established where a representative sample of the municipal water supply can be obtained. Municipal water supply samples shall be collected at approximately the same time as effluent samples.

Table E-9. Municipal Water Supply Monitoring Requirements for SPL-001

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Electrical Conductivity @ 25°C ¹	µmhos/cm	Grab	1/Quarter	²
Total Dissolved Solids ¹	mg/L	Grab	1/Quarter	²
Standard Minerals ³	mg/L	Grab	1/Year	²

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
-----------	-------	-------------	----------------------------	---------------------------------

- ¹ If the water supply is from more than one source, the total dissolved solids and electrical conductivity shall be reported as a weighted average and include copies of supporting calculations.
- ² Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; where no methods are specified for a given pollutant, method shall be approved by the Central Valley Water Board or the State Water Board.
- ³ Standard minerals shall include all major cations and anions and include verification that the analysis is complete (i.e., cation/anion balance).

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. Upon written request of the Central Valley Water Board, the Discharger shall submit a summary monitoring report. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year(s).
3. **Compliance Time Schedules.** For compliance time schedules included in the Order, the Discharger shall submit to the Central Valley Water Board, on or before each compliance due date, the specified document or a written report detailing compliance or noncompliance with the specific date and task. If noncompliance is reported, the Discharger shall state the reasons for noncompliance and include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Central Valley Water Board by letter when it returns to compliance with the compliance time schedule.
4. The Discharger shall report to the Central Valley Water Board any toxic chemical release data it reports to the State Emergency Response Commission within 15 days of reporting the data to the Commission pursuant to section 313 of the "Emergency Planning and Community Right to Know Act" of 1986.
5. **Calendar Year Annual Average Effluent Limits.** The Discharger shall report the calculated annual average monitoring results in the December SMR.

B. Self Monitoring Reports (SMRs)

1. At any time during the term of this permit, the State Water Board or the Central Valley Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.

2. The Discharger shall report in the SMR the results for all monitoring specified in this Monitoring and Reporting Program under sections III through IX. The Discharger shall submit monthly SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. If the Discharger monitors any parameter more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly whether the discharge complies with waste discharge requirements (e.g., effluent limitations and discharge specifications, receiving water limitations, special provisions, etc.). The highest daily maximum for the month and monthly and weekly averages shall be determined and recorded as needed to demonstrate compliance. In addition, the following shall be calculated and reported in the SMRs:
 - a. **Annual Average Limitations.** For constituents with effluent limitations specified as "annual average" (aluminum, electrical conductivity, iron, and manganese) the Discharger shall report the annual average in the December SMR. The annual average shall be calculated as the average of the samples gathered for the calendar year.
 - b. **Mass Loading Limitations.** For BOD₅, TSS, and ammonia, the Discharger shall calculate and report the mass loading (lbs/day) in the SMRs. The mass loading shall be calculated as follows:
$$\text{Mass Loading (lbs/day)} = \text{Flow (MGD)} \times \text{Concentration (mg/L)} \times 8.34$$

When calculating daily mass loading, the daily average flow and constituent concentration shall be used. For weekly average mass loading, the weekly average flow and constituent concentration shall be used. For monthly average mass loading, the monthly average flow and constituent concentration shall be used.
 - c. **Mercury.** The Discharger shall calculate and report effluent total annual mass loading of total mercury in the December SMR. The total annual mass loading shall be calculated as specified in Section VII.G. of the Limitations and Discharge Requirements.
 - d. **Removal Efficiency (BOD₅ and TSS).** The Discharger shall calculate and report the percent removal of BOD₅ and TSS in the SMRs. The percent removal shall be calculated as specified in Section VII.A. of the Limitations and Discharger Requirements.
 - e. **Average Dry Weather Flow.** The Discharger shall calculate and report the average dry weather flow for the Facility discharge in the December SMR. The

average dry weather flow shall be calculated annually as specified in Section VII.C. of the Limitations and Discharge Requirements.

- f. **Total Coliform Organisms Effluent Limitations.** The Discharger shall calculate and report the 7-day median of total coliform organisms for the effluent. The 7-day median of total coliform organisms shall be calculated as specified in Section VII.D. of the Limitations and Discharge Requirements.
- g. **Dissolved Oxygen Receiving Water Limitations.** The Discharger shall calculate and report monthly in the self-monitoring report: i) the dissolved oxygen concentration, ii) the percent of saturation in the main water mass, and iii) the 95th percentile dissolved oxygen concentration.
- h. **Turbidity Receiving Water Limitations.** The Discharger shall calculate and report the turbidity increase in the receiving water applicable to the natural turbidity condition specified in Section V.A.17.a-e. of the Limitations and Discharge Requirements. If there is no flow at RSW-001 at time of sampling, no RSW-001 sample is required, however, all reporting requirements for RSW-001 still apply and reporting the lack of flow is required. Flow is a downstream movement of water in sufficient volume to grab a reliable sample. Any effluent limitation dependant upon available flow in the receiving water shall not be considered in violation, if no flow is available for sampling.
- i. **Temperature Receiving Water Limitations.** The Discharger shall calculate and report the temperature increase in the receiving water based on the difference in temperature at RSW-001 and RSW-002. If there is no flow at RSW-001 at time of sampling, no RSW-001 sample is required, however, all reporting requirements for RSW-001 still apply and reporting the lack of flow is required. Flow is a downstream movement of water in sufficient volume to grab a reliable sample. Any effluent limitation dependant upon available flow in the receiving water shall not be considered in violation, if no flow is available for sampling.

4. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-10. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	Submit with monthly SMR
Daily	Permit effective date	All	Submit with monthly SMR
1/Week	Permit effective date	Sunday through Saturday	Submit with monthly SMR
3/Week	Permit effective date	Sunday through Saturday	Submit with monthly SMR
1/Month	Permit effective date	First day of calendar month through last day of calendar month	First day of second calendar month following month of sampling

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
1/Quarter	Permit effective date	1 January through 1 March; 1 April through 30 June; 1 July through 30 September; 1 October through 31 December	First day of second calendar month following the end of the monitoring period
1/Year	Permit effective date	1 January through 31 December	First day of February each year

5. Reporting Protocols. The Discharger shall report with each sample result the applicable reported Minimum Level (ML) and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the reported ML shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (+ a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
- d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.

6. Compliance Determination. Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined above and in Attachment A of this Order. For purposes of reporting and administrative enforcement by the Central Valley Water Board and the State Water Board, the Discharger shall be deemed out of compliance with effluent limitations if the

concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

- 7. Multiple Sample Data.** When determining compliance with an AMEL, AWEL, or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
- a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.
- 8.** The Discharger shall submit SMRs in accordance with the following requirements:
- a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
 - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
 - c. SMRs must be submitted to the Central Valley Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below:

Regional Water Quality Control Board
Central Valley Region
NPDES Compliance and Enforcement Unit
11020 Sun Center Dr., Suite #200
Rancho Cordova, CA 95670-6114

9. Reports must clearly show when discharging to EFF-001 or other permitted discharge locations. Reports must show the date and time that the discharge started and stopped at each location.

C. Discharge Monitoring Reports (DMRs)

1. As described in section X.B.1 above, at any time during the term of this permit, the State Water Board or Central Valley Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharger shall submit the original DMR and one copy of the DMR to the address listed below:

STANDARD MAIL	FEDEX/UPS/ OTHER PRIVATE CARRIERS
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated will not be accepted unless they follow the exact same format of EPA Form 3320-1.

D. Other Reports

1. **Progress Reports.** As specified in the compliance time schedules required in the Special Provisions contained in Section VI of the Order, progress reports shall be submitted in accordance with the following reporting requirements. At minimum, the progress reports shall include a discussion of the status of final compliance, whether the Discharger is on schedule to meet the final compliance date, and the remaining tasks to meet the final compliance date.

Table E-11. Reporting Requirements for Special Provisions Reports

Special Provision	Reporting Requirements
Initial Investigative TRE Workplan (Section VI.C.a.i.)	Within 90 days from the effective date of this Order
Summary Report on EC Monitoring (Section VI.C.2.b.)	Within 15 months following construction of the new tertiary facility
Salinity/EC Site-Specific Study Workplan and Time Schedule (Section VI.C.2.b.)	If necessary, based on results of Summary Report on EC Monitoring (see above), within 18 months following construction of the new tertiary facility

Special Provision	Reporting Requirements
Salinity/EC Site-Specific Study (Section VI.C.2.b.)	If necessary, based on results of Summary Report on EC Monitoring (see above), within 15 months following Executive Officer approval of Workplan and Time Schedule
Salinity Evaluation and Minimization Plan (Section VI.C.3.a.)	Within 14 months of the effective date of this Order, and annually thereafter on 30 June.
Mercury Evaluation and Minimization Plan (Section VI.C.3.b.)	Within 14 months of the effective date of this Order, and annually thereafter on 30 June

2. The Discharger shall report the results of any special studies, acute and chronic toxicity testing, TRE/TIE, and Pollution Prevention Plan required by Special Provisions VI.C.2 and VI.C.3 of this Order.
3. **Analytical Methods Report.** Within 60 days of permit adoption, the Discharger shall submit a report outlining minimum levels, method detection limits, and analytical methods for approval, with a goal to achieve detection levels below applicable water quality criteria. At a minimum, the Discharger shall comply with the monitoring requirements for CTR constituents as outlined in section 2.3 and 2.4 of the SIP.
4. The Discharger's sanitary sewer system collects wastewater using sewers, pipes, pumps, and/or other conveyance systems and directs the raw sewage to the wastewater treatment plant. A "sanitary sewer overflow" is defined as a discharge to ground or surface water from the sanitary sewer system at any point upstream of the wastewater treatment plant. Sanitary sewer overflows are prohibited by this Order. All violations must be reported as required in Standard Provisions. Facilities (such as wet wells, regulated impoundments, tanks, highlines, etc.) may be part of a sanitary sewer system and discharges to these facilities are not considered sanitary sewer overflows, provided that the waste is fully contained within these temporary storage facilities.
5. **Effluent and Receiving Water Characterization Report.** After the new tertiary treatment facility is operational, an effluent and receiving water monitoring study is required to ensure adequate information is available for the next permit renewal. During the third or fourth year of this permit term, the Discharger shall conduct quarterly monitoring of the effluent at EFF-001 and of the receiving water at RSW-001 concurrently for all priority pollutants and other constituents of concern as described in Attachment H. Dioxin and Furan sampling shall be performed only twice during the year, as described in Attachment H. The report shall be completed in conformance with the following schedule.

Task	Compliance Date
Submit Work Plan and Time Schedule	18 months from the adoption of this Order
Conduct Quarterly Sampling of All Priority Pollutants and Constituents of Concern	During 3 rd or 4 th year of permit term
Submit Final Report	Six months following completion of monitoring events

6. Annual Operations Report. By 30 January of each year, the Discharger shall submit a written report to the Executive Officer containing the following:

- a. The names, certificate grades, and general responsibilities of all persons employed at the Facility.
- b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
- c. A statement certifying when the flow meter(s) and other monitoring instruments and devices were last calibrated, including identification of who performed the calibration.
- d. A statement certifying whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last revised and last reviewed for adequacy.
- e. The Discharger may also be requested to submit an annual report to the Central Valley Water Board with both tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the compliance record. If violations have occurred, the report shall also discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.

ATTACHMENT F – FACT SHEET

Table of Contents

I.	Permit Information	F-3
II.	Facility Description	F-4
	A. Description of Wastewater and Biosolids Treatment or Controls	F-4
	B. Discharge Points and Receiving Waters	F-5
	C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data	F-5
	D. Compliance Summary	F-8
	E. Planned Changes	F-8
III.	Applicable Plans, Policies, and Regulations	F-8
	A. Legal Authorities	F-8
	B. California Environmental Quality Act (CEQA)	F-8
	C. State and Federal Regulations, Policies, and Plans	F-8
	D. Impaired Water Bodies on CWA 303(d) List	F-10
	E. Other Plans, Polices and Regulations	F-10
IV.	Rationale For Effluent Limitations and Discharge Specifications	F-11
	A. Discharge Prohibitions	F-12
	B. Technology-Based Effluent Limitations	F-13
	C. Water Quality-Based Effluent Limitations (WQBELs)	F-14
	D. Final Effluent Limitations	F-59
	E. Interim Effluent Limitation	F-66
	F. Land Discharge Specifications – NOT APPLICABLE	F-67
	G. Reclamation Specifications – NOT APPLICABLE	F-67
V.	Rationale for Receiving Water Limitations	F-67
	A. Surface Water	F-68
	B. Groundwater	F-68
VI.	Rationale for Monitoring and Reporting Requirements	F-70
	A. Influent Monitoring	F-70
	B. Effluent Monitoring	F-70
	C. Whole Effluent Toxicity Testing Requirements	F-71
	D. Receiving Water Monitoring	F-71
	E. Other Monitoring Requirements	F-72
VII.	Rationale for Provisions	F-72
	A. Standard Provisions	F-72
	B. Special Provisions	F-73
VIII.	Public Participation	F-80
	A. Notification of Interested Parties	F-80
	B. Written Comments	F-80
	C. Public Hearing	F-81
	D. Waste Discharge Requirements Petitions	F-81
	E. Information and Copying	F-81
	F. Register of Interested Persons	F-81
	G. Additional Information	F-82

List of Tables

Table F-1.	Facility Information	F-3
Table F-2.	Order No. R5-2004-0096 Effluent Limitations and Monitoring Data	F-5
Table F-3.	Interim Effluent Limitations and Monitoring Data	F-7
Table F-4.	Summary of Secondary Level Effluent Limitations	F-14
Table F-5.	Basin Plan Beneficial Uses	F-16
Table F-6.	Chronic Nickel ECA Evaluation	F-21
Table F-7.	Chronic Copper ECA Evaluation	F-22
Table F-8.	Chronic Lead ECA Evaluation	F-25
Table F-9.	Chronic Lead ECA Evaluation	F-26
Table F-10.	Total THMs	F-40
Table F-11.	Salinity Water Quality Criteria/Objectives	F-49
Table F-12.	WQBEL Calculations For Aluminum	F-54
Table F-13.	WQBEL Calculations For Ammonia	F-54
Table F-14.	WQBEL Calculations For Copper	F-55
Table F-15.	WQBEL Calculations For Cadmium	F-55
Table F-16.	WQBEL Calculations For Arsenic	F-55
Table F-17.	WQBEL Calculations For Dibromochloromethane	F-56
Table F-18.	WQBEL Calculations For Dichlorobromomethane	F-56
Table F-19.	Summary of Water Quality-Based Effluent Limitations	F-57
Table F-20.	Summary of Final Effluent Limitations	F-65
Table F-21.	Summary of TDS in Groundwater	F-69
Table F-22.	Summary of Nitrate (as N) in Groundwater	F-70

ATTACHMENT F – FACT SHEET

As described in the Findings in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the Facility.

Table F-1. Facility Information

WDID	5A510100001
Discharger	City of Live Oak
Name of Facility	City of Live Oak Wastewater Treatment Plant
Facility Address	3450 Treatment Road
	Live Oak, CA 95953
	Sutter County
Facility Contact, Title and Phone	Mr. Jim Goodwin, City Manager, 530.695.2112
Authorized Person to Sign and Submit Reports	City Manager or Chief Plant Operator 530.695.2112
Mailing Address	9955 Live Oak Boulevard Live Oak, CA 95953
Billing Address	Same as Mailing
Type of Facility	Publicly Owned Treatment Works
Major or Minor Facility	Major
Threat to Water Quality	1
Complexity	B
Pretreatment Program	N
Reclamation Requirements	N
Facility Permitted Flow	1.4 million gallons per day (MGD) average dry weather flow (ADWF)
Facility Design Flow	1.4 MGD
Watershed	Sacramento
Receiving Water	Reclamation District 777 Lateral Drain No. 1 and Reclamation District 777 Lateral Drain No. 2 (planned for new facility)
Receiving Water Type	Inland Surface Water

- A. The City of Live Oak (hereinafter Discharger) is the owner and operator of the Wastewater Treatment Plant (hereinafter Facility), a Publicly Owned Treatment Works.

For the purposes of this Order, references to the “discharger” or “permittee” in

applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The Facility discharges treated wastewater to Reclamation District 777 Lateral Drain No. 1 (a constructed agricultural drain), a water of the United States, and a tributary to the East Interceptor Canal, then Wadsworth Canal, and then the Sutter Bypass. The discharge is currently regulated by Order No. R5-2004-0096 which was adopted on 9 July 2004 and expired on 9 July 2009, and by Cease and Desist Order No. R5-2009-0012-01 adopted on 24 April 2009. The terms and conditions of the current Order have been automatically continued and remain in effect until new Waste Discharge Requirements (WDRs) and National Pollutant Discharge Elimination System (NPDES) permit are adopted pursuant to this Order.
- C.** The Discharger filed a report of waste discharge and submitted an application for renewal of its WDRs and NPDES permit on 30 September 2008.

II. FACILITY DESCRIPTION

The Discharger owns and operates the Publicly Owned Treatment Works. The Discharger provides sewerage service for the City of Live Oak and serves a population of approximately 8,000. The design ADWF capacity of the Facility is 1.4 MGD. The Facility currently provides secondary treatment of domestic wastewater from within the City limits. The collection system consists of 25 miles of sewer lines and 6 pump stations. The City's potable water is supplied by 5 City-owned groundwater wells. The current Facility consists of unlined aerated lagoons, unlined oxidation ponds, disinfection by chlorine, and dechlorination.

Cease and Desist Order No. R5-2009-0012-01 includes interim effluent limits and a time schedule for the Discharger to meet the effluent limitations of the existing Order by 30 September 2012. The Discharger began construction of major tertiary treatment upgrades to the Facility in September 2009. The new tertiary treatment plant will include a lined equalization basin, an unlined emergency storage basin, and a stormwater detention basin. The treatment system will include nitrification and will consist of an odor control system at the headworks, secondary feed pump station, selector basin, two oxidation ditches, two secondary clarifiers, cloth media filters, and ultraviolet disinfection system. Solids handling facilities will consist of storage basins and solar drying beds. Wastewater will be discharged from Discharge Point No. 001 and the new facility plans to use Reclamation District 777 Lateral Drain No. 2 (a constructed agricultural drain) as the receiving water (see section B below). Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the new Facility.

A. Description of Wastewater and Biosolids Treatment or Controls

The Facility is currently permitted to discharge 1.4 MGD design average dry weather flow from the secondary treatment plant. Current average dry weather flow is 0.72 MGD and peak wet weather flow is 3.2 MGD.

B. Discharge Points and Receiving Waters

1. The Facility is located in Section 7, T16N, R3E, MDB&M, as shown in Attachment B, a part of this Order.
2. Treated municipal wastewater is discharged at Discharge Point No. 001. Currently the receiving water is the Reclamation District 777 Lateral Drain No. 1; however, the new tertiary treatment facility may relocate Discharge Point No. 001 to Reclamation District 777 Lateral Drain No. 2 as the receiving water. Both receiving waters are waters of the United States and a tributary to the Sutter Bypass.
3. After the effluent discharges to Lateral Drain No. 1 or Lateral Drain No. 2, the receiving water flows into the East Interceptor Canal and then Wadsworth Canal, which is tributary to the Sutter Bypass.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Order No. R5-2004-0096 contained effluent discharge limits for the disinfected secondary treatment facility and a time schedule to meet Title 22 tertiary treatment requirements by April 1, 2009. The Discharger could not meet the 1 April 2009, deadline, therefore, Cease and Desist Order No. R5-2009-0012 was adopted on 5 February 2009, and subsequently amended on 24 April 2009, by Cease and Desist Order No. R5-2009-0012-01. Order No. R5-2009-0012-01 included a new time schedule to meet requirements of Order No. R5-2004-0096 including, aluminum, ammonia, BOD, copper, cyanide, diazinon, total coliform, TSS, turbidity, and BOD and TSS removal efficiency, by 30 September 2012. Order No. R5-2009-0012 also contained interim effluent limitations for aluminum, ammonia, copper, cyanide, and turbidity. Table F-2 includes the effluent limitations in Order No. R5-2004-0096 extended by the time schedule in Order No. R5-2009-0012-01. Table F-3 includes the interim effluent limitations contained in Order No. R5-2009-0012-01.

Effluent limitations and Discharge Specifications contained in Order No. R5-2004-0096 and Cease and Desist Order No. R5-2009-0012-01 for discharges from Discharge Point No. 001, and representative monitoring data from the term of Order No. R5-2004-0096, are as follows:

Table F-2. Order No. R5-2004-0096 Effluent Limitations and Monitoring Data

Parameter	Units	Effluent Limitation Order No. R5-2004-0096			Monitoring Data (From July 2005 To June 2009)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
BOD ¹	mg/L	10 ⁴	15 ⁴	20 ⁴	--	--	32
	lbs/day ⁵	120	180	230	--	--	170
BOD ¹ Minimum Monthly Removal	%	85	--	--	--	--	20

Parameter	Units	Effluent Limitation Order No. R5-2004-0096			Monitoring Data (From July 2005 To June 2009)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
TSS	mg/L	10 ⁴	15 ⁴	20 ⁴	--	--	88
	lbs/day ⁵	120	180	230	--	--	460
TSS Minimum Monthly Removal	%	85	--	--	--	--	60
Total Coliform Organisms	MPN/100 mL	--	2.2 ²	23 ⁹	--	--	1600
Settleable Solids	mL/L-hr	0.1	--	0.2	--	--	0.0
Organochlorine Pesticides	µg/L	--	--	ND ⁸	--	--	0.02
Cadmium (total recoverable)	µg/L	calculated ⁴	--	calculated ⁴	--	--	0.15
	lbs/day	calculated ⁷	--	calculated ⁷	--	--	0.00079
Chlorine, Total Residual	mg/L	--	0.01	0.02	--	--	0.02
	lbs/day ⁵	--	0.13	0.22	--	--	0.11
Diazinon	µg/L	0.04	--	0.08	--	--	ND
	lbs/day ⁵	0.0005	--	0.001	--	--	NA
Copper (total recoverable)	µg/L	calculated ⁴	--	calculated ⁴	--	--	11
	lbs/day	calculated ⁷	--	calculated ⁷	--	--	0.058
Cyanide (total recoverable)	µg/L	4.3	--	8.5	--	--	ND
	lbs/day ⁵	0.050	--	0.10	--	--	NA
pH	Standard Units	--	--	Minimum 6.5 Maximum 8.5	--	--	Min 6.3 Max 8.5
Average Dry Weather Flow	MGD	--	--	1.4	--	--	0.72
Acute Toxicity	%	1-sample not to fall below 70% and 3-sample median not to fall below 90% survival.			--	--	70
Aluminum ³	µg/L	71 ⁴	--	140 ⁴	--	--	530
	lbs/day ⁵	0.83	--	1.7	--	--	--
Ammonia, Total (as N)	mg/L	calculated	--	calculated	--	--	17.1
	lbs/day	calculated ⁶	--	calculated ⁶	--	--	--
Turbidity ¹⁰	NTU	--	--	2	--	--	120
Tertiary Treatment ¹¹	--	--	--	--	--	--	--

Parameter	Units	Effluent Limitation Order No. R5-2004-0096			Monitoring Data (From July 2005 To June 2009)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge

¹ 5-day, 20°C biochemical oxygen demand.

² 7-day median.

³ Acid soluble or total.

⁴ To be ascertained by 24-hour composite.

⁵ Based on Average Dry Weather Flow of 1.4 MGD.

⁶ The mass limit for ammonia shall be equal to the calculated concentration limit multiplied by the design flow of 1.4 MGD and the unit conversion factor of 8.345. Also includes a calculated instantaneous maximum limit.

⁷ The mass limit shall be equal to the calculated concentration limit multiplied by the design flow of 1.4 MGD and the unit conversion factor of 8.345 and divided by 1000 µg/L per mg/L.

⁸ The Non-Detectable limitation applies to each individual pesticide. No individual pesticide may be present in the discharge at detectable concentrations. The Discharger shall use EPA standard analytical techniques with the lowest possible detectable level for organochlorine pesticides with maximum acceptable detection level of 0.05 µg/L.

⁹ Not to be exceeded more than once in any 30-day period.

¹⁰ The turbidity shall not exceed 5 NTU more than 5 percent of the time within a 24-hour period. At no time shall the turbidity exceed 10 NTU.

¹¹ Wastewater shall be oxidized, coagulated, filtered, and disinfected, or equivalent treatment.

Table F-3. Interim Effluent Limitations and Monitoring Data

Parameter	Units	Effluent Limitation Cease and Desist Order No. R5-2009-0012-01			Monitoring Data (From August 2005 To June 2009)		
		Average Monthly	Average Weekly	Maximum Daily	Average Monthly Discharge	Average Weekly Discharge	Daily Discharge
Aluminum	µg/L	--	--	7300	--	--	530
Ammonia, Total (as N)	mg/L	--	--	23.7	--	--	17.1
Copper	µg/L	--	--	22	--	--	11
Cyanide	µg/L	--	--	16	--	--	ND
Turbidity	NTU	--	--	102	--	--	120

D. Compliance Summary

Administrative Civil Liability Complaint R5-2008-0605, issued 10 November 2008.

Administrative Civil Liability Order R5-2009-0587, issued 9 December 2009.

E. Planned Changes

The existing Facility consists of aeration lagoons, oxidation ponds, disinfection by chlorine, and dechlorination. The Facility is being improved to provide tertiary level treatment with nitrification. The improvement project is under construction and is scheduled to be completed in September 2012. The new Facility will not provide an increase in design capacity and is designed to treat the existing permitted 1.4 MGD average dry weather flow. The new Facility design capacity for peak day, peak week, peak month, and annual average flows are 4.27 MGD, 3.80 MGD, 3.33 MGD, and 1.73 MGD, respectively. The new treatment system will consist of an odor control system at the headworks, a secondary feed pump station, selector basin and splitter box, two oxidation ditches, two secondary clarifiers, cloth media filters, and an ultraviolet light disinfection system. Solids handling facilities will include storage basins and solar drying beds.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the applicable plans, policies, and regulations identified in the Findings in section II of this Order. The applicable plans, policies, and regulations relevant to the discharge include the following:

A. Legal Authorities

This Order is issued pursuant to regulations in the Clean Water Act (CWA) and the California Water Code (CWC) as specified in the Finding contained at section II.C of this Order.

B. California Environmental Quality Act (CEQA)

This Order meets the requirements of CEQA as specified in the Finding contained at section II.E of this Order.

C. State and Federal Regulations, Policies, and Plans

1. **Water Quality Control Plans.** This Order implements the following water quality control plans as specified in the Finding contained at section II.H of this Order.

- a. *Water Quality Control Plan, Fourth Edition (Revised September 2009), for the Sacramento and San Joaquin River Basins (Basin Plan).*

2. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** This Order implements the NTR and CTR as specified in the Finding contained at section II.I of this Order.
3. **State Implementation Policy (SIP).** This Order implements the SIP as specified in the Finding contained at section II.J of this Order.
4. **Alaska Rule.** This Order is consistent with the Alaska Rule as specified in the Finding contained at section II.L of this Order.
5. **Antidegradation Policy.** As specified in the Finding contained at section II.N of this Order and as discussed in detail in the Fact Sheet (Attachment F, Section IV.D.4.), the discharge is consistent with the antidegradation provisions of 40 CFR section 131.12 and State Water Resources Control Board (State Water Board) Resolution 68-16.
6. **Anti-Backsliding Requirements.** This Order is consistent with anti-backsliding policies as specified in the Finding contained at section II.M of this Order. Compliance with the anti-backsliding requirements is discussed in the Fact Sheet (Attachment F, Section IV.D.3).
7. **Emergency Planning and Community Right to Know Act**

Section 13263.6(a) of the CWC, requires that *"the Regional Water Board shall prescribe effluent limitations as part of the waste discharge requirements of a POTW for all substances that the most recent toxic chemical release data reported to the state emergency response commission pursuant to Section 313 of the Emergency Planning and Community Right to Know Act of 1986 (42 U.S.C. Sec. 11023) (EPCRA) indicate as discharged into the POTW, for which the State Water Board or the Regional Water Board has established numeric water quality objectives, and has determined that the discharge is or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to, an excursion above any numeric water quality objective"*.

The most recent toxic chemical data report does not indicate any reportable off-site releases or discharges to the collection system for this Facility. Therefore, a reasonable potential analysis based on information from EPCRA cannot be conducted. Based on information from EPCRA, there is no reasonable potential to cause or contribute to an excursion above any numeric water quality objectives included within the Basin Plan or in any State Water Board plan, so no effluent limitations are included in this permit pursuant to CWC section 13263.6(a).

However, as detailed elsewhere in this Order, available effluent data indicate that there are constituents present in the effluent that have a reasonable potential to cause or contribute to exceedances of water quality standards and require inclusion of effluent limitations based on federal and state laws and regulations.

8. Storm Water Requirements

USEPA promulgated federal regulations for storm water on 16 November 1990 in 40 CFR Parts 122, 123, and 124. The NPDES Industrial Storm Water Program regulates storm water discharges from wastewater treatment facilities. Wastewater treatment plants are applicable industries under the storm water program and are obligated to comply with the federal regulations.

9. **Endangered Species Act.** This Order is consistent with the Endangered Species Act as specified in the Finding contained at section II.P of this Order.

D. Impaired Water Bodies on CWA 303(d) List

1. Under section 303(d) of the 1972 CWA, states, territories and authorized tribes are required to develop lists of water quality limited segments. The waters on these lists do not meet water quality standards, even after point sources of pollution have installed the minimum required levels of pollution control technology. On 30 November 2006 USEPA gave final approval to California's 2006 section 303(d) List of Water Quality Limited Segments. The Basin Plan references this list of Water Quality Limited Segments (WQLSs), which are defined as "...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 CFR Part 130, et seq.)." The Basin Plan also states, "Additional treatment beyond minimum federal standards will be imposed on dischargers to [WQLSs]. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment." The listing for the Wadsworth Canal, which the Reclamation District 777 Lateral Drain No. 1 and Lateral Drain No. 2 are tributary to, includes diazinon.
2. **Total Maximum Daily Loads (TMDLs).** USEPA requires the Central Valley Water Board to develop TMDLs for each 303(d) listed pollutant and water body combination.
3. The 303(d) listings and TMDLs have been considered in the development of the Order. A pollutant-by-pollutant evaluation of each pollutant of concern is described in section IV.C.3. of this Fact Sheet.

E. Other Plans, Policies and Regulations

1. **Title 27, California Code of Regulations (CCR), section 20005 et seq. (hereafter Title 27).** Title 27 requirements apply to land disposal activities, and establish minimum standards governing the water quality aspects of waste discharges to land for treatment, storage, or disposal. Section 20090 of Title 27 includes exemptions to the requirements.
 - a. **Existing Facility.** The treatment system currently consists of aeration lagoons, oxidation ponds, chlorine disinfection, and dechlorination. The sewage

throughout the treatment system does not have to be managed as hazardous waste. The lagoons and ponds are unlined and therefore, some percolation to groundwater is expected. However, the lagoon and ponds are exempt from the requirements of Title 27 CCR pursuant to section 20090(a) since the lagoons and ponds are components within the treatment system.

- b. New Facility.** The new tertiary treatment system will include concrete structures such as an oxidation ditch and two secondary clarifiers, a lined equalization basin, a stormwater detention basin, and an emergency storage basin. The only component of the new Facility with the potential to percolate to the underlying groundwater is the emergency storage basin. The emergency storage basin is used to hold wastewater bypassed from the treatment system in case of an emergency. The emergency storage basin is not used as a discharge basin and the contents will be pumped back into the treatment process when feasible. The new Facility will be exempt from the requirements of Title 27 CCR pursuant to 20090(a) because the emergency storage basin is an essential component within the treatment system.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

Effluent limitations and toxic and pretreatment effluent standards established pursuant to sections 301 (Effluent Limitations), 302 (Water Quality Related Effluent Limitations), 304 (Information and Guidelines), and 307 (Toxic and Pretreatment Effluent Standards) of the CWA and amendments thereto are applicable to the discharge.

The CWA mandates the implementation of effluent limitations that are as stringent as necessary to meet water quality standards established pursuant to state or federal law [33 U.S.C., §1311(b)(1)(C); 40 CFR 122.44(d)(1)]. NPDES permits must incorporate discharge limits necessary to ensure that water quality standards are met. This requirement applies to narrative criteria as well as to criteria specifying maximum amounts of particular pollutants. Pursuant to federal regulations, 40 CFR 122.44(d)(1)(i), NPDES permits must contain limits that control all pollutants that *“are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state water quality standard, including state narrative criteria for water quality.”* Federal regulations, 40 CFR 122.44(d)(1)(vi), further provide that *“[w]here a state has not established a water quality criterion for a specific chemical pollutant that is present in an effluent at a concentration that causes, has the reasonable potential to cause, or contributes to an excursion above a narrative criterion within an applicable State water quality standard, the permitting authority must establish effluent limits.”*

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the Code of Federal Regulations: 40 CFR 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 CFR 122.44(d) requires that permits include WQBELs to attain and maintain applicable numeric and narrative water

quality criteria to protect the beneficial uses of the receiving water where numeric water quality objectives have not been established. The Basin Plan at page IV-17.00, contains an implementation policy, "*Policy for Application of Water Quality Objectives*", that specifies that the Central Valley Water Board "*will, on a case-by-case basis, adopt numerical limitations in orders which will implement the narrative objectives.*" This Policy complies with 40 CFR 122.44(d)(1). With respect to narrative objectives, the Central Valley Water Board must establish effluent limitations using one or more of three specified sources, including: (1) USEPA's published water quality criteria, (2) a proposed state criterion (i.e., water quality objective) or an explicit state policy interpreting its narrative water quality criteria (i.e., the Central Valley Water Board's "*Policy for Application of Water Quality Objectives*") (40 CFR 122.44(d)(1)(vi)(A), (B) or (C)), or (3) an indicator parameter.

The Basin Plan includes numeric site-specific water quality objectives and narrative objectives for toxicity, chemical constituents, discoloration, radionuclides, and tastes and odors. The narrative toxicity objective states: "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.*" (Basin Plan at III-8.00.) The Basin Plan states that material and relevant information, including numeric criteria, and recommendations from other agencies and scientific literature will be utilized in evaluating compliance with the narrative toxicity objective. The narrative chemical constituents objective states that waters shall not contain chemical constituents in concentrations that adversely affect beneficial uses. At minimum, "*...water designated for use as domestic or municipal supply (MUN) shall not contain concentrations of chemical constituents in excess of the maximum contaminant levels (MCLs)*" in Title 22 of CCR. The Basin Plan further states that, to protect all beneficial uses, the Central Valley Water Board may apply limits more stringent than MCLs. The narrative tastes and odors objective states: "*Water shall not contain taste- or odor-producing substances in concentrations that impart undesirable tastes or odors to domestic or municipal water supplies or to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.*"

A. Discharge Prohibitions

1. As stated in section I.G of Attachment D, Standard Provisions, this Order prohibits bypass from any portion of the treatment facility. Federal regulations, 40 CFR 122.41(m), define "bypass" as the intentional diversion of waste streams from any portion of a treatment facility. This section of the federal regulations, 40 CFR 122.41(m)(4), prohibits bypass unless it is unavoidable to prevent loss of life, personal injury, or severe property damage. In considering the Central Valley Water Board's prohibition of bypasses, the State Water Board adopted a precedential decision, Order No. WQO 2002-0015, which cites the federal regulations, 40 CFR 122.41(m), as allowing bypass only for essential maintenance to assure efficient operation.

B. Technology-Based Effluent Limitations

1. Scope and Authority

Section 301(b) of the CWA and implementing USEPA permit regulations at 40 CFR 122.44 require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at 40 CFR Part 133.

Regulations promulgated in 40 CFR 125.3(a)(1) require technology-based effluent limitations for municipal dischargers to be placed in NPDES permits based on Secondary Treatment Standards or Equivalent to Secondary Treatment Standards.

The Federal Water Pollution Control Act Amendments of 1972 (PL 92-500) established the minimum performance requirements for POTWs [defined in section 304(d)(1)]. Section 301(b)(1)(B) of that Act requires that such treatment works must, as a minimum, meet effluent limitations based on secondary treatment as defined by the USEPA Administrator.

Based on this statutory requirement, USEPA developed secondary treatment regulations, which are specified in 40 CFR Part 133. These technology-based regulations apply to all municipal wastewater treatment plants and identify the minimum level of effluent quality attainable by secondary treatment in terms of 5-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), and pH.

2. Applicable Technology-Based Effluent Limitations

- a. **BOD₅ and TSS.** Federal regulations, 40 CFR Part 133, establish the minimum weekly and monthly average level of effluent quality attainable by secondary treatment for BOD₅ and TSS. However, as described in section IV.C.3, this Order requires water quality-based effluent limitations (WQBELs) more stringent than the applicable technology-based effluent limitations which are based on tertiary treatment, which is necessary to protect the beneficial uses of the receiving stream. In addition, 40 CFR 133.102, in describing the minimum level of effluent quality attainable by secondary treatment, states that the 30-day average percent removal shall not be less than 85 percent. This Order contains a limitation requiring an average of 85 percent removal of BOD₅ and TSS over each calendar month.
- b. **Flow.** The Facility was designed to provide a tertiary level of treatment for up to a design flow of 1.4 MGD. Therefore, this Order contains an average dry weather discharge flow effluent limit of 1.4 MGD.
- c. **pH.** The secondary treatment regulations at 40 CFR Part 133 also require that pH be maintained between 6.0 and 9.0 standard units (SU).

**Summary of Secondary Level Effluent Limitations
Discharge Point No. 001**

Table F-4. Summary of Secondary Level Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Flow	MGD	--	--	1.4 ¹	--	--
BOD ₅ @ 20°C ²	mg/L	30	45	60	--	--
	lbs/day ³	350	525	700	--	--
	% Removal	85	--	--	--	--
Total Suspended Solids ²	mg/L	30	45	60	--	--
	lbs/day ³	350	525	700	--	--
pH	SU	--	--	--	6.0 ⁴	9.0 ⁴

¹ Average dry weather flow.

² The average monthly percent removal of BOD 5-day 20°C and total suspended solids shall not be less than 85 percent.

³ Based upon an average dry weather treatment design flow of 1.4 MGD.

⁴ More stringent water quality-based effluent limitations have been applied for pH in this Order.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

Section 301(b) of the CWA and 40 CFR 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements, expressed as a technology equivalence requirement, more stringent than secondary treatment requirements that are necessary to meet applicable water quality standards. The rationale for these requirements, which consist of tertiary treatment, is discussed in section IV.C.3.d.xv. (Pathogens) of this Fact Sheet.

40 CFR 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and

criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

The Basin Plan designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Board Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply.

The Basin Plan on page II-1.00 states: "*Protection and enhancement of existing and potential beneficial uses are primary goals of water quality planning...*" and with respect to disposal of wastewaters states that "*...disposal of wastewaters is [not] a prohibited use of waters of the State; it is merely a use which cannot be satisfied to the detriment of beneficial uses.*"

The federal CWA section 101(a)(2), states: "*it is the national goal that wherever attainable, an interim goal of water quality which provides for the protection and propagation of fish, shellfish, and wildlife, and for recreation in and on the water be achieved by July 1, 1983.*" Federal Regulations, developed to implement the requirements of the CWA, create a rebuttable presumption that all waters be designated as fishable and swimmable. Federal Regulations, 40 CFR sections 131.2 and 131.10, require that all waters of the State regulated to protect the beneficial uses of public water supply, protection and propagation of fish, shell fish and wildlife, recreation in and on the water, agricultural, industrial and other purposes including navigation. Section 131.3(e), 40 CFR, defines existing beneficial uses as those uses actually attained after 28 November 1975, whether or not they are included in the water quality standards. Federal Regulation, 40 CFR section 131.10 requires that uses be obtained by implementing effluent limitations, requires that all downstream uses be protected and states that in no case shall a state adopt waste transport or waste assimilation as a beneficial use for any waters of the United States.

The Central Valley Water Board considered the factors listed in CWC section 13241 at the time of adoption of the previous Order No. R5-2004-0096 which initially established tertiary level effluent limitations for protection of beneficial uses of the receiving water. The previous permit, however, did not recognize the MUN beneficial use to the receiving water. Although the receiving waters which consist of modified agricultural drains upstream of the Sutter Bypass, which is specifically not designated with the MUN beneficial use in Table II-1 in the Basin Plan, this Order correctly interprets the beneficial uses of the receiving waters to include the beneficial use of MUN through implementation of State Water Board Resolution No. 88-63. As stated in Chapter II of the Basin Plan, "Water Bodies within the basins that do not have beneficial uses designated in Table II-1 are assigned MUN designations in accordance with the provisions of State Water Board Resolution No. 88-63 which is, by reference, a part of the Basin Plan" except for two non-applicable

exceptions. Furthermore, as specified in Chapter IV of the Basin Plan, an exception to Resolution No. 88-63, and removal of the MUN beneficial use designation for the receiving waters, is effective after a Basin Plan Amendment is adopted by the Central Valley Water Board and approved by the State Water Board and Office of Administrative Law. Therefore, this Order contains new effluent limitations necessary to protect the municipal and domestic supply use of the receiving waters.

a. Receiving Water and Beneficial Uses. The receiving water is currently the Reclamation District 777 Lateral Drain No. 1 and may change to Lateral Drain No. 2 with the new tertiary treatment facility, which are waters of the United States and tributary to the Sutter Bypass within the Sacramento River Basin. Lateral Drain No. 1 and Lateral Drain No. 2 were apparently constructed prior to 1917 to capture and transport agricultural drain water. Lateral Drain No. 1 was deepened to three or four feet from the original depth of one foot in 1939. Since 1939 there have been limited improvements to the drains other than maintenance. The drains carry only agricultural and urban stormwater runoff and no surface water streams, creeks, sloughs, or other natural waterway discharges into the drains. Consequently, upstream Lateral Drain No. 1 flows are during winter and irrigation seasons, and the downstream flows are effluent dominant during most of the year. Lateral Drain No. 1 flows south along the western edge of the WWTP and continues until it enters the East Interceptor Canal. Lateral Drain No. 2 flows along the southeast edge of the WWTP until it enters Lateral Drain No. 1 near the southern tip of the WWTP.

The Basin Plan at II-2.00 states that the beneficial uses of any specifically identified water body generally apply to its tributary streams. The Basin Plan does not specifically identify beneficial uses for Reclamation District 777 Lateral Drain No. 1 or Lateral Drain No. 2, but does identify present and potential uses for the Sutter Bypass, to which these waters are tributary. Thus, pursuant to the Basin Plan and State Water Board plans and policies including Resolution No. 88-63, and consistent with the federal Clean Water Act, beneficial uses applicable to Reclamation District 777 Lateral Drain No. 1 and Lateral Drain No. 2 are as follows:

Table F-5. Basin Plan Beneficial Uses

Discharge Point	Receiving Water Name	Beneficial Use(s)
001	Reclamation District 777 Lateral Drain No. 1 and Reclamation District 777 Lateral Drain No. 2 (planned for new facility)	Municipal and domestic supply (MUN); Agricultural irrigation (AGR); Water contact recreation (REC-1); Warm freshwater habitat (WARM); Cold freshwater migration (MGR); Spawning, reproduction, and/or early development (SPWN); Wildlife habitat (WILD). Ground water recharge (GWR); Freshwater replenishment (FRSH).

- b. Effluent and Ambient Background Data.** The reasonable potential analysis (RPA), as described in section IV.C.3 of this Fact Sheet, was based on data from June 2006 through June 2009, which includes effluent and ambient background data submitted in SMRs and the Report of Waste Discharge (ROWD). Additional data outside of this range were also analyzed where there were inadequate data to perform an analysis. When there were not sufficient data (e.g., not required in MRP) effluent CTR data from January 2003, February 2003, October 2003, and March 2005 to August 2005 were used. Order No. R5-2004-0096 required receiving water monitoring only for dissolved oxygen, pH, turbidity, temperature, EC, radionuclides, and hardness. CTR monitoring was not required. Consequently, there was insufficient receiving water CTR data from the last 3 years, so receiving water data from March 2002 and July 2002 were used for the CTR constituents.

Order No. R5-2004-0096 includes effluent limits for cadmium, cyanide, and copper due to elevated concentrations of these constituents in the receiving water. Since no other receiving water data is available for these constituents, the 2002 data is being used for the RPA in this permit. The 2002 receiving water data results in reasonable potential for cadmium, and copper (i.e., B > C) for this permit. The effluent data showed detections for these constituents, but did not exceed the criteria. This Order includes receiving water sampling in order to have sufficient and better representative data to perform the reasonable potential analysis for the next permit.

- c. Hardness-Dependent CTR Metals Criteria.** The *California Toxics Rule* and the *National Toxics Rule* contain water quality criteria for seven metals that vary as a function of hardness. The lower the hardness the lower the water quality criteria. The metals with hardness-dependent criteria include cadmium, copper, chromium III, lead, nickel, silver, and zinc.

This Order has established the criteria for hardness-dependent metals based on the reasonable worst-case ambient hardness as required by the SIP¹, the CTR² and State Water Board Order No. WQO 2008-0008 (City of Davis). The SIP and the CTR require the use of "receiving water" or "actual ambient" hardness, respectively, to determine effluent limitations for these metals. (SIP, § 1.2; 40 CFR § 131.38(c)(4), Table 4, note 4.) The CTR does not define whether the term "ambient," as applied in the regulations, necessarily requires the consideration of upstream as opposed to downstream hardness conditions. Therefore, where reliable, representative data are available, the hardness value for calculating criteria can be the downstream receiving water hardness, after mixing with the effluent (Order WQO 2008-0008, p. 11). The Central Valley

¹ The SIP does not address how to determine the hardness for application to the equations for the protection of aquatic life when using hardness-dependent metals criteria. It simply states, in Section 1.2, that the criteria shall be properly adjusted for hardness using the hardness of the receiving water.

² The CTR requires that, for waters with a hardness of 400 mg/L (as CaCO₃), or less, the actual ambient hardness of the surface water must be used. It further requires that the hardness values used must be consistent with the design discharge conditions for design flows and mixing zones.

Water Board thus has considerable discretion in determining ambient hardness (*Id.*, p.10.).

The hardness values must also be protective under all flow conditions (*Id.*, pp. 10-11). As discussed below, scientific literature provides a reliable method for calculating protective hardness-dependent CTR criteria, considering all discharge conditions. This methodology produces criteria that ensure these metals do not cause receiving water toxicity, while avoiding criteria that are unnecessarily stringent.

- i. **Reasonable Potential Analysis (RPA).** The SIP in Section 1.3 states, "The RWQCB shall...determine whether a discharge may: (1) cause, (2) have a reasonable potential to cause, or (3) contribute to an excursion above any applicable priority pollutant criterion or objective." Section 1.3 provides a step-by-step procedure for conducting the RPA. The procedure requires the comparison of the Maximum Effluent Concentration (MEC) and Maximum Ambient Background Concentration to the applicable criterion that has been properly adjusted for hardness. Unless otherwise noted, for the hardness-dependent CTR metals criteria the following procedures were followed for properly adjusting the criterion for hardness when conducting the RPA.
 - For comparing the MEC to the applicable criterion, in accordance with the SIP, CTR, and Order WQO 2008-0008, the reasonable worst-case downstream hardness was used to adjust the criterion. In this evaluation the portion of the receiving water affected by the discharge is analyzed. For hardness-dependent criteria, the hardness of the effluent has an impact on the determination of the applicable criterion in areas in the receiving water affected by the discharge. Therefore, for this situation it is necessary to consider the hardness of the effluent in determining the applicable hardness to adjust the criterion. The procedures for determining the applicable criterion after proper adjustment using the reasonable worst-case downstream hardness is outlined in subsection ii, below.
 - For comparing the Maximum Ambient Background Concentration to the applicable criterion, in accordance with the SIP, CTR, and Order WQO 2008-0008, the reasonable worst-case upstream hardness was used to adjust the criterion. In this evaluation the area outside the influence of the discharge is analyzed. For this situation, the discharge does not impact the upstream hardness. Therefore, the effect of the effluent hardness was not included in this evaluation.
- ii. **Calculation of Water Quality-Based Effluent Limitations.** The remaining discussion in this section relates to the development of water quality-based effluent limits when it has been determined that the discharge has reasonable potential to cause or contribute to an exceedance of the CTR hardness-dependent metals criteria in the receiving water.

Once a discharge is made to a receiving water, the hardness downstream of the discharge will be altered and the applicable water quality criteria will alter accordingly. A 2006 Study¹ developed procedures for calculating the effluent concentration allowance (ECA)² for CTR hardness-dependent metals. The 2006 Study demonstrated that it is necessary to evaluate all discharge conditions (e.g. high and low flow conditions) and the hardness of the effluent and receiving water when determining the appropriate ECA for these hardness-dependent metals. Simply using the lowest recorded upstream receiving water hardness to calculate the ECA may result in over or under protective water quality-based effluent limitations.

The equation describing the total recoverable regulatory criterion, as established in the CTR, is as follows:

$$\text{CTR Criterion} = \text{WER} \times (e^{m[\ln(H)]+b}) \quad (\text{Equation 1})$$

Where:

H = hardness (as CaCO₃)

WER = water-effect ratio

m, b = metal- and criterion-specific constants

In accordance with the CTR, the default value for the WER is 1. A WER study must be conducted to use a value other than 1. The constants "m" and "b" are specific to both the metal under consideration, and the type of total recoverable criterion (i.e., acute or chronic). The metal-specific values for these constants are provided in the CTR at paragraph (b)(2), Table 1.

The equation for the ECA is defined in Section 1.4, Step 2, of the SIP and is as follows:

$$\text{ECA} = C \quad (\text{when } C \leq B)^3 \quad (\text{Equation 2})$$

Where

C = the priority pollutant criterion/objective, adjusted for hardness (see Equation 1, above)

B = the ambient background concentration

The 2006 Study demonstrated that the relationship between hardness and the calculated criteria is the same for some metals, so the same procedure for calculating the ECA may be used for these metals. The same procedure can

¹ Emerick, R.W.; Borroum, Y.; & Pedri, J.E., 2006. California and National Toxics Rule Implementation and Development of Protective Hardness Based Metal Effluent Limitations. WEFTEC, Chicago, Ill.

² The ECA is defined in Appendix 1 of the SIP (page Appendix 1-2). The ECA is used to calculate water quality-based effluent limitations in accordance with Section 1.4 of the SIP

³ The 2006 Study assumes the ambient background metals concentration is equal to the CTR criterion (i.e. C ≤ B)

be used for chronic cadmium, chromium III, copper, nickel, and zinc. These metals are hereinafter referred to as "Concave Down Metals". "Concave Down" refers to the shape of the curve represented by the relationship between hardness and the CTR criteria in Equation 1. Another similar procedure can be used for determining the ECA for acute cadmium, lead, and acute silver, which are referred to hereafter as "Concave Up Metals".

ECA for Concave Down Metals – For Concave Down Metals (i.e., chronic cadmium, chromium III, copper, nickel, and zinc) the 2006 Study demonstrates that when the effluent is in compliance with CTR criteria associated with its own hardness condition, it is not possible to cause or contribute to a violation of water quality criteria that are applicable once the effluent and receiving water are mixed (either fully or partially). Therefore, based on any observed ambient background hardness, even when there is no receiving water assimilative capacity for metals (i.e., the ambient background metals concentrations are at or above their respective CTR criterion) and the minimum effluent hardness, the ECA calculated using Equation 1 with a downstream ambient hardness equivalent to the minimum effluent hardness is protective under all discharge conditions (i.e., high and low dilution conditions and under all mixtures of effluent and receiving water as the effluent mixes with the receiving water). The conclusions of the study do not change whether the receiving water initially exhibited a higher or lower hardness value or the degree of dilution within the receiving water.

In some instances, the receiving water may already contain concentrations of concave down metals that exceed water quality criteria associated with the hardness condition previous to the discharge. The 2006 study procedures remain applicable under these conditions. The discharge can not cause or contribute to a violation of water quality criteria/objectives in the receiving water. Although metals concentrations downstream of the discharge exceed CTR criteria, the cause of the exceedance is not due to the discharge, it is due to the elevated metals concentrations upstream of the discharge. Implementing the procedures of the 2006 study does not result in an increase in toxicity downstream of the discharge, and in fact reduces the amount of toxicity already present in the receiving water. This is demonstrated in the example below for copper (see Table F-7).

The effluent hardness ranged from 220 mg/L to 330 mg/L (as CaCO₃), based on 35 samples from June 2006 to June 2009. The receiving water hardness varied from 30 mg/L to 520 mg/L (as CaCO₃), based on 35 samples from June 2006 to June 2009. Using a hardness of 220 mg/L (as CaCO₃) to calculate the ECA for copper, chronic cadmium, chromium III, nickel, and zinc will result in water quality-based effluent limitations that are protective under all potential effluent/receiving water mixing scenarios and under all known hardness conditions, as demonstrated in the example using nickel shown in

Table F-6, below. This example assumes the following conservative conditions for the upstream receiving water:

- Upstream receiving water is never greater than the lowest observed receiving water hardness (i.e., 30 mg/L as CaCO₃)
- Upstream receiving water nickel concentration is always at the CTR criteria (i.e., no assimilative capacity). Based on available data, the receiving water never exceeded the CTR criteria for chromium III, nickel, and zinc. For copper and cadmium, this condition has at times not been met in the receiving water upstream of the discharge. Further discussion regarding copper and cadmium is provided below.

Using these reasonable worst-case conditions, the discharge can be mixed with the receiving water and a resulting downstream mixed hardness (or metals concentration) can be calculated for all discharge and mixing conditions (e.g., 0% effluent to 100% effluent) based on a simple mass balance as shown in Equation 3, below. By evaluating all discharge conditions the reasonable worst-case downstream hardness can be determined for adjusting the CTR criteria.

$$C_{MIX} = C_{RW} \times (1-EF) + C_{Eff} \times (EF) \quad \text{(Equation 3)}$$

Where:

- C_{MIX} = Mixed concentration (e.g. metals or hardness)
- C_{RW} = Upstream receiving water concentration
- C_{Eff} = Effluent concentration
- EF = Effluent Fraction

As demonstrated in Table F-6, using a minimum effluent hardness of 220 mg/L (as CaCO₃) to calculate the ECA for chromium III, nickel, and zinc ensures the discharge is protective under all discharge and mixing conditions. In this example, the effluent is in compliance with the CTR criteria and any mixture of the effluent and receiving water is in compliance with the CTR criteria. An ECA based on a lower hardness (e.g. lowest upstream receiving water hardness) would also be protective, but would result in unreasonably stringent effluent limits considering the known conditions. Therefore, in this Order the ECA for chromium III, nickel, and zinc has been calculated using Equation 1 with a hardness of 220 mg/L (as CaCO₃).

Table F-6: Chronic Nickel ECA Evaluation

Minimum Observed Effluent Hardness	220 mg/L (as CaCO ₃)
Minimum Observed Upstream Receiving Water Hardness	30 mg/L (as CaCO ₃)
Maximum Upstream Receiving Water Nickel Concentration	19 µg/L ¹
Nickel ECA _{chronic} ²	102 µg/L

Effluent Fraction	Mixed Downstream Ambient Concentration		
	Hardness ³ (mg/L) (as CaCO ₃)	CTR Criteria ⁴ (µg/L)	Nickel ⁵ (µg/L)
1%	31.9	19.8	19.7
5%	39.5	23.8	23.0
15%	58.5	33.1	31.3
25%	77.5	42.0	39.5
50%	125	63.0	60.2
75%	172.5	82.7	80.9
100%	220	101.6	101.6

¹ Maximum upstream receiving water nickel concentration calculated using Equation 1 for chronic criterion at a hardness of 30 mg/L (as CaCO₃).

² ECA calculated using Equation 1 for chronic criterion at a hardness of 220 mg/L (as CaCO₃).

³ Mixed downstream ambient hardness is the mixture of the receiving water and effluent hardness at the applicable effluent fraction using Equation 3.

⁴ Mixed downstream ambient criteria are the chronic criteria calculated using Equation 1 at the mixed hardness.

⁵ Mixed downstream ambient nickel concentration is the mixture of the receiving water and effluent nickel concentrations at the applicable effluent fraction using Equation 3.

As discussed above, the receiving water at times exceeds the CTR criteria for copper and chronic cadmium. The 2006 study procedures remain applicable under these conditions. Using these procedures the discharge does not cause or contribute to a violation of the water quality criteria. Any exceedances of the CTR criteria are due to the elevated metal concentrations in the receiving water upstream of the discharge. For clarity, the impact of the copper discharge on the receiving water which already contains copper in excess of water quality criteria is illustrated in Table F-7.

As reported in Table F-7, prior to the discharge the copper has been observed to exceed water quality criteria by up to 86%. When the receiving water contains some fraction of effluent, the percent exceedance is reduced. The greater the amount of effluent in the receiving water, the lower the percent exceedance, until a fully compliant state is achieved when the effluent constitutes the entire flow. The effluent limitation associated with copper, therefore, was sufficient to assure that the discharge never causes or contributes to a violation of a water quality criterion, and in fact reduces the amount of toxicity already present in the receiving water. The results for chronic cadmium are similar.

Table F-7: Chronic Copper ECA Evaluation

Minimum Observed Effluent Hardness	220 mg/L (as CaCO ₃)
Minimum Observed Upstream Receiving Water Hardness	30 mg/L (as CaCO ₃)
Maximum Observed Upstream Receiving Water Copper Concentration	6.2 µg/L ¹

Copper ECA _{chronic} ²			18.3 µg/L	
Effluent Fraction	Mixed Downstream Ambient Concentration			
	Hardness ³ (mg/L) (as CaCO ₃)	CTR Criteria ⁴ (µg/L)	Copper ⁵ (µg/L)	Percent exceedance
0%	30	3.3	6.2	86%
1%	31.9	3.5	6.32	80%
5%	39.5	4.2	6.81	61%
15%	58.5	5.9	8.02	36%
25%	77.5	7.5	9.23	23%
50%	125	11.3	12.3	9%
75%	172.5	14.9	15.3	3%
100%	220	18.3	18.3	0%

- 1 Maximum observed upstream receiving water copper concentration.
- 2 ECA calculated using Equation 1 for chronic criterion at a hardness of 220 mg/L (as CaCO₃).
- 3 Mixed downstream ambient hardness is the mixture of the receiving water and effluent hardness at the applicable effluent fraction using Equation 3.
- 4 Mixed downstream ambient criteria are the chronic criteria calculated using Equation 1 at the mixed hardness.
- 5 Mixed downstream ambient copper concentration is the mixture of the receiving water and effluent copper concentrations at the applicable effluent fraction using Equation 3.

ECA for Concave Up Metals – For Concave Up Metals (i.e., acute cadmium, lead, and acute silver), the 2006 Study demonstrates that due to a different relationship between hardness and the metals criteria, the effluent and upstream receiving water can be in compliance with the CTR criteria, but the resulting mixture may be out of compliance. Therefore, the 2006 Study provides a mathematical approach to calculate the ECA to ensure that any mixture of effluent and receiving water is in compliance with the CTR criteria (see Equation 4, below). The ECA, as calculated using Equation 4, is based on the reasonable worst-case ambient background hardness, no receiving water assimilative capacity for metals (i.e., ambient background metals concentrations are at their respective CTR criterion), and the minimum observed effluent hardness. The reasonable worst-case ambient background hardness depends on whether the effluent hardness is greater than or less than the upstream receiving water hardness. There are circumstances where the conservative ambient background hardness assumption is to assume that the upstream receiving water is at the highest observed hardness concentration. The conservative upstream receiving water condition as used in the Equation 4 below is defined by the term H_{rw}.

$$ECA = \left(\frac{m(H_e - H_{rw}) \left(e^{m \{ \ln(H_{rw}) \} + b} \right)}{H_{rw}} \right) + e^{m \{ \ln(H_{rw}) \} + b} \quad \text{(Equation 4)}$$

Where:

m, b = criterion specific constants (from CTR)

H_e = minimum observed effluent hardness

H_{rw} = minimum observed upstream receiving water hardness when the minimum effluent hardness is always greater than observed upstream receiving water hardness ($H_{rw} < H_e$)

-or-

maximum observed upstream receiving water hardness when the minimum effluent hardness is always less than observed upstream receiving water hardness ($H_{rw} > H_e$)¹

These procedures are applicable to calculate the CTR criteria for the Concave Up Metals lead and silver. However, the receiving water has been shown to exceed the CTR criteria for acute cadmium, based on paired hardness and metals receiving water data from March 2002 and July 2002. This is not consistent with the assumptions of the 2006 Study, therefore, these procedures for calculating the ECA for the Concave Up Metals are not applicable for acute cadmium. The procedure for selecting the appropriate hardness for acute cadmium is discussed below.

A similar example as was done for the Concave Down Metals is shown for lead, a Concave Up Metal, in Tables F-7 and F-8, below. As previously mentioned, the minimum effluent hardness is 220 mg/L (as CaCO_3), while the upstream receiving water hardness ranged from 30 mg/L to 520 mg/L (as CaCO_3). In this case, the minimum effluent concentration is within the range of observed upstream receiving water hardness concentrations. Therefore, Equation 4 was used to calculate two ECAs, one based on the minimum observed upstream receiving water hardness and one based on the maximum observed upstream receiving water hardness². Using Equation 4, the lowest ECA results from using the maximum upstream receiving water hardness, the minimum effluent hardness, and assuming no receiving water capacity for lead (i.e., ambient background lead concentration is at the CTR chronic criterion). However, based on paired ambient hardness and metals data, the receiving water exceeded the CTR criteria for acute cadmium. Therefore, a different hardness must be used for acute cadmium to ensure protective WQBELs are calculated, as discussed below.

Using Equation 4 to calculate the ECA for lead and acute silver will result in water quality-based effluent limitations that are protective under all potential

¹ When the minimum effluent hardness falls within the range of observed receiving water hardness concentrations, Equation 3 is used to calculate two ECAs, one based on the minimum observed upstream receiving water hardness and one based on the maximum observed upstream receiving water hardness. The minimum of the two calculated ECAs represents the ECA that ensures any mixture of effluent and receiving water is in compliance with the CTR criteria.

² Although the maximum upstream receiving water hardness is 550 mg/L (as CaCO_3) a maximum hardness of 400 mg/L (as CaCO_3) was used in this evaluation, because the CTR equations are not applicable for a hardness greater than 400 mg/L.

effluent/receiving water mixing scenarios and under all known hardness conditions, as demonstrated in Tables F-7 and F-8, for chronic lead. In this example, the effluent is in compliance with the CTR criteria and any mixture of the effluent and receiving water is in compliance with the CTR criteria. Use of a lower ECA (e.g., calculated based solely on the lowest upstream receiving water hardness) is also protective, but would lead to unreasonably stringent effluent limits considering the known conditions. Therefore, Equation 4 has been used to calculate the ECA for lead and acute silver in this Order. For acute cadmium, the minimum observed upstream receiving water hardness of 30 mg/L (as CaCO₃) is required to calculate the ECA to ensure the discharge is protective.

Table F-8: Chronic Lead ECA Evaluation

Minimum Observed Effluent Hardness		220 mg/L (as CaCO₃)	
Minimum Observed Upstream Receiving Water Hardness		30 mg/L (as CaCO₃)	
Maximum Upstream Receiving Water Lead Concentration		0.69 µg/L¹	
Lead ECA_{chronic}²		6.2 µg/L	
Mixed Downstream Ambient Concentration			
Effluent Fraction	Hardness³ (mg/L) (as CaCO₃)	CTR Criteria⁴ (µg/L)	Lead⁵ (µg/L)
1%	31.9	0.7	0.7
5%	39.5	1.0	1.0
15%	58.5	1.6	1.5
25%	77.5	2.3	2.1
50%	125.0	4.2	3.5
75%	172.5	6.4	4.8
100%	220.0	8.7	6.2

¹ Minimum upstream receiving water lead concentration calculated using Equation 1 for chronic criterion at a hardness of 30 mg/L (as CaCO₃).

² ECA calculated using Equation 3 for chronic criteria.

³ Mixed downstream ambient hardness is the mixture of the receiving water and effluent hardness at the applicable effluent fraction.

⁴ Mixed downstream ambient criteria are the chronic criteria calculated using Equation 1 at the mixed hardness.

⁵ Mixed downstream ambient lead concentration is the mixture of the receiving water and effluent lead concentrations at the applicable effluent fraction.

Table F-9: Chronic Lead ECA Evaluation

Minimum Observed Effluent Hardness		220 mg/L (as CaCO₃)	
Maximum Observed Upstream Receiving Water Hardness		400 mg/L (as CaCO₃)	
Maximum Upstream Receiving Water Lead Concentration		19 µg/L¹	
Lead ECA_{chronic}²		8.0 µg/L	
Mixed Downstream Ambient Concentration			
Effluent Fraction	Hardness³ (mg/L) (as CaCO₃)	CTR Criteria⁴ (µg/L)	Lead⁵ (µg/L)
1%	398.2	18.5	18.5
5%	391.0	17.1	18.0
15%	373.0	17.0	17.0
25%	355.0	16.0	15.9
50%	310.0	13.4	13.3
75%	265.0	11.0	10.6
100%	220.0	8.7	7.9

¹ Maximum upstream receiving water lead concentration calculated using Equation 1 for chronic criterion at a hardness of 400 mg/L (as CaCO₃).

² ECA calculated using Equation 3 for chronic criteria.

³ Mixed downstream ambient hardness is the mixture of the receiving water and effluent hardness at the applicable effluent fraction using Equation 3.

⁴ Mixed downstream ambient criteria are the chronic criteria calculated using Equation 1 at the mixed hardness.

⁵ Mixed downstream ambient lead concentration is the mixture of the receiving water and effluent lead concentrations at the applicable effluent fraction using Equation 3.

3. Determining the Need for WQBELs

- a. The Central Valley Water Board conducted the RPA in accordance with section 1.3 of the SIP. Although the SIP applies directly to the control of CTR priority pollutants, the State Water Board has held that the Central Valley Water Board may use the SIP as guidance for water quality-based toxics control.¹ The SIP states in the introduction *“The goal of this Policy is to establish a standardized approach for permitting discharges of toxic pollutants to non-ocean surface waters in a manner that promotes statewide consistency.”* Therefore, in this Order the RPA procedures from the SIP were used to evaluate reasonable potential for both CTR and non-CTR constituents based on information submitted as part of the application, in studies, and as directed by monitoring and reporting programs. When sufficient data were available, the RPA for each constituent was conducted based on effluent and receiving water data from June 2006 to June 2009. For CTR constituents, when effluent data were not available from June 2006 to June 2009, effluent CTR data from January 2003, February 2003, and March 2005 through August 2005 were used. Due to the lack of more recent

¹ See Order WQO 2001-16 (Napa) and Order WQO 2004-0013 (Yuba City).

receiving water CTR data, data from March 2002 and July 2002 were used for receiving water CTR constituents.

- b. Constituents with Limited Data.** Reasonable potential cannot be determined for the following constituents because representative effluent data are limited and the Facility tertiary treatment upgrade will provide additional removal for constituents, or ambient background concentrations are not available. The Discharger is required to continue to monitor for these constituents in the effluent using analytical methods that provide the best feasible detection limits. When additional data become available, further analysis will be conducted to determine whether to add numeric effluent limitations or to continue monitoring.
- i. Electrical Conductivity.** The Discharger submitted a Salinity Report dated June 2006, which identified potential sources of salinity and indicated that the effluent EC of the Facility was at expected levels. This permit requires the Discharger to conduct a site-specific study to develop EC objectives that will protect water quality. An effluent limitation for EC is included in this permit until the site-specific study is completed, and based upon the results of the site-specific study, the final effluent limitation may be modified or additional salinity requirements may be added.
- c. Constituents with No Reasonable Potential.** WQBELs are not included in this Order for constituents that do not demonstrate reasonable potential; however, monitoring for those pollutants may be established in this Order as required by the SIP. If the results of effluent monitoring demonstrate reasonable potential, this Order may be reopened and modified by adding an appropriate effluent limitation.
- i. Diazinon.** Order No. R5-2004-0096 included effluent limitations and monthly monitoring requirements for diazinon and 31 samples from June 2006 through June 2009 were used for the RPA. Diazinon was not detected in all 31 samples and therefore, the discharge does not demonstrate reasonable potential to cause or contribute to an in-stream excursion above non-CTR water quality criterion for diazinon (see Attachment G Reasonable Potential Analysis).
- ii. Settleable Solids.** Order No. R5-2004-0096 requires that the effluent comply with a daily maximum effluent limitation of 0.2 ml/L hr and a monthly average effluent limit of 0.1 ml/L hr for settleable solids to implement the Basin Plan's narrative objectives for Settleable Material. Based on the RPA dataset, over 1100 daily samples from June 2006 through September 2009, Settleable Solids measured 0.1 ml/L only twice (two consecutive days) in February 2007 and was not detected (less than reporting levels of < 0.1 ml/L) in all the other effluent samples. Based on the procedures established in Section 1.3 of the SIP for determining reasonable potential, the discharge no longer demonstrates reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's narrative objective for Settleable Material, therefore, no effluent limit is included in this Order.

iii. **Cyanide.** Order No. R5-2004-0096 included effluent limitations and monthly monitoring requirements for cyanide, and 33 samples from June 2006 through June 2009 were used for the RPA. Cyanide was not detected in all 33 samples and therefore, the discharge does not demonstrate reasonable potential to cause or contribute to an in-stream excursion above CTR water quality criterion for cyanide (see Attachment G Reasonable Potential Analysis).

iv. **Bis (2-ethylhexyl) phthalate.** The CTR includes a criterion of 1.8 µg/L for the protection of human health and is based on a one-in-a-million cancer risk for waters from which both water and organisms are consumed. CTR monitoring was performed in April 2005 and August 2005. The April 2005 sample revealed a detection that was not quantifiable, but was estimated at 0.7 µg/L, which is less than the CTR criterion of 1.8 µg/L. The August 2005 sample was non-detect. The upstream receiving water has not been sampled by the Discharger since 2002, at which time the two samples taken resulted in non-detects. Based on this data and the procedures established in Section 1.3 of the SIP for determining reasonable potential, the discharge does not demonstrate reasonable potential to cause or contribute to an in-stream excursion above CTR water quality criterion for bis(2-ethylhexyl)phthalate (see Attachment G Reasonable Potential Analysis).

d. **Constituents with Reasonable Potential.** The Central Valley Water Board finds that the discharge has a reasonable potential to cause or contribute to an in-stream excursion above a water quality standard for aluminum, ammonia, arsenic, cadmium, copper, dibromochloromethane, dichlorobromomethane, iron, manganese, nitrate, pathogens, persistent chlorinated hydrocarbon pesticides, pH, salinity, and total trihalomethane,. WQBELs for these constituents are included in this Order. A summary of the RPA is provided in Attachment G, and a detailed discussion of the RPA for each constituent is provided below.

i. **Aluminum**

(a) **WQO.** USEPA developed National Recommended Ambient Water Quality Criteria (NAWQC) for protection of freshwater aquatic life for aluminum. The recommended 4-day average (chronic) and 1-hour average (acute) criteria for aluminum are 87 µg/L and 750 µg/L, respectively, for waters with a pH of 6.5 to 9.0. The Secondary Maximum Contaminant Level - Consumer Acceptance Limit (MCL) for aluminum for the protection of the MUN beneficial use is 200 µg/L. USEPA recommends that the ambient criteria are protective of the aquatic beneficial uses of receiving waters. However, information contained in footnote L to the NAWQC Correction (1999) summary table for aluminum indicates that the chronic aquatic life criterion is based on studies conducted under specific receiving water conditions with a low pH (6.5 to 6.6 pH units) and low hardness (<10 mg/L as CaCO₃). Monitoring data demonstrates that these conditions are not similar to those in Reclamation District 777 Lateral Drain No. 1. The receiving water monitoring indicates

upstream hardness concentrations ranging from 72 to 546 mg/L as CaCO₃ and a pH that is greater than 7.0 standard units. Thus, it is unlikely that application of the chronic criterion of 87 µg/L is necessary to protect aquatic life in Reclamation District 777 Lateral Drain No. 1. For similar reasons, the Utah Department of Environmental Quality (Department) only applies the 87 µg/L chronic criterion for aluminum where the pH is less than 7.0 and the hardness is less than 50 mg/L as CaCO₃ in the receiving water after mixing. For conditions where the pH equals or exceeds 7.0 and the hardness is equal to or exceeds 50 mg/L as CaCO₃, the Department regulates aluminum based on the 750 µg/L acute criterion. USEPA is aware of field data indicating that many high quality waters in the U.S. contain more than 87 µg aluminum/L, when either total recoverable or dissolved is measured (Footnote L). As such, USEPA suggest the use of a water effects ratio (WER) might be appropriate for implementation of its recommended chronic criterion for aluminum to protect aquatic organisms.

Due to uncertainties with NAWQC for aluminum, in May 2006, the Arid West Water Quality Research Project produced its technical report, *Evaluation of the EPA Recalculation Procedure in the Arid West Technical Report*, to update NAWQC based on more recent data, and to recalculate USEPA's recommended NAWQC to reflect the resident species and water quality observed in arid West surface waters. Five effluent-dependent and ephemeral streams were studied during the research project for ambient water characteristics, and the aluminum criteria recalculation was based on this data and on taxa more representative of communities found in these streams. The Arid West research study found and the report states that "*speciation and/or complexation of aluminum is highly dependent on ambient water quality characteristics and ultimately determines the mechanism of toxicity. [Increased] Concentrations of calcium in the water was shown to decrease toxic effects to fish.*" Based on the Arid West Technical Report, the Chronic Aluminum (total) Criterion Recalculation Value is 1954 µg/L for a mean hardness value of 272 mg/L as CaCO₃.

The Arid West Technical Report that recalculated the aluminum NAWQC for effluent-dependent streams as waters that are "created by the discharge of treated effluent into ephemeral streambeds or streams that in the absence of effluent discharge would have only minimal flow." Similarly, as described previously in section IV.C.2.a of this Fact Sheet, Lateral Drain No. 1 does not receive natural water flows but at times receives stormwater or agricultural runoff, and thus is effluent dominant. Therefore since the stream morphology of Lateral Drain No. 1 is similar to the streams in the Arid West Research Project, Board staff also compared the ambient water quality characteristics.

The Arid West study streams' water quality characteristics and applicable recalculated aluminum criteria from Tables 10-1 and 10-2 in their Technical Report are summarized below:

	Santa Ana River	Santa Cruz River	Salt/Gila River	Fountain Creek	South Platte River
Mean Hardness (mg/L)	188	170	388	218	280
Mean pH (standard units)	7.2	7.5	7.4	7.4	7.4
Acute Criterion (GMC): Total Aluminum (µg/L)	3464	6054	7763	3609	4826
Chronic Criterion (CCC) Total Aluminum (µg/L)	1384	2420	3103	1443	1929

Additionally, for comparison, monitoring results obtained from Lateral Drain No. 1, and other receiving waters within the Central Valley Region surrounded by similar land uses (e.g. agricultural runoff), are summarized in the following table:

	Lateral Drain No. 1 RSW-002	San Joaquin River Near Manteca	San Joaquin River Near Modesto
Hardness Range (mg/L)	72 - 546	56 - 152	50-700
pH Range(standard units)	7.1 - 8.7	6.0 - 9.1	6.7-8.7
EC Range (µmhos/cm)	51-1079 ¹	113 - 1102	160-1812

1. Upstream Monitoring Location, RSW 001

As shown in these two tables, the ambient water quality characteristics of the Arid West study streams and the streams in the Central Valley Region are similar, including Lateral Drain No. 1. Thus, based on the recalculated aluminum chronic criterion in the Arid West Technical Report (shown in the previous table in this section) that ranges from 1384 µg/L to 3103 µg/L, and the WER studies conducted by the Cities of Manteca and Modesto as discussed below, the NAWQC (EPA-822-R-02-047) is overly protective in effluent dominant receiving waters such as Lateral Drain No. 1, and therefore, the NAWQC chronic criterion of 87 µg/L is not used to interpret the Basin Plan's narrative toxicity objective in this Order.

The Discharger did not conduct a site-specific study to determine the appropriate water quality criteria or whether the Arid West recalculated Chronic Aluminum (total) Criterion Value at 1954 µg/L for a mean hardness value of 272 mg/L is fully protective of the representative species found in Lateral Drain No. 1 or nearby waterbodies. However, four Dischargers within the Central Valley Region have conducted site-specific aluminum WERs (Cities of Manteca, Yuba City, Modesto, and Auburn), and the representative species used in the aluminum WER studies were *Ceriodaphnia dubia*, *Daphnia magna*, or *Oncorhynchus mykiss* (rainbow trout). The 1994 WER Guidance for determining aluminum WERs recommends using these three species in toxicity tests, and ranks them as the most sensitive species cited in the aluminum

criteria document. Moreover, these three representative species are within the resident fish communities listed in Table 2-1 of the Arid West Technical Report, and therefore are appropriate test species.

The following table summarizes the Arid West Technical Report recalculated final aluminum criterion (normalized to Hardness of 50 mg/L) for these three test species. (Tables 3-4 and 3-5 of the Arid West Report).

Arid West Results					
Species	Common Name	GMAV ¹	GMCV ¹	SMAV ²	SMCV ²
Ceriodaphnia dubia	Cladoceran	2741 ³	4165	2466	4165
<i>Daphnia magna</i>	Cladoceran	10890	274	10890	274
Oncorhynchus mykiss	Rainbow Trout	No Values	No Values	10835	No Values

¹ GMAV: Genus Mean Acute Value or GMCV: Genus Mean Chronic Value

² SMAV: Species Mean Acute Value or SMCV: Species Mean Chronic Value

³ No GMAV value specifically for *Ceriodaphnia dubia*; this GMAV value is for *Ceriodaphnia* sp. and the applicable SMAV = 3046

For comparison, the following table summarizes the Central Valley Region Specie Specific Toxicity Results obtained during the Dischargers' WER studies. As shown in this table, the Total Aluminum EC50 values are within the range of the mean values obtained in the Arid West Results.

Discharger (City)	Species	Test Waters	Hardness Value	Total Aluminum EC ₅₀ Value
Auburn	Ceriodaphnia dubia	Effluent	99	>5270
	" "	Surface Water	16	>5160
Manteca	" "	Surface Water/Effluent	124	>8800
	" "	Effluent	117	>8700
	" "	Surface Water	57	7823
	" "	Effluent	139	>9500
	" "	Surface Water	104	>11000
	" "	Effluent	128	>9700
	" "	Surface Water	85	>9450
	" "	Effluent	106	>11900
	" "	Surface Water	146	>10650
Modesto	" "	Surface Water/Effluent	150-250	31604
Yuba City	" "	Surface Water/Effluent	114/164	>8000
Manteca	<i>Daphnia magna</i>	Surface Water/Effluent	124	>8350
Modesto	" "	Surface Water/Effluent	150-250	>11900
Yuba City	" "	Surface Water/Effluent	114/164	>8000
Manteca	Oncorhynchus mykiss	Surface Water/Effluent	124	>8600
Auburn	" "	Surface Water	16	>16500
Modesto	" "	Surface Water/Effluent	150-250	>34250
Yuba City	" "	Surface Water/Effluent	114/164	>8000

The Arid West Technical Report updated and revised the NAWQC criterion based upon selected hardness values from 1 mg/L to 400 mg/L (Table 3-8). However, the report cautions that "Since the equation models hardness values that ranged from 1 mg to 220 mg of CaCO₃/L, estimations made beyond outside of this range should be treated with caution." As previously discussed in this section, the mean hardness value down stream of the discharge (Monitoring Location RSW-002) is 278 mg/L as CaCO₃; however to be fully protective, the Central Valley

Board used a conservative mean hardness value at 200 mg/L as CaCO₃. The Arid West recalculated Aluminum (total) Chronic Criterion Value for a mean hardness value of 200 mg/L is 1623 µg/L. Based on these findings, the NAWQC acute and chronic criteria are overly protective. However, because the Discharger did not provide any any site-specific information regarding threshold concentrations of aluminum at which acute toxicity occurs, this Order applies the NAWQC acute criterion to interpret the Basin Plan's narrative toxicity objective to protect aquatic life, and the Secondary MCL for the protection of the MUN beneficial use.

- (b) **RPA Results.** The maximum effluent concentration (MEC) for aluminum was 530 µg/L based on 34 samples from June 2006 through June 2009, while the maximum observed upstream receiving water concentration was 1300 µg/L from a sample on 2 July 2002. Therefore, aluminum in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the recommended criteria.
- (c) **WQBELs.** This Order contains final Average Monthly Effluent Limitations (AMEL) and Maximum Daily Effluent Limitations (MDEL) for aluminum of 260 µg/L and 750 µg/L, respectively, based on the acute criterion recommended in USEPA's NAWQC for the protection of freshwater aquatic life (See Table F-11 for WQBEL calculations). Based on input from the California Department of Public Health (DPH) and the fact that secondary MCLs are designed to protect consumer acceptance, effluent limitations based on secondary MCLs are to be applied as an annual average concentration. Therefore, this Order contains new WQBELs for aluminum as an annual average effluent limitation of 200 µg/L to protect the MUN beneficial use. Due to no assimilative capacity, dilution credits are not allowed for development of the WQBELs for aluminum. This Order contains a final average monthly effluent limitation (AMEL) and maximum daily effluent limitation (MDEL) for aluminum of 260 µg/L and 750 µg/L, respectively, based on best professional judgment the recommended NAWQC for protection of freshwater aquatic life.
- (d) **Plant Performance and Attainability.** Analysis of the effluent data shows that the MEC of 530 µg/L is less than the applicable acute criterion. However, the Discharge may not be able to comply with the annual average of 200 µg/L, and therefore, the Discharger appears to be in immediate non-compliance with the aluminum final effluent limitations. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. The annual average final effluent limitation represents a new limit and therefore, based on the Discharger's request, a time schedule for compliance with the effluent limit is established in amended CDO R5-2009-0012-02 in accordance with CWC section 13301. The CDO

requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3.

ii. Ammonia

(a) **WQO.** The NAWQC for the protection of freshwater aquatic life for total ammonia, recommends acute (1-hour average; criteria maximum concentration or CMC) standards based on pH and chronic (30-day average; criteria continuous concentration or CCC) standards based on pH and temperature. USEPA also recommends that no 4-day average concentration should exceed 2.5 times the 30-day CCC. USEPA found that as pH increased, both the acute and chronic toxicity of ammonia increased. Salmonids were more sensitive to acute toxicity effects than other species. However, while the acute toxicity of ammonia was not influenced by temperature, it was found that invertebrates and young fish experienced increasing chronic toxicity effects with increasing temperature.

The maximum permitted effluent pH is 8.3. In order to protect against the worst-case short-term exposure of an organism, a pH value of 8.3 was used to derive the acute criterion. The resulting acute criterion is 3.15 mg/L.

The 30-day average chronic criterion (CCC) was evaluated for the receiving water based on monitoring data obtained from June 2006 through June 2009. Each chronic criterion value was calculated using the rolling 30-day average pH and temperature of the receiving water. From 150 chronic criterion data values, the 99.9th percentile of the data set was selected as the most stringent criteria, which is consistent with the 1-in-3 year average frequency for criteria excursions recommended by the USEPA. As a result, the effluent CCC was 1.16 mg/L ammonia as N, which was used for development of water quality-based effluent limitations for ammonia.

The 4-day average concentration is derived in accordance with the USEPA criterion as 2.5 times the 30-day CCC. Based on the 30-day CCC of 1.16 mg/L (as N), the 4-day average concentration that should not be exceeded is 2.90 mg/L (as N).

(b) **RPA Results.** Untreated domestic wastewater contains ammonia. Nitrification is a biological process that converts ammonia to nitrite and nitrite to nitrate. Denitrification is a process that converts nitrate to nitrite or nitric oxide and then to nitrous oxide or nitrogen gas, which is then released to the atmosphere. The Discharger does not currently use nitrification to remove ammonia from the waste stream. Inadequate or incomplete nitrification may result in the discharge of ammonia to the receiving stream. Ammonia is known to cause toxicity to aquatic organisms in surface waters. Discharges of ammonia would violate the

Basin Plan narrative toxicity objective. The MEC for ammonia was 17.1 mg/L while the maximum observed upstream receiving water concentration was 3.1 mg/L. Therefore, ammonia in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the NAWQC. The new facility will include nitrification facilities which will help reduce ammonia in the effluent.

(c) **WQBELs.** The Central Valley Water Board calculates WQBELs in accordance with SIP procedures for non-CTR constituents, and ammonia is a non-CTR constituent. Section 1.4 of the SIP allows the use of a coefficient of variation (CV) equal to 0.6 when there is a lack of sufficient data points to calculate a CV value. Since the new facility has not been constructed, at this time there are no data points from the new facility and a CV value cannot be determined. Therefore, a CV equal to 0.6 was used to determine the final effluent ammonia limits for the new facility. The SIP procedure assumes a 4-day averaging period for calculating the long-term average discharge condition (LTA). However, USEPA recommends modifying the procedure for calculating permit limits for ammonia using a 30-day averaging period for the calculation of the LTA corresponding to the 30-day CCC. Therefore, while the LTAs corresponding to the acute and 4-day chronic criteria were calculated according to SIP procedures, the LTA corresponding to the 30-day CCC was calculated assuming a 30-day averaging period. The lowest LTA representing the acute, 4-day CCC, and 30-day CCC is then selected for deriving the average monthly effluent limitation (AMEL) and the maximum daily effluent limitation (MDEL), which in this case is the 30-day chronic criterion. The remainder of the WQBEL calculation for ammonia was performed according to the SIP procedures (For Ammonia calculations, see Table F-12 below). This Order contains a final average monthly effluent limitation (AMEL) and maximum daily effluent limitation (MDEL) for ammonia of 1.4 mg/L and 2.8 mg/L, respectively, based on the NAWQC (chronic criteria).

(d) **Plant Performance and Attainability.** Analysis of the effluent data shows that the MEC of 17.1 µg/L is greater than applicable WQBELs. Based on the sample results for the effluent, the final ammonia effluent limitations appear to put the Discharger in immediate non-compliance. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. The existing Permit contains a floating ammonia limit, and the existing CDO contains a performance-based interim limit at 23.7 mg/L. According to State Water Board Resolution No. 2008-0025 (Compliance Schedule Policy), *"Numeric interim limitations for the pollutant must, at a minimum, be based on current treatment facility performance or on existing permit limitations, whichever is more stringent. If the existing permit limitations are more stringent, and the discharger is not in compliance with those limitations, the noncompliance under the existing*

permit must be addressed through appropriate enforcement action...” The floating ammonia limit is the more stringent; however, the Discharger cannot comply with that limit. Therefore, a compliance schedule must be included in a separate enforcement Order. The compliance schedule for ammonia is included in amended CDO R5-2009-0012-02, in accordance with CWC section 13301. The CDO requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3.

iii. Mercury

- (a) **WQO.** The current NAWQC for protection of freshwater aquatic life, continuous concentration, for mercury is 0.77 µg/L (30-day average, chronic criteria). The CTR contains a human health criterion (based on a threshold dose level causing neurological effects in infants) of 0.050 µg/L for waters from which both water and aquatic organisms are consumed. Both values are controversial and subject to change. In 40 CFR Part 131, USEPA acknowledges that the human health criteria may not be protective of some aquatic or endangered species and that “...*more stringent mercury limits may be determined and implemented through use of the State’s narrative criterion.*” In the CTR, USEPA reserved the mercury criteria for freshwater and aquatic life and may adopt new criteria at a later date.
- (b) **RPA Results.** The maximum observed effluent mercury concentration was 0.0134 µg/L. There are no recent receiving water samples for mercury. Data from receiving water samples taken in March 2002 and July 2002 showed mercury concentrations below the criteria. Mercury bioaccumulates in fish tissue and, therefore, the discharge of mercury to the receiving water may contribute to exceedances of the narrative toxicity objective and impact beneficial uses.
- (c) **WQBELs.** On 11 June 2009, the Central Valley Water Board adopted Resolution No. R5-2009-0059 updating the Section 303(d) list of Water Quality Limited Segments for the Central Valley Region. The Sutter Bypass has been identified as impaired for mercury in the June 2009 update.

The SIP states in Section 2.1.1 that, “For bioaccumulative priority pollutants for which the receiving water has been included on the CWA Section 303(d) list, the RWQCB should consider whether the mass loading of the bioaccumulative pollutant(s) should be limited to representative, current levels pending TMDL development...” Although there is no reasonable potential for mercury based on the currently applicable water quality objectives, mercury is bioaccumulative and may impact waterways that are impaired downstream of the discharge. Therefore, this Order contains a performance-based mass effluent limitation of 0.057 lbs/year for mercury for the effluent discharged to the

receiving water. This limitation is based on maintaining the mercury loading at the current level until a TMDL can be established or USEPA develops mercury standards that are protective of human health. This Order also requires the Discharger prepare and implement a mercury evaluation and minimization plan to address sources of mercury from the Facility. The performance-based effluent limitation was calculated as follows:

$[\text{Maximum Effluent Concentration (mg/L)}] * [\text{Average Dry Weather Flow Rate}] * [8.34 \text{ (conversion factor)}] * [365 \text{ days}] = \text{lbs/year.}$

- (d) **Plant Performance and Attainability.** Since the limitation is a performance-based effluent limitation, the Discharger can meet this new limitation.

iv. Chlorine Residual

- (a) **WQO.** USEPA developed NAWQC for protection of freshwater aquatic life for chlorine residual. The recommended 4-day average (chronic) and 1-hour average (acute) criteria for chlorine residual are 0.011 µg/L and 0.019 µg/L, respectively. These criteria are protective of the Basin Plan's narrative toxicity objective.

When the new Facility is operational, effluent disinfection will be accomplished by a UV disinfection system and chlorine will no longer be used for effluent disinfection. The new Facility will continue to use chlorine for maintenance purposes such as in the oxidation ditch to control foaming. The threat of a chlorine release will be significantly less with the use of UV disinfection of the effluent than with the chlorination/dechlorination process. However, since chlorine is highly toxic to aquatic life, this Order includes effluent limitations and monitoring requirements for when chlorine is used for maintenance purposes.

- (b) **RPA Results.** The Discharger will continue to use chlorine for disinfection, which is extremely toxic to aquatic organisms, until the new UV disinfection system is operational with the new Facility. The Discharger uses a sulfur dioxide process to dechlorinate the effluent prior to discharge to Reclamation District 777 Lateral Drain No. 1. Due to the existing chlorine use and the potential for chlorine to be discharged, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the NAWQC.
- (c) **WQBELs.** The USEPA *Technical Support Document for Water Quality-Based Toxics Control* [EPA/505/2-90-001] contains statistical methods for converting chronic (4-day) and acute (1-hour) aquatic life criteria to average monthly and maximum daily effluent limitations based on the variability of the existing data and the expected frequency of monitoring.

However, because chlorine is an acutely toxic constituent that can and will be monitored continuously, an average 1-hour limitation is considered more appropriate than an average daily limitation. This Order contains a 4-day average effluent limitation and 1-hour average effluent limitation for chlorine residual of 0.011 µg/L and 0.019 µg/L, respectively, based on USEPA's NAWQC, which implements the Basin Plan's narrative toxicity objective for protection of aquatic life. The Discharger began construction of major tertiary treatment upgrades to the Facility in September 2009. The new tertiary treatment facility will include, in part, an ultraviolet light (UV) disinfection system that should be completed during the term of this permit to replace the existing chlorine disinfection system. Therefore, monitoring requirements for chlorine residual may be discontinued upon completion of the UV disinfection system

- (d) Plant Performance and Attainability.** The effluent limitations for total chlorine residual is carried over from the previous permit and the new Facility will use UV disinfection of the effluent which replaces the use of chlorine for disinfection. The Central Valley Water Board concludes that immediate compliance with these effluent limitations is feasible.

v. Nitrate

- (a) WQO.** DPH has adopted primary MCLs for the protection of human health for nitrite and nitrate that are equal to 1 mg/L and 10 mg/L (measured as nitrogen), respectively. DPH has also adopted a primary MCL of 10 mg/L for the sum of nitrate and nitrite, measured as nitrogen.

USEPA has developed a primary MCL and an MCL goal of 1 mg/L for nitrite (as nitrogen). For nitrate, USEPA has developed Drinking Water Standards (10 mg/L as primary MCL) and NAWQC for protection of human health (10 mg/L for non-cancer health effects). Recent toxicity studies have indicated a possibility that nitrate is toxic to aquatic organisms.

- (b) RPA Results.** Untreated domestic wastewater contains ammonia. Nitrification is a biological process that converts ammonia to nitrite and nitrite to nitrate. Denitrification is a process that converts nitrate to nitrite or nitric oxide and then to nitrous oxide or nitrogen gas, which is then released to the atmosphere. Nitrate and nitrite are known to cause adverse health effects in humans. Inadequate or incomplete denitrification may result in the discharge of nitrate and/or nitrite to the receiving stream. The conversion of ammonia to nitrites and the conversion of nitrites to nitrates present a reasonable potential for the discharge to cause or contribute to an in-stream excursion above the Primary MCLs for nitrite and nitrate.

- (c) WQBELs.** This Order contains a final average monthly effluent limitation (AMEL) for nitrate of 10 mg/L, based on the protection of the Basin Plan's

narrative chemical constituents' objective and to assure the treatment process adequately nitrifies and denitrifies the waste stream.

- (d) Plant Performance and Attainability.** Analysis of the effluent data shows that the MEC for nitrate (as N) of 13.8 mg/L plus nitrite (as N) of 0.77 mg/L is greater than the WQBELs, and therefore, the Discharger appears to be in immediate non-compliance with nitrate final effluent limitations. The new Facility includes nitrification, but does not include denitrification. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Therefore, a time schedule for compliance with the effluent limit is established in amended CDO R5-2009-0012-02 in accordance with CWC section 13301. The CDO also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3.

vi. Dibromochloromethane

- (a) WQO.** The CTR includes a criterion of 0.41 µg/L for dibromochloromethane for the protection of human health for waters from which both water and organisms are consumed.
- (b) RPA Results.** CTR monitoring was performed monthly from March through August 2005. The MEC for dibromochloromethane was 4.2 µg/L. Therefore, dibromochloromethane in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for the protection of human health.
- (c) WQBELs.** This Order contains a final average monthly effluent limitation (AMEL) and maximum daily effluent limitation (MDEL) for dibromochloromethane of 0.41 µg/L and 0.82 µg/L, respectively, based on the CTR criterion for the protection of human health.
- (d) Plant Performance and Attainability.** Analysis of the effluent monitoring samples shows an MEC of 4.2 µg/L, and therefore, the Discharger appears to be in immediate non-compliance with dibromochloromethane final effluent limitations. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Therefore, a time schedule for compliance with the effluent limit is established in amended CDO R5-2009-0012-02 in accordance with CWC section 13301. The CDO also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3. The Discharger began construction of major Facility upgrades in September 2009. The new Facility will use UV disinfection of the effluent which replaces the use of chlorine for disinfection. The Central Valley Water Board concludes that

compliance with the effluent limit will be feasible as soon as the new Facility is operational.

vii. Dichlorobromomethane

- (a) **WQO.** The CTR includes a criterion of 0.56 µg/L for dichlorobromomethane for the protection of human health for waters from which both water and organisms are consumed.
- (b) **RPA Results.** CTR monitoring was performed monthly from March through August 2005. The MEC for dichlorobromomethane was 28.2 µg/L. Therefore, dichlorobromomethane in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for the protection of human health.
- (c) **WQBELs.** This Order contains a final average monthly effluent limitation (AMEL) and maximum daily effluent limitation (MDEL) for dichlorobromomethane of 0.56 µg/L and 1.2 µg/L, respectively, based on the CTR criterion for the protection of human health.
- (d) **Plant Performance and Attainability.** Analysis of the effluent monitoring samples shows an MEC of 28.2 µg/L; therefore, the Discharger appears to be in immediate non-compliance with dichlorobromomethane final effluent limitations. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Therefore, a time schedule for compliance with the effluent limit is established in amended CDO R5-2009-0012-02 in accordance with CWC section 13301. The CDO also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3. The Discharger began construction of major Facility upgrades in September 2009. The new Facility will use UV disinfection of the effluent which replaces the use of chlorine for disinfection. The Central Valley Water Board concludes that compliance with the effluent limit will be feasible as soon as the new Facility is operational.

viii. Total Trihalomethanes (THM)

- (a) **WQO.** DPH has adopted a primary MCL for total THM of 80 µg/L, which is protective of the Basin Plan's chemical constituent objective. Total Trihalomethanes is a primary MCL and a sum of four CTR constituents: bromoform, chloroform, dibromochloromethane, and dichlorobromomethane.
- (b) **RPA Results.** The Discharger did not sample for total THM, however, monitoring results of the four CTR constituents that typically comprise total THMs are shown in Table F-9. Chloroform concentration is often used as an indication of total THM concentration. The MEC for chloroform was

150 µg/L. Additionally, three of the four CTR constituents (chloroform, dibromochloromethane, and dichlorobromomethane) had MECs greater than the individual criterion, and the MEC sum of the four CTR constituents was 182.4 µg/L, which is greater than the primary MCL for total THMs of 80 µg/L. Therefore, total THM in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the primary MCL.

Table F-10. Total THMs

Parameter	Units	Criterion Basis	Criterion Standard	MEC
Bromoform	µg/L	CTR	4.3	<0.5
Chloroform	µg/L	CTR	--	150
Dibromochloromethane	µg/L	CTR	0.41	4.2
Dichlorobromomethane	µg/L	CTR	0.56	28.2
Total THMs ¹	µg/L	Primary MCL	80	182.4 ¹

¹ Total THMs is the additive total of bromoform, chloroform, dibromochloromethane, and dichlorobromomethane.

(c) WQBELS. Title 40 CFR 122.45 (d) requires, in part, average monthly discharge limitations for publicly owned treatment works (POTWs) unless impracticable. Total THMs is a primary MCL and is a sum of four CTR constituents. The SIP governs establishment of effluent limitations for CTR priority pollutants, but Total THMs is not a CTR priority pollutant. However, for protection of human health, priority pollutants are regulated as a monthly average, and therefore, the Central Valley Water Board has determined that a similar averaging period is appropriate. Thus, this Order contains new WQBELS for total THMs as a monthly average effluent limitation of 80 µg/L.

(d) Plant Performance and Attainability. Summation of the four constituents equals a combined MEC of 182.4 µg/L for total THMs, which is greater than the applicable WQBELS. Therefore, the Discharger appears to be in immediate non-compliance with the total THMs final effluent limitation. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Therefore, a time schedule for compliance with the effluent limit is established in this Order. This Order also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3. The Discharger began construction of major Facility upgrades in September 2009. The new Facility will use UV disinfection of the effluent which replaces the use of chlorine for disinfection. The Central Valley Water Board concludes that compliance with the effluent limit will be feasible as soon as the new Facility is operational.

ix. Copper

- (a) **WQO.** The CTR contains hardness dependent criteria for copper. Section 1.3 of the SIP contains the requirements for conducting the RPA for CTR constituents. Step 1 of the RPA requires that the CTR criteria be adjusted for hardness, as applicable. In this case, the reasonable worst-case downstream hardness (e.g., represented by the minimum observed effluent hardness, see Section IV.C.2.c) was used to adjust the CTR criteria for copper when comparing the MEC to the criteria and the minimum observed upstream receiving water hardness was used when comparing the maximum background receiving water copper concentrations to the criteria as discussed in section IV.C.2., above. The criteria are presented in dissolved concentrations. USEPA recommends using a default translator of 0.96 as a conversion factor to translate dissolved concentrations to total concentrations.
- (b) **RPA Results.** For comparing the maximum ambient background concentration to the criteria, the applicable copper chronic criterion (maximum 4-day average concentration) is 3.3 µg/L and the applicable acute criterion (maximum 1-hour average concentration) is 4.5 µg/L, as total recoverable, based on a hardness of 30 mg/L. For comparing the MEC to the criteria, the applicable copper chronic criterion (maximum 4-day average concentration) is 18 µg/L and the applicable acute criterion (maximum 1-hour average concentration) is 29 µg/L, as total recoverable, based on a hardness of 220 mg/L. The previous Order required the Discharger sample copper monthly according to Order No. R5-2004-0096. Out of the 34 samples obtained from June 2006 through June 2009, the MEC of copper was 11 µg/L, which does not exceed the lowest applicable criterion of 18 µg/L. Due to the lack of recent receiving water samples, data from samples taken in March 2002 and July 2002 were used for the RPA. The receiving water concentration measured in the July 2002 sample was 6.2 µg/L, which is greater than the lowest applicable copper criterion of 3.3 µg/L. Based on this information, the discharge exhibits reasonable potential to cause or contribute to an in-stream excursion of the CTR criteria for copper.
- (c) **WQBELs.** Using the procedures for calculating WQBELs in the Section 1.4 of the SIP, results in final effluent limitations for total recoverable copper of 15 µg/L and 28 µg/L, as the AMEL and MDEL, respectively.
- (d) **Plant Performance and Attainability.** Analysis of 34 effluent samples over three years of monitoring shows an MEC of 11 µg/L with the average effluent concentration of 1.9 µg/L. Therefore, it appears that immediate compliance with the copper final effluent limitations is feasible.

x. Arsenic

- (a) **WQO.** DPH has adopted a primary MCL for arsenic of 10 µg/L, which is protective of the Basin Plan's chemical constituent objective. Arsenic is a CTR constituent.
- (b) **RPA Results.** Effluent CTR monitoring was performed monthly from March through August 2005. All six effluent samples for arsenic exceeded the criterion and the MEC for arsenic was 28.6 µg/L. There are no recent receiving water samples, however, data from receiving water samples taken in March 2002 and July 2002 resulted in arsenic concentrations of 6.9 µg/L and 14 µg/L, respectively, which also exceeds the primary MCL for arsenic. Based on the effluent and the background concentrations being greater than the criteria, arsenic in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for the protection of human health.
- (c) **WQBELs.** Title 40 CFR 122.45 (d) requires, in part, average monthly discharge limitations for publicly owned treatment works (POTWs) unless impracticable. Additionally, the SIP governs establishment of effluent limitations for CTR priority pollutants. Arsenic is a CTR constituent, and therefore, the arsenic effluent limitation was established in accordance with section 1.4 of the SIP, which requires CTR constituent limitations as an average monthly effluent limitation and a maximum daily effluent limitation. This Order contains new WQBELs for arsenic as a monthly average effluent limitation of 10 µg/L and as a maximum daily effluent limitation of 20.1 µg/L.
- (d) **Plant Performance and Attainability.** The effluent data shows that the MEC of 28.6 µg/L for arsenic is greater than the applicable WQBELs. Therefore, the Discharger appears to be in immediate non-compliance with the arsenic final effluent limitation. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Therefore, a time schedule for compliance with the effluent limit is established in this Order. This Order also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3.

xi. Iron

- (a) **WQO.** The secondary MCL established for iron is 300 µg/L, used to implement the Basin Plan's chemical constituent objective for the protection of municipal and domestic supply.
- (b) **RPA Results.** Effluent monitoring was performed monthly from March through August 2005. All six samples for iron exceeded the criterion and the MEC detected for iron was 1210 µg/L, which is greater than the lowest

applicable iron criterion of 300 µg/L. Due to the lack of recent receiving water samples, data from samples taken in March 2002 and July 2002 were used for the RPA. The receiving water iron concentration measured in the July 2002 sample was 2000 µg/L, which is also greater than the lowest applicable iron criterion of 300 µg/L. Based on this information, the discharge has reasonable potential to cause or contribute to in-stream excursion above the secondary MCL.

- (c) **WQBELs.** This Order contains an annual average effluent limitation for iron of 300 µg/L based on the Basin Plan's narrative chemical constituents objective and the secondary MCL. Secondary MCLs are drinking water standards contained in Title 22 of the California Code of Regulations. For secondary MCLs, Title 22 requires compliance with these standards on an annual average basis, when sampling at least quarterly. Since water that meets these requirements on an annual average basis is suitable for drinking, it is impracticable to calculate average weekly and average monthly effluent limitations because such limits would be more stringent than necessary to protect the MUN beneficial use. Central Valley Water Board has determined that an averaging period similar to what is used by the DPH for those parameters regulated by secondary MCLs is appropriate, and that using shorter averaging periods is impracticable because it sets more stringent limits than necessary.
- (d) **Plant Performance and Attainability.** The effluent data shows that the MEC of 1210 µg/L for iron is greater than the applicable WQBELs. Therefore, the Discharger appears to be in immediate non-compliance with the iron final effluent limitation. New or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Therefore, a time schedule for compliance with the effluent limit is established in amended CDO R5-2009-0012-02 in accordance with CWC section 13301. The CDO also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3.

xii. Cadmium

- (a) **WQO.** The CTR includes hardness dependent criteria for the protection of freshwater aquatic life for cadmium. Using the default conversion factors and reasonable worst-case measured hardness, as described in section VI.C.2.c of this Fact Sheet, the applicable acute (1-hour average) criterion is 9.5 µg/L and the applicable chronic (4-day average) criterion is 4.6 µg/L, as total recoverable.
- (b) **RPA Results.** Order No. R5-2004-0096 included effluent limitations and quarterly monitoring requirements for cadmium and 17 samples from March 2005 through June 2009 were used for the RPA. Cadmium was detected in only one sample at a concentration of 0.15 µg/L and the other

16 samples were non-detect. Because cadmium was detected in the effluent, receiving water samples were also used for the RPA. Due to the lack of recent receiving water samples, data from samples taken in March 2002 and July 2002 were used for the RPA. The receiving water cadmium concentration measured in the March 2002 sample was non-detect and the July 2002 sample was 31 µg/L, which is greater than the lowest applicable receiving water cadmium criterion of 1.0 µg/L. Based on this information, the discharge exhibits reasonable potential to cause or contribute to an in-stream excursion of the CTR criteria for cadmium.

(c) **WQBELs.** This Order contains a final average monthly effluent limitation (AMEL) and maximum daily effluent limitation (MDEL) for cadmium of 3.8 µg/L and 7.6 µg/L, respectively, based on the CTR criterion for the protection of freshwater aquatic life.

(d) **Plant Performance and Attainability.** Analysis of 17 effluent samples over four plus years of monitoring shows an MEC of 0.15 µg/L. The Central Valley Water Board concludes, therefore, that immediate compliance with these effluent limitations is feasible.

xiii. Manganese

(a) **WQO.** The secondary MCL established for manganese is 50 µg/L used to implement the Basin Plan's chemical constituent objective for the protection of municipal and domestic supply.

(b) **RPA Results.** The MEC detected for manganese was 43.2 µg/L. Due to the lack of recent receiving water samples, data from samples taken in March 2002 and July 2002 were used for the RPA. The receiving water manganese concentration measured in the July 2002 sample was 270 µg/L, which is greater than the lowest applicable manganese criterion of 50 µg/L. Based on this information, the discharge has reasonable potential to cause or contribute to in-stream excursion above the secondary MCL.

(c) **WQBELs.** This Order contains an annual average effluent limitation for manganese of 50 µg/L based on the Basin Plan's narrative chemical constituents objective and the secondary MCL. Secondary MCLs are drinking water standards contained in Title 22 of the California Code of Regulations. For secondary MCLs, Title 22 requires compliance with these standards on an annual average basis, when sampling at least quarterly. Since water that meets these requirements on an annual average basis is suitable for drinking, it is impracticable to calculate average weekly and average monthly effluent limitations because such limits would be more stringent than necessary to protect the MUN beneficial use. Central Valley Water Board has determined that an averaging period similar to what is used by the DPH for those parameters regulated by secondary MCLs is appropriate, and that using shorter

averaging periods is impracticable because it sets more stringent limits than necessary.

(d) Plant Performance and Attainability. Analysis of the effluent data shows that the MEC of 43.2 µg/L is less than the applicable WQBELs. Although the monitoring data indicates that the Discharger can currently comply with the new effluent limitation, the new Facility was not designed to remove manganese and therefore, the Discharger submitted an Infeasibility Study requesting a compliance schedule to determine if additional upgrades to the Facility will be necessary to meet the limit. Therefore, a time schedule for compliance with the effluent limit is established in amended CDO R5-2009-0012-02 in accordance with CWC section 13301. The CDO also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3.

xiv. Persistent Chlorinated Hydrocarbon Pesticides

(a) WQO. The Basin Plan requires that no individual pesticides shall be present in concentrations that adversely affect beneficial uses; discharges shall not result in pesticide concentrations in bottom sediments or aquatic life that adversely affect beneficial uses; persistent chlorinated hydrocarbon pesticides shall not be present in the water column at detectable concentrations; and pesticide concentrations shall not exceed those allowable by applicable antidegradation policies. Persistent chlorinated hydrocarbon pesticides include aldrin; alpha-BHC; beta-BHC; gamma-BHC; delta-BHC; chlordane; 4,4-DDT; 4,4-DDE; 4,4-DDD; dieldrin; alpha-endosulfan; beta-endosulfan; endosulfan sulfate; endrin; endrin aldehyde; heptachlor; heptachlor epoxide; and toxaphene.

(b) RPA Results. Alpha BHC, 4,4'-DDE, endrin aldehyde, and alpha endosulfan were detected in effluent samples. Alpha BHC was not detected in a 7 April 2005 sample, but was detected above the Reporting Level at 0.022 µg/L in the 4 August 2005 sample. The pesticide 4,4'-DDE was detected below the Reporting Level in the 7 April 2005 sample, but was detected above the Reporting Level at 0.012 µg/L in the 4 August 2005 sample. Endrin aldehyde and alpha endosulfan were not detected in the 7 April 2005 sample, but were detected below the Reporting Level in the 4 August 2005 sample. The detection of alpha BHC, 4,4'-DDE, endrin aldehyde, and alpha endosulfan in the effluent presents a reasonable potential to exceed the Basin Plan objectives for persistent chlorinated hydrocarbon pesticides.

(c) WQBELs. Effluent Limitations for Alpha BHC, 4,4'-DDE, endrin aldehyde, and alpha endosulfan are included in this Order and are based on the Basin Plan objective of no detectable concentrations of chlorinated hydrocarbon pesticides.

(d) Plant Performance and Attainability. Detection of individual pesticides in the effluent is typically at very low levels and close to Minimum Detection Levels. There is no reason to believe pesticides should be in the effluent and the specific constituent detected is not always consistent. However, the Discharger submitted an infeasibility analysis on 19 July 2010 requesting time to complete the new Facility, which will effectively remove any pesticides that have the propensity to adhere to solids. Analysis of the effluent monitoring samples shows detections in the effluent for alpha BHC, 4,4'-DDE, endrin aldehyde, and alpha endosulfan, which is above the criterion of non-detect, therefore, the Discharger appears to be in immediate non-compliance with dichlorobromomethane final effluent limitations. Should the new Facility not be effective, additional new or modified control measures may be necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Therefore, a time schedule for compliance with the effluent limit is established in amended CDO R5-2009-0012-02 in accordance with CWC section 13301. The CDO also requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3. The Discharger began construction of major Facility upgrades in September 2009.

xv. Pathogens

The Central Valley Water Board, when developing NPDES permits, implements recommendations by DPH for the appropriate disinfection requirements for the protection of MUN, REC-1 and AGR. The disinfection requirements in this Order implement the DPH recommendations and are fully protective of the beneficial uses of the receiving water.

(a) WQO. DPH has developed reclamation criteria, CCR, Division 4, Chapter 3 (Title 22), for the reuse of wastewater. Title 22 requires that for spray irrigation of food crops, parks, playgrounds, schoolyards, and other areas of similar public access, wastewater be adequately disinfected, oxidized, coagulated, clarified, and filtered, and that the effluent total coliform levels not exceed 2.2 MPN/100 mL as a 7-day median. As coliform organisms are living and mobile, it is impracticable to quantify an exact number of coliform organisms and to establish weekly average limitations. Instead, coliform organisms are measured as a most probable number and regulated based on a 7-day median limitation. The measure of total coliform organisms is utilized as an indicator of the effectiveness of the entire treatment train and the effectiveness of removing other pathogens

Title 22 also requires that recycled water used as a source of water supply for non-restricted recreational impoundments be disinfected tertiary recycled water that has been subjected to conventional treatment. A non-restricted recreational impoundment is defined as "...an impoundment of recycled water, in which no limitations are imposed on body-contact water

recreational activities." Title 22 is not directly applicable to surface waters; however, the Central Valley Water Board finds that it is appropriate to apply an equivalent level of treatment to that required by the DPH reclamation criteria because the receiving water is used for irrigation of agricultural land and for contact recreation purposes. The stringent disinfection criteria of Title 22 are appropriate since the undiluted effluent may be used for the irrigation of food crops and/or for body-contact water recreation.

- (b) RPA Results.** The beneficial uses of the Reclamation District 777 Lateral Drain No. 1 include municipal and domestic supply, water contact recreation, and agricultural irrigation supply. To protect these beneficial uses, the Central Valley Water Board finds that the wastewater must be disinfected and adequately treated to prevent disease. The method of treatment is not prescribed by this Order; however, wastewater must be treated to a level equivalent to that recommended by DPH.
- (c) WQBELs.** In accordance with the requirements of Title 22, this Order includes effluent limitations for total coliform organisms of 2.2 MPN/100 mL as a 7-day median; 23 MPN/100 mL, not to be exceeded more than once in a 30-day period; and 240 MPN/100 mL as an instantaneous maximum.

In addition to coliform testing, an operational specification for turbidity has been included to monitor the effectiveness of treatment filter performance, and to immediately signal the Discharger to implement operational procedures to correct deficiencies in filter performance. Higher effluent turbidity measurements do not necessarily indicate that the effluent discharge exceeds the water quality criteria/objectives for pathogens (i.e., bacteria, parasites, and viruses), which are the principal infectious agents that may be present in raw sewage. Since turbidity is not a valid indicator parameter for pathogens, the turbidity limitations in Order No. R5-2004-0096 are not imposed to protect the receiving water from excess turbidity. The former turbidity limitations were not technology-based effluent limitations or WQBELs for either pathogens or turbidity. WQBELs are not required because the effluent does not have a reasonable potential to cause or contribute to an exceedance of the applicable water quality objectives for turbidity.

The tertiary treatment process, or equivalent, is capable of reliably treating wastewater to a turbidity level of 2 nephelometric turbidity units (NTU) as a daily average. Failure of the filtration system such that virus removal is impaired would normally result in increased particles in the effluent, which result in higher effluent turbidity. Turbidity has a major advantage for monitoring filter performance. Coliform testing, by comparison, is not conducted continuously and

requires several hours, to days, to identify high coliform concentrations. Therefore, to ensure compliance with the DPH recommended Title 22 disinfection criteria, weekly average specifications are impracticable for turbidity. This Order includes operational specifications for turbidity of 2 NTU as a daily average; 5 NTU, not to be exceeded more than 5 percent of the time within a 24-hour period; and 10 NTU as an instantaneous maximum.

Final WQBELs for BOD₅ and TSS are based on the technical capability of the tertiary process, which is necessary to protect the beneficial uses of the receiving water. BOD₅ is a measure of the amount of oxygen used in the biochemical oxidation of organic matter. The tertiary treatment standards for BOD₅ and TSS are indicators of the effectiveness of the tertiary treatment process. The principal design parameter for wastewater treatment plants is the daily BOD₅ and TSS loading rates and the corresponding removal rate of the system. The application of tertiary treatment processes results in the ability to achieve lower levels for BOD₅ and TSS than the secondary standards currently prescribed. Therefore, this Order requires AWELs and AMELs for BOD₅ and TSS of 15 mg/L and 10 mg/L, respectively, which is technically based on the capability of a tertiary system. In addition to the average weekly and average monthly effluent limitations, a daily maximum effluent limitation for BOD₅ and TSS of 20 mg/L is included in the Order to ensure that the treatment works are not organically overloaded and operate in accordance with design capabilities.

This Order contains effluent limitations for BOD₅, total coliform organisms, and TSS, and requires a tertiary level of treatment, or equivalent, necessary to protect the beneficial uses of the receiving water. The Central Valley Water Board has previously considered the factors in CWC section 13241 in establishing these requirements.

(d) Plant Performance and Attainability. The Facility is not designed to provide full tertiary treatment. The Discharger began construction of major tertiary treatment upgrades to the Facility in September 2009; however, the new tertiary treatment plant has not been completed. Therefore, the Discharger cannot currently comply with the effluent limitations for BOD₅, total coliform organisms, or TSS. The existing CDO No. R5-2009-0012-01 includes a time schedule for the Discharger to meet the effluent limitations for BOD₅, total coliform organisms, or TSS, however, the Discharger submitted information from an independent schedule analyst that determined that construction is behind schedule and that completion of the project on the proposed schedule is doubtful. Therefore, an extended time schedule for compliance with the final effluent limitations for BOD₅, total coliform organisms, and TSS is included in amended CDO R5-2009-0012-02.

xvi. pH

- (a) **WQO.** The Basin Plan includes a water quality objective for surface waters (except for Goose Lake) that the *“The pH shall not be depressed below 6.5 nor raised above 8.5.”* Due to periods of no flow in the receiving water and at a minimum, instantaneous minimum and maximum effluent limits of 6.5 and 8.5, respectively, are necessary to comply with the Basin Plan objectives for pH. The Discharger is upgrading the Facility to tertiary treatment and nitrification, and has requested a more stringent instantaneous maximum pH to allow less stringent ammonia limits, which are based on pH-dependent ammonia criteria.
- (b) **RPA Results.** The Discharger monitored daily pH levels in the effluent. Based on 1162 pH samples taken from October 2006 through December 2009, the pH level exceeded 8.3 only one time and the minimum pH level was 6.7. This complies with the once in three years excursion recommended by USEPA. The 30-day average maximum pH was 8.0. Therefore, it is reasonable to require the more stringent instantaneous maximum effluent pH limit of 8.3 and allow a corresponding less stringent effluent ammonia limit. The discharge has a reasonable potential to cause or contribute to an excursion above the effluent limit for pH.
- (c) **WQBELs.** Effluent limitations for pH of 6.5 as an instantaneous minimum and 8.3 as an instantaneous maximum are included in this Order based on the Basin Plan objectives for pH and Facility performance.
- (d) **Plant Performance and Attainability.** The Facility is capable of meeting the effluent limitations for pH.

xvii. Salinity

- (a) **WQO.** There are no USEPA water quality criteria for the protection of aquatic organisms for electrical conductivity, total dissolved solids, sulfate, and chloride. The Basin Plan contains a chemical constituent objective that incorporates state MCLs, contains a narrative objective, and contains numeric water quality objectives for electrical conductivity, total dissolved solids, sulfate, and chloride.

Table F-11. Salinity Water Quality Criteria/Objectives

Parameter	RPA Screening Levels	Secondary MCL ³	Effluent	
			Average	Maximum
EC (µmhos/cm)	700 ²	900, 1600, 2200	914 ⁴	953 ⁴
TDS (mg/L)	450	500, 1000, 1500	621	680
Sulfate (mg/L)	250	250, 500, 600	78	87.5
Chloride (mg/L)	106	250, 500, 600	75	118

- ¹ Agricultural water quality goals based on *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985)
- ² The EC level in irrigation water that harms crop production depends on the crop type, soil type, irrigation methods, rainfall, and other factors. An EC level of 700 $\mu\text{mhos/cm}$ is generally considered to present no risk of salinity impacts to crops. However, many crops are grown successfully with higher salinities.
- ³ The secondary MCLs are stated as a recommended level, upper level, and a short-term maximum level.
- ⁴ The average and maximum EC values are based on annual averages from July 2005 through June 2008.

- (1) Chloride.** The secondary MCL for chloride is 250 mg/L, as a recommended level, 500 mg/L as an upper level, and 600 mg/L as a short-term maximum. The recommended agricultural water quality goal for chloride, that would apply the narrative chemical constituent objective, is 106 mg/L as a long-term average based on *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). The 106 mg/L water quality goal is intended to protect against adverse effects on sensitive crops when irrigated via sprinklers.
- (2) Electrical Conductivity.** The secondary MCL for EC is 900 $\mu\text{mhos/cm}$ as a recommended level, 1600 $\mu\text{mhos/cm}$ as an upper level, and 2200 $\mu\text{mhos/cm}$ as a short-term maximum. The agricultural water quality goal, that would apply the narrative chemical constituents objective, is 700 $\mu\text{mhos/cm}$ as a long-term average based on *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). The 700 $\mu\text{mhos/cm}$ agricultural water quality goal is intended to prevent reduction in crop yield, i.e. a restriction on use of water, for salt-sensitive crops, such as beans, carrots, turnips, and strawberries. These crops are either currently grown in the area or may be grown in the future. Most other crops can tolerate higher EC concentrations without harm, however, as the salinity of the irrigation water increases, more crops are potentially harmed by the EC, or extra measures must be taken by the farmer to minimize or eliminate any harmful impacts.
- (3) Sulfate.** The secondary MCL for sulfate is 250 mg/L as a recommended level, 500 mg/L as an upper level, and 600 mg/L as a short-term maximum.
- (4) Total Dissolved Solids.** The secondary MCL for TDS is 500 mg/L as a recommended level, 1000 mg/L as an upper level, and 1500 mg/L as a short-term maximum. The recommended agricultural water quality goal for TDS, that would apply the narrative chemical constituent objective, is 450 mg/L as a long-term average based on *Water Quality for Agriculture*, Food and Agriculture Organization of the United

Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). Water Quality for Agriculture evaluates the impacts of salinity levels on crop tolerance and yield reduction, and establishes water quality goals that are protective of the agricultural uses. The 450 mg/L water quality goal is intended to prevent reduction in crop yield, i.e. a restriction on use of water, for salt-sensitive crops. Only the most salt sensitive crops require irrigation water of 450 mg/L or less to prevent loss of yield. Most other crops can tolerate higher TDS concentrations without harm, however, as the salinity of the irrigation water increases, more crops are potentially harmed by the TDS, or extra measures must be taken by the farmer to minimize or eliminate any harmful impacts.

(b) RPA Results.

- (1) Chloride.** Chloride concentrations in the effluent ranged from 44.3 mg/L to 118 mg/L, with an average of 75 mg/L from five monthly samples taken from April 2005 through August 2005. The MEC exceeds the agricultural water quality goal. Due to the lack of recent receiving water samples, data from samples taken in March 2002 and July 2002 were used for the RPA. The measured chloride concentrations for March 2002 and July 2002 were 23 mg/L and 65 mg/L, respectively.
- (2) Electrical Conductivity.** A review of the Discharger's monitoring reports shows an annual average effluent EC of 914 μ mhos/cm, with an annual average range from 850 μ mhos/cm to 953 μ mhos/cm. Effluent EC data is from 1083 samples from July 2005 through June 2008. These levels exceed the agricultural water quality goal. The background receiving water EC averaged 820 μ mhos/cm for 152 samples taken from June 2006 through June 2009. The source water EC averaged 525 μ mhos/cm for 58 samples taken from June 2005 through February 2006.
- (3) Sulfate.** Sulfate concentrations in the effluent ranged from 70.7 mg/L to 87.5 mg/L, with an average of 78 mg/L from five monthly samples taken from April 2005 through August 2005. These levels do not exceed the secondary MCL. Due to the lack of recent receiving water samples, data from samples taken in March 2002 and July 2002 were used for the RPA. The measured receiving water sulfate concentrations for March 2002 and July 2002 were 58 mg/L and 42 mg/L, respectively.
- (4) Total Dissolved Solids.** The average TDS effluent concentration was 621 mg/L with concentrations ranging from 320 mg/L to 680 mg/L. Effluent TDS data is from 64 samples from June 2006 through June 2009. These levels exceed the applicable water quality objectives. Due to the lack of recent receiving water samples, data

from samples taken in March 2002 and July 2002 were used for the RPA. The measured receiving water TDS concentrations for March 2002 and July 2002 were 480 mg/L and 490 mg/L, respectively.

(c) WQBELs.

To protect the receiving water from further salinity degradation, this Order includes a performance-based annual average effluent limitation of 1,100 $\mu\text{mhos/cm}$ for EC. This interim performance-based effluent limitation is derived using the 99.9 percentile of the rolling 12-month average effluent concentration from July 2005 through June 2008.

The Antidegradation Policy (Resolution No. 68-16) requires that the Discharger implement best practicable treatment or control (BPTC) of its discharge. For salinity, the Central Valley Water Board is considering limiting effluent salinity of municipal wastewater treatment plants to an increment of 500 $\mu\text{mhos/cm}$ over the salinity of the municipal water supply as representing BPTC. This Order includes a performance-based effluent limitation for EC because sufficient information does not exist for the water supply for the Discharger. The final effluent limitations for salinity based on BPTC may be modified subsequent to the collection and analysis by the Discharger of EC in the Discharger's water supply. Therefore, this Order requires quarterly monitoring of EC and TDS of the Discharger's influent and water supply (see Attachment E sections III.A. and IX.E.).

This Order also requires the Discharger to implement pollution prevention measures to reduce the salinity in its discharge to the receiving water. Specifically, the Special Provision contained in VI.C.3.a. of this Order requires the Discharger to prepare and implement a salinity evaluation and minimization plan in accordance with CWC section 13263.3(d)(3), and the Special Provision contained in VI.C.3.a. requires the Discharger to report on progress in reducing salinity discharges to the receiving water. Implementation measures to reduce salt loading may include source control, mineralization reduction, chemical addition reductions, changing to water supplies with lower salinity, and limiting the salt load from domestic and industrial dischargers. The Discharger has instituted complete potable water metering of their system resulting in significant reduction in water usage. At this time, it is not known how this will affect EC levels. After one year following completion of the Facility upgrades, should EC levels in the effluent discharge not attain compliance with the agricultural water quality goal of 700 $\mu\text{mhos/cm}$, which applies the Basin Plan's narrative chemical constituents objective, this Order requires the Discharger to conduct site specific studies to determine the appropriate EC level to protect beneficial uses. It is the intent of the Central Valley Water Board to include a final EC effluent limitation in a subsequent permit

renewal or amendment, based on the results of approved site-specific studies.

4. WQBEL Calculations

- a. This Order includes WQBELs for aluminum, ammonia, arsenic, EC, cadmium, copper, dibromochloromethane, dichlorobromomethane, iron, manganese, nitrate, alpha BHC, 4,4'-DDE, alpha endosulfan, endrin aldehyde, pH, total coliform, and total THM. The general methodology for calculating WQBELs based on the different criteria/objectives is described in subsections IV.C.4.b through e, below. See Attachment H for the WQBEL calculations.
- b. **Effluent Concentration Allowance.** For each water quality criterion/objective, the ECA is calculated using the following steady-state mass balance equation from Section 1.4 of the SIP:

$$\begin{aligned} ECA &= C + D(C - B) && \text{where } C > B, \text{ and} \\ ECA &= C && \text{where } C \leq B \end{aligned}$$

where:

- ECA = effluent concentration allowance
D = dilution credit
C = the priority pollutant criterion/objective
B = the ambient background concentration.

According to the SIP, the ambient background concentration (B) in the equation above shall be the observed maximum with the exception that an ECA calculated from a priority pollutant criterion/objective that is intended to protect human health from carcinogenic effects shall use the arithmetic mean concentration of the ambient background samples. For ECAs based on MCLs, which implement the Basin Plan's chemical constituents objective and are applied as annual averages, an arithmetic mean is also used for B due to the long-term basis of the criteria.

- c. **Basin Plan Objectives and MCLs.** For WQBELs based on site-specific numeric Basin Plan objectives or MCLs, the effluent limitations are applied directly as the ECA as either an MDEL, AMEL, or average annual effluent limitations, depending on the averaging period of the objective.
- d. **Aquatic Toxicity Criteria.** WQBELs based on acute and chronic aquatic toxicity criteria are calculated in accordance with Section 1.4 of the SIP. The ECAs are converted to equivalent long-term averages (i.e. LTAacute and LTAchronic) using statistical multipliers and the lowest LTA is used to calculate the AMEL and MDEL using additional statistical multipliers.

- e. **Human Health Criteria.** WQBELs based on human health criteria, are also calculated in accordance with Section 1.4 of the SIP. The ECAs are set equal to the AMEL and a statistical multiplier was used to calculate the MDEL.

$$AMEL = mult_{AMEL} \left[\min \left(M_A ECA_{acute}, M_C ECA_{chronic} \right) \right] LTA_{acute}$$

$$MDEL = mult_{MDEL} \left[\min \left(M_A ECA_{acute}, M_C ECA_{chronic} \right) \right] LTA_{chronic}$$

$$MDEL_{HH} = \left(\frac{mult_{MDEL}}{mult_{AMEL}} \right) AMEL_{HH}$$

where:

$mult_{AMEL}$ = statistical multiplier converting minimum LTA to AMEL

$mult_{MDEL}$ = statistical multiplier converting minimum LTA to MDEL

M_A = statistical multiplier converting acute ECA to LTA_{acute}

M_C = statistical multiplier converting chronic ECA to $LTA_{chronic}$

Table F-12. WQBEL Calculations For Aluminum

	Acute	Chronic
Criteria (µg/L) ¹	750	750
Dilution Credit	No Dilution	No Dilution
ECA	750	750
ECA Multiplier	0.144	0.264
LTA	108.219	198.212
AMEL Multiplier (95 th %)	2.40	²
AMEL (µg/L)	260	²
MDEL Multiplier (99 th %)	6.93	²
MDEL (µg/L)	750	²

¹ USEPA Ambient Water Quality Criteria

² Limitations based on acute LTA (Acute LTA < Chronic LTA)

Table F-13. WQBEL Calculations For Ammonia

	Acute	Chronic 30-day	Chronic 4-day
Criteria (µg/L) ¹	3.2	1.2	2.9
Dilution Credit	No Dilution	No Dilution	No Dilution
ECA	3.2	1.2	2.9
ECA Multiplier	0.321	0.780	0.527
LTA	1.011	0.906	1.531
AMEL Multiplier (95 th %)	²	1.55	²
AMEL (µg/L)	²	1.4	²
MDEL Multiplier (99 th %)	²	3.11	²
MDEL (µg/L)	²	2.8	²

¹ USEPA Ambient Water Quality Criteria

² Limitations based on chronic LTA (Chronic LTA < Acute LTA)

Table F-14. WQBEL Calculations For Copper

	Acute	Chronic
Criteria (µg/L) ¹	29	18
Dilution Credit	No Dilution	No Dilution
ECA	29	18
ECA Multiplier	0.367	0.576
LTA	10.65	10.37
AMEL Multiplier (95 th %)	²	1.46
AMEL (µg/L)	²	15
MDEL Multiplier (99 th %)	²	2.72
MDEL (µg/L)	²	28

¹ CTR Criteria (Total)

² Limitations based on chronic LTA (Chronic LTA < Acute LTA)

Table F-15. WQBEL Calculations For Cadmium

	Acute	Chronic
Criteria (µg/L) ¹	9.5	4.6
Dilution Credit	No Dilution	No Dilution
ECA	9.5	4.6
ECA Multiplier	0.321	0.527
LTA	3.050	2.426
AMEL Multiplier (95 th %)	²	1.55
AMEL (µg/L)	²	3.8
MDEL Multiplier (99 th %)	²	3.11
MDEL (µg/L)	²	7.6

¹ CTR Criteria (Total)

² Limitations based on chronic LTA (Chronic LTA < Acute LTA)

Table F-16. WQBEL Calculations For Arsenic

	Human Health
Criteria (µg/L)	10
Dilution Credit	No Dilution
ECA	10
AMEL (µg/L) ⁽¹⁾	10
MDEL/AMEL Multiplier ⁽²⁾	2.01
MDEL (µg/L)	20.1

¹ AMEL = ECA per section 1.4.B, Step 6 of SIP

² Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-17. WQBEL Calculations For Dibromochloromethane

	Human Health
Criteria (mg/L)	0.41
Dilution Credit	No Dilution
ECA	0.41
AMEL (mg/L)⁽¹⁾	0.41
MDEL/AMEL Multiplier ⁽²⁾	2.03
MDEL (mg/L)	0.82

¹ AMEL = ECA per section 1.4.B, Step 6 of SIP

² Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-18. WQBEL Calculations For Dichlorobromomethane

	Human Health
Criteria (mg/L)	0.56
Dilution Credit	No Dilution
ECA	0.56
AMEL (mg/L)⁽¹⁾	0.56
MDEL/AMEL Multiplier ⁽²⁾	2.38
MDEL (mg/L)	1.2

¹ AMEL = ECA per section 1.4.B, Step 6 of SIP

² Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

**Summary of Water Quality-Based Effluent Limitations
Discharge Point No. 001**

Table F-19. Summary of Water Quality-Based Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	10	15	20	--	--
Total Suspended Solids	mg/L	10	15	20	--	--
pH	standard units	--	--	--	6.5	8.3
Ammonia, Total (as N)	mg/L	1.4	--	2.8	--	--
Aluminum, Total Recoverable	µg/L	260	--	750	--	--
Copper, Total Recoverable	µg/L	15	--	28	--	--
Cadmium, Total Recoverable	µg/L	3.8	--	7.6	--	--
Dibromochloromethane	µg/L	0.41	--	0.82	--	--
Dichlorobromomethane	µg/L	0.56	--	1.2	--	--
alpha BHC	µg/L	--	--	--	--	ND
4,4'-DDE	µg/L	--	--	--	--	ND
Alpha Endosulfan	µg/L	--	--	--	--	ND
Endrin Aldehyde	µg/L	--	--	--	--	ND
Nitrate (as N)	mg/L	10	--	--	--	--
Total Residual Chlorine	mg/L	--	0.011 ¹	0.019 ²	--	--
Total Coliform Organisms	MPN	--	2.2 ³	23 ⁴	--	240 ⁵
Total THM	µg/L	80	--	--	--	--
Arsenic	µg/L	10	--	20.1	--	--
Iron	µg/L	300 ⁶	--	--	--	--
Manganese	µg/L	50 ⁶	--	--	--	--
Acute Toxicity ⁷	--	--	--	--	--	--
Chronic Toxicity ⁸	--	--	--	--	--	--

¹ 4-day average.

² 1-hour average.

³ 7-day median.

⁴ Not to be exceeded more than once in any 30-day period.

⁵ Instantaneous maximum.

⁶ Annual average.

⁷ Survival of aquatic organisms is 96-hour bioassays of undiluted waste shall be no less than:

Minimum for any one bioassay----- 70%

Median for any three consecutive bioassays----- 90%

⁸ There shall be no chronic toxicity in the effluent discharge.

5. Whole Effluent Toxicity (WET)

For compliance with the Basin Plan's narrative toxicity objective, this Order requires the Discharger to conduct whole effluent toxicity testing for acute and chronic toxicity, as specified in the Monitoring and Reporting Program (Attachment E section V.). This Order also contains effluent limitations for acute toxicity and a new narrative effluent limitation for chronic toxicity, and requires the Discharger to implement best management practices to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity.

a. Acute Aquatic Toxicity. The Basin Plan contains a narrative toxicity objective that states, "All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life." (Basin Plan at page III-8.00) The Basin Plan also states that, "...effluent limits based upon acute biotoxicity tests of effluents will be prescribed where appropriate...". USEPA Region 9 provided guidance for the development of acute toxicity effluent limitations in the absence of numeric water quality objectives for toxicity in its document titled "Guidance for NPDES Permit Issuance", dated February 1994. In section B.2. "Toxicity Requirements" (pgs. 14-15) it states that, "In the absence of specific numeric water quality objectives for acute and chronic toxicity, the narrative criterion 'no toxics in toxic amounts' applies. Achievement of the narrative criterion, as applied herein, means that ambient waters shall not demonstrate for acute toxicity: 1) less than 90% survival, 50% of the time, based on the monthly median, or 2) less than 70% survival, 10% of the time, based on any monthly median. For chronic toxicity, ambient waters shall not demonstrate a test result of greater than 1 TUc." Accordingly, effluent limitations for acute toxicity have been included in this Order as follows:

Acute Toxicity. Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:

Minimum for any one bioassay-- -----	70%
Median for any three or more consecutive bioassays -----	90%

b. Chronic Aquatic Toxicity. The Basin Plan contains a narrative toxicity objective that states, "All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life." (Basin Plan at page III-8.00) Based on chronic WET testing performed by the Discharger from March 2005 through December 2008, the discharge has reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's narrative toxicity objective.

No dilution has been granted for the chronic condition. Therefore, chronic toxicity testing results exceeding one chronic toxicity unit (TUc) demonstrates the discharge has a reasonable potential to cause or contribute to an exceedance of the Basin Plan's narrative toxicity objective. This Order contains a new narrative

chronic toxicity limitation effective 30 September 2012, the projected completion date of the new tertiary treatment plant.

To ensure compliance with the Basin Plan's narrative toxicity objective, the Discharger is required to conduct chronic WET testing, as specified in the Monitoring and Reporting Program (Attachment E section V.). Furthermore, the Special Provision contained at VI.C.2.a. of this Order requires the Discharger to investigate the causes of, and identify and implement corrective actions to reduce or eliminate effluent toxicity. If the discharge demonstrates toxicity exceeding the numeric toxicity monitoring trigger, the Discharger is required to initiate a Toxicity Reduction Evaluation (TRE) in accordance with an approved TRE workplan. The numeric toxicity monitoring trigger is not an effluent limitation; it is the toxicity threshold at which the Discharger is required to perform accelerated chronic toxicity monitoring, as well as, the threshold to initiate a TRE if effluent toxicity has been demonstrated.

D. Final Effluent Limitations

1. Mass-based Effluent Limitations

40 CFR 122.45(f)(1) requires effluent limitations be expressed in terms of mass, with some exceptions, and 40 CFR 122.45(f)(2) allows pollutants that are limited in terms of mass to additionally be limited in terms of other units of measurement. This Order includes effluent limitations expressed in terms of mass and concentration. In addition, pursuant to the exceptions to mass limitations provided in 40 CFR 122.45(f)(1), some effluent limitations are not expressed in terms of mass, such as pH, and when the applicable standards are expressed in terms of concentration (e.g., CTR criteria and MCLs) and mass limitations are not necessary to protect the beneficial uses of the receiving water.

Mass-based effluent limitations were calculated based upon the design flow (Average Dry Weather Flow) permitted in section IV.A.1.g. of this Order.

2. Averaging Periods for Effluent Limitations

40 CFR 122.45 (d) requires average weekly and average monthly discharge limitations for publicly owned treatment works (POTWs) unless impracticable. However, for toxic pollutants and pollutant parameters in water quality permitting, USEPA recommends the use of a maximum daily effluent limitation in lieu of average weekly effluent limitations for two reasons. *"First, the basis for the 7-day average for POTWs derives from the secondary treatment requirements. This basis is not related to the need for assuring achievement of water quality standards. Second, a 7-day average, which could comprise up to seven or more daily samples, could average out peak toxic concentrations and therefore the discharge's potential for causing acute toxic effects would be missed."* (TSD, pg. 96) This Order utilizes maximum daily effluent limitations in lieu of average weekly effluent limitations for aluminum, ammonia, copper, cadmium, dibromochloromethane, and dichlorobromomethane as recommended by the TSD for the achievement of water

quality standards and for the protection of the beneficial uses of the receiving stream. Furthermore, for BOD, TSS, pH, coliform, total residual chlorine, endrin aldehyde, alpha endosulfan, alpha BHC, and 4,4'-DDE, weekly average effluent limitations have been replaced or supplemented with effluent limitations utilizing shorter averaging periods. The rationale for using shorter averaging periods for these constituents is discussed in section IV.C.3. of this Fact Sheet.

For effluent limitations based on Primary and Secondary MCLs, except nitrate, arsenic, and total THMs, this Order includes annual average effluent limitations. The Primary and Secondary MCLs are drinking water standards contained in Title 22 of the California Code of Regulations. Title 22 requires compliance with these standards on an annual average basis when sampling at least quarterly. Since water that meets these requirements on an annual average basis is suitable for drinking,, it is impracticable to calculate average weekly and average monthly effluent limitations because such limits would be more stringent than necessary to protect the MUN beneficial use.

3. Satisfaction of Anti-Backsliding Requirements

The effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order No. R5-2004-0096, with the exception of effluent limitations for diazinon, cyanide, and settleable solids. The effluent limitations for these pollutants were not carried forward from Order No. R5-2004-0096. As discussed in section IV.C.3.c. above, data collected during the term of Order No. R5-2004-0096 demonstrate there is no longer reasonable potential for the discharge to cause, have potential to cause, or contribute to an exceedance of the applicable water quality objectives for these constituents. This relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations, and the antidegradation provisions of 40 CFR 131.12 and State Water Resources Control Board Resolution 68-16. Any impact on existing water quality will be insignificant.

The Clean Water Act specifies that a revised permit may not include effluent limitations that are less stringent than the previous permit unless a less stringent limitation is justified based on exceptions to the anti-backsliding provisions contained in Clean Water Act sections 402(o) or 303(d)(4), or, where applicable, 40 CFR 122.44(l). This Order contains less stringent effluent limitations for aluminum and changes the effluent limitations for turbidity, to operational specifications. This relaxation of effluent limitations is consistent with the anti-backsliding provisions, and the antidegradation provisions of 40 CFR 131.12 and State Water Resources Control Board Resolution 68-16. Any impact on existing water quality will be insignificant.

- a. **Aluminum.** Order No. R5-2004-0096 contained effluent limitations for aluminum that were based upon the chronic criterion of 87 µg/L. However, as discussed in section IV.C.3.d.i, since that time we have learned more about the toxicity of the receiving water. Site-specific monitoring data indicated that the chronic criterion is likely overly stringent, and that the acute criterion applied to the discharge is

protective of the beneficial uses. Therefore, the relaxation of the aluminum effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations. Still, as discussed in the following section of this Fact Sheet, Central Valley Water Board conducted an antidegradation analysis that determine that the relaxation of the aluminum effluent limitation is consistent with antidegradation provisions of 40 CFR 131.12 and State Water Resources Control Board Resolution 68-16.

- b. Turbidity.** Order No. R5-2004-0096 contained effluent limitations for turbidity. The prior limitations were solely an operational check to ensure the treatment system was functioning properly and could meet the limits for solids and coliform. The prior effluent limitations were not intended to regulate turbidity in the receiving water. Rather, turbidity is an operational parameter to determine proper system functioning and not a WQBEL. Therefore, to ensure compliance with the DPH recommended Title 22 disinfection criteria, this Order contains performance-based operational turbidity specifications (See Special Provisions VI.C.4.a in the Limitations and Discharge Requirements section of this Order) to be met prior to disinfection in lieu of effluent limitations. This Order does not include effluent limitations for turbidity. However, the revised operational specifications for turbidity are the same as the effluent limitations in Order No. R5-2004-0096, with the inclusion of a more stringent requirement for an instantaneous maximum limitation at any time. (See Special Provisions VI.C.4.a. and c., Turbidity and Ultraviolet Disinfection (UV) System Operating Specifications for turbidity specifications, respectively.) This Order moves the point of compliance from the final effluent after disinfection to an internal compliance point prior to disinfection. These revisions are consistent with state regulations implementing recycled water requirements.

The revision in the turbidity limitation is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution 68-16 because this Order imposes equivalent or more stringent requirements than Order No. R5-2004-0096 and therefore does not allow degradation.

- c. Copper.** Order R5-2004-0096 contained floating effluent limitations for copper that were calculated based on measured hardness of the receiving water downstream of the discharge at monitoring location RSW-002 (R-2 in the previous Order). Since adoption of Order R5-2004-0096, the average hardness of RSW-002 was 279 mg/L (as CaCO₃). Based on Attachment F of Order R5-2004-0096, this corresponds to copper effluent limits of 18 µg/L and 36 µg/L, as an average monthly and maximum daily, respectively. The new effluent limits for copper in this Order are 15 µg/L and 28 µg/L, as an average monthly and maximum daily, respectively. Therefore, the new limits are on average more stringent than the previous Order and are consistent with the anti-backsliding requirements of the CWA and federal regulations.

The revision in the copper effluent limitations is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution

68-16 because this Order imposes on average more stringent requirements than Order No. R5-2004-0096 and therefore does not allow degradation.

- d. **Cadmium.** Order R5-2004-0096 contained floating effluent limitations for cadmium that were calculated based on measured hardness of the receiving water downstream of the discharge at monitoring location RSW-002 (R-2 in the previous Order). Since adoption of Order R5-2004-0096, the average hardness of RSW-002 was 279 mg/L (as CaCO₃). Based on Attachment E of Order R5-2004-0096, this corresponds to cadmium effluent limits of 4.5 µg/L and 9.1 µg/L, as an average monthly and maximum daily, respectively. The new effluent limits for cadmium in this Order are 3.8 µg/L and 7.6 µg/L, as an average monthly and maximum daily, respectively. Therefore, the new limits are on average more stringent than the previous Order and are consistent with the anti-backsliding requirements of the CWA and federal regulations.

The revision in the cadmium effluent limitations is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution 68-16 because this Order imposes on average more stringent requirements than Order No. R5-2004-0096 and therefore does not allow degradation.

4. Satisfaction of Antidegradation Policy

This Order does not allow for an increase in flow or mass of pollutants to the receiving water with the exception of relaxed effluent limitations for aluminum. Therefore, a complete antidegradation analysis is not necessary. The Order requires compliance with applicable federal technology-based standards and with WQBELs where the discharge could have the reasonable potential to cause or contribute to an exceedance of water quality standards. The permitted discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution No. 68-16. Compliance with these requirements will result in the use of best practicable treatment or control of the discharge. The impact on existing water quality will be insignificant.

- a. **Aluminum.** Proposed effluent limitations for aluminum have been relaxed. As previously discussed in section IV.C.3.d.i, Central Valley Water Board has determined that USEPA National Ambient Water Quality Criteria chronic criterion of 87 µg/L is not applicable to this discharge based upon the site-specific findings of the receiving water. Therefore, the new limits are based on the National Ambient Water Quality Criteria acute criterion of 750 µg/L. This Order contains a final average monthly effluent limitation (AMEL) and maximum daily effluent limitation (MDEL) for aluminum of 260 µg/L and 750 µg/L, respectively. This Order also includes an annual average effluent limitation for aluminum of 200 µg/L. The previous permit contained aluminum average monthly and maximum daily effluent limitations of 71 mg/L and 140 mg/L, respectively. The previous permit also required monthly monitoring of aluminum in the effluent discharge.

During the period from August 2005 through June 2007, monthly monitoring analytical results indicated aluminum concentrations in the effluent ranged from

77 µg/L to 3700 µg/L, with median of 228 µg/L. The Facility does not use any aluminum products within the treatment train, and there are no known industrial facilities, or other sources, that would discharge aluminum into the City's collection system. Thus the City suspected that the source of aluminum was from an illicit discharger (e.g. illegal drug lab). Therefore, the Discharger improved treatment to reduce the levels of aluminum in the effluent discharge.

Receiving water analytical monitoring results (2 sampling events in March and July of 2002) show that upstream aluminum concentrations (average of 692 µg/L) are greater than downstream concentrations (average of 265 µg/L), indicating that the effluent discharge improves the receiving water quality through dilution. Analytical results of 31 effluent monitoring samples obtained during the past three years showed aluminum concentrations in the effluent ranged from <10 µg/L to 200 µg/L, with a median at 23 µg/L. The Central Valley Water Board concludes that the proposed relaxation of the aluminum effluent limitations will not result in a reduction of water quality, since the treatment system is already in place, the Discharger employs BPTC for aluminum (e.g. aluminum is not used within the treatment system), there are no known sources of aluminum within the collection system, effluent concentrations in the discharge are consistent, and the effluent discharge will likely improve the water quality of the receiving water. Based upon the findings of the simple analysis, a complete antidegradation analysis is not necessary.

5. Stringency of Requirements for Individual Pollutants

This Order contains both technology-based effluent limitations and WQBELs for individual pollutants. The technology-based effluent limitations consist of restrictions on flow and percent removal requirements for BOD and TSS. The WQBELs consist of restrictions on aluminum, ammonia, arsenic, cadmium, copper, dibromochloromethane, dichlorobromomethane, iron, manganese, nitrate, endrin aldehyde, alpha endosulfan, alpha BHC, and 4,4'-DDE, pH, total coliform, and total THM. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order includes new effluent limitations for BOD, dibromochloromethane, dichlorobromomethane, total coliform organisms, TSS, total THMs, alpha BHC, 4,4'-DDE, alpha endosulfan, endrin aldehyde, arsenic, iron, manganese, and electrical conductivity to meet numeric objectives or protect beneficial uses.

WQBELs have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR 131.38. The scientific procedures for calculating the individual WQBELs for priority pollutants are based on the CTR-SIP, which was approved by USEPA on 18 May 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to 30 May 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to 30 May 2000, but

not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 CFR 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

This Order contains pollutant restrictions that are more stringent than applicable federal requirements and standards. Specifically, this Order includes effluent limitations for 4,4'-DDE, alpha BHC, alpha endosulfan, and endrin aldehyde that are more stringent than applicable federal standards, but that are nonetheless necessary to meet numeric objectives or protect beneficial uses. The rationale for including these limitations is explained in Section IV.D.5. of this Fact Sheet. In addition, the Central Valley Water Board has considered the factors in CWC Section 13241.

**Summary of Final Effluent Limitations
Discharge Point No. 001**

Table F-20. Summary of Final Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	10	15	20	--	--
	lbs/day ⁹	120	180	230	--	--
Total Suspended Solids	mg/L	10	15	20	--	--
	lbs/day ⁹	120	180	230	--	--
pH	standard units	--	--	--	6.5	8.3
Ammonia, Total (as N)	mg/L	1.4	--	2.8	--	--
	lbs/day ⁹	16	--	33	--	--
Aluminum, Total Recoverable ¹⁰	µg/L	260	--	750	--	--
Copper, Total Recoverable	µg/L	15	--	28	--	--
Cadmium, Total Recoverable	µg/L	3.8	--	7.6	--	--
Dibromochloromethane	µg/L	0.41	--	0.82	--	--
Dichlorobromomethane	µg/L	0.56	--	1.2	--	--
alpha BHC	µg/L	--	--	--	--	ND
4,4'-DDE	µg/L	--	--	--	--	ND
Alpha Endosulfan	µg/L	--	--	--	--	ND
Endrin Aldelhyde	µg/L	--	--	--	--	ND
Nitrate (as N)	mg/L	10	--	--	--	--
Total Residual Chlorine	mg/L	--	0.011 ¹	0.019 ²	--	--
Total Coliform Organisms	MPN	--	2.2 ³	23 ⁴	--	240 ⁵
Total THM	µg/L	80	--	--	--	--
Arsenic	µg/L	10	--	20.1	--	--
Iron	µg/L	300 ⁶	--	--	--	--
Manganese	µg/L	50 ⁶	--	--	--	--
Electrical Conductivity	µmhos/cm	1100 ⁶	--	--	--	--
Mercury	lbs/year	0.057 ⁶	--	--	--	--
Acute Toxicity ⁷	--	--	--	--	--	--
Chronic Toxicity ⁸	--	--	--	--	--	--

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum

- 1 4-day average.
- 2 1-hour average.
- 3 7-day median.
- 4 Not to be exceeded more than once in any 30-day period.
- 5 Instantaneous maximum.
- 6 Annual average.
- 7 Survival of aquatic organisms is 96-hour bioassays of undiluted waste shall be no less than:
 - Minimum for any one bioassay----- 70%
 - Median for any three consecutive bioassays----- 90%
- 8 There shall be no chronic toxicity in the effluent discharge.
- 9 Based on an average dry weather flow of 1.4 MGD.
- 10 And 200 µg/L as an annual average effluent limitation

E. Interim Effluent Limitation

1. Compliance Schedules for total Trihalomethanes and Arsenic. The permit limitations for total trihalomethanes and arsenic are new limitations that are based on a new interpretation of the narrative chemical constituents objective. To implement the narrative objective, this Order contains effluent limitations for total trihalomethane and arsenic based on the Department of Public Health's Drinking Water Standards that were promulgated after September 1995. The Drinking Water Standards' primary maximum contaminant levels for total trihalomethanes became effective on 17 June 2006 and for arsenic became effective on 28 November 2008.

The Discharger submitted an Infeasibility Analysis on 19 July 2010 (and updated on 26 August 2010) in compliance with paragraph 4 of the State Water Board's Compliance Schedule Policy. The Discharger's analysis demonstrates the need for additional time to implement actions to comply with the new limitations. Therefore, a compliance schedule for compliance with the effluent limitations for total trihalomethanes and arsenic are established in this Order.

2. Interim Effluent Limitation for total Trihalomethanes and Arsenic. The Compliance Schedule Policy requires the Central Valley Water Board to establish interim requirements and dates for their achievement in the NPDES permit. Interim numeric effluent limitations are required for compliance schedules longer than 1 year. Interim effluent limitations must be based on current treatment plant performance or existing permit limitations, whichever is more stringent.

The interim limitations for total trihalomethanes and arsenic in this Order are based on the current treatment plant performance. Therefore, this Order includes an interim average daily effluent limit for total trihalomethanes of 567.3 µg/L and for arsenic of 88.9 µg/L. In developing the interim limitation, where there are 10 sampling data points or more, sampling and laboratory variability is accounted for by establishing interim limits that are based on normally distributed data where 99.9% of the data points will lie within 3.3 standard deviations of the mean (Basic Statistical Methods for Engineers and Scientists, Kennedy and Neville, Harper and Row).

When there are less than 10 sampling data points available, the EPA *Technical Support Document for Water Quality-based Toxics Control* (EPA/505/2-90-001), or TSD, recommends a coefficient of variation of 0.6 be utilized as representative of wastewater effluent sampling. The TSD recognizes that a minimum of 10 data points is necessary to conduct a valid statistical analysis. The multipliers contained in Table 5-2 of the TSD are used to determine a maximum daily limitation based on a long-term average objective. In this case, the long-term average objective is to maintain, at a minimum, the current plant performance level. Therefore, when there are less than 10 sampling points for a constituent, interim limitations are based on 3.11 times the maximum observed effluent concentration to obtain the daily maximum interim limitation (TSD, Table 5 2). Therefore, the interim limitations in this Order are established as 3.11 times the maximum observed effluent concentration of the available data.

The Central Valley Water Board finds that the Discharger can undertake source control and treatment plant measures to maintain compliance with the interim limitations included in this Order. Interim limitations are established when compliance with final effluent limitations cannot be achieved by the existing discharge. Discharge of constituents in concentrations in excess of the final effluent limitations, but in compliance with the interim effluent limitations, can significantly degrade water quality and adversely affect the beneficial uses of the receiving stream on a long-term basis. The interim limitations, however, establish an enforceable ceiling concentration until compliance with the effluent limitation can be achieved. The limited, short-term degradation associated with the compliance schedule is consistent with State and federal policies and is authorized by 40 CFR 122.47 and the Compliance Schedule Policy.

F. Land Discharge Specifications – NOT APPLICABLE

G. Reclamation Specifications – NOT APPLICABLE

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

Basin Plan water quality objectives to protect the beneficial uses of surface water and groundwater include numeric objectives and narrative objectives, including objectives for chemical constituents, toxicity, and tastes and odors. The toxicity objective requires that surface water and groundwater be maintained free of toxic substances in concentrations that produce detrimental physiological responses in humans, plants, animals, or aquatic life. The chemical constituent objective requires that surface water and groundwater shall not contain chemical constituents in concentrations that adversely affect any beneficial use or that exceed the maximum contaminant levels (MCLs) in Title 22, CCR. The tastes and odors objective states that surface water and groundwater shall not contain taste- or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses. The Basin Plan requires the application of the most stringent objective necessary to ensure that surface water and groundwater do not contain chemical constituents, toxic substances, radionuclides, or taste and odor producing substances in concentrations that adversely affect domestic drinking water supply, agricultural supply, or any other beneficial use.

A. Surface Water

1. CWA section 303(a-c), requires states to adopt water quality standards, including criteria where they are necessary to protect beneficial uses. The Central Valley Water Board adopted water quality criteria as water quality objectives in the Basin Plan. The Basin Plan states that “[t]he numerical and narrative water quality objectives define the least stringent standards that the Regional Water Board will apply to regional waters in order to protect the beneficial uses.” The Basin Plan includes numeric and narrative water quality objectives for various beneficial uses and water bodies. This Order contains receiving surface water limitations based on the Basin Plan numerical and narrative water quality objectives for bacteria, biostimulatory substances, color, chemical constituents, dissolved oxygen, floating material, oil and grease, pH, pesticides, radioactivity, salinity, suspended sediment, settleable substances, suspended material, tastes and odors, temperature, toxicity, and turbidity.

This Order includes a narrative receiving water limitation based on the Basin Plan objectives that the discharge shall not cause the instantaneous natural temperature to be increased by more than 5°F. Compliance is to be determined based on the difference in temperature at RSW-001 and RSW-002. However, the receiving water at RSW-001 is often dry or without a measurable flow, and thus, representative sampling data is limited. As such, the Discharger may perform a temperature study to determine an accurate upstream temperature in order to determine compliance with the Basin Plan temperature objective.

B. Groundwater

1. **Beneficial Uses, Basin Plan, and Regulatory Conditions.** The beneficial uses of the underlying ground water are municipal and domestic supply, industrial service supply, industrial process supply, and agricultural supply.

Basin Plan water quality objectives include narrative objectives for chemical constituents, tastes and odors, and toxicity of groundwater. The toxicity objective requires that groundwater be maintained free of toxic substances in concentrations that produce detrimental physiological responses in humans, plants, animals, or aquatic life. The chemical constituent objective states groundwater shall not contain chemical constituents in concentrations that adversely affect any beneficial use. The tastes and odors objective prohibits taste- or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses. The Basin Plan also establishes numerical water quality objectives for chemical constituents and radioactivity in groundwaters designated as municipal supply. These include, at a minimum, compliance with MCLs in Title 22 of the CCR. The bacteria objective prohibits coliform organisms at or above 2.2 MPN/100 mL. The Basin Plan requires the application of the most stringent objective necessary to ensure that waters do not contain chemical constituents, toxic substances, radionuclides, taste- or odor-producing substances, or bacteria in concentrations that adversely affect municipal or domestic supply, agricultural supply, industrial supply or some other beneficial use.

2. Discharge Locations. The current Facility consists of a series of aeration lagoons and oxidation ponds that have potential to impact underlying groundwater quality; However, the Discharger is replacing the existing Facility (completion expected 30 September 2012), The new Facility will include one lined equalization basin, one stormwater detention basin, and one emergency storage basin. The equalization basin, which can store 2.9 million gallons, is designed for shaving peak flows and is located between the headworks and the secondary feed pump station. The stormwater detention basin is designed to collect all onsite runoff during rainfall events. The emergency storage basin can store up to 6.8 million gallons of wastewater and will only be used to capture bypassed flow during an emergency at the plant. Operation of the new Facility's stormwater detention basin and emergency storage basin is not expected to pose a potential threat to groundwater quality.

3. Groundwater Quality. The Facility is located southwest of the City of Live Oak in the northern portion of Sutter County. Land use surrounding the Facility is predominantly agricultural. There are four groundwater monitoring wells around the Facility identified as: MW-1R, MW-2, MW-3, and MW-4. Monitoring well MW-1R is located near the northern boundary of the Facility, MW-2 is located along the east edge of the Facility near the southeastern corner, MW-3 is located near the confluence of Reclamation District 777 Lateral Drain No. 1 and Lateral Drain No. 2 just south of the Facility, and MW-4 is located at about the midpoint along the western boundary of the Facility. The wells were constructed in early 2004.

According to the *City of Live Oak WWTP Hydrogeologic Evaluation* report dated July 2006, by ECO:LOGIC Engineering, the local groundwater flow direction can vary by almost 360 degrees depending on seasonal conditions. The regional groundwater flow direction is generally toward the south. In order to determine background condition of the groundwater, a statistical analysis of the data from the four monitoring wells was performed pursuant to Title 27 Section 20415(e)(10) of the California Code of Regulations. Based on this analysis, MW-1R and MW-3 were determined to be most likely representative of background water quality.

Combining the data from MW-1R and MW-3 and comparing the results to data from MW-2 and MW-4 indicates that the Facility does not appear to be impacting groundwater quality. Tables F-19 and F-20 below summarize the groundwater data from the second quarter of 2005 through the second quarter of 2010 for TDS and nitrate.

Table F-21. Summary of TDS in Groundwater

Parameter	Water Quality Objective	Statistics	Background Wells		MW-2	MW-4
			MW-1R	MW-3		
TDS (mg/L)	450 ¹	No. of Samples	19	21	21	20
		Mean	594	701	557	583
		Standard Deviation	57	76	28	39
		Maximum	700	810	620	660
		95th%	682	810	600	632
		99th%	696	810	616	654

¹ Agricultural water quality goals based on *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). Agricultural water quality goals listed provide no restrictions on crop type or irrigation methods for maximum crop yield. Higher concentrations may require special irrigation methods to maintain crop yields or may restrict types of crops grown.

Table F-22. Summary of Nitrate (as N) in Groundwater

Parameter	Water Quality Objective	Statistics	Background Wells		MW-2	MW-4
			MW-1R	MW-3		
Nitrate (as N) (mg/L)	10 ¹	No. of Samples	19	21	21	20
		Mean	15.0	4.5	2.8	0.4
		Standard Deviation	4.8	4.5	6.2	1.8
		Maximum	22.8	20.3	22.8	8.0
		95th%	22.5	8.5	18.6	0.4
		99th%	22.7	17.9	22.0	6.5

USEPA Drinking Water Standards (Primary Maximum Contaminant Level)

- 4. Groundwater Limits.** This Order includes narrative groundwater limitations in Section V.B. to protect the beneficial uses. However, there is little potential impacts to groundwater from the new facility and therefore, this Order does not retain groundwater monitoring requirements as explained in Section VI.D.2.

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

40 CFR 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorize the Central Valley Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (Attachment E) of this Order establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the Monitoring and Reporting Program for the Facility.

A. Influent Monitoring

1. Influent monitoring is required to collect data on the characteristics of the wastewater and to assess compliance with effluent limitations (e.g., BOD₅ and TSS reduction requirements). The Monitoring and Reporting Requirements (Attachment E) include influent monitoring requirements in Attachment E, section III.

B. Effluent Monitoring

1. Pursuant to the requirements of 40 CFR 122.44(i)(2) effluent monitoring is required for all constituents with effluent limitations. Effluent monitoring is necessary to assess compliance with effluent limitations, assess the effectiveness of the treatment process, and to assess the impacts of the discharge on the receiving stream and groundwater.

2. Effluent monitoring frequencies and sample types for flow, aluminum, cadmium, whole effluent toxicity, total coliform organisms, turbidity, hardness, and total dissolved solids have been retained from Order No. R5-2004-0096 to determine compliance with effluent limitations for these parameters.
3. Monitoring data collected over the existing permit term for cyanide, diazinon and settleable solids did not demonstrate reasonable potential to exceed water quality objectives/criteria. Thus, specific monitoring requirements for these parameters have not been retained from Order No. R5-2004-0096. However, this Order requires quarterly monitoring of cyanide and diazinon with other Priority Pollutants for one year to characterize the effluent and receiving water for the next permit renewal.
4. The SIP states that if "...all reported detection limits of the pollutant in the effluent are greater than or equal to the C [water quality criterion or objective] value, the RWQCB [Regional Water Board] shall establish interim requirements...that require additional monitoring for the pollutant..." All reported detection limits are greater than or equal to corresponding applicable water quality criteria or objectives. Monitoring for these constituents has been included in this Order in accordance with the SIP.
5. While no effluent limitations for hardness, turbidity, dissolved oxygen, temperature, total dissolved solids, or methylmercury are necessary at this time, these constituents are critical in the assessment of the need for, and the development of, effluent limitations. Therefore, this Order requires monitoring of these constituents.
6. Effluent monitoring frequencies and/or sample type have been adjusted from Order No. R5-2004-0096 for pH, BOD, TSS, turbidity, ammonia, copper, pesticides, temperature, electrical conductivity, and mercury (total recoverable) for consistency with other NPDES permits with similar discharges.

C. Whole Effluent Toxicity Testing Requirements

1. **Acute Toxicity.** Quarterly 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity. Acute toxicity testing may be conducted as part of the chronic test provided the testing is in accordance with the Monitoring and Reporting Requirements (Attachment E), Section V.
2. **Chronic Toxicity.** Quarterly chronic whole effluent toxicity testing is required in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.

D. Receiving Water Monitoring

1. Surface Water

- a. Receiving water monitoring is necessary to assess compliance with receiving water limitations and to assess the impacts of the discharge on the receiving stream. Receiving water sampling data was limited and therefore, some samples from 2002 were used in the reasonable potential analysis. This older data may

not be representative of current discharges and new data will be needed when the new tertiary treatment facility is operational. Therefore, the Monitoring and Reporting Requirements (Attachment E) include receiving water monitoring requirements in Attachment E, Section VIII.

2. **Groundwater** The Discharger is nearing completion of a new treatment facility and will no longer be using treatment ponds. The new facility includes wastewater structures that are lined, so there will be no threat to groundwater. The Discharger plans to maintain one pond as an emergency storage basin that has the potential to discharge to groundwater. However, the emergency storage basin will only be used intermittently and wastewater will be drained as soon as possible. Therefore, there is insufficient threat to groundwater to require groundwater monitoring.

E. Other Monitoring Requirements

1. Biosolids Monitoring

Biosolids monitoring is required to ensure compliance with the biosolids disposal requirements contained in the Special Provision contained in section VI.C.5.b-d., of this Order. Biosolids disposal requirements are imposed pursuant to 40 CFR Part 503 to protect public health and prevent groundwater degradation.

2. Water Supply Monitoring

Water supply monitoring is required to evaluate the source of EC, TDS, and standard minerals in the wastewater.

3. Ultraviolet Disinfection System Monitoring

UV System specifications and monitoring and reporting is required to ensure that adequate UV dosage is applied to the wastewater to inactivate pathogens (e.g. viruses) in the wastewater. UV disinfection system monitoring requirements are imposed pursuant to requirements established by the DPH and the National Water Research Institute (NWRI) and American Water Works Association Research Foundation NWRI/AWWARF's *"Ultraviolet Disinfection Guidelines for Drinking Water and Water Reuse"*.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR 122.42.

40 CFR 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either

expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. 40 CFR 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with 40 CFR 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR 122.41(j)(5) and (k)(2) because the enforcement authority under the CWC is more stringent. In lieu of these conditions, this Order incorporates by reference CWC section 13387(e).

B. Special Provisions

1. Reopener Provisions

- a. **Mercury.** This provision allows the Central Valley Water Board to reopen this Order in the event mercury is found to be causing toxicity based on acute or chronic toxicity test results, or if a TMDL program is adopted. In addition, this Order may be reopened if the Central Valley Water Board determines that a mercury offset program is feasible for dischargers subject to NPDES permits.
- b. **Whole Effluent Toxicity.** This Order requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity through a Toxicity Reduction Evaluation (TRE). This Order may be reopened to include a numeric chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if a numeric chronic toxicity water quality objective is adopted by the State Water Board, this Order may be reopened to include a numeric chronic toxicity limitation based on that objective.
- c. **Water Effects Ratio (WER) and Metal Translators.** This provision allows the Central Valley Water Board to reopen the permit to modify applicable inorganic effluent limitations based upon the results of the Discharger's site specific studies.
- d. **Salinity/EC Site-Specific Study.** This Order requires the Discharger to complete and submit a report on the results of salinity/EC site-specific studies to determine appropriate salinity/EC levels necessary to protect downstream beneficial uses. The studies shall be completed and submitted to the Central Valley Water Board as specified in section VI.C.2.b. of this Order. Based on a review of the results of the report on the salinity/EC site-specific studies this Order may be reopened for addition of an effluent limitation and requirements for salinity and/or EC.

2. Special Studies and Additional Monitoring Requirements

- a. **Chronic Whole Effluent Toxicity Requirements.** The Basin Plan contains a narrative toxicity objective that states, "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.*" (Basin Plan at page III-8.00) Based on whole effluent chronic toxicity testing performed by the Discharger from

March 2005 through December 2008, the discharge has reasonable potential to cause or contribute to an in-stream excursion above of the Basin Plan's narrative toxicity objective.

This provision requires the Discharger to develop a TRE Workplan in accordance with USEPA guidance. In addition, the provision provides a numeric toxicity monitoring trigger and requirements for accelerated monitoring, as well as, requirements for TRE initiation if toxicity has been demonstrated.

Monitoring Trigger. A numeric toxicity monitoring trigger of > 1 TUc (where TUc = $100/\text{NOEC}$) is applied in the provision, because this Order does not allow any dilution for the chronic condition. Therefore, a TRE is triggered when the effluent exhibits toxicity at 100% effluent.

Accelerated Monitoring. The provision requires accelerated WET testing when a regular WET test result exceeds the monitoring trigger. The purpose of accelerated monitoring is to determine, in an expedient manner, whether there is of toxicity before requiring the implementation of a TRE. Due to possible seasonality of the toxicity, the accelerated monitoring should be performed in a timely manner, preferably taking no more than 2 to 3 months to complete.

The provision requires accelerated monitoring consisting of four chronic toxicity tests in a six-week period (i.e., one test every two weeks) using the species that exhibited toxicity. Guidance regarding accelerated monitoring and TRE initiation is provided in the *Technical Support Document for Water Quality-based Toxics Control*, EPA/505/2-90-001, March 1991 (TSD). The TSD at page 118 states, "EPA recommends if toxicity is repeatedly or periodically present at levels above effluent limits more than 20 percent of the time, a TRE should be required." Therefore, four accelerated monitoring tests are required in this provision. If no toxicity is demonstrated in the four accelerated tests, then it demonstrates that toxicity is not present at levels above the monitoring trigger more than 20 percent of the time (only 1 of 5 tests are toxic, including the initial test). However, notwithstanding the accelerated monitoring results, if there is adequate evidence of effluent toxicity (i.e. toxicity present exceeding the monitoring trigger more than 20 percent of the time), the Executive Officer may require that the Discharger initiate a TRE.


See the WET Accelerated Monitoring Flow Chart (Figure F-1), below, for further clarification of the accelerated monitoring requirements and for the decision points for determining the need for TRE initiation.

TRE Guidance. The Discharger is required to prepare a TRE Workplan in accordance with USEPA guidance. Numerous guidance documents are available, as identified below:

- Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants, EPA/833-B-99/002, August 1999.

- Generalized Methodology for Conducting Industrial Toxicity Reduction Evaluations (TREs), EPA/600/2-88/070, April 1989.
- Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures, Second Edition, EPA 600/6-91/003, February 1991.
- Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I, EPA/600/6-91/005F, May 1992.
- Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity, Second Edition, EPA/600/R-92/080, September 1993.
- Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity, Second Edition, EPA 600/R-92/081, September 1993.
- Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fifth Edition, EPA-821-R-02-012, October 2002.
- Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA-821-R-02-013, October 2002.
- Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991.

Figure F-1
WET Accelerated Monitoring Flow Chart



- b. Salinity/EC Site-Specific Studies.** This Order requires the Discharger to prepare and submit a report on the results of salinity/EC site-specific studies to determine appropriate salinity/EC levels necessary to protect downstream beneficial uses. The study shall determine local drinking water intakes. Based on these factors, the study shall recommend site-specific numeric values for salinity/EC that fully protect the agricultural irrigation use designation of Reclamation District 777 Lateral Drain No. 1. The Central Valley Water Board will evaluate the recommendations, select appropriate values, reevaluate reasonable potential for salinity/EC, and reopen the permit, as necessary, to include appropriate effluent limitations for these constituents. The study shall be completed and submitted to the Central Valley Water Board within 27 months following approval of the study workplan and time schedule by the Executive Officer.

3. Best Management Practices and Pollution Prevention

- a. Salinity Evaluation and Minimization Plan.** This provision requires the Discharger to prepare and implement a salinity evaluation and minimization plan, and is necessary to address sources of salinity from the Facility to protect the beneficial uses.
- b. Mercury Evaluation and Minimization Plan.** This provision requires the Discharger to prepare and implement a mercury evaluation and minimization plan to address sources of mercury from the Facility, and is necessary to protect the receiving water that is impaired for mercury.

4. Construction, Operation, and Maintenance Specifications

- a. Turbidity.** Turbidity is included as an operational specification as an indicator of the effectiveness of the treatment process and to assure compliance with effluent limitations for total coliform organisms. The tertiary treatment process utilized at this Facility is capable of reliably meeting a turbidity limitation of 2 nephelometric turbidity units (NTU) as a daily average. Failure of the treatment system such that virus removal is impaired would normally result in increased particles in the effluent, which result in higher effluent turbidity and could impact UV dosage.

Turbidity has a major advantage for monitoring filter performance, allowing immediate detection of filter failure and rapid corrective action. The operational specification requires that turbidity prior to disinfection shall not exceed 2 NTU as a daily average; 5 NTU, more than 5 percent of the time within a 24-hour period; and an instantaneous maximum of 10 NTU.

- b. Emergency Pond Operating Requirements.** The operation and maintenance specifications for the emergency pond in this Order are necessary to protect the public and the beneficial uses of the groundwater, and to prevent nuisance conditions.

- c. Ultraviolet Light (UV) Disinfection System Operating Requirements.** UV disinfection system specifications and monitoring and reporting requirements are required to ensure that adequate UV dosage is applied to the wastewater to inactivate pathogens (e.g. viruses) in the wastewater. UV dosage is dependent on several factors such as UV transmittance, UV power setting, wastewater turbidity, and wastewater flow through the UV disinfection system. Monitoring and reporting of these parameters is necessary to determine compliance with minimum dosage requirements established by the DPH and the National Water Research Institute (NWRI) and American Water Works Association Research Foundation NWRI/AWWRF's "*Ultraviolet Disinfection Guidelines for Drinking Water and Water Reuse*" first published in December 2000 revised as a Second Edition dated May 2003. In addition, a Memorandum dated 1 November 2004 issued by DPH to Central Valley Water Board executive offices recommended that provisions be included in permits to water recycling treatment plants employing UV disinfection requiring dischargers to establish fixed cleaning frequency if quartz sleeves as well as include provisions that specify minimum delivered UV dose that must be maintained (as recommended by the NWRI/AWWRF UV Disinfection Guidelines). Minimum UV dosage and operating criteria are necessary to ensure that adequate disinfection of wastewater is achieved to protect beneficial uses. As described in section VII.B.4.a above, turbidity is included as an operational specification as an indicator of the effectiveness of the treatment process and to assure compliance with effluent limitations for total coliform organisms. The operational specification requires that turbidity prior to disinfection shall not exceed 2 NTU as a daily average; 5 NTU, more than 5 percent of the time within a 24-hour period, and an instantaneous maximum of 10 NTU.

Minimum UV dosage and turbidity specifications are included as operating criteria in section VI.C.4.c of this Order and section IX.D of the Monitoring and Reporting Program (Attachment E) to ensure that adequate disinfection of wastewater is achieved.

5. Special Provisions for Municipal Facilities (POTWs Only)

- a. Biosolids.** The sludge/biosolids provisions are required to ensure compliance with State disposal requirements (Title 27, CCR, Division 2, Subdivision 1, section 20005, et seq) and USEPA sludge/biosolids use and disposal requirements at 40 CFR Part 503.
- b. Collection System.** The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order No. 2006-0003-DWQ (General Order) on 2 May 2006. The General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans (SSMPs) and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions.

Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. Inasmuch that the Discharger's collection system is part of the system that is subject to this Order, certain standard provisions are applicable as specified in Provisions, section VI.C.5. For instance, the 24-hour reporting requirements in this Order are not included in the General Order. The Discharger must comply with both the General Order and this Order. The Discharger and public agencies that are discharging wastewater into the facility were required to obtain enrollment for regulation under the General Order by 1 December 2006.

6. Other Special Provisions

- a. **Tertiary Treatment, or equivalent.** To protect public health and safety, the Discharger is to comply with DHS reclamation criteria, CCR Title 22, Division 4, Chapter 3, or equivalent.
- b. **Ownership Change.** To maintain the accountability of the operation of the Facility, the Discharger is required to notify the succeeding owner or operator of the existence of this Order by letter if, and when, there is any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger.

7. Compliance Schedules

- a. The Discharger submitted a request, and justification (dated 19 July 2010, and updated on 26 August 2010) for compliance schedules for arsenic and total trihalomethanes. The compliance schedule justification included all items specified in paragraph 4 of the Compliance Schedule Policy, as discussed in Section IV.E of this Fact Sheet. This Order establishes a compliance schedule that is as short as practicable for the new, final, WQBELs for total trihalomethanes and arsenic.
- b. A pollution prevention plan for arsenic and total trihalomethanes is required in this Order per CWC section 13263.3(d)(1)(C). In accordance with CWC section 13263.3(d)(3), these pollution prevention plans shall, at a minimum, meet the following requirements:
 - i. An estimate of all of the sources of a pollutant contributing, or potentially contributing, to the loadings of a pollutant in the treatment plant influent.
 - ii. An analysis of the methods that could be used to prevent the discharge of the pollutants into the Facility, including application of local limits to industrial or commercial dischargers regarding pollution prevention techniques, public education and outreach, or other innovative and alternative approaches to reduce discharges of the pollutant to the Facility. The analysis also shall identify sources, or potential sources, not within the ability or authority of the Discharger to control, such as pollutants in the

potable water supply, airborne pollutants, pharmaceuticals, or pesticides, and estimate the magnitude of those sources, to the extent feasible.

- iii. An estimate of load reductions that may be attained through the methods identified in subparagraph ii.
- iv. A plan for monitoring the results of the pollution prevention program.
- v. A description of the tasks, cost, and time required to investigate and implement various elements in the pollution prevention plan.
- vi. A statement of the Discharger's pollution prevention goals and strategies, including priorities for short-term and long-term action, and a description of the Discharger's intended pollution prevention activities for the immediate future.
- vii. A description of the Discharger's existing pollution prevention programs.
- viii. An analysis, to the extent feasible, of any adverse environmental impacts, including cross-media impacts or substitute chemicals that may result from the implementation of the pollution prevention program.
- ix. An analysis, to the extent feasible, of the costs and benefits that may be incurred to implement the pollution prevention program.

VIII PUBLIC PARTICIPATION

The Central Valley Water Board is considering the issuance of WDRs that will serve as an NPDES permit for the Facility. As a step in the WDR adoption process, the Central Valley Water Board staff has developed tentative WDRs. The Central Valley Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Central Valley Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through the following: Direct mailing to agencies and known interested parties; Posting of NOPH at the Facility, the Discharger's offices and the local post office; and Publication in the local paper.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Office at the Central Valley Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Central Valley Water Board, written comments must be received at the Central Valley Water Board offices by 5:00 p.m. on **30 August 2010**.

C. Public Hearing

The Central Valley Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: 8/9/10 June 2011
Time: 8:30 a.m.
Location: Regional Water Quality Control Board, Central Valley Region
11020 Sun Center Dr., Suite #200
Rancho Cordova, CA 95670

Interested persons are invited to attend. At the public hearing, the Central Valley Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is www.waterboards.ca.gov/centralvalley, where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Board to review the decision of the Central Valley Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Central Valley Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The Report of Waste Discharge, related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Central Valley Water Board by calling (916) 464-3291.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Central Valley Water Board, reference this Facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to Mr. David Kirn at 916.464.4761 or at dwkirn@waterboards.ca.gov.

ATTACHMENT G – SUMMARY OF REASONABLE POTENTIAL ANALYSIS

Constituent	Units	MEC	B	C	CMC	CCC	Water & Org	Org. Only	Basin Plan	MCL	Reasonable Potential
4,4'-DDE	µg/L	0.012	ND	ND	--	--	--	--	--	--	Yes
Alpha BHC	µg/L	0.022	ND	ND	--	--	--	--	--	--	Yes
Alpha Endosulfan	µg/L	0.0008	ND	ND	--	--	--	--	--	--	Yes
Aluminum	µg/L	530	1300	200	750	87	--	--	--	200	Yes
Ammonia, Total (as N)	mg/L	17.1	3.1	1.17	--	--	--	--	--	50	Yes
Arsenic	µg/L	28.6	22	10	--	--	--	--	--	10	Yes
Bis (2-ethylhexyl) phthalate	µg/L	0.7	ND	1.8	--	--	--	--	--	--	No
Cadmium, Total Recoverable	µg/L	0.15	31	4.6/0.96	9.5/1.2	4.6/0.96	--	--	--	--	Yes
Chlorine, Total Residual	µg/L	NA	--	0.011	--	--	--	--	--	--	Yes
Chloroform	µg/L	150	1.7	80	--	--	--	--	--	--	Yes
Chronic Toxicity	TU	>1.0	--	1.0	--	--	--	--	--	--	Yes
Copper, Total Recoverable	µg/L	11	6.2	18/3.3	29/4.5	18/3.3	--	--	--	--	Yes
Cyanide	µg/L	ND	6.9	5.2	--	--	--	--	--	--	No
Diazinon	µg/L	ND	ND	0.05	--	--	--	--	--	--	No
Dibromochloromethane	µg/L	4.2	ND	0.41	--	--	--	--	--	--	Yes
Dichlorobromomethane	µg/L	28.2	ND	0.56	--	--	--	--	--	--	Yes
EC (Salinity)	µmhos/cm	1188	1079	700	--	--	--	--	--	900	Yes
Endrin Aldehyde	µg/L	0.006	ND	ND	--	--	--	--	--	--	Yes
Iron	µg/L	1210	2000	300	--	--	--	--	--	300	Yes
Manganese	µg/L	43.2	470	50	--	--	--	--	--	50	Yes
Mercury	µg/L	0.0134	0.0115	0.05	--	--	--	--	--	--	Yes
Nitrate (as N)	mg/L	13.8	6.6	10	--	--	--	--	--	10	Yes

CITY OF LIVE OAK
WASTEWATER TREATMENT PLANT

ORDER NO. R5-2011-0034
NPDES NO. CA0079022

Constituent	Units	MEC	B	C	CMC	CCC	Water & Org	Org. Only	Basin Plan	MCL	Reasonable Potential
-------------	-------	-----	---	---	-----	-----	-------------	-----------	------------	-----	----------------------

General Note: All inorganic concentrations are given as a total recoverable.

MEC = Maximum Effluent Concentration

B = Maximum Receiving Water Concentration or lowest detection level, if non-detect

C = Criterion used for Reasonable Potential Analysis

CMC = Criterion Maximum Concentration (CTR or NTR)

CCC = Criterion Continuous Concentration (CTR or NTR)

Water & Org = Human Health Criterion for Consumption of Water & Organisms (CTR or NTR)

Org. Only = Human Health Criterion for Consumption of Organisms Only (CTR or NTR)

Basin Plan = Numeric Site-specific Basin Plan Water Quality Objective

MCL = Drinking Water Standards Maximum Contaminant Level

NA = Not Available

ND = Non-detect

Footnotes:

(1)

(2)

ATTACHMENT H – CONSTITUENTS TO BE MONITORED

- I. Background.** Sections 2.4.1 through 2.4.4 of the SIP provide minimum standards for analyses and reporting. (Copies of the SIP may be obtained from the State Water Resources Control Board, or downloaded from <http://www.waterboards.ca.gov/iswp/index.html>). To implement the SIP, effluent and receiving water data are needed for all priority pollutants. Effluent and receiving water pH and hardness are required to evaluate the toxicity of certain priority pollutants (such as heavy metals) where the toxicity of the constituents varies with pH and/or hardness. Section 3 of the SIP prescribes mandatory monitoring of dioxin congeners. In addition to specific requirements of the SIP, the Central Valley Water Board is requiring the following monitoring:
- A. Drinking water constituents.** Constituents for which drinking water Maximum Contaminant Levels (MCLs) have been prescribed in the California Code of Regulation are included in the *Water Quality Control Plan, Fourth Edition, for the Sacramento and San Joaquin River Basins* (Basin Plan). The Drinking Water Policy implemented through the Basin Plan defines virtually all surface waters within the Central Valley Region as being suitable or potentially suitable for municipal and domestic supply. The Basin Plan further requires that, at a minimum, water designated for use as domestic or municipal supply shall not contain concentrations of chemical constituents in excess of the MCLs contained in the California Code of Regulations.
 - B. Effluent and receiving water temperature.** This is both a concern for application of certain temperature-sensitive constituents, such as fluoride, and for compliance with the Basin Plan's thermal discharge requirements.
 - C. Effluent and receiving water hardness and pH.** These are necessary because several of the CTR constituents are hardness and pH dependent.
 - D. Dioxin and furan sampling.** Section 3 of the SIP has specific requirements for the collection of samples for analysis of dioxin and furan congeners, which are detailed in section III.G., below. Pursuant to Section 13267 of the California Water Code, this Order includes a requirement for the Discharger to submit monitoring data for the effluent and receiving water as described in section III.G., below.
- II. Monitoring Requirements.**
- A. Quarterly Monitoring.** Quarterly priority pollutant samples shall be collected from the effluent and upstream receiving water (EFF-001 and RSW-001) and analyzed for the constituents listed in Table I-1. Quarterly monitoring shall be conducted during the third or fourth year of the permit term for 1 year (4 consecutive samples, evenly distributed throughout the year) and the results of such monitoring be submitted to the Central Valley Water Board. Each individual monitoring event shall provide representative sample results for the effluent and upstream receiving water.

B. Semi-annual Monitoring (dioxins and furans only). Semi-annual monitoring for one year is required for dioxins and furans, as specified in Attachment H. The results of dioxin and furan monitoring shall be submitted to the Central Valley Water Board with the quarterly priority data at the completion of the Effluent and Receiving Water Characterization Study, and during the fourth year of the permit term.

C. Concurrent Sampling. Effluent and receiving water sampling shall be performed at approximately the same time, on the same date.

D. Sample type. All effluent samples shall be taken as 24-hour flow proportioned composite samples unless designated as a grab sample such as dioxins and furans, Bis(2-ethylhexyl) phthalate, and other volatile compounds. All receiving water samples shall be taken as grab samples.

Table I-1. Priority Pollutants

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted ¹		
VOLATILE ORGANICS						
28	1,1-Dichloroethane	75343	Primary MCL	5	0.5	EPA 8260B
30	1,1-Dichloroethene	75354	National Toxics Rule	0.057	0.5	EPA 8260B
41	1,1,1-Trichloroethane	71556	Primary MCL	200	0.5	EPA 8260B
42	1,1,2-Trichloroethane	79005	National Toxics Rule	0.6	0.5	EPA 8260B
37	1,1,2,2-Tetrachloroethane	79345	National Toxics Rule	0.17	0.5	EPA 8260B
75	1,2-Dichlorobenzene	95501	Taste & Odor	10	0.5	EPA 8260B
29	1,2-Dichloroethane	107062	National Toxics Rule	0.38	0.5	EPA 8260B
	cis-1,2-Dichloroethene	156592	Primary MCL	6	0.5	EPA 8260B
31	1,2-Dichloropropane	78875	Calif. Toxics Rule	0.52	0.5	EPA 8260B
101	1,2,4-Trichlorobenzene	120821	Public Health Goal	5	0.5	EPA 8260B
76	1,3-Dichlorobenzene	541731	Taste & Odor	10	0.5	EPA 8260B
32	1,3-Dichloropropene	542756	Primary MCL	0.5	0.5	EPA 8260B
77	1,4-Dichlorobenzene	106467	Primary MCL	5	0.5	EPA 8260B
17	Acrolein	107028	Aquatic Toxicity	21	2	EPA 8260B
18	Acrylonitrile	107131	National Toxics Rule	0.059	2	EPA 8260B
19	Benzene	71432	Primary MCL	1	0.5	EPA 8260B
20	Bromoform	75252	Calif. Toxics Rule	4.3	0.5	EPA 8260B
34	Bromomethane	74839	Calif. Toxics Rule	48	1	EPA 8260B
21	Carbon tetrachloride	56235	National Toxics Rule	0.25	0.5	EPA 8260B
22	Chlorobenzene (mono chlorobenzene)	108907	Taste & Odor	50	0.5	EPA 8260B
24	Chloroethane	75003	Taste & Odor	16	0.5	EPA 8260B
25	2- Chloroethyl vinyl ether	110758	Aquatic Toxicity	122 (3)	1	EPA 8260B

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted ¹		
26	Chloroform	67663	OEHHA Cancer Risk	1.1	0.5	EPA 8260B
35	Chloromethane	74873	USEPA Health Advisory	3	0.5	EPA 8260B
23	Dibromochloromethane	124481	Calif. Toxics Rule	0.41	0.5	EPA 8260B
27	Dichlorobromomethane	75274	Calif. Toxics Rule	0.56	0.5	EPA 8260B
36	Dichloromethane	75092	Calif. Toxics Rule	4.7	0.5	EPA 8260B
33	Ethylbenzene	100414	Taste & Odor	29	0.5	EPA 8260B
88	Hexachlorobenzene	118741	Calif. Toxics Rule	0.00075	1	EPA 8260B
89	Hexachlorobutadiene	87683	National Toxics Rule	0.44	1	EPA 8260B
91	Hexachloroethane	67721	National Toxics Rule	1.9	1	EPA 8260B
94	Naphthalene	91203	USEPA IRIS	14	10	EPA 8260B
38	Tetrachloroethene	127184	National Toxics Rule	0.8	0.5	EPA 8260B
39	Toluene	108883	Taste & Odor	42	0.5	EPA 8260B
40	trans-1,2-Dichloroethylene	156605	Primary MCL	10	0.5	EPA 8260B
43	Trichloroethene	79016	National Toxics Rule	2.7	0.5	EPA 8260B
44	Vinyl chloride	75014	Primary MCL	0.5	0.5	EPA 8260B
	Methyl-tert-butyl ether (MTBE)	1634044	Secondary MCL	5	0.5	EPA 8260B
	Trichlorofluoromethane	75694	Primary MCL	150	5	EPA 8260B
	1,1,2-Trichloro-1,2,2-Trifluoroethane	76131	Primary MCL	1200	10	EPA 8260B
	Styrene	100425	Taste & Odor	11	0.5	EPA 8260B
	Xylenes	1330207	Taste & Odor	17	0.5	EPA 8260B
SEMI-VOLATILE ORGANICS						
60	1,2-Benzanthracene	56553	Calif. Toxics Rule	0.0044	5	EPA 8270C
85	1,2-Diphenylhydrazine	122667	National Toxics Rule	0.04	1	EPA 8270C
45	2-Chlorophenol	95578	Taste and Odor	0.1	2	EPA 8270C
46	2,4-Dichlorophenol	120832	Taste and Odor	0.3	1	EPA 8270C
47	2,4-Dimethylphenol	105679	Calif. Toxics Rule	540	2	EPA 8270C
49	2,4-Dinitrophenol	51285	National Toxics Rule	70	5	EPA 8270C
82	2,4-Dinitrotoluene	121142	National Toxics Rule	0.11	5	EPA 8270C
55	2,4,6-Trichlorophenol	88062	Taste and Odor	2	10	EPA 8270C
83	2,6-Dinitrotoluene	606202	USEPA IRIS	0.05	5	EPA 8270C
50	2-Nitrophenol	25154557	Aquatic Toxicity	150 (5)	10	EPA 8270C
71	2-Chloronaphthalene	91587	Aquatic Toxicity	1600 (6)	10	EPA 8270C
78	3,3'-Dichlorobenzidine	91941	National Toxics Rule	0.04	5	EPA 8270C
62	3,4-Benzofluoranthene	205992	Calif. Toxics Rule	0.0044	10	EPA 8270C
52	4-Chloro-3-methylphenol	59507	Aquatic Toxicity	30	5	EPA 8270C

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted ¹		
48	4,6-Dinitro-2-methylphenol	534521	National Toxics Rule	13.4	10	EPA 8270C
51	4-Nitrophenol	100027	USEPA Health Advisory	60	5	EPA 8270C
69	4-Bromophenyl-phenyl-ether	101553	Aquatic Toxicity	122	10	EPA 8270C
72	4-Chlorophenyl phenyl ether	7005723	Aquatic Toxicity	122 (3)	5	EPA 8270C
56	Acenaphthene	83329	Taste and Odor	20	1	EPA 8270C
57	Acenaphthylene	208968	No Criteria Available		10	EPA 8270C
58	Anthracene	120127	Calif. Toxics Rule	9,600	10	EPA 8270C
59	Benzdine	92875	National Toxics Rule	0.00012	5	EPA 8270C
61	Benzo(a)pyrene (3,4-Benzopyrene)	50328	Calif. Toxics Rule	0.0044	0.1	EPA 8270C
63	Benzo(g,h,i)perylene	191242	No Criteria Available		5	EPA 8270C
64	Benzo(k)fluoranthene	207089	Calif. Toxics Rule	0.0044	2	EPA 8270C
65	Bis(2-chloroethoxy) methane	111911	No Criteria Available		5	EPA 8270C
66	Bis(2-chloroethyl) ether	111444	National Toxics Rule	0.031	1	EPA 8270C
67	Bis(2-chloroisopropyl) ether	39638329	Aquatic Toxicity	122 (3)	10	EPA 8270C
68	Bis(2-ethylhexyl) phthalate	117817	National Toxics Rule	1.8	3	EPA 8270C
70	Butyl benzyl phthalate	85687	Aquatic Toxicity	3 (7)	10	EPA 8270C
73	Chrysene	218019	Calif. Toxics Rule	0.0044	5	EPA 8270C
81	Di-n-butylphthalate	84742	Aquatic Toxicity	3 (7)	10	EPA 8270C
84	Di-n-octylphthalate	117840	Aquatic Toxicity	3 (7)	10	EPA 8270C
74	Dibenzo(a,h)-anthracene	53703	Calif. Toxics Rule	0.0044	0.1	EPA 8270C
79	Diethyl phthalate	84662	Aquatic Toxicity	3 (7)	2	EPA 8270C
80	Dimethyl phthalate	131113	Aquatic Toxicity	3 (7)	2	EPA 8270C
86	Fluoranthene	206440	Calif. Toxics Rule	300	10	EPA 8270C
87	Fluorene	86737	Calif. Toxics Rule	1300	10	EPA 8270C
90	Hexachlorocyclopentadiene	77474	Taste and Odor	1	1	EPA 8270C
92	Indeno(1,2,3-c,d)pyrene	193395	Calif. Toxics Rule	0.0044	0.05	EPA 8270C
93	Isophorone	78591	National Toxics Rule	8.4	1	EPA 8270C
98	N-Nitrosodiphenylamine	86306	National Toxics Rule	5	1	EPA 8270C
96	N-Nitrosodimethylamine	62759	National Toxics Rule	0.00069	5	EPA 8270C
97	N-Nitrosodi-n-propylamine	621647	Calif. Toxics Rule	0.005	5	EPA 8270C
95	Nitrobenzene	98953	National Toxics Rule	17	10	EPA 8270C
53	Pentachlorophenol	87865	Calif. Toxics Rule	0.28	0.2	EPA 8270C
99	Phenanthrene	85018	No Criteria Available		5	EPA 8270C
54	Phenol	108952	Taste and Odor	5	1	EPA 8270C
100	Pyrene	129000	Calif. Toxics Rule	960	10	EPA 8270C

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted ¹		
INORGANICS						
	Aluminum	7429905	Ambient Water Quality	87	50	EPA 6020/200.8
1	Antimony	7440360	Primary MCL	6	5	EPA 6020/200.8
2	Arsenic	7440382	Ambient Water Quality	0.018	0.01	EPA 1632
15	Asbestos	1332214	National Toxics Rule/ Primary MCL	7 MFL	0.2 MFL >10um	EPA/600/R-93/116(PCM)
	Barium	7440393	Basin Plan Objective	100	100	EPA 6020/200.8
3	Beryllium	7440417	Primary MCL	4	1	EPA 6020/200.8
4	Cadmium	7440439	Public Health Goal	0.07	0.25	EPA 1638/200.8
5a	Chromium (total)	7440473	Primary MCL	50	2	EPA 6020/200.8
5b	Chromium (VI)	18540299	Public Health Goal	0.2	0.5	EPA 7199/1636
6	Copper	7440508	National Toxics Rule	4.1 (2)	0.5	EPA 6020/200.8
14	Cyanide	57125	National Toxics Rule	5.2	5	EPA 9012A
	Fluoride	7782414	Public Health Goal	1000	0.1	EPA 300
	Iron	7439896	Secondary MCL	300	100	EPA 6020/200.8
7	Lead	7439921	Calif. Toxics Rule	0.92 (2)	0.5	EPA 1638
8	Mercury	7439976	TMDL Development		0.0002 (11)	EPA 1669/1631
	Manganese	7439965	Secondary MCL/ Basin Plan Objective	50	20	EPA 6020/200.8
9	Nickel	7440020	Calif. Toxics Rule	24 (2)	5	EPA 6020/200.8
10	Selenium	7782492	Calif. Toxics Rule	5 (8)	5	EPA 6020/200.8
11	Silver	7440224	Calif. Toxics Rule	0.71 (2)	1	EPA 6020/200.8
12	Thallium	7440280	National Toxics Rule	1.7	1	EPA 6020/200.8
	Tributyltin	688733	Ambient Water Quality	0.063	0.002	EV-024/025
13	Zinc	7440666	Calif. Toxics Rule/ Basin Plan Objective	54/ 16 (2)	10	EPA 6020/200.8
PESTICIDES - PCBs						
110	4,4'-DDD	72548	Calif. Toxics Rule	0.00083	0.02	EPA 8081A
109	4,4'-DDE	72559	Calif. Toxics Rule	0.00059	0.01	EPA 8081A
108	4,4'-DDT	50293	Calif. Toxics Rule	0.00059	0.01	EPA 8081A
112	alpha-Endosulfan	959988	National Toxics Rule	0.056 (9)	0.02	EPA 8081A
103	alpha-Hexachlorocyclohexane (BHC)	319846	Calif. Toxics Rule	0.0039	0.01	EPA 8081A
	Aalachlor	15972608	Primary MCL	2	1	EPA 8081A
102	Aldrin	309002	Calif. Toxics Rule	0.00013	0.005	EPA 8081A
113	beta-Endosulfan	33213659	Calif. Toxics Rule	0.056 (9)	0.01	EPA 8081A
104	beta-Hexachlorocyclohexane	319857	Calif. Toxics Rule	0.014	0.005	EPA 8081A
107	Chlordane	57749	Calif. Toxics Rule	0.00057	0.1	EPA 8081A

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted ¹		
106	delta-Hexachlorocyclohexane	319868	No Criteria Available		0.005	EPA 8081A
111	Dieldrin	60571	Calif. Toxics Rule	0.00014	0.01	EPA 8081A
114	Endosulfan-sulfate	1031078	Ambient Water Quality	0.056	0.05	EPA 8081A
115	Endrin	72208	Calif. Toxics Rule	0.036	0.01	EPA 8081A
116	Endrin Aldehyde	7421934	Calif. Toxics Rule	0.76	0.01	EPA 8081A
117	Heptachlor	76448	Calif. Toxics Rule	0.00021	0.01	EPA 8081A
118	Heptachlor Epoxide	1024573	Calif. Toxics Rule	0.0001	0.01	EPA 8081A
105	Lindane (gamma-Hexachlorocyclohexane)	58899	Calif. Toxics Rule	0.019	0.019	EPA 8081A
119	PCB-1016	12674112	Calif. Toxics Rule	0.00017 (10)	0.5	EPA 8082
120	PCB-1221	11104282	Calif. Toxics Rule	0.00017 (10)	0.5	EPA 8082
121	PCB-1232	11141165	Calif. Toxics Rule	0.00017 (10)	0.5	EPA 8082
122	PCB-1242	53469219	Calif. Toxics Rule	0.00017 (10)	0.5	EPA 8082
123	PCB-1248	12672296	Calif. Toxics Rule	0.00017 (10)	0.5	EPA 8082
124	PCB-1254	11097691	Calif. Toxics Rule	0.00017 (10)	0.5	EPA 8082
125	PCB-1260	11096825	Calif. Toxics Rule	0.00017 (10)	0.5	EPA 8082
126	Toxaphene	8001352	Calif. Toxics Rule	0.0002	0.5	EPA 8081A
	Atrazine	1912249	Public Health Goal	0.15	1	EPA 8141A
	Bentazon	25057890	Primary MCL	18	2	EPA 643/ 515.2
	Carbofuran	1563662	CDFG Hazard Assess.	0.5	5	EPA 8318
	2,4-D	94757	Primary MCL	70	10	EPA 8151A
	Dalapon	75990	Ambient Water Quality	110	10	EPA 8151A
	1,2-Dibromo-3-chloropropane (DBCP)	96128	Public Health Goal	0.0017	0.01	EPA 8260B
	Di(2-ethylhexyl)adipate	103231	USEPA IRIS	30	5	EPA 8270C
	Dinoseb	88857	Primary MCL	7	2	EPA 8151A
	Diquat	85007	Ambient Water Quality	0.5	4	EPA 8340/ 549.1/HPLC
	Endothal	145733	Primary MCL	100	45	EPA 548.1
	Ethylene Dibromide	106934	OEHHA Cancer Risk	0.0097	0.02	EPA 8260B/504
	Glyphosate	1071836	Primary MCL	700	25	HPLC/EPA 547
	Methoxychlor	72435	Public Health Goal	30	10	EPA 8081A
	Molinate (Ordram)	2212671	CDFG Hazard Assess.	13	2	EPA 634
	Oxamyl	23135220	Public Health Goal	50	20	EPA 8318/632
	Picloram	1918021	Primary MCL	500	1	EPA 8151A
	Simazine (Princep)	122349	USEPA IRIS	3.4	1	EPA 8141A
	Thiobencarb	28249776	Basin Plan Objective/ Secondary MCL	1	1	HPLC/EPA 639

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted ¹		
16	2,3,7,8-TCDD (Dioxin)	1746016	Calif. Toxics Rule	1.30E-08	5.00E-06	EPA 8290 (HRGC) MS
	2,4,5-TP (Silvex)	93765	Ambient Water Quality	10	1	EPA 8151A
	Diazinon	333415	CDFG Hazard Assess.	0.05	0.25	EPA 8141A/GCMS
	Chlorpyrifos	2921882	CDFG Hazard Assess.	0.014	1	EPA 8141A/GCMS
OTHER CONSTITUENTS						
	Ammonia (as N)	7664417	Ambient Water Quality	1500 (4)		EPA 350.1
	Chloride	16887006	Agricultural Use	106,000		EPA 300.0
	Flow			1 CFS		
	Hardness (as CaCO ₃)			5000		EPA 130.2
	Foaming Agents (MBAS)		Secondary MCL	500		SM5540C
	Nitrate (as N)	14797558	Primary MCL	10,000	2,000	EPA 300.0
	Nitrite (as N)	14797650	Primary MCL	1000	400	EPA 300.0
	pH		Basin Plan Objective	6.5-8.5	0.1	EPA 150.1
	Phosphorus, Total (as P)	7723140	USEPA IRIS	0.14		EPA 365.3
	Specific conductance (EC)		Agricultural Use	700 umhos/cm		EPA 120.1
	Sulfate		Secondary MCL	250,000	500	EPA 300.0
	Sulfide (as S)		Taste and Odor	0.029		EPA 376.2
	Sulfite (as SO ₃)		No Criteria Available			SM4500-SO3
	Temperature		Basin Plan Objective	°F		
	Total Dissolved Solids (TDS)		Agricultural Use	450,000		EPA 160.1

FOOTNOTES:

(1) - The Criterion Concentrations serve only as a point of reference for the selection of the appropriate analytical method. They do not indicate a regulatory decision that the cited concentration is either necessary or sufficient for full protection of beneficial uses. Available technology may require that effluent limits be set lower than these values.

(2) - Freshwater aquatic life criteria for metals are expressed as a function of total hardness (mg/L) in the water body. Values displayed correspond to a total hardness of 40 mg/L.

(3) - For haloethers

(4) - Freshwater aquatic life criteria for ammonia are expressed as a function of pH and temperature of the water body. Values displayed correspond to pH 8.0 and temperature of 22°C.

(5) - For nitrophenols.

(6) - For chlorinated naphthalenes.

(7) - For phthalate esters.

(8) - Basin Plan objective = 2 ug/L for Salt Slough and specific constructed channels in the Grassland watershed.

(9) - Criteria for sum of alpha- and beta- forms.

(10) - Criteria for sum of all PCBs.

(11) - Mercury monitoring shall utilize "ultra-clean" sampling and analytical methods. These methods include:

Method 1669: Sampling Ambient Water for Trace Metals at USEPA Water Quality Criteria Levels, USEPA; and

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted ¹		

Method 1631: Mercury in Water by Oxidation, Purge and Trap, and Cold Vapor Atomic Fluorescence, USEPA

III. Additional Study Requirements

- A. Laboratory Requirements.** The laboratory analyzing the monitoring samples shall be certified by the Department of Public Health in accordance with the provisions of Water Code 13176 and must include quality assurance/quality control data with their reports (ELAP certified).
- B. Criterion Quantitation Limit (CQL).** The criterion quantitation limits will be equal to or lower than the minimum levels (MLs) in Appendix 4 of the SIP or the detection limits for purposes of reporting (DLRs) below the controlling water quality criterion concentrations summarized in Table I-1 of this Order. In cases where the controlling water quality criteria concentrations are below the detection limits of all approved analytical methods, the best available procedure will be utilized that meets the lowest of the MLs and DLR. Table I-1 contains suggested analytical procedures. The Discharger is not required to use these specific procedures as long as the procedure selected achieves the desired minimum detection level.
- C. Method Detection Limit (MDL).** The method detection limit for the laboratory shall be determined by the procedure found in 40 CFR Part 136, Appendix B (revised as of May 14, 1999).
- D. Reporting Limit (RL).** The reporting limit for the laboratory. This is the lowest quantifiable concentration that the laboratory can determine. Ideally, the RL should be equal to or lower than the CQL to meet the purposes of this monitoring.
- E. Reporting Protocols.** The results of analytical determinations for the presence of chemical constituents in a sample shall use the following reporting protocols:
1. Sample results greater than or equal to the reported RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
 2. Sample results less than the reported RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.
 3. For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may shortened to "Est. Conc."). The laboratory, if such information is available, may include numerical estimates of the data quantity for the reported result. Numerical estimates of data quality may be percent accuracy (+ or - a percentage of the

reported value), numerical ranges (low and high), or any other means considered appropriate by the laboratory.

4. Sample results that are less than the laboratory's MDL shall be reported as "Not Detected" or ND.

F. Data Format. The monitoring report shall contain the following information for each pollutant:

1. The name of the constituent.
2. Sampling location.
3. The date the sample was collected.
4. The time the sample was collected.
5. The date the sample was analyzed. For organic analyses, the extraction data will also be indicated to assure that hold times are not exceeded for prepared samples.
6. The analytical method utilized.
7. The measured or estimated concentration.
8. The required Criterion Quantitation Limit (CQL).
9. The laboratory's current Method Detection Limit (MDL), as determined by the procedure found in 40 CFR Part 136, Appendix B (revised as of May 14, 1999).
10. The laboratory's lowest reporting limit (RL).
11. Any additional comments.

G. Dioxin and Furan Sampling

The CTR includes criteria for 2,3,7,8-tetrachlorodibenzo-pdioxin (2,3,7,8-TCDD). In addition to this compound, there are many congeners of chlorinated dibenzodioxins (2,3,7,8-CDDs) and chlorinated dibenzofurans (2,3,7,8-CDFs) that exhibit toxic effects similar to those of 2,3,7,8-TCDD. The USEPA has published toxic equivalency factors (TEFs) for 17 of the congeners. The TEFs express the relative toxicities of the congeners compared to 2,3,7,8-TCDD (whose TEF equals 1.0). In June 1997, participants in a World Health Organization (WHO) expert meeting revised TEF values for 1,2,3,7,8-PentaCDD, OctaCDD, and OctaCDF. The current TEFs for the 17 congeners, which include the three revised values, are shown below:

Toxic Equivalency Factors (TEFs) for 2,3,7,8-TCDD Equivalents

Congener	TEF
2,3,7,8-TetraCDD	1
1,2,3,7,8-PentaCDD	1.0
1,2,3,4,7,8-HexaCDD	0.1
1,2,3,6,7,8-HexaCDD	0.1
1,2,3,7,8,9-HexaCDD	0.1
1,2,3,4,6,7,8-HeptaCDD	0.01
OctaCDD	0.0001
2,3,7,8-TetraCDF	0.1
1,2,3,7,8-PentaCDF	0.05
2,3,4,7,8-PentaCDF	0.5
1,2,3,4,7,8-HexaCDF	0.1
1,2,3,6,7,8-HexaCDF	0.1
1,2,3,7,8,9-HexaCDF	0.1
2,3,4,6,7,8-HexaCDF	0.1
1,2,3,4,6,7,8-HeptaCDF	0.01
1,2,3,4,7,8,9-HeptaCDF	0.01
OctaCDF	0.0001

The Discharger shall conduct effluent and receiving water monitoring for the 2,3,7,8-TCDD congeners listed above to assess the presence and amounts of the congeners being discharged and already present in the receiving water. Effluent and upstream receiving water shall be monitored for the presence of the 17 congeners once during dry weather and once during wet weather for 1 year within the term of the study.

The Discharger shall report, for each congener, the analytical results of the effluent and receiving water monitoring, including the quantifiable limit and the method detection limit, and the measured or estimated concentration.

In addition, the Discharger shall multiply each measured or estimated congener concentration by its respective TEF value and report the sum of these values.




EXHIBIT B

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER. R5-2011-0035

AMENDING CEASE AND DESIST ORDER NO. R5-2009-0012-01
(NPDES NO. CA0079022)

CITY OF LIVE OAK
WASTEWATER TREATMENT PLANT
SUTTER COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereinafter Central Valley Water Board) finds:

1. On 9 July 2004, the Central Valley Water Board adopted Waste Discharge Requirements (WDRs) Order No. R5-2004-0096, and Cease and Desist Order (CDO) No. R5-2004-0097 prescribing waste discharge requirements and compliance time schedules for the City of Live Oak (hereafter Discharger) Wastewater Treatment Plant, Sutter County.
2. WDRs Order No. R5-2004-0096 included limits, in part, for aluminum, ammonia, biochemical oxygen demand (BOD), copper, total coliform, and total suspended solids (TSS) as contained in Effluent Limitations Section B.2.
3. On 5 February 2009, the Central Valley Water Board adopted CDO No. R5-2009-0012 amending CDO No. R5-2004-0097 to include time schedules and interim limitations, in part, for aluminum and ammonia.
4. On 24 April 2009, the Central Valley Water Board adopted CDO No. R5-2009-0012-01 amending CDO No. R5-2009-0012 to include new interim limitations for BOD, copper, total coliform, and TSS.
5. On 10 June 2011, the Central Valley Water Board adopted WDRs Order No. R5-2011-0034 prescribing waste discharge requirements and Final Effluent Limitations IV.A.1.a, b, f, and h through j, and specific requirements for a tertiary treatment plant, in part. (See Order No. R5-2011-0034, sections IV through VII and Attachment F, sections IV and VII.)
6. California Water Code (CWC) section 13301 states: *"When a regional board finds that a discharge of waste is taking place, or threatening to take place, in violation of requirements or discharge prohibitions prescribed by the regional board or the state board, the board may issue an order to cease and desist and direct that those persons not complying with the requirements or discharge prohibitions (a) comply forthwith, (b) comply in accordance with a time schedule set by the board, or (c) in the event of a threatened violation, take appropriate remedial or preventive action. In the event of an existing or threatened violation of waste discharge requirements in the operation of a community sewer system, cease and desist orders may restrict or prohibit the volume, type, or concentration of waste that might be*

EXHIBIT B

added to that system by dischargers who did not discharge into the system prior to the issuance of the cease and desist order. Cease and desist orders may be issued directly by a board, after notice and hearing."

7. On 19 July 2010, the Discharger submitted "City of Live Oak Compliance Extension Request Infeasibility Analysis" that included justification for a compliance schedule for the new Effluent Limitations for aluminum, ammonia, arsenic, alpha-BHC, copper, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, nitrate, and total THMs. In addition to source control measures, the Discharger proposes to construct and implement a Title 22 tertiary filtration system and an ultraviolet light disinfection system. The new treatment system is expected to be completed by 30 September 2012. However on 8 December 2010, the Discharger submitted information from an independent schedule analyst that determined the construction contractor is behind schedule and that completion of the project on the proposed schedule is doubtful at the current rate of progress. Therefore, the compliance schedule to meet the final technology based effluent limitations was extended accordingly. If the new treatment system does not achieve compliance with some constituents, the Discharger requests time to conduct source investigations and site-specific studies (e.g. WER study) where applicable. For the newly imposed effluent limitations for arsenic, dibromochloromethane, dichlorobromomethane, total Trihalomethanes, iron, and manganese that are based on the municipal and domestic supply (or MUN) beneficial use, the Discharger may request additional time to complete a Basin Plan amendment study to de-designate the MUN beneficial use of the receiving water.
8. Immediate compliance with the final effluent limitations for aluminum, ammonia, alpha-BHC, BOD, total coliform, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, nitrate, and TSS is not possible or practicable. The Clean Water Act and the California Water Code authorize time schedules for achieving compliance. This Order amends CDO No. R5-2009-0012-01 (Attachment 1) to include or extend compliance time schedules for these final effluent limitations. Additionally, this Order removes the compliance schedules for cyanide, diazinon, and turbidity because these effluent limitations are not contained in WDRs Order No. R5-2011-0034, and therefore, a compliance schedule is no longer necessary.
9. Since the time schedules for completion of actions necessary to bring the waste discharge into compliance exceeds one year, this Order includes interim requirements and dates for achievement. The time schedules do not exceed five years. The compliance time schedules in the proposed Order (Attachment 1) that amends CDO No. R5-2009-0012-01 includes interim effluent limitations for aluminum, ammonia, alpha-BHC, BOD, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, nitrate, total coliform, and TSS.
10. The Central Valley Water Board finds that the Discharger can maintain compliance with the interim limitations included in the proposed Order (Attachment 1 of this Order). Interim limitations are established when compliance with the final effluent limitations cannot be achieved by the existing discharge. Discharge of constituents in concentrations in excess of the final effluent limitations, but in compliance with the interim effluent limitations, can

significantly degrade water quality and adversely affect the beneficial uses of the receiving stream on a long-term basis. The interim limitations, however, establish an enforceable ceiling concentration until compliance with the final effluent limitation can be achieved.

Other Regulatory Requirements

11. On **10 June 2011**, in Rancho Cordova, California, after due notice to the Discharger and all other affected persons, the Central Valley Water Board conducted a public hearing at which evidence was received to consider a Cease and Desist Order under CWC section 13301 to establish a time schedule to achieve compliance with waste discharge requirements.
12. Issuance of this Order is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000, *et seq.*) (CEQA), in accordance with CWC Section 15321(a)(2), Title 14, California Code of Regulations (CCR).
13. Any person aggrieved by this action of the Central Valley Water Board may petition the State Water Board to review the action in accordance with CWC section 13320 and California Code of Regulations, Title 23, sections 2050 and following. The State Water Board must receive the petition by 5:00 p.m., 30 days after the date that this Order becomes final, except that if the thirtieth day following the date that this Order becomes final falls on a Saturday, Sunday, or state holiday (including mandatory furlough days), the petition must be received by the State Water Board by 5:00 p.m. on the next business day. Copies of the law and regulations applicable to filing petitions may be found on the Internet at: http://www.waterboards.ca.gov/public_notices/petitions/water_quality or will be provided upon request.

IT IS HEREBY ORDERED THAT:

Cease and Desist Order No. R5-2010-0012-01 (NPDES No. CA0079022) is amended as shown in underline/strikeout format in Attachment 1 to this Order.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on **10 June 2011**.

Original Signed by

PAMELA C CREEDON, Executive Office

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. R5-2009-0012-0204
REQUIRING
CITY OF LIVE OAK
WASTEWATER TREATMENT PLANT
SUTTER COUNTY

TO CEASE AND DESIST
FROM DISCHARGING CONTRARY TO REQUIREMENTS

The California Regional Water Quality Control Board, Central Valley Region (hereafter Central Valley Water Board), finds:

1. On 9 July 2004, the Central Valley Water Board adopted Waste Discharge Requirements (WDRs) Order No. R5-2004-0096, and Cease and Desist Order (CDO) No. R5-2004-0097 prescribing waste discharge requirements and compliance time schedules for the City of Live Oak (hereafter Discharger) Wastewater Treatment Plant (WWTP). The WDRs allow for a regulated discharge of 1.4 million gallons per day (mgd) of treated domestic wastewater to Reclamation District 777 Lateral Drain No. 1, which is tributary to Main Canal and the Sutter Bypass.
2. WDRs Order No. R5-2004-0096 includes limits for aluminum, ammonia, biochemical oxygen demand (BOD), copper, cyanide, diazinon, organochlorine pesticides, total coliform, total suspended solids (TSS), and turbidity as contained in Effluent Limitations Section B.2., which states in part:

<u>Constituents</u>	<u>Units</u>	<u>Average Monthly</u>	<u>7-Day Median</u>	<u>Average Weekly</u>	<u>Average Daily</u>	<u>Instantaneous Maximum</u>
BOD ¹	mg//	10 ²	--	15 ²	20 ²	--
	lbs/day ³	120	--	180	230	--
Total Suspended Solids	mg//	10 ²	--	15 ²	20 ²	--
	lbs/day	120	--	180	230	--
Total Coliform Organisms	MPN/100 m/	--	2.2	--	--	23 ⁴
Organochlorine Pesticides	µg//	--	--	--	--	ND ⁵
Turbidity	NTU	--	--	--	2	5 ⁶

¹ 5-day, 20°C biochemical oxygen demand (BOD)

² To be ascertained by a 24-hour composite

³ Based upon a design treatment capacity of 1.4 mgd ($x \text{ mg//} \times 8.345 \times 1.4 \text{ mgd} = y \text{ lbs/day}$)

⁴ The total coliform organisms concentration shall not exceed 23 MPN/100 m/ more than once in any 30-day period. No sample shall exceed a concentration of 240 MPN/100 m/.

⁵ The Non-Detectable (ND) limitation applies to each individual pesticide. No individual pesticide may be present in the discharge at detectable concentrations. The Discharger shall use EPA standard analytical techniques with the lowest possible detectable level for organochlorine pesticides with a maximum acceptable detection level of 0.05 µg//.

⁶ The turbidity shall not exceed 5 NTU more than 5 percent of the time within a 24-hour period. At no time shall the turbidity exceed 10 NTU.

<u>Constituents</u>	<u>Units</u>	<u>Average Monthly</u>	<u>Average 4-Day</u>	<u>Average Daily</u>	<u>Average 1-Hour</u>
Aluminum ¹	µg/l	71 ²	--	140 ²	--
	lbs/day ³	0.83	--	1.7	--
Ammonia, Total	mg/l	Attachment B	Attachment C	--	Attachment D
(as N)	lbs/day ⁴	⁵	⁵	--	⁵
Copper	µg/l	Attachment F ²	--	Attachment F ²	--
(total recoverable)	lbs/day ³	⁶	--	⁶	--
Cyanide	µg/l	4.3 ²	--	8.5 ²	--
(total recoverable)	lbs/day ³	0.050	--	0.10	--
Diazinon	µg/l	0.04	--	0.08	--
	lbs/day ³	0.0005	--	0.001	--

¹ Acid-soluble or total

² To be ascertained by 24-hour composite

³ Based upon a design treatment capacity of 1.4 mgd [x µg/l x (1 mg/1000 µg) x 8.345 x 1.4 mgd = y lbs/day]

⁴ Based upon a design treatment capacity of 1.4 mgd (x mg/l X 8.345 X 1.4 mgd = y lbs/day)

⁵ The mass limit (lb/day) for ammonia shall be equal to the concentration limit (from Attachments) multiplied by the design flow of 1.4 mgd and the unit conversion factor of 8.345 (see footnote 3 for equation).

⁶ The mass limit (lbs/day) shall be equal to the concentration limit (from corresponding Attachment, for corresponding period) multiplied by the design flow of 1.4 mgd and the unit conversion factor of 8.345 and divided by 1000 µg/l per mg/l (see footnote 3 for equation).

3. WDRs Order No. R5-2004-0096 includes Effluent Limitations B.4., which states:

"The arithmetic mean of 20°C BOD (5-day) and of total suspended solids in effluent samples collected over a calendar month shall not exceed 15 percent of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period (85 percent removal) by 1 April 2009."

4. WDRs Order No. R5-2004-0096 includes Effluent Limitations B.8., which states:

"Wastewater shall be oxidized, coagulated, filtered, and disinfected, or equivalent treatment provided by 1 April 2009."

5. WDRs Order No. R5-2004-0096 included time schedules for achieving compliance with Effluent Limitations B.2. for BOD, TSS, total coliform organisms, turbidity, copper, and cyanide by 1 April 2009.
6. CDO No. R5-2004-0097 included a time schedule for achieving compliance with Effluent Limitations B.1. for aluminum, ammonia, diazinon, and organochlorine pesticides by 1 April 2009.
7. WDRs Order No. R5-2011-0034 includes Effluent Limitations IV.A.1.a, b, f, h through j, in part as follows:

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	10	15	20	--	--
	lbs/day ¹	120	180	230	--	--
Total Suspended Solids	mg/L	10	15	20	--	--
	lbs/day ¹	120	180	230	--	--
Ammonia, Total (as N)	mg/L	1.4	--	2.8	--	--
	lbs/day ¹	16	--	33	--	--
Aluminum, Total Recoverable	µg/L	260	--	750	--	--
Arsenic	µg/L	10	--	20.1	--	--
Dibromochloromethane	µg/L	0.41	--	0.82	--	--
Dichlorobromomethane	µg/L	0.56	--	1.2	--	--
Alpha BHC	µg/L	--	--	--	--	ND
4,4'-DDE	µg/L	--	--	--	--	ND
Alpha Endosulfan	µg/L	--	--	--	--	ND
Endrin Aldehyde	µg/L	--	--	--	--	ND
Nitrate (as N)	mg/L	10	--	--	--	--
Total Trihalomethanes	µg/L	80	--	162	--	--

¹ Based on an average dry weather flow of 1.4 mgd.

- b. Percent Removal.** The average monthly percent removal of 5-day biochemical oxygen demand (BOD₅) and total suspended solids (TSS) shall not be less than 85 percent
- f. Total Coliform Organisms.** Effluent total coliform organisms shall not exceed:
- i. 2.2 most probable number (MPN) per 100 mL, as a 7-day median; and
 - ii. 23 MPN/100 mL, more than once in any 30-day period, and
 - iii. 240 MPN/100 mL, instantaneous maximum.
- h. Iron.** For a calendar year, the annual average effluent total recoverable iron shall not exceed 300 µg/L.
- i. Manganese.** For a calendar year, the annual average effluent total recoverable manganese shall not exceed 50 µg/L.
- j. Aluminum.** For a calendar year, the annual average effluent total recoverable aluminum shall not exceed 200 µg/L.
8. Section 13301 of the California Water Code (CWC) states in part, "When a regional board finds that a discharge of waste is taking place or threatening to take place in violation of requirements or discharge prohibitions prescribed by the regional board or the state board, the board may issue an order to cease and desist and direct that those persons not complying with the requirements or discharge prohibitions (a) comply forthwith, (b) comply in accordance with a time schedule set by the board, or (c) in the event of a threatened violation, take appropriate remedial or preventative action. In the event of an existing or

threatened violation of waste discharge requirements in the operation of a community sewer system, cease and desist orders may restrict or prohibit the volume, type, or concentration of waste that might be added to such system by dischargers who did not discharge into the system prior to the issuance of the cease and desist order. Cease and desist orders may be issued directly by a board, after notice and hearing,"

9. ~~Section 13267(b)(1) of the California Water Code provides that: "In conducting an investigation specified in subdivision (a), the regional board may require that any person who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge waste within its region, or any citizen or domiciliary, or political agency or entity of this state who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge, waste outside of its region that could affect the quality of waters within its region shall furnish, under penalty of perjury, technical or monitoring program reports which the regional board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports. In requiring those reports, the regional board shall provide the person with a written explanation with regard to the need for the reports, and shall identify the evidence that supports requiring that person to provide the reports."~~

10. In accordance with California Water Code (CWC) Section 13385(j)(3), the Central Valley Water Board finds that the Discharger is not able to consistently comply with WDRs Order No. R5-2011-0034, Effluent Limitations IV.A.1. for aluminum, ammonia, arsenic, alpha-BHC, BOD, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, nitrate, total coliform, and TSS. Additional time is necessary to finalize onsite plant upgrades. New time schedules are necessary in a CDO for aluminum, ammonia, alpha-BHC, BOD, cyanide, diazinon, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, nitrate, total coliform, and TSS and turbidity. Effluent limitations for these constituents are new requirements that became applicable to the Orders after the effective waste discharge requirements adoption date and/or after 1 July 2000, for which new or modified control measures are necessary in order to comply with the limitation, and the new or modified control measures cannot be designed, installed, and put into operation within 30 calendar days.

~~10. CWC section 13385(h) and (i) require the Regional Water Board to impose mandatory minimum penalties upon dischargers that violate certain effluent limitations. CWC section 13385(j) exempts certain violations from the mandatory minimum penalties. CWC section 13385(j)(3) exempts the discharge from mandatory minimum penalties "where the waste discharge is in compliance with either a cease and desist order issued pursuant to Section 13301 or a time schedule order issued pursuant to Section 13300, if all the [specified] requirements are met...For the purposes of this subdivision, the time schedule may not exceed five years in length..." 11. 12.~~

11. Since the time schedules for completion of actions necessary to bring the waste discharge into compliance exceeds one year, this Order includes interim requirements and dates for their achievement.

12. The compliance time schedule in this Order includes interim effluent limitations for aluminum, ammonia, alpha-BHC, BOD, total coliform, TSS, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, and nitrate, total coliform, and TSS. Interim effluent limitations typically consist of a daily effluent concentration derived using sample data provided by the Discharger demonstrating actual treatment plant performance. In developing the interim limitations, when there are ten sampling data points or more, sampling and laboratory variability is accounted for by establishing interim limits that are based on normally distributed data where 99.9% of the data points will lie within 3.3 standard deviations of the mean (*Basic Statistical Methods for Engineers and Scientists, Kennedy and Neville, Harper and Row*). When there are less than ten sampling data points available, the *Technical Support Document for Water Quality- Based Toxics Control (EPA/505/2-90-001) (TSD)* recommends a coefficient of variation of 0.6 be utilized as representative of wastewater effluent sampling. The TSD recognizes that a minimum of ten data points is necessary to conduct a valid statistical analysis. The multipliers contained in Table 5-2 of the TSD are used to determine a daily limitation based on a long-term average objective. In this case, the long-term average objective is to maintain, at a minimum, the current plant performance level. Thus, when there are less than ten sampling points for a constituent, interim limitations are based on 3.11 times the maximum observed effluent concentration to obtain the daily interim limitation (TSD, Table 5-2). If the statistically-projected interim limitation is less than the maximum observed effluent concentration, the interim limitation is established as the maximum observed concentration. The following table summarizes the calculations of the daily maximum interim effluent limitations for these constituents:

Parameter	Units	MEC	Mean (x)	Std. Dev. (sd)	Formula Used	Interim Limitation Maximum Daily
Aluminum	µg/L	--	--	--	Previous CDO	7300
Ammonia	mg/L	--	--	--	Previous CDO	23.7
Alpha-BHC	µg/L	0.022	--	--	3.11*MEC	0.068
BOD	mg/L	--	--	--	Previous CDO	See Table Below
4,4'-DDE	µg/L	0.012	--	--	3.11*MEC	0.037
Dibromochloromethane	µg/L	4.2	3.6	0.67	3.11*MEC	13.1
Dichlorobromomethane	µg/L	28.2	21.7	7.24	3.11*MEC	87.7
Alpha-Endosulfan	µg/L	0.01	--	--	3.11*MEC	0.031
Endrin Aldehyde	µg/L	0.01	--	--	3.11*MEC	0.031
Iron	µg/L	1210	719.5	254.9	3.11*MEC	3763
Manganese	µg/L	43.2	36.9	7.13	3.11*MEC	134.4
Nitrate	mg/L	13.8	6.97	4.33	3.11*MEC	42.9
Total Coliform	MPN/100 ml	--	--	--	Previous CDO	See Table Below
TSS	mg/L	--	--	--	Previous CDO	See Table Below

13. Issuance of this Order is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000, et seq.) ("CEQA"), under Water Code Section 13389, since any adoption or modification of a NPDES Permit for an existing source is exempt and this order only serves to implement such a NPDES permit. This Order is also exempt from CEQA in accordance with Section 15321(a)(2), Title 14, California Code of Regulations. This Order is not subject to the limitations of Government Code section 65962.5(c)(3) [Cortese List] on use of categorical exemptions because it does not involve the discharge of "hazardous" materials as used in that statute, but rather involves the discharge of domestic sewage; and because the Cortese List exception was

not intended to apply to cease and desist orders to existing facilities. In addition, adoption of this Order is not subject to CEQA because this Order does not have the potential to cause a significant impact on the environment (Title 14 CCR section 15061(b)(3)) as it is intended to enforce preexisting requirements to improve the quality of ongoing discharges that are part of the CEQA "baseline". Any plant upgrades or replacement are the result of WDRs Order No. R5-2011-0034 and not this Order.

14. Any person adversely affected by this action of the Central Valley Water Board may petition the State Water Resources Control Board (State Water Board) to review the action. The petition must be received by the State Water Board Office of Chief Counsel, P.O. Box 100, Sacramento CA 95812-0100, within 30 days of the date in which the action was taken. Copies of the law and regulations applicable to filing petitions will be provided on request.
15. CWC section 13385(h) and (i) require the Central Valley Water Board to impose mandatory minimum penalties upon dischargers that violate certain effluent limitations. CWC section 13385(j) exempts certain violations from the mandatory minimum penalties. CWC section 13385(i)(3) exempts the discharge from mandatory minimum penalties "where the waste discharge is in compliance with either a cease and desist order issued pursuant to Section 13301 or a time schedule order issued pursuant to Section 13300, if all the [specified] requirements are met...For the purposes of this subdivision, the time schedule may not exceed five years in length..."
16. In accordance with CWC section 13385(j)(3), the Central Valley Water Board finds that, based upon results of effluent monitoring, the Discharger is not able to consistently comply with the new effluent limitations for BOD and TSS, aluminum, ammonia, alpha-BHC, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha-endosulfan, endrin aldehyde, iron, manganese, nitrate, and total coliform. The final effluent limitations for BOD, TSS, aluminum, ammonia, alpha-BHC, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha-endosulfan, endrin aldehyde, iron, manganese, nitrate, and total coliform are new, or more stringent, requirements included in Cease and Desist Order No. R5-2009-0012-02 and WDR Order No. R5-2011-0034, which become effective on 30 July 2011, and for which new or modified control measures are necessary in order to comply with the limitations, and the new or modified control measures cannot be designed, installed, and put into operation within 30 calendar days.
17. By statute, a Cease and Desist Order or Time Schedule Order may provide protection from MMPs for no more than five years. This Order provides protection from MMPs for the following constituents for the following periods:
 - BOD, Total Suspended Solids and Total Coliform Organisms: MMP protection began with adoption of CDO R5-2009-0012 on 5 February 2009. The effluent limits in WDRs Order R5-2011-0034 are the same as those in WDRs Order R5-2004-0096, and therefore MMP protection may not extend beyond the compliance date of this Order or 5 February 2014, whichever is shorter.
 - Ammonia: The effluent limits in WDRs Order R5-2011-0034 are lower than the limit in the previous Order. Therefore MMP protection begins with adoption of this Order on

10 June 2011 and may not extend beyond the compliance date of this Order or five years from adoption of Order No. R5-2009-0012-02, whichever is shorter.

• Dibromochloromethane, Dichlorobromomethane, Iron, Manganese, and Nitrate. These constituents did not previously have MMP protection. Therefore MMP protection begins with adoption of this Order on 10 June 2011 and may not extend beyond the compliance date of this Order or five years from adoption of this Order, whichever is shorter.

18. By statute, a Cease and Desist Order or Time Schedule Order may provide protection from MMPs for no more than five years. This Order does not provide protection from MMPs for the following constituents:

• Aluminum (CDO No. R5-2004-0097 provided almost five years to comply with the effluent limitation found in WDRs Order R5-2004-0096. The limitation in Order R5-2011-0034 is higher than the previous limit. Therefore the Discharger is not protected from MMPs for this constituent).

• Alpha BHC, 4,4'-DDE, Alpha Endosulfan, and Endrin Aldehyde (CDO No. R5-2004-0097 provided almost five years to comply with the effluent limitation found in WDRs Order R5-2004-0096 for organochlorine pesticides. The limitation in Order R5-2011-0034 is the same as the previous limit. Therefore the Discharger is not protected from MMPs for this constituent).

IT IS HEREBY ORDERED that CDO No. R5-2004-0097 is rescinded, and, pursuant to CWC section 13301:

1. The Discharger shall comply with the following time schedule to assure compliance with WDRs Order No. R5-2011-0034, Effluent Limitations IV.A.1, in part, for aluminum, ammonia, alpha-BHC, BOD, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, nitrate, total coliform, TSS, for aluminum, BOD, copper, total coliform, TSS, , require for 85 percent BOD and TSS removal, and the provisional requirement for Title 22 tertiary treatment, or equivalent:

<u>Task</u>	<u>Compliance Date</u>
Implement PPP ¹	Ongoing
Progress Reports ²	1 March and 1 September of each year

~~30 September 2012~~

~~Onsite WWTP improvements, achieve Full Compliance with Effluent Limitations B.2. for aluminum, ammonia, BOD, coliform, copper, cyanide, TSS, turbidity, and diazinon.~~

Task

Compliance Date

Implement PPP¹

Ongoing

Progress Reports²

1 March and 1 September of each year

Achieve full compliance with Effluent Limitations IV.A.1.a. for alpha BHC, alpha endosulfan, endrin aldehyde, and 4,4'-DDE.

30 September 2012

Achieve full compliance with Effluent Limitations IV.A.1.a., b., and f. for BOD, TSS, and total coliform, and implementation of Title 22 tertiary, or equivalent, treatment system.

2 years from the effective date of this Order

Achieve full compliance with Effluent Limitations IV.A.1.a. for dibromochloromethane, dichlorobromomethane.

3 years from the effective date of this Order

Achieve full compliance with Effluent Limitations IV.A.1.a., h., i., and j. for aluminum, ammonia, iron, manganese, and nitrate.

5 years from the effective date of this Order

¹ The Discharger shall implement new or existing Pollution Prevention Plans for all constituents listed in Provision 1 above and shall meet the requirements specified in California Water Code Section 13263.

² The progress reports shall detail steps implemented towards achieving compliance with waste discharge requirements, including construction progress regarding onsite WWTP improvements, whichever is applicable. The progress reports shall also evaluate the effectiveness of the implemented treatment and pollution prevention measures and assess whether additional measures are necessary to comply with final effluent limits.

2. For the compliance schedules required by this Order, the Discharger shall submit to the Central Valley Water Board on or before each compliance due date, the specified document or, if appropriate, a written report detailing compliance or noncompliance with the specific schedule date and task. If noncompliance is being reported, the reasons for such noncompliance shall be stated, and shall include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Central Valley Water Board by letter when it returns to compliance with the time schedule.
3. The following interim effluent limitations for aluminum, ammonia, alpha-BHC, 4,4'-DDE, dibromochloromethane, dichlorobromomethane, alpha endosulfan, endrin aldehyde, iron, manganese, and nitrate shall be effective immediately, and shall remain in effect until the final compliance date, in accordance with Provision 1 above, or when the Discharger is able to come into compliance with the final effluent limitations, whichever is sooner.

Parameter	Average Daily Effluent Limitation
Aluminum	7300 µg/L
Ammonia	23.7 mg/L
alpha-BHC	0.068 µg/L
4,4'-DDE	0.037 µg/L

Dibromochloromethane	13.1 µg/L
Dichlorobromomethane	87.7 µg/L
alpha-Endosulfan	0.031 µg/L
Endrin Aldehyde	0.031 µg/L
Iron	3763 µg/L
Manganese	134.4 µg/L
Nitrate	42.9 mg/L

The following interim effluent limitations for BOD, Total Suspended Solids (TSS), and coliform shall be effective immediately, and shall remain in effect until the final compliance date, in accordance with Provision 1 above, or when the Discharger is able to come into compliance with the final effluent limitations, whichever is sooner.

<u>Constituents</u>	<u>Units</u>	<u>Average Monthly</u>	<u>7-Day Median</u>	<u>Average Weekly</u>	<u>Average Daily</u>	<u>Instantaneous Maximum</u>
BOD ¹	mg/l	45 ²	--	65 ²	90 ²	--
	lbs/day ³	530	--	760	1,100	--
Total Suspended Solids	mg/l	70 ²	--	110 ²	140 ²	--
	lbs/day	820	--	1300	1600	--
Total Coliform Organisms	MPN/100 m/	--	23	--	--	500

¹ 5-day, 20°C biochemical oxygen demand (BOD)

² To be ascertained by 24-hour composite

³ Based upon a design treatment capacity of 1.4 mgd [x g/l x (1 mg/1000 g) x 8.345 x 1.4 mgd = y lbs/day]

- If, in the opinion of the Executive Officer, the Discharger fails to comply with the provisions of this Order, the Executive Officer may apply to the Attorney General for judicial enforcement or issue a complaint for Administrative Civil Liability.
- Any person signing a document submitted under this Order shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my knowledge and on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 24 April 2009 and as amended on 10 June 2011.

PAMELA C. CREEDON, Executive Officer

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

PROOF OF SERVICE

I am employed in the County of Sacramento; my business address is 500 Capitol Mall, Suite 1000, Sacramento, California; I am over the age of 18 years and not a party to the foregoing action.

On July 11, 2011, I served a true and correct copy of:

CITY OF LIVE OAK'S PETITION FOR REVIEW AND STATEMENT OF POINTS AND AUTHORITIES IN SUPPORT THEREOF

XXX (by mail) on all parties in said action, in accordance with Code of Civil Procedure §1013a(3); by placing a true copy thereof enclosed in a sealed envelope, with postage fully paid thereon, in the designated area for outgoing mail, addressed as set forth below.

Pamela Creedon, Executive Officer
Central Valley Regional Water Quality
Control Board
11020 Sun Center Drive, Suite 200
Rancho Cordova, CA 95670-6114

David P. Coupe, Staff Counsel
San Francisco Bay Regional Water Quality
Control Board
1515 Clay Street, Suite 1400
Oakland, CA 94612

Brant Bordsen, Esquire
Live Oak City Attorney
Rich, Fuidge, Morris & Iverson
P.O. Box "A"
Marysville, CA 95901

I declare under penalty of perjury that the foregoing is true and correct. Executed on July 11, 2011, at Sacramento, California.



Crystal Rivera

1 CITY OF LIVE OAK
BRANT BORDSEN, ESQ. (SBN 101590)
2 City Attorney
Rich, Fuidge, Morris & Iverson
3 1129 D Street
P.O. Box "A"
4 Marysville, CA 95901
Telephone: (530) 742-7371
5 Facsimile: (530) 742-5982

6 SOMACH SIMMONS & DUNN
A Professional Corporation
7 THERESA A. DUNHAM, ESQ. (SBN 187644)
ROBERTA L. LARSON, ESQ. (SBN 191705)
8 500 Capitol Mall, Suite 1000
Sacramento, CA 95814
9 Telephone: (916) 446-7979
Facsimile: (916) 446-8199

10 Attorneys for Petitioner CITY OF LIVE OAK
11



12
13 BEFORE THE
14 CALIFORNIA STATE WATER RESOURCES CONTROL BOARD
15

16 In the Matter of the Petition of City of Live Oak
for Review of Action and Failure to Act by
17 Central Valley Regional Water Quality Control
Board.
18

SWRCB/OCC File No. _____

CITY OF LIVE OAK'S REQUEST FOR
STAY AND MEMORANDUM OF
POINTS AND AUTHORITIES IN
SUPPORT THEREOF
[Wat. Code, § 13320]

19
20
21 Pursuant to Water Code sections 13320 and 13321, and title 23, section 2053 of the
22 California Code of Regulations, the City of Live Oak (Live Oak) hereby requests a stay of certain
23 provisions of Order No. R5-2011-0034 NPDES¹ No. CA0079022 *Waste Discharge Requirements*
24 *for City of Live Oak Wastewater Treatment Plant* (Order No. R5-2011-0034 or Permit) and of
25 Order No. R5-2011-0035 *Amending Cease and Desist Order No. R5-2009-0012-001* (Order
26 No. R5-2011-0035 or CDO), which were adopted by the Regional Water Quality Control Board,
27

28 ¹ National Pollutant Discharge Elimination System.

1 Central Valley Region (Regional Water Board) on June 10, 2011. The Permit and CDO are
2 attached as Exhibits A and B, respectively, to Live Oak's Petition for Review and Statement of
3 Points and Authorities in Support Thereof (Petition), filed concurrently herewith. Live Oak's
4 Petition challenges certain provisions of Order Nos. R5-2011-0034 and R5-2011-0035.

5 Live Oak seeks a stay of various effluent limitations, receiving water limitations, and
6 compliance schedule provisions resulting from terms in the Permit and CDO that are improper
7 and unsupported. In particular, Live Oak seeks a stay of effluent limitations, receiving water
8 limitations, and compliance schedule provisions that are based on the assumption that municipal
9 or domestic water supply (MUN) is a beneficial use of Reclamation District 777's constructed
10 Lateral Drain Nos. 1 and 2 (Lateral Drain Nos. 1 and 2) as set forth in the Permit. (See Petition,
11 pp. 2-4; Permit, Table 5, page 6, and Table F-5, page F-16.) The Permit and CDO also contain
12 interim effluent limitations, and compliance schedule provisions that require Live Oak to comply
13 with provisions in the interim. (Permit, pp. 12, 28; CDO, p. 8.)

14 Live Oak requests that any such stay take effect as of the effective date of the Permit until
15 the State Water Resources Control Board (State Water Board) fully acts on the Petition or the
16 time to do so at Live Oak's request expires.

17 Concurrent with this Stay Request, Live Oak submits declarations in support of the
18 evidence referred to herein. (See Declaration of William Lewis in Support of City of Live Oak's
19 Request for Stay (Lewis Decl.); see also Declaration of Michael Harrison in Support of City of
20 Live Oak's Request for Stay (Harrison Decl.)) The Stay Request and declarations demonstrate
21 that a stay is appropriate in this case because: (1) the stay will prevent substantial harm to Live
22 Oak and the public interest; (2) the stay will not cause substantial harm to other interested persons
23 or the public interest; and (3) the Petition raises substantial questions of fact or law. (See Cal.
24 Code Regs., tit. 23, § 2053(a)(1)-(3).) To comply with the Permit's effluent limitations, receiving
25 water limitations, and compliance schedule provisions associated with the MUN use designation
26 for Lateral Drain Nos. 1 and 2, Live Oak needs to plan, design, and install new treatment facilities
27 at a substantial cost for no meaningful water quality benefit. In short, Live Oak would have to
28 spend a significant amount of public funds on such facilities *before* the State Water Board can

1 resolve the Petition. In challenging the MUN use designation for Lateral Drain Nos. 1 and 2 as
2 not necessary, reasonable, or supported by the record, this Stay Request explains that Live Oak
3 will incur substantial harm as a result of the unnecessary expenditure of public funds.

4 SOMACH SIMMONS & DUNN
5 A Professional Corporation

6 DATED: July 11, 2011

7 By: Theresa A. Dunham
8 Theresa A. Dunham
9 Attorneys for Petitioner City of Live Oak

10 **MEMORANDUM OF POINTS AND AUTHORITIES**

11 Pursuant to Water Code sections 13320 and 13321, Petitioner Live Oak concurrently files
12 its Petition related to Live Oak's Permit. This Stay Request satisfies the requirements of
13 section 2053 of title 23 of the California Code of Regulations.

14 **A. STATEMENT OF FACTS**

15 Live Oak owns and operates the Live Oak Wastewater Treatment Plant (WWTP). The
16 WWTP serves a total population of approximately 8500 people in the Live Oak community. The
17 WWTP currently produces equivalent to secondary treated municipal effluent. The average dry
18 weather flow capacity of the facility is 1.4 million gallons per day (MGD). Wastewater is
19 discharged from the Live Oak facility at Discharge Point No. 001 to Reclamation District 777
20 Lateral Drain No. 1 (a constructed agricultural drain), the use designation of which is at issue in
21 this Petition. Lateral Drain No. 1 flows to the East Interceptor Canal, then to Wadsworth Canal,
22 and finally to Sutter Bypass.

23 The Live Oak WWTP previously operated under Order No. R5-2004-0096 issued by the
24 Regional Water Board in 2004. (Order No. R5-2004-0096, NPDES No. CA0079022 *Waste*
25 *Discharge Requirements for City of Live Oak Wastewater Treatment Plant (2004 Permit).*) To
26 comply with the 2004 Permit, Live Oak is in the process of building major tertiary treatment plant
27 upgrades that include a lined equalization basin, an unlined emergency storage basin, and a
28 stormwater detention basin. Furthermore, the upgrade also includes nitrification and an odor
control system, secondary feed pump station, selector basin, two oxidation ditches, two secondary

1 clarifiers, cloth media filters, and an ultraviolet disinfection system. As part of the upgrade, the
2 discharge is being relocated to Reclamation District 777's constructed Lateral Drain No. 2, which
3 is just upstream of where Lateral Drain No. 2 joins and becomes part of Lateral Drain No. 1.
4 Like with Lateral Drain No. 1, Lateral Drain No. 2 is a constructed agricultural drain. The cost
5 for the upgrade to comply with the 2004 Permit is over \$20 million.

6 Live Oak meets the definition of a distressed community. (Lewis Decl., ¶ 17; see also
7 Hearing Transcript for Meeting of the Central Valley Regional Water Quality Control Board
8 (Feb. 3, 2011) (February Transcript), Exh. 1, Testimony of Mayor Baland, p. 27:20-21.) The
9 unemployment rate is over 36%, and the median household income (MHI) is only \$31,663.
10 (Lewis Decl., ¶ 17; February Transcript, Testimony of Mayor Baland, pp. 27:24-25, 28:1-4.) To
11 comply with the water quality-based effluent limitations for nitrate (as N) alone, as included in
12 Order No. R5-2011-0034, Live Oak will need to upgrade its not yet completed new tertiary
13 treatment facility, at a cost of over \$4 million. (Lewis Decl., ¶ 17; Harrison Decl., ¶ 5.) The
14 additional cost will cause household sewer rates in Live Oak to be over \$80 per month, which
15 would exceed U.S. EPA's recommended guideline that sewer rates not exceed two percent of the
16 MHI. (Lewis Decl., ¶ 20; February Transcript, Testimony of William Lewis, p. 34:5-21.)

17 The Permit classifies Lateral Drain Nos. 1 and 2 for MUN beneficial use. (Permit,
18 pp. 6, F-16.) The Permit indicates that the Basin Plan does not specifically identify beneficial
19 uses for Lateral Drain Nos. 1 and 2. (*Id.*, p. 5.) Additionally, it states that the Water Quality
20 Control Plan for the Sacramento and San Joaquin River Basins (Basin Plan) does not designate
21 the Sutter Bypass, downstream of Lateral Drain Nos. 1 and 2 for MUN use. (Permit, p. 5.) The
22 Permit applies the State Water Board's "Sources of Drinking Water" Policy, Resolution
23 No. 88-63 (Resolution 88-63), which established a state water policy that all waters, with
24 exceptions, must be considered suitable or potentially suitable for municipal and domestic use.
25 (*Ibid.*) According to the Permit, the Regional Water Board believes that it must adopt a Basin
26 Plan amendment, a resource-intensive process, to allow an exception to Resolution 88-63. (*Ibid.*)

1 **B. PROVISIONS LIVE OAK SEEKS TO STAY**

2 To avoid immediate harm to Live Oak, Live Oak requests a stay of the following
3 provisions:

4 a. The determination or finding that the MUN beneficial use applied to Reclamation
5 District 777's constructed Lateral Drain Nos. 1 and 2 through the State Water Board's Resolution
6 No. 88-63, as incorporated into the Water Quality Control Plan for the Sacramento and San
7 Joaquin River Basins (Basin Plan);

8 b. Water quality-based effluent limitations for nitrate (as N), arsenic, iron, aluminum
9 annual average based on MCL, manganese, total trihalomethanes, dibromochloromethane,
10 dichlorobromomethane, and the annual average effluent limitation for aluminum based on the
11 improper determination or finding that MUN is a beneficial use in Reclamation District 777's
12 constructed Lateral Drain Nos. 1 and 2 under the Basin Plan;

13 c. Receiving water limitations prohibiting the discharge from causing pesticides to be
14 present in concentrations that exceed maximum contaminant levels (MCLs) set forth in the
15 California Code of Regulations, title 22, division 54, chapter 15, thiobencarb to be present in
16 excess of 1.0 µg/L, and radionuclides to be present in excess of the maximum contaminant levels
17 specified in Table 64443 (MCL Radioactivity) of section 64443 of title 22 of the California Code
18 of Regulations in surface water based on the improper determination that MUN is a beneficial use
19 in Reclamation District 777's constructed Lateral Drain Nos. 1 and 2 under the Basin Plan;

20 d. Interim effluent limitations and compliance schedule provisions for arsenic and
21 total trihalomethanes, which would not be required but for the improper determination of finding
22 that MUN is a beneficial use in Reclamation District 777's constructed Lateral Drain Nos. 1 and 2
23 under the Basin Plan; and,

24 e. Amendments to the CDO to meet the final water quality-based effluent limitations
25 for nitrate (as N), iron, manganese, dibromochloromethane, and dichlorobromomethane, which
26 would not be required but for the improper determination of finding that MUN is a beneficial use
27 in Reclamation District 777's constructed Lateral Drain Nos. 1 and 2 under the Basin Plan.
28

1 **C. STANDARD FOR ISSUANCE OF A STAY**

2 Water Code section 13321(a) provides: "In the case of a review by the state board under
3 Section 13320, the state board, upon notice and hearing, if a hearing is requested, may stay in
4 whole or in part the effect of the decision and order of a regional board or of the state board."

5 The State Water Board's regulations further provide that it may grant a stay if the petitioner
6 demonstrates:

- 7 (1) [S]ubstantial harm to petitioner or to the public interest if a stay is not
8 granted;
9 (2) [A] lack of substantial harm to other interested persons and to the public
10 interest if a stay is granted, and
11 (3) [S]ubstantial questions of fact or law regarding the disputed action.

12 (Cal. Code Regs., tit. 23, § 2053(a).)

13 The request for stay must be supported by a declaration under penalty of perjury of a
14 person or persons with knowledge of the facts alleged. (Cal. Code Regs., tit. 23, § 2053(a).) As
15 demonstrated below, Live Oak's request satisfies these requirements.

16 **D. THE STATE WATER BOARD SHOULD ISSUE A STAY PENDING
17 RESOLUTION OF LIVE OAK'S PETITION FOR REVIEW**

18 On June 10, 2011, after holding the item over from the February 3, 2011 hearing, the
19 Regional Water Board reluctantly issued the Permit that is the subject of Live Oak's Petition.
20 (See February Transcript, pp. 95:12-101:14; see also Transcript of the Central Valley Regional
21 Water Quality Control Board Hearing (June 10, 2011) (June Transcript), Exh. 2, p. 144:3-13.)
22 The Regional Water Board members expressed great concern and frustration with respect to the
23 Permit's application of MUN to Lateral Drain Nos. 1 and 2 through a blanket incorporation of
24 Resolution 88-63, which results in the unreasonable application of drinking water standards to a
25 constructed agricultural drain. (See, e.g., February Transcript, statements of Board Member
26 Mulholland, p. 41:12-20 ["This strikes me as the exact stuff that drives me absolutely crazy. I
27 mean, I hate stuff like that. There's no way we're going to drink that water. So I'm going to ask
28 staff again - What are the alternatives besides saying this is drinking water? I mean, it's
crazy."]; see also June Transcript, Statements of Board Chair Hart, p. 132:4-5 ["that makes zero
common sense. Not an iota of common sense."].) The Regional Water Board members also

1 questioned whether the State Water Board's decision in Vacaville for Old Alamo Creek is
2 applicable to Lateral Drain Nos. 1 and 2, which are constructed agricultural drains. (February
3 Transcript, p. 56:14-18.) Despite their concern and reluctance to apply the MUN use to Lateral
4 Drain Nos. 1 and 2, the Regional Water Board ultimately adopted the Permit by a single vote
5 margin. (June Transcript, p. 144:3-12.)

6 The real world effect of the unreasonable application of MUN to constructed agricultural
7 drains that fall within explicit exceptions contained in Resolution 88-63, is Live Oak's need to
8 expend over \$4 million complying with the resulting effluent limitations. Because of the short
9 time period within which Live Oak must perform several tasks to come into compliance with
10 water quality-based effluent limitations (WQBELs) for nitrate (as N), and others, Live Oak would
11 need to spend a significant amount of public funds toward this end *before* the State Water Board
12 can resolve the Petition. As noted, Live Oak is already undertaking a significant \$20 million
13 upgrade to its facility to comply with the 2004 Permit. The MUN use designation results in
14 WQBELs and other Permit provisions that will strap an already severely distressed community of
15 ratepayers who will be forced to bear the cost to protect the non-existent MUN use.

16 In challenging the MUN use designation as unnecessary and unreasonable, the Petition
17 raises substantial regulatory and legal issues. On balance, Live Oak and the public—the
18 ratepayers—will incur substantial harm as a result of the unnecessary expenditure of public funds
19 if the State Water Board declines to grant this Stay Request. The minimal impact of Live Oak's
20 discharge to Lateral Drain Nos. 1 and 2 is undisputed, given the acknowledgment by the Regional
21 Water Board that the MUN use is currently non-existent, and thus no substantial harm to
22 interested persons or the public interest will result if the State Water Board grants the Stay
23 Request. (See, e.g., June Transcript, statement of Executive Officer Creedon, p. 128:6-9
24 ["I mean, the staff, we're not in general disagreement that, we need to look at this water body
25 further. And we're not in disagreement that possibly some relief can be provided through a Basin
26 Plan amendment."].) All other legitimate beneficial use designations will continue to be
27 protected.
28

1 Live Oak requests that the stay of the provisions identified in section B take effect as of
2 the date the Permit became effective. The provisions subject to the stay would remain stayed
3 until the State Water Board resolves Live Oak's Petition.

4 **1. A Stay of the MUN Use Designation for Lateral Drain Nos. 1 and 2 Is**
5 **Warranted**

6 Live Oak timely submits this request for a stay of effluent limitations, receiving water
7 limitations, and compliance schedule provisions, which are based on the MUN use designation
8 for Lateral Drain Nos. 1 and 2 as adopted by the Regional Water Board on June 10, 2011. (See *In*
9 *the Matter of the Petitions of Boeing Company* (June 21, 2006), Order WQ 2006-0007 (Boeing
10 Order), p. 5.) As subsequently demonstrated, a stay is proper and should issue in this case. Live
11 Oak and the public interest will suffer substantial harm if the State Water Board does not grant
12 the Stay Request; no substantial harm to other interested persons or the public interest would
13 result if the State Water Board grants the Stay Request; and, the dispute raises substantial
14 questions of fact or law regarding the challenged action.

15 **a. Live Oak and the Public Interest will Suffer Substantial Harm If the**
16 **State Water Board Does Not Grant Live Oak's Stay Request**

17 Live Oak and the public interest will suffer substantial harm if the State Water Board
18 does not grant Live Oak's Stay Request for the period of time pending resolution of the Petition.
19 (See Boeing Order, p. 4 ["whether a stay is appropriate must be judged in the temporal sense"].)
20 For Live Oak to comply with effluent limitations based on the MUN beneficial use designation
21 for Lateral Drain Nos. 1 and 2, excessive costs will be imposed on an already distressed
22 community.² Live Oak will be forced to bear the burden of correcting the Regional Water
23 Board's failure to properly consider and designate waterways in the Basin Plan, which included
24 a failure to properly implement the exceptions specifically contained Resolution 88-63. To wait
25

26 _____
27 ² Excessive compliance costs may justify a stay. (See *City of Manteca v. State Water Resources Control Bd.*,
28 Sacramento County Superior Court Case No. 34-2010-80000492-CU-WM-GDS (Manteca Decision), Exh. 3 [court
found that State Water Board's denial for a stay was improper because Manteca had established that compliance
costs were disproportionate to the benefit to be gained].)

1 until the State Water Board resolves the Petition would jeopardize Live Oak's ability to timely
2 comply with the Permit.

3 Live Oak estimates that the design and construction costs of a facility to comply with the
4 effluent limitation for nitrate (as N) alone, which is based on the MUN use designation for Lateral
5 Drain Nos. 1 and 2, will be \$4.1 million. (Harrison Decl., ¶ 5; Lewis Decl., ¶ 11.) Live Oak will
6 have to raise the rates of its service to pay for planning, design, and construction to upgrade the
7 WWTP facility to meet the adopted effluent limits for nitrate (as N). (Lewis Decl., ¶ 19.)³ For a
8 small city like Live Oak, \$4.1 million is a significant investment.

9 First, the current annual operating budget for the WWTP is only \$1.5 million. (Lewis
10 Decl., ¶ 15.) Any increase in capital expenditure costs, increased costs in operation or
11 maintenance, or the need for additional studies, significantly impacts such a small annual
12 operating budget. Next, Live Oak meets the definition of a "distressed community." (Lewis
13 Decl., ¶ 17.) The unemployment rate is currently over 36 percent, and the median household
14 income (MHI) is only \$31,663. (*Ibid.*) To pay for the increased cost of compliance based on the
15 MUN designation, single-family resident sewer fees will need to rise to an estimated \$80 per
16 month. (*Id.*, ¶ 19.) Considering the low MHI and anticipated sewer fees, the cost of sewer rates
17 for Live Oak residents will exceed U.S. EPA's recommended guideline that sewer rates should
18 not exceed 2 percent of the MHI. In this case, the percentage of sewer rates to MHI will be 3.1%.
19 (*Id.*, ¶ 20.) Once expended, Live Oak's limited resources are irretrievable. (*Id.*, ¶ 21.)

20 Compounding the strain of the future expenditures of public funds needed to comply with
21 the Permit, Live Oak has already spent significant resources to comply with current permit
22 requirements. The 2004 Permit represented a significant change from prior permits because it
23 was clear that the existing pond treatment system would not meet the new effluent limits.
24 Currently, Live Oak estimates that the cost to comply with the 2004 permit will exceed
25 \$20 million. (Lewis Decl., ¶ 10.) For Live Oak residents, compliance with the 2004 Permit

26
27 ³ See also February Transcript, comments of Executive Officer Creedon, p. 81:22-25 ("This is a problem, because
28 they [Live Oak] would take this permit and then move forward to try to design. What you've heard today, for them
to get this permit will cost money for them to do the design.").

1 equates to sewer rate fees of \$69 per month, which also exceeds U.S. EPA's recommended
2 guideline for affordability of sewer rates. (Lewis Decl., §§ 18 and 20.)

3 Excessive compliance costs may justify a stay. (See *In the Matter of the Petition of*
4 *International Business Machines* (Dec. 15, 1988), Order No. WQ 88-15, pp. 5-6 [State Water
5 Board implicitly indicates that IBM could be substantially prejudiced by preparing technical
6 reports and plans while the matter is under review by the State Water Board]; see also Manteca
7 Decision.) As indicated, the costs for Live Oak in complying with the Permit provisions based on
8 the MUN designation of Lateral Drain Nos. 1 and 2 are excessive considering the community's
9 size, budget, and lack of available resources. For example, to meet the time line for compliance,
10 Live Oak will need to immediately begin spending money on planning, monitoring, CEQA, and
11 other preliminary design activities. (Harrison Decl., § 6; Lewis Decl., § 14.)

12 Further, the costs of compliance for Live Oak are disproportionate to the benefit to be
13 gained. (See *In the Matter of the Petition of County of Sacramento Sanitation District No. 1*
14 (Aug. 22, 2003), Order WQO 2003-0010, p. 4; see also *In the Matter of the Petition of Pacific*
15 *Lumber Company* (May 17, 2001), Order WQ 2001-09, p. 3; see also Manteca Decision.) Live
16 Oak estimates that the cost to comply with the effluent limitation for nitrate (as N) alone will
17 exceed \$4 million. (Harrison Decl., § 5; Lewis Decl., § 11.) That cost of compliance includes
18 costs for planning, pre-design, monitoring, and CEQA compliance, which will need to be
19 expended in the more immediate future. Importantly, once expended, these costs are irretrievable
20 and will result in significant rate increases for Live Oak residents. (Lewis Decl., §§ 19, 21.)

21 With respect to the benefit to be gained, there is none. The Regional Water Board
22 members stated that it is was "crazy," or at the very least unreasonable, to protect the non-existent
23 MUN beneficial use in the constructed agricultural drains of Lateral Drain Nos. 1 and 2.
24 (February Transcript, p. 41:12-20; June Transcript, pp. 132:2-13, 133:16-19.) As clearly
25 indicated in the hearing transcripts, the alleged designation of Lateral Drain Nos. 1 and 2 as MUN
26 is apparently the result of inarticulate and unclear actions by a previous Regional Water Board
27 with little thought or consideration of future impacts. (June Transcript, statement of Executive
28 Officer Creedon, p. 137:22-25 ["And the intent was that the Regional Boards would go through

1 the effort needed to de-designate. For whatever reason, we didn't do it."].) General agreement
2 was expressed that a Basin Plan amendment de-designating MUN from Lateral Drain Nos. 1
3 and 2 should be considered, however, none could guarantee that such a Basin Plan amendment
4 could be prepared, considered, and approved by all agencies prior to the time when Live Oak
5 must comply with the effluent limitation for nitrate (as N). (June Transcript, pp. 128:6, 136:5-8.)
6 In the meantime, Live Oak must comply with the Permit and CDO as adopted, which requires
7 Live Oak to expend money immediately to ensure compliance with the June 16, 2016, deadline.
8 As the Executive Officer notes, Live Oak does not have the luxury of being able to "wait and see"
9 if a Basin Plan amendment is prepared, considered, adopted, and approved by all required
10 agencies prior to needing to comply with the Permit, and its effluent limitations based on the
11 MUN designation.⁴

12 Accordingly, the costs of over \$4 million to comply with effluent limitations based on
13 MUN are excessive in relation to the benefit to be gained to water quality. As previously stated,
14 Lateral Drain Nos. 1 and 2 have never been used for municipal drinking water supply and likely
15 will never be used for such a beneficial use in the future—certainly not during the pendency of
16 Live Oak's Petition. Furthermore, having to complete the tasks in the Permit to comply with
17 MUN use designation of Lateral Drain Nos. 1 and 2 before the State Water Board acts fully on
18 the Petition would result in substantial harm to Live Oak and the public interest because any costs
19 expended prior to the review of the Petition are irretrievable.

20 **b. If the State Water Board Grants the Stay, Neither Interested Persons**
21 **Nor the Public Interest Will Suffer Substantial Harm**

22 The evidence in the record clearly demonstrates a lack of substantial harm to interested
23 persons or to the public if Live Oak's Stay Request is granted. Specifically, Live Oak is in the
24 process of upgrading its equivalent-to-secondary treatment system to tertiary treatment. This
25 upgrade was necessitated by requirements contained in the 2004 Permit, which are carried over
26 into this Permit. Once completed, effluent from the Live Oak WWTP will meet requirements

27 _____
28 ⁴ "I can assure you a Basin Plan amendment will not be done in time for them [Live Oak] to not have to consider the
limits that are being imposed." (February Transcript, p. 82:4-6.)

1 necessary to protect other beneficial uses such as those for aquatic life, recreation, and
2 agriculture. Live Oak anticipates completing this upgrade early in 2012. (Permit, p. F-4.)
3 Compliance with the 2004 Permit has cost Live Oak over \$20 million, and residential sewer rates
4 have already risen to \$69 per month. (Lewis Decl., ¶¶ 10 and 18.)

5 The only Permit requirements that the stay would affect are those based on the MUN use
6 designation for Lateral Drain Nos. 1 and 2, which are alleged to be designated through the
7 Regional Water Board's incorporation of Resolution 88-63. Lateral Drain Nos. 1 and 2 have
8 never been and are unlikely to ever be used as a municipal drinking water supply. Regional
9 Water Board members and staff agree that Lateral Drain Nos. 1 and 2 are constructed agricultural
10 drains that likely meet the exception for such facilities in Resolution 88-63. (June Transcript,
11 p. 128:6-9.) Further, the closest downstream water body identified in the Basin Plan to which
12 Lateral Drain Nos. 1 and 2 eventually join is the Sutter Bypass, which is specifically *not*
13 designated as MUN. Regional Water Board members overall found it inappropriate to adopt a
14 Permit that includes requirements to protect the non-existent MUN use. Ultimately, the Regional
15 Water Board adopted the Permit but directed the Regional Water Board staff to proceed with
16 pursuing a Basin Plan amendment that would consider de-designating MUN from Lateral Drain
17 Nos. 1 and 2. (June Transcript, pp. 138:23-139:2.) In the meantime, Live Oak is left with no
18 option but to move forward toward compliance. Based on the evidence in the record, it is clear
19 that Lateral Drain Nos. 1 and 2 are not sources of drinking water. As such, neither interested
20 persons nor the public interest will suffer substantial harm if Live Oak receives a stay of certain
21 Permit provisions based on the MUN use designation for Lateral Drain Nos. 1 and 2 while the
22 State Water Board conducts its review.

23 **c. The Disputed Action Raises Substantial Questions of Fact or Law**

24 The Permit applies the MUN beneficial use designation to Lateral Drain Nos. 1 and 2
25 based on the Regional Water Board's incorporation of the State Water Board's Resolution 88-63
26 in the Basin Plan. Although the State Water Board's policy includes a specific exception for
27 systems designed or modified for the primary purpose of conveying or holding agricultural
28 drainage waters, the Regional Water Board concluded that a Basin Plan amendment is necessary

1 to apply the exception contained in Resolution 88-63. The Regional Water Board's determination
2 that a Basin Plan amendment is necessary to implement one of the exceptions contained in
3 Resolution 88-63 raises substantial questions of fact and law.

4 Specifically, the language of Resolution 88-63 clearly states that Regional Water Quality
5 Control Boards should designate:

6 All surface and ground waters of the State [] considered to be suitable, . . . for
7 municipal or domestic water supply . . . with the exception of: . . . 2. Surface
8 waters where: . . . b. [t]he water is in systems designed or modified for the primary
9 purpose of conveying or holding agricultural drainage waters, provided that the
10 discharge from such systems is monitored to assure compliance with all relevant
11 water quality objectives as required by the Regional Boards. (Resolution 88-63,
12 pp. 1-2.)

13 In other words, the State Water Board specifically directed the Regional Water Quality
14 Control Boards to so designate, except for those waters of the state that fell within the exceptions
15 of the policy.

16 Further, in a memorandum to Regional Water Board staff in 1994, Senior Staff Counsel
17 from the State Water Board advised Regional Water Board staff that constructed agricultural
18 drains, "and certain other collection and treatment systems which are described in the Policy," are
19 excepted from the MUN designation via Resolution 88-63, as incorporated into the Basin Plan.
20 (Memorandum to Dennis Westcot from Elizabeth Miller Jennings (Mar. 3, 1994), Exh. 4, p. 2.)
21 The memorandum specifically states, "[t]he designation of beneficial uses in constructed
22 agricultural drains is not covered by either the tributary footnote or the Sources of Drinking Water
23 Policy." (*Id.*, p. 3.)

24 The State Water Board's decision in Order WQO 2002-0015, "In the Matter of Review on
25 Own Motion . . . For Vacaville's Easterly Wastewater Treatment Plant" (Oct. 3, 2002) (Vacaville
26 Order), does not contradict the conclusions expressed in the 1994 memorandum. In the Vacaville
27 Order, the State Water Board found Old Alamo Creek to be designated as MUN through
28 Resolution 88-63; however, the State Water Board also found that none of the exception
categories applied to Old Alamo Creek. (Vacaville Order, p. 28.) Specifically, Old Alamo Creek
was not designed or modified to be an agricultural drain. (*Ibid.*) Thus, the State Water Board's
Vacaville Order does not opine on the issue now presented: whether the Basin Plan designates

1 MUN for constructed agricultural drains that *do* fit within the exception language of
2 Resolution 88-63.

3 Because the language of Resolution 88-63 provided specific exclusions for constructed
4 agricultural drains, the Regional Water Board's incorporation by reference thereof could not have
5 designated such drains as MUN because they were not in the class of water bodies to be
6 considered for designation.

7 In the alternative, if the Regional Water Board's incorporation by reference is found to
8 include the exceptions and the types of water bodies for which the exceptions would apply, then
9 the Regional Water Board's incorporation of Resolution 88-63 must have included the exceptions
10 as self-executing provisions. In that case, Basin Plan amendments are not required to apply the
11 exceptions. The Basin Plan specifically states:

12 Water Bodies within the basins that do not have beneficial uses designated in [the
13 Basin Plan] are assigned MUN designations in accordance with the provisions of
14 State Water Board Resolution No. 88-63 which is, by reference, a part of this
15 Basin Plan. . . . These MUN designations in no way affect the presence or absence
of other beneficial use designations in these water bodies. (Basin Plan, p. II-2.01.)

16 In the Vacaville Order, the State Water Board concluded that the Regional Water Board's
17 incorporation of Resolution 88-63, and in particular the "in accordance" language, meant that, in
18 the Central Valley Basin Plan, the Regional Water Board actually assigned the MUN beneficial
19 use to all unidentified water bodies. (Vacaville Order, p. 27.) As discussed previously, the
20 Vacaville Order does not specifically state that the Regional Water Board's blanket designation
21 included water bodies that fell within the exceptions. If the Vacaville Order were given this
22 reading, both the Regional Water Board's interpretation and the State Water Board's conclusion
23 fail to interpret the Basin Plan according to the accepted rules of construction. A Basin Plan is a
24 quasi-legislative regulation (*State Water Resources Control Bd. v. Office of Administrative Law*
25 (1993) 12 Cal.App.4th 697, 701-702) and, like any other regulation, must be interpreted
26 according to the standard rules of construction. Among those rules is the rule promoting an
27 interpretation that will give each word meaning and not render language superfluous.
28

1 “Significance should be given, if possible, to every word of an act. [Citations omitted.]
2 Conversely, a construction that renders a word surplusage should be avoided. [Citations
3 omitted.]” (*Delaney v. Superior Court (Kopetman)* (1990) 50 Cal.3d 785, 798-799.)

4 The relevant Basin Plan language consists of four paragraphs that must be read
5 collectively and harmonized. The first paragraph sets up the general application of beneficial use
6 designations through the tributary statement, but qualifies that statement’s application by stating
7 that the Regional Water Board’s judgment will be applied where the beneficial uses may not be
8 applicable. The second paragraph further explains that it is impractical to list every water body
9 and that “[f]or unidentified water bodies, the beneficial uses will be evaluated on a case-by-case
10 basis.” (Basin Plan, p. II-2.00.) Next, the language references the Regional Water Board’s
11 incorporation of Resolution 88-63 and assigns MUN beneficial uses “in accordance” with
12 Resolution 88-63. Finally, the last paragraph states, “[i]n making any exemptions to the
13 beneficial use designation of MUN, the Regional Board will apply the exceptions listed in
14 Resolution 88-63 [].” (Basin Plan, p. II-2.01.)

15 This language plainly establishes the Basin Plan’s intended process for designating
16 beneficial uses (e.g., “MUN” for drinking-water supplies) for water bodies not specifically
17 identified in the Basin Plan. This language explicitly requires the Regional Water Board to
18 evaluate the application of beneficial uses on a case-by-case basis for undesignated water bodies
19 and designate unidentified water bodies with the “MUN” beneficial use only in accordance with
20 Resolution 88-63. (Basin Plan, p. II 2.00.) Resolution 88-63, as adopted by the State Water
21 Board, directs the regional boards to consider all surface waters to be suitable for the MUN
22 beneficial use except where, “[t]he water is in systems designed or modified for the primary
23 purpose of conveying or holding agricultural drainage waters, provided that the discharge from
24 such systems is monitored to assure compliance with all relevant water quality objectives as
25 required by the Regional Boards.” (Resolution 88-63, p. 2, other exceptions omitted.) In
26 adopting Resolution 88-63, the State Water Board thus expressly recognized the problem later
27 created by the Vacaville Order and expressly directed the regional boards not to apply the
28 “MUN” beneficial use to agricultural drainage facilities. To comply with this direction, the

1 Regional Water Board explicitly incorporated language into the Basin Plan that states, “the
2 Regional Board will apply the exceptions listed in Resolution 88-63.” (Basin Plan, p. II-2.01.)

3 The Permit, however, ignores the impact and significance of this language. In fact, the
4 State Water Board’s Vacaville Order fails to discuss at all the application and impact of the
5 specific Basin Plan language that states the Regional Water Board will apply the exceptions from
6 Resolution 88-63. The Permit also fails to recognize that the literal reading of “in accordance”
7 with Resolution 88-63 means that the exceptions in the policy were incorporated into the Basin
8 Plan and thus require that the Regional Water Board not assign the “MUN” beneficial use
9 designation to water bodies that fit within Resolution 88-63’s exceptions. The Regional Water
10 Board’s interpretation of the Basin Plan thus renders those exceptions surplusage in contradiction
11 of standard rules of construction.

12 As applied in the Permit, the Regional Water Board’s interpretation of the Basin Plan also
13 contradicts the rule of construction that interpretations of laws and rules not create absurd results.
14 (See, e.g., *People v. Valtakis* (2003) 105 Cal.App.4th 1066, 1076.) This consideration applies
15 particularly where an interpretation of law could cause institutions to be overburdened to the
16 point of breaking down. (See *City of Orange v. San Diego County Employees Retirement Assn.*
17 (2002) 103 Cal.App.4th 45, 55.) Based on the Regional Water Board’s interpretation of the Basin
18 Plan as applying the “MUN” beneficial use designation to all Central Valley water bodies, Live
19 Oak must now either pursue a Basin Plan amendment to apply the exception specifically
20 identified in the State Water Board’s policy, or install new treatment that will cost Live Oak’s
21 ratepayers millions of dollars on top of the \$20 million already spent to comply with the
22 2004 Permit. The Regional Water Board cannot justify the enormous burden that this approach
23 would foist on Live Oak and its ratepayers in light of the nature of the facilities in question and
24 the fact that the State Water Board (as evinced by its express words in Resolution 88-63) never
25 intended for such facilities to be regulated as a drinking water source.

26 The Permit relies on language in the Implementation Chapter of the Basin Plan to support
27 the premise that the Regional Water Board must adopt a Basin Plan amendment to apply an
28 exception that is specifically identified in Resolution 88-63. (Permit, p. F-16; Basin Plan,

1 p. IV-9.00.) However, the language identified (and as included in the Implementation Chapter of
2 the Basin Plan) directly contradicts Resolution 88-63 and is therefore invalid as adopted into the
3 Basin Plan and as applied here. As indicated previously, the Regional Water Board was required
4 by Resolution 88-63 to identify water bodies that are suitable for municipal use except for those
5 that fell within the categories identified in the Resolution. Thus, the Regional Water Board's
6 blanket designation through its incorporation-by-reference was specifically directed to not include
7 water bodies that fit within the exceptions. In fact, the administrative record for the Basin Plan
8 indicates that the Regional Water Board did follow this direction when it first incorporated
9 Resolution 88-63 into the Basin Plan. However, as discussed below, the language was changed in
10 1994 for no specified reason or purpose.

11 When the Regional Water Board first adopted Resolution 88-63 into the Basin Plan, the
12 language in the Implementation Chapter stated as follows: "This policy was adopted on 19 May
13 1988. It specifies which ground and surface waters are considered to be suitable or potentially
14 suitable for the beneficial use of water supply (MUN). It allows the Regional Board some
15 discretion in making MUN determinations." (*Water Quality Control Plan for the Sacramento
16 and San Joaquin River Basins* (2d ed., 3rd Printing, 1992), Exh. 5, p. IV-7.) This original
17 language clearly defers to Resolution 88-63 for determining what waters are suitable or
18 potentially suitable for MUN. Thus, the exceptions and their implementation thereof were part
19 of the Regional Water Board's incorporation of Resolution 88-63 into the Basin Plan.

20 Later, in 1994, the Regional Water Board amended the Basin Plan to include the language
21 that currently exists and is referred to in the Permit. (Permit, pp. 5, F-16.) However, the
22 administrative record for the 1994 amendments provides no rationale or basis for the changes
23 made in 1994. It merely states that, "[n]ew and/or updated summary paragraphs are provided for
24 the following: 1. State Water Board Resolution No. 88-63, Sources of Drinking Water"
25 (*Staff Report Amendment of the Water Quality Control Plan for Sacramento River Basin,
26 Sacramento-San Joaquin Delta Basin, and the San Joaquin River Basin* (Oct. 11, 1994) (Staff
27 Report), Exh. 6, p. 7.) In the 74-page Staff Report, there is no further mention of the new
28 language except with respect to its application to the designation of beneficial uses for

1 groundwater. On this point, the Staff Report merely states that “[w]here a discharger chooses to
2 seek exemption from one or more beneficial use designation based on the exception criteria,
3 development of the case for consideration by the Regional Water Board will involve the
4 expenditure of both private and state resources.” (*Id.*, p. 28.) In its discussion with respect to
5 “one or more” beneficial use designations, it references the fact that the 1994 amendments
6 provided blanket designations for agricultural and industrial supply that did not previously apply
7 to unidentified groundwater basins. The Staff Report provides no further explanation as to why
8 the language proposed in the Implementation Chapter was proposed and for what purpose.
9 Without support and appropriate findings, the language cannot implement a substantive change to
10 the original language, which results in the need for a formal Basin Plan amendment where one
11 was not previously required. Thus, the changes to the Implementation Chapter in 1994 with
12 respect to Resolution 88-63 are invalid and cannot be used as the basis for requiring a Basin Plan
13 amendment today.

14 In sum, the MUN designation is inappropriately applied to the constructed agricultural
15 drain, Lateral Drain Nos. 1 and 2, and all effluent limitations, receiving water limitations, and
16 compliance schedule provisions derived from this designation are invalid. Thus, all such Permit
17 provisions should be removed. However, contrary to the language of Resolution 88-63 and the
18 Regional Water Board’s incorporation thereof, the Regional Water Board now takes the position
19 that a Basin Plan amendment is required to apply the exception to otherwise “unidentified” water
20 bodies in the Basin Plan. Accordingly, Live Oak’s Petition raises substantial questions of fact
21 and law.

22 ///

23 ///

24 ///

25 ///

26 ///

27 ///

28 ///

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

E. CONCLUSION

This Stay Request demonstrates that the action disputed in the Petition raises substantial questions of fact or law. This Stay Request also demonstrates that a stay of the challenged MUN use designation will not cause substantial harm to interested persons or the public. However, a lack of a stay will cause Live Oak substantial harm in the form of an expenditure of scarce resources and imposition of rate increases. Accordingly, Live Oak respectfully requests that the State Water Board stay the Permit provisions based on MUN for Lateral Drain Nos. 1 and 2.

SOMACH SIMMONS & DUNN
A Professional Corporation

DATED: July 11, 2011

By: 
Theresa A. Dunham
Attorneys for Petitioner City of Live Oak

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MEETING
STATE OF CALIFORNIA
CENTRAL VALLEY REGIONAL
WATER QUALITY CONTROL BOARD

CENTRAL VALLEY REGIONAL
WATER QUALITY CONTROL BOARD
11020 SUN CENTER DRIVE, #200
SACRAMENTO, CALIFORNIA

THURSDAY, FEBRUARY 3, 2011

 COPY

TIFFANY C. KRAFT, CSR
CERTIFIED SHORTHAND REPORTER
LICENSE NUMBER 12277

CALIFORNIA REPORTING, LLC
52 LONGWOOD DRIVE
SAN RAFAEL, CA 94901
(415) 457-4417

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

APPEARANCES CONTINUED

ALSO PRESENT

Mayor Gary Baland, City of Live Oak

Ms. Bobbi Larson, firm of Somach Simmons & Dunn

Mr. William Lewis, City of Live Oak

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

INDEX

PAGE

Staff Presentation	6
City of Live Oak Presentation	26
Closing Statement by City of Live Oak	87
Closing Statement by staff	89
Motion	102
Vote	107
Adjournment	109
Reporter's Certificate	110

PROCEEDINGS

1
2 CHAIRPERSON HART: Moving on to Agenda Item 13,
3 this is the time and place for a public hearing to
4 consider renewal of an NPDES permit and adoption of a
5 Cease and Desist Order for the City of Live Oak Wastewater
6 Treatment Plant in Sutter County.

7 This hearing will be conducted in accordance with
8 the meeting procedures published with the meeting agenda
9 and with the applicable notice of public hearing.

10 At this time, evidence should be introduced on
11 whether the proposed action should be taken.

12 All persons expecting to testify, please stand at
13 this time, raise your right hand, and take the following
14 oath.

15 (Whereupon all prospective witnesses were sworn.)

16 CHAIRPERSON HART: Thank you all for testifying.
17 You can sit down now.

18 I'm going to finish the meeting procedures and
19 then we're going to take a very, very quick break.

20 The designated parties in this item are the City
21 of Live Oak and CSPA. The total time allowed for
22 testimony and cross-examination is as follows: Regional
23 Board staff will have 30 minutes. City of Live Oak will
24 have 20 minutes. CSPA will have ten minutes, although I
25 don't see a representative here. All other parties are

1 interested persons and shall limit their testimony to
2 three minutes. A timer will be used.

3 If everyone would state their name, affiliation,
4 and whether they've taken the oath before testifying, that
5 would be appreciated.

6 And before we go to legal counsel to discuss
7 issues, we are going to take the break for five minutes.

8 (Thereupon a recess was taken.)

9 CHAIRPERSON HART: Coming back into session here.
10 Dave, do we have any legal issues?

11 STAFF COUNSEL COUPE: Nothing at this time. I'll
12 have something later on.

13 CHAIRPERSON HART: We're going to take the
14 testimony.

15 (Thereupon an overhead presentation was
16 presented as follows.)

17 NPDES PROGRAM STAFF ENGINEER KIRN: Good
18 afternoon, Chair Hart and member of the Board. My name is
19 David Kirn. I'm a Staff Engineer for the NPDES Program
20 here in Sacramento office. And I have taken the oath.

21 The next item for your consideration is an NPDES
22 permit renewal and an amendment to a Cease and Desist
23 Order for the City of Live Oak Wastewater Treatment Plant.

24 --o0o--

25 NPDES PROGRAM STAFF ENGINEER KIRN: The City of

1 Live Oak, as shown circled in red, is in Sutter County and
2 about 52 miles north of city of Sacramento.

3 --o0o--

4 NPDES PROGRAM STAFF ENGINEER KIRN: Here is an
5 aerial view showing the 1.4 million gallon per day
6 treatment facility outlined in orange in relation to the
7 City of Live Oak in the northeast corner of the photo.

8 Currently, the effluent discharge is to lateral
9 Drain Number 1 about approximately where the red dot is.
10 And the new discharge location will be lateral Drain
11 Number 2 approximately in this area. And then lateral
12 Drain Number 2 actually is tributary to Drain Number 2.
13 The City owns and operates the treatment facility. And as
14 the photo indicates, the facility is predominantly
15 surrounded by agricultural land.

16 The city serves a population of 8,000. Live Oak
17 is a disadvantaged community with a median income of
18 \$32,000. The single family resident sewer fees are
19 currently \$55 per month. And on July 1st of this year,
20 they will go up to \$60 per month and then 69 the year
21 after that.

22 --o0o--

23 NPDES PROGRAM STAFF ENGINEER KIRN: The Live Oak
24 facility is currently a pond system that provides
25 secondary level treatment. The existing permit requires

1 the city to upgrade to a territory facility by April 2009.
2 However, a Cease and Desist Order was adopted in 2009 to
3 allow the city more time to evaluate and decide between
4 regionalization project and an on-site plant upgrade
5 project in order to comply with the waste discharger
6 requirement.

7 Regionalization was evaluated. However, the City
8 chose to upgrade the facility when they were able to get a
9 \$10 million stimulus grant for their \$20 million project.
10 The new facility is under construction and is expected to
11 be completed in early 2013. The tertiary facility
12 represents a substantial improvement and major upgrade as
13 compared to the existing facility.

14 --o0o--

15 NPDES PROGRAM STAFF ENGINEER KIRN: Next for
16 salinity, electrical conductivity, or EC, the current
17 average annual EC concentrations is 915 micromhos per
18 centimeter. The proposed EC effluent limit is 1100
19 micromhos per centimeter developed using over a thousand
20 effluent samples.

21 This is a performance-based final effluent limit
22 that will act as a cap until additional studies can be
23 completed. The proposed permit requires the city to
24 implement a salinity evaluation and minimization plan and
25 complete a salinity EC site-specific study if necessary to

1 protect the beneficial uses of the receiving water.

2 --o0o--

3 NPDES PROGRAM STAFF ENGINEER KIRN: Now I will
4 highlight the proposed permit in your agenda package.

5 Some noteworthy changes from the existing permit
6 are new and more stringent effluent limits for arsenic,
7 nitrate, iron, manganese, chlorine byproducts, ammonia,
8 copper, and cadmium.

9 The City is not able to immediately comply with
10 many of the new limits, therefore, we are also proposing
11 compliance schedules for these constituents.

12 --o0o--

13 NPDES PROGRAM STAFF ENGINEER KIRN: During the
14 public comment period, we received comments from the City,
15 Central Valley Clean Water Association, and the California
16 Sportsfishing Protection Alliance, or CSPA. All comments
17 have been addressed, and responses are included in the
18 agenda package.

19 --o0o--

20 NPDES PROGRAM STAFF ENGINEER KIRN: This slide
21 lists the major issues I will be discussing in my
22 presentation regarding the NPDES permit renewal.

23 First, the application of the municipal and
24 domestic supply, MUN, or mun beneficial use, also arsenic
25 and total trihalomethanes, especially the effluent limits

1 and compliance schedules, copper and cadmium, and finally
2 the aluminum effluent limits.

3 And now I will hand the presentation over to
4 Diana Messina to give some background and details on the
5 MUN beneficial use.

6 ---o0o--

7 NPDES PROGRAM MANAGER MESSINA: Good afternoon,
8 Board members. I'm Diana Messina, NPDES Program Manager.
9 And I have taken the oath.

10 I'm stepping in to explain this first issue,
11 which is why we are bringing forth the permit renewal to
12 you that contains lots of new effluent limitations for the
13 purpose of protecting the municipal and domestic water
14 supply of an agricultural ditch. We are finding that this
15 issue spans over several permits, not just the Live Oak
16 permit. And it's worth a few minutes to explain it to
17 you.

18 First with a little background. I'm not an
19 artist. So I have a stick figure here that represents the
20 City of Live Oak, the ag canals, and the downstream water
21 bodies.

22 So looking at this figure, we have the discharge
23 point here with the green dot. The existing permit was
24 adopted back in 2004. And it was adopted implementing the
25 tributary role from our Basin Plan. So basically, the

1 tributary role is when you go downstream to the nearest
2 water body that has uses designated to it and you bring
3 those uses upstream to the water bodies that are not --
4 don't have uses specific in the Basin Plan.

5 So in this situation, it's a Sutter Bypass that
6 has designated uses in the Basin Plan. So as this other
7 bypass is specifically named to not have a municipal and
8 domestic water supply use, we applied that same what we
9 call non-MUN designation to the upstream ag ditches.
10 Therefore, the existing permit did not have effluent
11 limitations to protect the municipal water supply.

12 This is incorrect. And the reason it's incorrect
13 is because we have incorporated the statewide drinking
14 water, which is Resolution 88-63, into our Basin Plan.
15 And by doing that with a blanket approach, it places the
16 MUN use on all water bodies that have not been
17 specifically identified to not have MUN. Therefore, these
18 tributaries in this instance must be protected for
19 municipal and domestic water supply. Because we are
20 catching this error now, the proposed permit has a bunch
21 of new limits.

22 ---o0o---

23 NPDES PROGRAM MANAGER MESSINA: The reason this
24 is an issue is because of the high costs, not only for
25 Live Oak, but for other small communities to make further

1 drinking water policy does have exceptions within the
2 policy. And one of the exceptions is 2B, which addresses
3 agricultural conveyance systems. And you'll see here a
4 picture of the ag ditch that Live Oak does discharge into.
5 And it's clearly an ag ditch. Unfortunately, we cannot
6 implement that exception through an NPDES permit action.
7 It must be implemented through a Basin Plan amendment
8 process.

9 And now I'm going to let David Couple explain
10 that legal component.

11 STAFF COUNSEL COUPE: Just a couple of quick
12 points to amplify on Ms. Messina's presentation.

13 As I think she mentioned earlier, when State
14 Board adopted 88-63, the sources of drinking water policy,
15 it essentially established a municipal beneficial use for
16 all unidentified water bodies, whether that's natural or
17 not, within the state.

18 Now, when it came time for the Regional Board to
19 implement 88-63 within its Basin Plan, in 1989, it did so
20 as a blanket municipal use such that it essentially said
21 for all unidentified water bodies within the region, we're
22 going to specifically attribute a municipal use to them,
23 and again, regardless of whether that water body is
24 natural or not natural. You very well may hear from the
25 discharger today pertaining to the -- whether, in fact,

1 the State Board or the Regional Board in implementing
2 88-63, whether there was, in fact, a legal basis to do so.
3 Quite frankly, it's a very old issue that I think goes
4 back at least as far as the 2002 Vacaville State Board
5 decision, which is currently in litigation. And we'll
6 have to see how that ultimately works out.

7 But at least as far as we're concerned, we firmly
8 believe that 88-63 was properly promulgated by State Board
9 and implemented by the Regional Board into its Basin Plan.
10 There may be a subsequent or subsidiary argument the
11 discharger may raise to the extent that there was an OAL
12 opinion or determination I think arising roughly around
13 the time that either State Board adopted 88-63 or when the
14 Regional Board implemented 88-63 and its Basin Plan saying
15 something to the effect that it had some issues or
16 concerns and that they thought that those particular --
17 any Basin Plan amendments themselves would have to go
18 through a specific rulemaking process.

19 As a result of that dispute, there was some
20 litigation. I wasn't back in 2002. But from the record,
21 as I can reconstruct it, what ultimately happened is that
22 there was some legislation that was passed that
23 specifically exempted the Office of Administrative Law's
24 ability to provide review of Basin Plan amendments prior
25 to I believe it's June of 1992 and that didn't provide for

1 an abbreviated process post June of 1992. And I think as
2 we may have referenced in our response to comments,
3 because State Board adopted 88-63 prior to June of 1992,
4 and because the Regional Board implemented 88-63 within
5 its Basin Plan prior to 1992, that we think that the
6 implementation of 88-63 and into the Regional Board's
7 Basin Plan is full legal force and effect.

8 Did we follow all that?

9 CHAIRPERSON HART: We did.

10 STAFF COUNSEL COUPE: Thank you.

11 CHAIRPERSON HART: Sounds like a little bit of
12 legal trickery.

13 BOARD MEMBER LONGLEY: That was from an attorney,
14 too, David.

15 --o0o--

16 NPDES PROGRAM STAFF ENGINEER KIRN: The next
17 issue to discuss is the arsenic and total trihalomethanes,
18 or THM. The tentative permit issued for public review
19 included a monthly effluent limit for arsenic and an
20 annual average effluent limit for total trihalomethanes.
21 These are regulated as CTR constituents. However, the
22 criteria is based on drinking water standards.

23 Of note, total trihalomethanes is considered a
24 CTR constituent because it is made up of the four
25 individual CTR constituents shown on this slide.

1 The proposed permit in your agenda package
2 corrects the effluent limits and includes monthly and
3 daily effluent limits for arsenic and total
4 trihalomethanes because the SIP requires CTR constituents
5 to be regulated as such.

6 --o0o--

7 NPDES PROGRAM STAFF ENGINEER KIRN: The City and
8 CVCWA commented that final effluent limitations based on
9 state drinking water standards should be regulated as
10 annual averages. We do not concur. Arsenic and total
11 trihalomethanes are CTR constituents and the SIP requires
12 us to regulate CTR constituents with monthly and daily
13 effluent limits.

14 --o0o--

15 NPDES PROGRAM STAFF ENGINEER KIRN: The City
16 cannot immediately comply with the effluent limits,
17 therefore the agenda package included compliance schedules
18 for arsenic and total trihalomethanes in the proposed
19 Cease and Desist Order.

20 The City and CVCWA commented that since the
21 effluent limits are based on the State drinking water
22 standards promulgated after September 1995, the criterion
23 for arsenic was adopted in 2008 and the trihalomethanes
24 were adopted in 2006. Therefore, according to the State's
25 compliance schedule policy, the effluent limits are new

1 and/or more stringent and can be contained in the NPDES
2 permit.

3 We concur these compliance schedules can be in
4 the permit. Moving the compliance schedules for arsenic
5 and total trihalomethanes from the proposed Cease and
6 Desist Order to the proposed permit is included with the
7 late revisions provided to you.

8 --oOo--

9 NPDES PROGRAM STAFF ENGINEER KIRN: The next
10 issue and another comment from the City is regarding
11 effluent limits for California toxic rule, or CTR,
12 hardness based metals, copper, and cadmium. The City
13 comments that copper and cadmium effluent limits are
14 overly stringent because we did not use the Emmerich study
15 to establish the limit.

16 --oOo--

17 NPDES PROGRAM STAFF ENGINEER KIRN: We commonly
18 use the Emmerich study when establishing effluent limits
19 for CTR hardness dependent metals. The Emmerich study was
20 used for other CTR metals in the proposed permit, but not
21 for copper and cadmium. The Emmerich study was not used
22 because the receiving water has been shown at times to be
23 out of compliance with the criteria upstream of the
24 discharge. It was our understanding that a limiting
25 condition of the Emmerich study was that the receiving

1 water needed to be in compliance with the criteria.

2 Staff met with Dr. Emmerich, and we now
3 understand that the receiving water compliance is not a
4 condition of the study. The study demonstrates that the
5 effluent limits based on the procedures in the study
6 result in a discharge that does not cause or contribute to
7 toxicity in the receiving water. Therefore, staff agrees
8 with the City that the Emmerich study is appropriate for
9 copper and cadmium.

10 --o0o--

11 NPDES PROGRAM STAFF ENGINEER KIRN: These are the
12 late revisions proposed to modify the copper and cadmium
13 effluent limits and to make associated changes in the fact
14 sheet.

15 This table shows the proposed changes to the
16 final limits for copper and cadmium. With these proposed
17 changes, there is no longer a compliance issue for copper.
18 Therefore, the late revisions also remove the copper
19 compliance schedule from the Cease and Desist Order.

20 --o0o--

21 NPDES PROGRAM STAFF ENGINEER KIRN: The next
22 issue is the aluminum effluent limits. CSPA commented
23 that we did not properly apply the federal regulations
24 since we didn't use the U.S. EPA recommended chronic
25 criterion of 87 micrograms per liter for aluminum to

1 develop the proposed effluent limitations.

2 --o0o--

3 --o0o--

4 NPDES PROGRAM STAFF ENGINEER KIRN: We do not
5 concur. Aluminum is not a CTR constituent, so the Basin
6 Plan's narrative toxicity objective is applied for
7 aluminum to protect the freshwater aquatic life beneficial
8 use.

9 US EPA's recommended criteria is used to
10 interpret the narrative toxicity objective, which includes
11 a chronic four-day average criterion of 87 micrograms per
12 liter and an acute one-hour average criterion of 750
13 micrograms per liter.

14 --o0o--

15 --o0o--

16 NPDES PROGRAM MANAGER MESSINA: EPA's chronic
17 criterion was developed using laboratory waters with low
18 hardness and low PM. Monitoring data demonstrates that
19 these conditions are not similar to those in the receiving
20 water for Live Oak. EPA has recognized that there are
21 high quality waters that do not show toxicity at higher
22 concentrations of aluminum and that specific studies are
23 recommended to determine the appropriate chronic
24 criterion. For this discharge, we considered other
25 available studies with similar water quality

1 characteristics as the receiving water.

2 --o0o--

3 --o0o--

4 NPDES PROGRAM STAFF ENGINEER KIRN: We evaluated
5 the studies done by the City of Modesto, the City of
6 Manteca, as well as the Arid West Water Quality Research
7 Project technical report. These other studies
8 demonstrated that the chronic criterion of 87 micrograms
9 per liter was overly stringent and it was not appropriate
10 to use the chronic criterion to interpret the narrative
11 toxicity objective.

12 In this case, the acute criterion of 750
13 micrograms per liter is the applicable criterion. The
14 proposed effluent limits for aluminum properly implement
15 the federal regulation.

16 And now Diana Messina will again speak.

17 CHAIRPERSON HART: David, just quick before you
18 go back, I presume the use the Modesto, Manteca, and Arid
19 West studies because those water bodies are, if not
20 identical, substantially similar to the water body in
21 question.

22 NPDES PROGRAM STAFF ENGINEER KIRN: Exactly.

23 CHAIRPERSON HART: And we have that documented.

24 --o0o--

25 NPDES PROGRAM MANAGER MESSINA: Yes, Diana

1 Messina here.

2 And, Kate, our fact sheet clearly shows that
3 those water bodies have similar conditions.

4 CHAIRPERSON HART: I think I read about that.

5 NPDES PROGRAM MANAGER MESSINA: Before I start
6 with these late revisions that have been provided to you,
7 I just want to express that we have heard you very clearly
8 when you tell us as staff that you do not like late
9 revisions. I think that's why I'm up at the podium and
10 not David.

11 BOARD MEMBER LONGLEY: In other words, you want
12 to irritate us?

13 NPDES PROGRAM MANAGER MESSINA: No. Especially
14 you, Dr. Longley.

15 These late revisions have resulted just because
16 we have continued on having ongoing meetings at the
17 request of the discharger even after the agenda package
18 was issued. And so there have been lots of issues that we
19 have been able to come to agreement with and I believe are
20 no longer contested by the discharger. Your consideration
21 of these late revisions is very important to the small
22 community, and that's why we're bringing them to you, even
23 though they're quite late.

24 So I'm going to start going down the list. I
25 just want to note I think we all know how detailed and

1 lengthy NPDES permits are. And so even though you have 21
2 pages of late revisions, it all just boils down to kind of
3 two changes that are -- I hate to use the word
4 significant, but significant. And then the last three are
5 actually minor.

6 So I'm going to start with copper and cadmium.
7 There's 11 of these late revision items that address the
8 fact that we are now accepting the Emmerich study, the
9 2006 study, and we're applying it to this water body. And
10 that changes the hardness that we're using to develop the
11 criteria for copper and cadmium. So that's that hardness
12 dependent metals criteria. So as the criteria changes,
13 the effluent limits change, as Dave just showed you in the
14 previous slide.

15 And now that the discharger is able to comply
16 with the copper limit, that triggers even more revisions
17 as we have to change findings and compliance schedules.
18 So we're basically removing the copper compliance schedule
19 out of the proposed enforcement order amendment.

20 --oOo--

21 NPDES PROGRAM MANAGER MESSINA: So number two, we
22 have 15 additional items that pertain to moving the
23 compliance schedules for arsenic and total trihalomethanes
24 out of the enforcement order and into the permit. And so
25 I hope it was clear to you through David's discussion,

1 even though these are CTR constituents, David Coupe has
2 helped us identify that because the criteria that we base
3 these limits on were recently promulgated that we are able
4 to put them in the permit. So as we delete and edit
5 findings and milestone schedules and so forth out of the
6 CDO and place them in the permit, it just triggers a lot
7 of volume when it comes to late revisions.

8 Third item is very small, but I think very
9 significant, and that is regarding aluminum. We just
10 added further clarification in the fact sheet. We did not
11 change the criteria or the effluent limits. But the
12 clarification we provided was to add further information
13 on how this receiving water body has similar conditions to
14 those in the arid west report and studies performed by
15 other dischargers.

16 We have one more lonely little revision that
17 basically clarifies a finding in the Cease and Desist
18 Order for if this discharger does choose to pursue a Basin
19 Plan amendment in order to address this MUN issue in
20 compliance with those effluent limits.

21 And then lastly, we just have I think it's five
22 revisions which address minor corrections. Those were
23 small corrections for very obvious reasons and just
24 further clarification.

25 --o0o--

1 NPDES PROGRAM MANAGER MESSINA: So to be
2 thorough, we also revised the staff response to comments
3 to correspond with these late revisions.

4 --oOo--

5 NPDES PROGRAM MANAGER MESSINA: So with that, we
6 recommend that you adopt the proposed permit renewal with
7 the late revisions and you adopt the proposed Cease and
8 Desist Order amendment with the late revisions.

9 So at this time, I'd like to enter several things
10 into the record. That is the staff presentation, the
11 agenda package, the late revisions, the revised response
12 to comments, and the case files for this facility into the
13 record.

14 Thank you.

15 CHAIRPERSON HART: Thank you, Diana.

16 Yes, Carl and then Dan.

17 BOARD MEMBER LONGLEY: I think you did a great
18 job. It certainly will make this much more affordable, if
19 you will, by the City and moving things out of the cleanup
20 and abatement order -- or Cease and Desist Order and
21 moving it into the discharge permit I think was a wise
22 move. The fact you were able to do that is not a problem.

23 NPDES PROGRAM MANAGER MESSINA: And still be
24 alive up here at the podium.

25 BOARD MEMBER LONGLEY: You're very much alive.

1 David made it very clear, that was anticipated with his
2 presentation. And I thought that was an extremely good
3 presentation.

4 CHAIRPERSON HART: Yes, Dan.

5 BOARD MEMBER ODENWELLER: I commend the staff on
6 their handling of the presentation. When I got the binder
7 with the half of it full of this particular item and then
8 got the comment list, the revisions list, I thought we
9 were going to be here until midnight. But this looks like
10 we've done much better. I'll move approval.

11 CHAIRPERSON HART: You can't do that yet. We're
12 not even close to done, Dan. I'm sorry.

13 Do we have any questions or comments for Diana or
14 Dave right now?

15 If not, is there any-cross examination of our
16 staff? No.

17 Seeing none right now, we will take the testimony
18 of Live Oak at this time.

19 EXECUTIVE OFFICER CREEDON: Ms. Hart, if I could
20 just clarify for staff. On Dr. Emmerich, we use that
21 study quite a bit in our permit development, and that's
22 fine. But it's not regulatory and not policy. So it
23 can't be cited in our reports or anything as if we are
24 bound to the Emmerich. And I'm afraid a little bit came
25 across that way, and I just want to make that clear,

1 especially for those in the audience that that is not a
2 regulation. We're not bound to that. And we can choose
3 not to implement if it's not appropriate. So I just want
4 to make that clear for the Board.

5 CHAIRPERSON HART: I'm presuming staff feels it's
6 appropriate in this instance.

7 EXECUTIVE OFFICER CREEDON: Yes, it is. And
8 we've documented that it is. But I just want to make that
9 really clear, because we get that thrown back at us
10 sometimes from dischargers that we should use it.

11 CHAIRPERSON HART: We're not required to. But
12 when it's appropriate, we will. Thank you.

13 Yes, sir.

14 MAYOR BALAND: Good afternoon, Madam Chair and
15 members of the Board. My name is Gary Baland. I'm the
16 Mayor of the City of Live Oak, and I've taken the oath.

17 I might be a little nervous and then I might not
18 be. This isn't something that you're born into.

19 Live Oak is a community of approximately 8500
20 people located 50 miles north of Sacramento on Highway 99.
21 We're a rural ag community with fruit and nuts in our
22 sphere of influence. And I just would like to take the
23 time and thank your staff for taking the time that your
24 staff has taken to work with the City staff to discuss the
25 work on many of the complicated issues associated with

1 this permit.

2 The City and I are committed to protecting water
3 quality and committed to meeting regulations as evidenced
4 by our new state-of-the-art \$20 million wastewater
5 treatment facility under construction in Live Oak right
6 now. Construction is well advanced for the new wastewater
7 facility. This facility will meet all of the criteria for
8 the current permit.

9 I'm before you because we're concerned about the
10 content of the new permit. In particular, cannot
11 understand the designation of the agricultural ditch dug
12 100 years ago to capture agricultural runoff now being
13 designated as appropriate for drinking water supply.

14 Our new plant is not designed to meet drinking
15 water standards required for discharge into a municipal
16 water source. It is not designed that way, because we do
17 not now, have never before, and do not intend to discharge
18 into a municipal water source. But rather the same ditch
19 we've always used.

20 Live Oak meets the definition of a distressed
21 community.

22 And I'd just like to add that I think that we're
23 a great city. We're servicing a much needed ag centered
24 people, group. And our unemployment rate currently is
25 over 36 percent. Over one in three people are currently

1 unemployed. Our median household income is only \$31,663 a
2 year. And since retiring from the Union Pacific Railroad
3 as a bridge foreman, I now set right at that median
4 income. About half -- this is about half that of that of
5 Sacramento County.

6 Our sewer rates have been approved to raise \$60
7 million next year, and our rate is already over
8 established affordability guidelines. And additional
9 required facilities to meet this proposed unreasonable
10 rule of drinking water being supplied from an agricultural
11 runoff will make the rate even more unaffordable.

12 As an elected official, I fully understand that
13 at times my hands are tied. I have to make decisions that
14 I do not favor, but I always try to find a way around the
15 situation and work with my constituents.

16 I'm asking you to consider our residents and
17 apply some common sense to this drinking water
18 designation. It is a critical issue for our community.
19 We simply cannot afford the consequences of labeling this
20 ditch as a source of drinking water.

21 And I'd just like to thank you for your time and
22 consideration of our issues.

23 I will now turn the podium over to our public
24 works director to discuss the technical issues. But first
25 I'd be glad to answer any questions that you might have.

1 CHAIRPERSON HART: Thank you, Mr. Mayor. If only
2 our Board were governed solely by common sense, we'd all
3 be a lot happier.

4 Does anyone currently have any questions for the
5 mayor? Seeing none --

6 MAYOR BALAND: Thank you for your time.

7 CHAIRPERSON HART: Thank you.

8 (Thereupon an overhead presentation was
9 presented as follows.)

10 MR. LEWIS: Good afternoon, Madam Chair and
11 members of the Board. My name is William Lewis. I'm the
12 City of Live Oak Public Works Director. And I have taken
13 the oath.

14 I also want to thank the staff for their
15 assistance with the permit. We've not always and still
16 today do not agree on all the issues, but your staff has
17 remained professional and helpful.

18 Also want to thank you for the late revisions.
19 It looks like a lot of changes. But as Ms. Messina said,
20 it really only covered two issues.

21 --o0o--

22 MR. LEWIS: I did have two issues to discuss.
23 It's really going to be one now because of the in-permit
24 compliance schedule. I will be spending most of my time
25 on the MUN designation.

1 was adopted. The permit was a significant change from
2 prior permits. It was clear that the existing pond
3 treatment system would not meet the new effluent limits.
4 Compliance with the new permit was to have been achieved
5 by April 2009.

6 March of 2008, the City bid a project for
7 construction. The cost came in higher than expected and
8 beyond the ability of the community to pay for it.

9 In February 2009, your Board approved a new CDO
10 that recognized the April 2000 date would not be met and
11 allowed more time for the City to investigate
12 regionalization with surrounding communities.

13 In early 2009, the AMERICAN Recovery and
14 Reinvestment Act was adopted by Congress, and California
15 began awarding grants. Live Oak was a recipient of a \$10
16 million grant for construction of the new wastewater
17 facility.

18 Staff met with your executive officer to discuss
19 if the funds could be used for a regionalization project,
20 and it was to determined that due to the tight ARRA time
21 constraints, there was insufficient time to complete a
22 regionalization analysis and still use the grant funds.
23 We were forced to build our own facility or lose the \$10
24 million grant. Live Oak then re-bid the construction
25 project, which is currently under construction today.

--o0o--

1
2 MR. LEWIS: This diagram has been gone over, but
3 historically, the wastewater discharged to the reclamation
4 District 1A that's shown on the left-hand side. As part
5 of the plant upgrade, the discharge is being relocated to
6 Drain 2.

7 The drain system was constructed in the early
8 1910s. No evidence exists to suggest that the drain
9 system was ever a natural water body. The drainage system
10 is purely a drain. It is not used to convey or wheel
11 agricultural water. And there are no known water rights
12 associated with the water in the ditch system.

13 The drain system is a tributary to the Sutter
14 Bypass. However, the Basin Plan does not designate the
15 Sutter Bypass as including municipal water supply
16 beneficial use. In this case, the MUN beneficial use is
17 being applied solely through the sources of drinking water
18 policy, as was incorporated into the Basin Plan.

19 The 2004 permit did not apply MUN beneficial use
20 and did not include permit limits for MUN. And I'm
21 quoting, "Therefore, RD 777 lateral drain could likely
22 meet the criteria for a municipal domestic exemption under
23 Resolution 88-63."

--o0o--

24
25 MR. LEWIS: So what does 88-63 say? I think we

1 need to read it and really see what it says. It says,
2 "Therefore, be it resolved, all surface and groundwaters
3 of the State of California to be considered suitable or
4 potentially suitable for municipal or domestic water
5 supply and should be so designated by the Regional Boards
6 with the exception of the" -- they list I believe four
7 exceptions. And the appropriate one in this case is 2B.
8 And I'm quoting exactly from the resolution. This is an
9 exception. "The water is in systems designed or modified
10 for the primary purpose of conveying or holding
11 agricultural drainage waters."

12 That is exactly the situation in this case.
13 Staff has stated that due to the Vacaville State Board
14 order the basin plan amendments are necessary to execute
15 the exception. The Vacaville order does not apply in this
16 case.

17 ---o0o---

18 MR. LEWIS: It was determined that old Alamo
19 Creek was not designed or modified to carry agricultural
20 drain water. Therefore, the exception did not apply and a
21 Basin Plan was necessary.

22 The tentative permit applies the MUN use and
23 associated effluent limits for eight new constituents for
24 the first time.

25 ---o0o---

1 MR. LEWIS: It is unknown if the treatment plant,
2 which was not designed to address these constituents
3 because there were no limits, will achieve compliance for
4 any of these constituents.

5 The most problematic is the limit for nitrate.
6 The new facility was designed to remove ammonia, but not
7 nitrate, and will not meet the new effluent limit. Based
8 on the estimate provided by our design engineer,
9 denitrification facilities are estimated to cost an
10 additional \$4.1 million. And that would add about \$10 per
11 month to a typical bill, taking the total bill to over \$80
12 per month.

13 It should be noted that the 2004 permit fact
14 sheet states that the Regional Board estimated cost to
15 comply with the new limit -- that is back in the 2004
16 permit -- was \$2.2 million. That estimate was ten times
17 too low. Total cost to meet the 2004 permit limits will
18 exceed \$20 million.

19 U.S. EPA guidelines recommend that sewer rates
20 should not exceed two percent of the median household
21 income.

22 I would just note in a recent all-day permit
23 hearing I attended, a large amount of time was spent
24 discussing cost. Those costs will result in significantly
25 lower percentage of the median household income for that.

1 community directed towards than our customers are already
2 paying today.

3 --o0o--

4 MR. LEWIS: As can you see, Live Oak citizens
5 will be paying 2.6 percent of the medium household income
6 towards monthly sewer. And if de-nitrification facilities
7 are constructed and operated, the percent increases over
8 three percent. And for what benefit? To protect a drain
9 that conveys agricultural runoff, urban runoff, and
10 treated wastewater to a downstream tributary that is not
11 designated as having MUN as a beneficial use. Requiring
12 the small community of Live Oak have its wastewater meet
13 drinking water standards under these facts just appears to
14 us to defy common sense.

15 --o0o--

16 MR. LEWIS: Further, there is no natural flow of
17 water in the drain. As far back as the early 1900s, there
18 is no indication that there ever was a natural water body
19 in these drains. It is reasonable to assume the
20 California Department of Public Health would never grant
21 approval for a drain water as being suitable for drinking
22 water supply.

23 If the City were to pipe the water about twelve
24 miles directly to the Sutter Bypass, these criteria would
25 not apply. We're simply using the drain as a pipeline.

1 This is a case where all reasonable people would conclude
2 that it is not appropriate to consider this drain system
3 as a water supply source.

4 --o0o--

5 MR. LEWIS: So let's just look at what these
6 drains are. This is a picture looking upstream from our
7 current discharge location. There was no downstream flow
8 when I took this picture on Monday.

9 This is a picture looking downstream. The weeds
10 are controlled by the staff to facilitate sampling, but
11 the drain becomes overgrown within a few hundred feet.

12 --o0o--

13 MR. LEWIS: This is a picture upstream of the
14 future location. The ditch is deeper and has standing
15 water with duck weed.

16 --o0o--

17 MR. LEWIS: This is a bit further upstream and an
18 orchard can be seen on one side with the drip irrigation
19 system and the hay crop on the other. This is typical of
20 the agricultural areas served by the constructed
21 agricultural drains.

22 --o0o--

23 MR. LEWIS: When I took the picture on Monday, a
24 farmer was having his nearby field airily sprayed. This
25 is a typical method of application for pest and weed

1 control. The constructed ag drains, as you saw in the
2 previous picture, run directly next to the crops, so it
3 would be reasonable to assume there would be some drift
4 into the drains.

5 --o0o--

6 MR. LEWIS: This is a picture of the future
7 discharge location. I'm standing in the ten-foot deep
8 drain in less than a foot of standing water. There is no
9 apparent flow, and the location had a thick layer of duck
10 weed. So this is our new location. On the left-side, you
11 can see some wood. And that's the construction that's
12 taking place.

13 I believe your staff will admit they do not want
14 to make the designation. And I don't think that I would
15 want my drinking water coming from these drains, and I
16 don't think that you would either. It doesn't make any
17 sense.

18 But as I've heard them state, our hands are tied.
19 There is nothing we can do. While we appreciate that
20 sentiment, it's very frustrating for our and our citizens
21 to hear. I know it doesn't make any sense. I don't
22 agree, but the rules are the rules. I'm just following
23 the rules.

24 Just as the Mayor stated, he, at times, has to
25 make decisions he does not like. But he always looks for

1 alternatives. Today, you, as a Board, have alternatives
2 other than saying "My hands are tied."

3 --o0o--

4 MR. LEWIS: The first A issue has been taken care
5 of, but on the -- the B issue has been taken care of. On
6 A, we would like to have the arsenic and trihalomethanes
7 as monthly limits. But the main issue today --

8 --o0o--

9 MR. LEWIS: -- is the alternatives as relates to
10 MUN. We and many other communities continue to maintain
11 the position that the Resolution 88-63, which we read, was
12 adopted into the Basin Plan. It allowed the Regional
13 Board discretion in making NUM designations and to
14 implement the exception without amending the Basin Plan.
15 Considering the bizarre results that occur here and many
16 other cases, we encourage the Board to re-evaluate its
17 previous interpretation and use your discretion and remove
18 the MUN designation. That was done in Willows back in
19 2006.

20 In the alternative, the Board could refrain from
21 adopting effluent limits, resulting from MUN designation
22 today until after considering the Basin Plan amendment
23 that removes MUN from the agricultural drain and applies
24 the exception as allowed in the source of drinking water
25 policy. This is similar to what's done for the City of

1 Biggs in Butte County in 2007.

2 We understand that the Board may be hesitant to
3 employ either Options 1 or 2. In that case, another
4 option is direct the Board staff to implement a Basin Plan
5 amendment process to initiate de-designation of the drain
6 system. This is similar to what was done for the City of
7 Colusa two years ago. There are many more small
8 communities that will be coming forward in the next few
9 years and will be caught by the same interpretation of the
10 1988 resolution.

11 The problem can be resolved by you making
12 applications to agricultural drain exception self
13 actuating without Basin Plan amendment in each case.
14 Please do not lay the cost of the small communities to
15 implement these exceptions to one at a time.

16 To perform this analysis, we estimate it will be
17 50 percent of our annual budget for one year to do just
18 the study to de-designate this plan.

19 The Board can fix this unreasonable
20 interpretation of assuming agriculture drain water would
21 ever be approved for drinking water sources. At a
22 minimum, please direct your staff to undertake the Basin
23 Plan amendment and report back to you within six months
24 regarding this and require the MUN limits -- not require
25 MUN limits at this time for the City of Live Oak.

1 I'd be glad to answer any questions you may have.

2 CHAIRPERSON HART: Yes, we have questions.

3 BOARD MEMBER LONGLEY: I understand the issue as
4 you're presenting it. I'm wondering, because my
5 estimation shows that you're producing -- if my estimation
6 is correct -- roughly 1,600 acre feet of wastewater a
7 year. And it strikes me, particularly given the order by
8 the State Board in February of 2009 I believe, that you
9 have a possibility of another use for that rather than
10 putting it in that ag drain, and that's to use it for ag
11 purposes. Have you considered that?

12 MR. LEWIS: That could be considered can the new
13 plant, in particular. That would not resolve the
14 wintertime disposal issues.

15 BOARD MEMBER LONGLEY: Unless you went to
16 storage.

17 MR. LEWIS: There's inadequate space to store.

18 BOARD MEMBER LONGLEY: Okay.

19 MR. LEWIS: And, of course, there would be costs
20 associated with doing that as well.

21 BOARD MEMBER LONGLEY: Well, water is getting
22 very precious. And the cost of water is going up. And
23 that has value.

24 MR. LEWIS: And that's one of the reasons I
25 stress the point that the farmers have gone to drip

1 irrigation systems. They have eliminated a flood
2 irrigation, gone to drip, and these ag drains are not
3 being used anywhere near as much as they used to in the
4 summer months.

5 BOARD MEMBER LONGLEY: I think what you're going
6 to see is more and more pressure from all quarters to be
7 looking at, rather than discharging this water, of finding
8 another use for it.

9 MR. LEWIS: And it does, of course, go into the
10 Sutter Bypass as used for agricultural water apply.

11 CHAIRPERSON HART: Soapy.

12 BOARD MEMBER MULHOLLAND: This strikes me as the
13 exact thing that drives me absolutely crazy. I mean, I
14 hate stuff like that. There's no way we're going to drink
15 that water.

16 So I'm going to ask staff again -- I mean, I know
17 that our hands are tied, as Kate said. But this is what
18 makes us all look insane. What are the alternatives
19 besides saying this is drinkable water? I mean, it's
20 crazy. I don't know -- explain to me a Basin Plan
21 amendment. I know that's supposed to be really, really
22 hard to do. He's come up with alternatives. Are any all
23 of these alternatives ones that we can look at, rather
24 than just pass this insane ruling on?

25 STAFF COUNSEL COUPE: I wouldn't recommend

1 changing the MUN designated use for the constructed ag
2 drain.

3 With that said, I'll be frank and say there very
4 well may not be a lot of alternatives that Board members
5 think are particularly useful or valuable. The one that
6 comes immediately to mind and the one that staff brought
7 forward had to do with a Basin Plan amendment. But again,
8 that would be a relatively long, protracted, and rigorous
9 process. And my limited experience in working with Basin
10 Plans is that could be a year, one, two, three years down
11 the road.

12 CHAIRPERSON HART: Why were we able to do that in
13 Colusa? This drains into another ag drain. This is
14 silly. Somehow --

15 EXECUTIVE OFFICER CREEDON: In Colusa, we didn't.
16 You directed us to -- well, we offered to look into what
17 it would be for staff to help Colusa do it, because
18 they're a small disadvantaged community. Staff has
19 started the activity. But it's still here.

20 And Ken can probably speak to it more. I'll let
21 Ken speak.

22 ASSISTANT EXECUTIVE OFFICER LANDAU: Yeah, Ken
23 Landau, Assistant Executive Officer. I have taken the
24 oath.

25 We basically have been working with Colusa on

1 this. It's taken far too long. But we're squeezing the
2 permitting staff working on a Basin Plan amendment in
3 between all of the permits and other things going on.

4 We have completed the water quality evaluation.
5 We're working on the flow evaluation. I'm supposed to be
6 receiving the technical report on the various watershed
7 factors and water quality factors in about a week, middle
8 of this month. It's very shortly. And we are talking
9 about where we can go from there. There are a list of EPA
10 criteria under which you can de-designate and some of
11 those simply don't apply to that situation. Some of them
12 the data aren't supporting. So we're trying to figure out
13 how to move forward on that. But it is not completed at
14 this point.

15 CHAIRPERSON HART: Thank you, Ken.

16 I'm going to go with Dan, and then I have a card
17 for Bobbi if Mr. Lewis is done.

18 So Dan.

19 BOARD MEMBER ODENWELLER: I think we need to look
20 at this, because as I read it, the staff concurs that the
21 receiving water may have been constructed or modified for
22 the purpose of conveying ag drainage water.

23 CHAIRPERSON HART: It for sure was. I don't
24 think there is any question in anybody's mind. This is an
25 ag drain. No ifs, ands, or buts about it. We have staff

1 going yes, yes, nodding their heads.

2 MR. LEWIS: Within the record contains minutes
3 from 1939 that indicates the cost of construction in the
4 1910s.

5 BOARD MEMBER ODENWELLER: To go on, the blanket
6 municipal designation for all unidentified water bodies in
7 the region, I question whether this was an unidentified
8 water body, since it was in the record of a series of
9 meetings and permitted previously. And so it appears to
10 me the designation was inappropriate if we want to look at
11 it that way. And --

12 CHAIRPERSON HART: Should have been a lawyer,
13 Dan. I'm impressed.

14 BOARD MEMBER ODENWELLER: They have a name for
15 us.

16 CHAIRPERSON HART: I don't think you can say it
17 in public.

18 BOARD MEMBER ODENWELLER: But I think I would be
19 favorably inclined to consider a change to something they
20 come up with what I just saw in the pictures.

21 CHAIRPERSON HART: So if we can hear from Bobbi
22 Larson.

23 MS. LARSON: Thank you, Madam Chair and members
24 of the Board. I'm Bobbi Larson with the firm of Somach
25 Simmons & Dunn, and we are outside counsel to the City of

1 Live Oak.

2 I just want to -- it sounds like I don't need to
3 bring you back to what we're talking about here, which is
4 an ag ditch which everyone agrees is not suitable for
5 municipal drinking water that flows to another water body
6 that is not designated for municipal drinking water. I
7 don't think there is any question about this actually
8 being driven by a need to protect some use. It's more a
9 matter of people feeling there is a legal obligation to do
10 this.

11 I would like to try in the time I have to
12 persuade you that you do have an option, because, of
13 course, everything that we've been discussing about your
14 hands being tied relies on this water body having been
15 designated municipal drinking water in the first place.
16 And I'd like to try, if I can, to piece together for you
17 why that is not the case. Starting with, as Mr. Coupe
18 referenced, the Basin Plan did incorporate by reference
19 Resolution 88-63. That was done in 1988. And the Basin
20 Plan refers to the language of the resolution that Mr.
21 Lewis put up. And it specifically says that the
22 language -- in accordance with the language of the
23 resolution. But that's how it's being incorporated. And
24 the language expressly includes the exception.

25 Now, I know that you get multiple opinions from

1 multiple lawyers and you're probably not that interested
2 in mine. I will give you the opinion of the attorney who
3 was advising the Regional Board in 1994, Betsy Jennings.
4 Many of you know her from her work at the State Board.
5 She was at the time the staff counsel to the Regional
6 Board, and this memorandum was attached to our comment
7 letters. So you have it there. That 1994 memorandum to
8 Regional Board staff stated that "The incorporation of
9 Resolution 88-63 into the Basin Plan did not designate the
10 MUN use for constructed ag drains, and neither did the
11 tributary footnote."

12 That was the opinion of this Board's own lawyer
13 in 1994 very contemporaneous to the time all these things
14 were happening.

15 So then comes the issue what about the Vacaville
16 order? Because the State Board certainly did come through
17 in 2002 with that order that presumably maybe changed the
18 landscape with regard to this. Well, I would suggest the
19 State Board in an order cannot designate something in your
20 Basin Plan. However, what they did lend confusion to was
21 they made a statement in Footnote 1 of the revised redline
22 permit. Your staff has quoted it accurately. That Board
23 seemed to suggest that you could only de-designate with
24 the Basin Plan amendment. That issue was not before them,
25 because they were dealing with a natural water body, not a

1 water body that fit into either of the exceptions.

2 So the best thing I can say about the Water
3 Board's language there in the order, which is not the
4 ordered section -- it's in the discussion -- is that's
5 dicta for you lawyers. It's a discussion of something the
6 State Board was musing about.

7 CHAIRPERSON HART: It's not binding

8 MS. LARSON: It's not binding. It was not part
9 of the order. The order addressed a water body that did
10 not fit into one of the exceptions. So I believe that you
11 do have the opportunity to do this.

12 There's one other thing I should address, AND I'm
13 running out of time. If I could have just another minute
14 to do so.

15 CHAIRPERSON HART: Yes. You may.

16 MS. LARSON: There is this implementation
17 language that is confusing, also. There is nothing about
18 this that is not confusing. But there is implementation
19 language that was added in the Basin Plan that seems to
20 suggest that you have to do a basin plan amendment to
21 effect these exceptions.

22 I would say that didn't seem to deter counsel
23 back in 1994 from the statement that was made. But in
24 addition, I don't believe that you can affect a
25 designation that did not exist by implementation language

1 in the Basin Plan. You have a beneficial use section.
2 That's where uses are designated. It is not altered by
3 that particular reference in the implementation section.

4 So I think the best meaning of that language is
5 that it was intended to clarify what you needed to do for
6 those waters that had been designated in order to
7 de-designate them.

8 So I do hope you will feel that you do have an
9 option here that you do not have to impose these
10 requirements on the City of Live Oak or some of these
11 other small communities that are going to be before you in
12 the same boat.

13 I would just like to say, if you don't feel that
14 you can get there -- and at a minimum I would hope that
15 this Board would direct the implementation of the Basin
16 Plan amendment to address this.

17 And I would just like to say that while we are
18 very appreciative of the recognition in the CDO of this as
19 an option, if we are going to say the Vacaville order
20 controls and you need to do a designation, I think we need
21 to respect what the Board said in that order, which is
22 that where a Regional Board has evidence that a beneficial
23 use does not exist and likely cannot be feasibly attained,
24 the Regional Board must expeditiously initiate an
25 appropriate Basin Plan amendment for de-designation.

1 I understand your staffing shortages. I know the
2 City is fully prepared to assist in providing studies and
3 data and those kinds of things. But I don't think it's
4 fair to say that the discharger has the responsibility to
5 correct this problem in the Basin Plan.

6 So thank you for your indulgence, Madam Chair. I
7 would just urge you, your hands are not tied. You have
8 the option of doing the right thing here. And we would
9 urge you to do that. Thank you.

10 CHAIRPERSON HART: Thank you, Ms. Larson.

11 Yes, Carl.

12 BOARD MEMBER LONGLEY: Bobbi, you're always
13 persuasive. Two days in a row. My God, I'm inundated.

14 David, I have a question for you. How can this
15 Board make a finding? I don't want to see us having to go
16 through a Basin Plan amendment, the cost and time and
17 everything. How can we make a finding that this is not a
18 municipal water -- or doesn't have a municipal
19 designation?

20 STAFF COUNSEL COUPE: I would have quite a bit of
21 difficulty trying to do that, let alone making that
22 recommendation.

23 BOARD MEMBER LONGLEY: It would seem to me based
24 upon what we've heard, not only from Bobbie, but from
25 others, that there is precedence for doing that. And in

1 our record, Betsy's --

2 STAFF COUNSEL COUPE: What was specifically
3 referenced as the "precedence" for doing that was
4 referenced in Ms. Messina's presentation where staff
5 specifically recognized that 88-63 was not properly
6 applied in those situations and that we're going to need
7 to go back and fix and make those particular changes in
8 the permit.

9 Just want to point out one other thing. Aside
10 from Vacaville, there's been at least one subsequent State
11 Board order post-Vacaville that made it pretty darn, I'd
12 say, very clear that for the purposes of not --
13 de-designating a MUN use for a particular water body that
14 it cannot be done through a self-implementing action,
15 i.e., through a permitting action and needs to be through
16 a basin plan amendment process.

17 I can empathize to a certain extent with Board's
18 concerns. One possible avenue I think, as Ms. Larson
19 pointed out, is there is some specific language in the
20 Vacaville order that talks about acting expeditiously to
21 pursue a Basin Plan amendment. And it certainly is within
22 the discretion of this Board if they decide that they want
23 to adopt this permit to provide that general direction to
24 staff as well.

25 BOARD MEMBER ODENWELLER: Kate.

1 CHAIRPERSON HART: Yes.

2 BOARD MEMBER ODENWELLER: Bobbie, I agree with

3 you on your first part, but I don't think it has anything
4 to do with the size of the community. It has to do with
5 the ditch that the water is going back into.

6 CHAIRPERSON HART: She didn't reference the size
7 of the community.

8 BOARD MEMBER ODENWELLER: Yes, she did.

9 CHAIRPERSON HART: No, she didn't.

10 BOARD MEMBER ODENWELLER: As near as I understand
11 this, the action that is being taken is designating it
12 municipal. If we hadn't taken this step in this permit,
13 it would not be municipal.

14 EXECUTIVE OFFICER CREEDON: We're not designating
15 it through the permit, Board Member Odenweller. What
16 they're saying --

17 CHAIRPERSON HART: They're re-interpreting.

18 EXECUTIVE OFFICER CREEDON: We're just
19 interpreting the way that in accordance with what recent
20 actions are. That's according to what -- how the
21 attorneys are advising us, that this is the way the Board
22 has to consider this designated use, that we improperly
23 did not identify MUN in the last permit. And we should
24 have. And so we're correcting that error. That it has
25 always been designated that by 88-63.

1 CHAIRPERSON HART: Yes, Carl.

2 BOARD MEMBER LONGLEY: I have a question for
3 Executive Officer.

4 If we would follow the line that our counsel
5 suggested and give direction to the Board -- to the staff,
6 if I'm stating it properly, to do the Basin Plan
7 amendment, am I correct.

8 EXECUTIVE OFFICER CREEDON: The question --

9 BOARD MEMBER LONGLEY: What sort of issues would
10 you have with that?

11 EXECUTIVE OFFICER CREEDON: It's time. My
12 question -- there was a lot going on over here. I
13 apologize for the chatting over here.

14 Because one of my questions to David was, you
15 know, if we only bound by the tributary rule, the MUN
16 would not have moved up, because it wasn't a designated
17 use in the downstream.

18 My question is because of 88-63 and the blanket
19 application of MUN, can we remove it based on that
20 exemption alone? Or are we limited to -- or do we have to
21 also make the federal de-designation standards meet as
22 well? And that might cause a lot of problems with us
23 being able to de-designate.

24 So we never got to that answer, because we had to
25 turn to the meeting. But if we have to do a Basin Plan

1 just to say that 88-63 met these exemption, therefore it
2 doesn't have MUN and it won't apply to the tributary rule,
3 that's a different threshold than if we have to go through
4 all the factors for de-designating a use by the federal
5 standards, which is a very, very tough threshold to get
6 over.

7 CHAIRPERSON HART: I'm still lost at why we're
8 not applying the ag exemption in the resolution. I'm
9 totally lost.

10 And, David, you've got to go over that again.

11 STAFF COUNSEL COUPE: Well --

12 CHAIRPERSON HART: Just like from a common-sense
13 perspective, that the interpretation that is being
14 proposed to us, it's just --

15 STAFF COUNSEL COUPE: The exceptions themselves
16 weren't -- they weren't self-implementing at the time that
17 88-63 got adopted by State Board and as it was
18 subsequently implemented into the regional Board's Basin
19 Plan.

20 So I think there are probably a couple of
21 practical reasons why that occurred. And I think this is
22 consistent with the position that the Board is taking as
23 it pertains to the ongoing Vacaville litigation, i.e., it
24 just didn't make -- staff just didn't have the resources
25 or the capability at the time to go through the exercise

1 of trying to cull out every possible water body that
2 arguably could meet an exception and do all the analysis
3 that's associated with specifically exempting those water
4 bodies.

5 CHAIRPERSON HART: Those were unidentified water
6 body. This is an identified ag drain. So how would that
7 be covered?. And can't we just make a finding that says
8 this was a clearly identified water body. It is not
9 governed by the resolution and --

10 STAFF COUNSEL COUPE: There was no specific
11 beneficial use attributed to that ag drain -- that's my
12 understanding -- at the time that 88-63 was adopted by
13 State Board and at the time that it was subsequently
14 implemented by the Regional Board in 1989.

15 Consequently, because there was no attributed
16 beneficial use to that constructed ag drain, as a result
17 of the implementation of 88-63 into the Regional Board's
18 Basin Plan, all surface water bodies within the basin,
19 within the Basin Plan, are subject to the MUN use --

20 CHAIRPERSON HART: So anything that wasn't
21 identified as the beneficial use --

22 STAFF COUNSEL COUPE: All unidentified water
23 bodies, whether natural or not natural --

24 CHAIRPERSON HART: And you're defining
25 "unidentified" as not having a beneficial use assigned?

1 STAFF COUNSEL COUPE: That's my understanding.
2 And my understanding is that the constructed ag drain
3 that's under consideration had no specifically assigned
4 beneficial use to it at the time.

5 Consequently, when we implemented 88-63 into our
6 Basin Plan in '89, it had -- it became an MUN designated
7 beneficial use.

8 BOARD MEMBER LONGLEY: Maybe I'm a little slow
9 today, but that sounds disingenuous to me. It was a
10 construct ag drain. I guess you're saying it had to be in
11 the Basin Plan with that with some beneficial use
12 associated with it?

13 STAFF COUNSEL COUPE: You know, again, I want to
14 convey the position we're taking in a way that's
15 consistent with the ongoing Vacaville litigation. And the
16 position we're taking in the ongoing Vacaville litigation
17 is, yes, that's precisely what happened. And as
18 specifically characterized by State Board, when they
19 characterized the Regional Board's action in 1989, it was
20 specifically characterized as a blanket MUN designation
21 for all surface water bodies within the jurisdiction of
22 the Basin Plan.

23 CHAIRPERSON HART: Okay. Soapy has a question
24 and then I have a comment.

25 BOARD MEMBER MULHOLLAND: I'm looking at you and

1 saying you work for us. And I'm hearing everybody up at
2 this podium saying this makes no sense. We don't like
3 putting rules into effect that don't work. And I'm
4 hearing you say, "We are taking this stance."

5 So I'm going to turn it around and say that I
6 think you've got almost every person up here spoken
7 they're not happy about it. So I'm going to turn it
8 around and say, what can you do for us so we don't have to
9 implement something that's stupid? How can you work for
10 us to make this okay?

11 CHAIRPERSON HART: I think I have maybe a partial
12 solution in that -- David, I understand that there is a
13 specific legal argument that's being applied in the
14 Vacaville case. But I also understand and know that the
15 water body at issue in the Vacaville case is Alamo Creek,
16 and Alamo Creek clearly is a drinking water body and not
17 an ag drain. I don't think it ever was an ag drain. Am I
18 right?

19 ASSISTANT EXECUTIVE OFFICER LANDAU: This is Ken
20 Landau. Alamo Creek was a natural body of water, natural
21 stream. It has been modified significantly, including
22 having its headwaters cut off. At one time, it was a
23 natural stream.

24 CHAIRPERSON HART: Yes. Okay. So could we not
25 make findings to distinguish this case from the Vacaville

1 case?

2 STAFF COUNSEL COUPE: The concern that I would
3 have in the Board's efforts trying to do that is because,
4 as I mentioned previously, the MUN designation that was
5 provided as a result of the Regional Board implementing
6 88-63 in 1989 was a blanket MUN designation for all
7 unidentified water bodies within the basin, within the
8 jurisdiction of the Regional Board.

9 CHAIRPERSON HART: Fair enough. So here's a
10 question for you. It seems to me that we have not had
11 litigation then on this issue on an exact interpretation
12 and whether there was or wasn't a blanket -- Lori is
13 shaking her head. Lori is here to help you. Your backup
14 is here.

15 SENIOR STAFF COUNSEL OKUN: Lori Okun, Office of
16 Chief Counsel.

17 The Basin Plan did designate the MUN use for all
18 surface water bodies, including ag drains that don't have
19 specific designated uses.

20 It is a specific issue in the Vacaville case.
21 It's been briefed. If the Board would like to discuss
22 that case, it is pending litigation, so you could adjourn
23 to closed session to discuss that case.

24 But the State Board and the Regional Board are
25 parties in that case, and it's very clear that the way the

1 Basin Plan reads is that those uses were designated.
2 Whether that was a good decision in retrospect or a bad
3 decision in retrospect, that's what happened when the
4 Basin Plan language was adopted. And it's clear under EPA
5 regulations that there is a process for removing those
6 uses.

7 It's not what's called a fishable, swimable use
8 under the Clean Water Act. You don't have to do a use
9 attainability analysis to amend the Basin Plan. But you
10 still do need to meet the factors that are set forth in
11 EPA's Basin Plan regulations in order to remove the use.
12 And it's a very cumbersome process, and nobody likes
13 having to go through that. But that's the way the State
14 Board reads it. That's the way EPA has indicated that
15 they read it.

16 CHAIRPERSON HART: Sandra has a question.

17 BOARD MEMBER MERAZ: Can we go into closed
18 session?

19 CHAIRPERSON HART: Well, if you would like to do
20 that, we can do that.

21 Dan, do you have a comment?

22 BOARD MEMBER ODENWELLER: I just pulled up 88-63,
23 and I'm stuck with it doesn't have a designated use until
24 now. And we go all surface and groundwaters of the state
25 are considered to be suitable or potentially suitable for

1 municipal or domestic water supply and should be so
2 designated by the Regional Board, with the exception of
3 surface and groundwater where TDS exceeds 3,000 milligrams
4 per liter. There is contaminations either by natural
5 processes or human activity or water source does not
6 provide sufficient water to provide a single well capable
7 of producing the average yield under two surface waters
8 where the water is in the system designed or modified to
9 collect or treat municipal or industrial wastewaters,
10 processed waters, place waters, or stormwater runoff,
11 provided that the discharger from such systems is
12 monitored to a certain compliance water quality objectives
13 as required by the Board. Or the water is in systems
14 designed or modified for the primary purpose of conveying
15 or holding agricultural drainage waters, provided that the
16 discharge from such systems is monitored to ensure
17 compliance.

18 Now, it seems to me that this ditch meets that to
19 be definition and that as an example, to put the shoe
20 inside a different perspective, there are a number of
21 delta islands that have old waterways that are blocked off
22 on both ends and used as either drains or ditches
23 depending on their situation. Are they all now municipal
24 water facilities that are going to have to be covered in
25 the NPDES permits?

1 STAFF COUNSEL COUPE: Dan, I'm just going to
2 reiterate I think what I tried to convey earlier and I
3 think is consistent with what Ms. Okun said earlier. And
4 that is, taking aside the issue of whether, in fact, we
5 think an exception may be applicable under 88-63, that's
6 not the specific action that the Regional Board took when
7 they implemented 88-63 into the Basin Plan. The action
8 that the Regional Board took in '89 was a blanket
9 municipal use designation for all unidentified water
10 bodies within the Basin Plan.

11 Consequently, there needs to be both compliance
12 with that requirement as a condition of trying to
13 de-designate that water body through a Basin Plan
14 amendment process, but also through as Lori mentioned, if
15 my memory serves me correctly, the federal regs is under
16 131.10(g). In fact, we have to walk through both a state
17 and federal process to de-designate the use.

18 CHAIRPERSON HART: Pamela.

19 BOARD MEMBER ODENWELLER: I'm still Objecting to
20 de-designate. Do we have a volume somewhere that shows a
21 list of water bodies that were listed as designated
22 municipal? Or do we have a list of bodies that were
23 excluded because of their use?

24 EXECUTIVE OFFICER CREEDON: We have 88-63, which
25 I agree with you, because I've had very similar arguments

1 with our attorneys, but -- maybe not this set, but the
2 ones before. And it is frustrating for us. But it's how
3 it was -- 88-63 is worded one way. The Basin Plan amended
4 adopted in a slightly different way. That's what's
5 causing the rub here is the way it was adopted through our
6 Basin Plan. It's the basis plan language that is putting
7 the constraints on you more than anything. And that's why
8 they say we need a Basin Plan amendment to change that.

9 We, as a Board, and whenever this addition was
10 added, applied that blanket designation. So it was
11 designated at the time the Basin Plan was amended to
12 corporate. It was a de-designation question -- or issue.
13 Not a question.

14 CHAIRPERSON HART: So essentially what you're
15 saying is the amendment to the basis plan that got adopted
16 that slapped an MUN over all these "unidentified" water
17 bodies wiped out any exceptions in Resolution 88-63?

18 LEGAL COUNSEL PULUPA: It's one of those. And I
19 don't know what the presumptions were. I just handed
20 Pamela the Basin Plan provisions.

21 But you're exactly right. I mean, what
22 essentially this Board did, the Central Valley Board did
23 after the State Board in adopting 88-63, 88-63 contained a
24 few exceptions. This Board went and incorporated 88-63
25 into our Basin Plan. Said that the only way --

1 essentially, slapped the MUN on everything and said that
2 the only way you pull this off is you go through the Basin
3 Plan process.

4 SENIOR STAFF COUNSEL OKUN: It didn't eliminate
5 the exceptions. It just made the process to apply those
6 exceptions of a basin planning process rather than not
7 designating the uses in the first place.

8 BOARD MEMBER ODENWELLER: Unless a party to the
9 proceedings here in the future comes in with a piece of
10 paper signed by the Regional Board designating their water
11 way as other than MUN, Paul, we're going to treat them all
12 as municipals and require those water quality standards in
13 the discharger; is that what I'm hearing?

14 EXECUTIVE OFFICER CREEDON: That's what Diana was
15 pointing out. We have a number of these where we applied
16 the tributary rule improperly by not designating MUN where
17 there wasn't a specific de-designation made through a
18 basin plan amendment. You will see this again; that's why
19 we're having this discussion.

20 But I can read to you the exact language from the
21 basin plan. It basically incorporated 88-63 where, "The
22 Regional Board finds that one of the exception applies, it
23 may remove the municipal and domestic supply beneficial
24 use designation for the particular body of water through a
25 formal Basin Plan amendment and a public hearing, followed

1 by approval of such amendment by the State Board and the
2 Office of Administrative Law."

3 So we have that very specific language in the
4 Basin Plan. And this Board has no choice but to do what
5 the Basin Plan requires us to do.

6 CHAIRPERSON HART: And Ms. Larson, do you have a
7 legal opinion on that as well?

8 MS. LARSON: I believe just -- Ms. Creedon, is
9 that the language in the implementation section of the
10 Basin Plan?

11 EXECUTIVE OFFICER CREEDON: Yes.

12 MS. LARSON: Yes, I do have an interpretation of
13 that, which is that implementation language did not affect
14 a designation in the first place. So that would apply to
15 the extent something has been designated.

16 My argument is that it was not designated in the
17 first place based on the fact that there was language in
18 the original Basin Plan. And I have the reference here.
19 Unfortunately, I don't have the page reference, but when
20 it was first amended in, the Basin Plan specifically
21 stated that, "The Regional Board will apply the exceptions
22 listed in Resolution 88-63." And that was in that '92
23 version of the Basin Plan. I don't know what that means.

24 If they were designated, what does it mean to say
25 "we will apply the exceptions"?

1 And again, I can only direct you to the 1994
2 legal opinion of the Regional Board's counsel which opined
3 they were not designated. And we don't believe that
4 anything that's happened subsequently has changed that.
5 And there's certainly no record of any findings or any --
6 when you do something like designated use, you have to
7 have findings of fact and link those findings to the
8 record. And there's nothing in the Basin Plan record that
9 support those uses having been designated, other than the
10 sentence that was read to you by Pamela.

11 CHAIRPERSON HART: I have so much respect for you
12 guys. I don't think any of the Board members up here mean
13 any disrespect. And I know this is probably the most --
14 God, a million times I've represented local agencies and
15 been exactly where you going "I wish these Board members
16 would shut their mouth right now."

17 But this is truly an extraordinary, extremely
18 concerning issue and interpretation for us. And I cannot
19 in good conscious think and even determine that our --
20 that Betsy Jennings' interpretation is incorrect. I can't
21 fathom for the life of me that that's what this Board --
22 and I want everyone to know, I was not on this Board in
23 1988. I was actually still in high school. But anyway --

24 BOARD MEMBER LONGLEY: Nor I was. Year after,
25 though.

1 CHAIRPERSON HART: You were close, Carl.

2 But I will still say that I can't imagine that
3 our interpretation could be anything other than -- if you
4 have to make findings to designate water bodies, how could
5 you just slap MUN all over everything? It sounds like a
6 great idea to protect water quality, but it just isn't
7 even legal in the first instance.

8 BOARD MEMBER LONGLEY: Madam Chair.

9 CHAIRPERSON HART: Hold on just a second. Lyle
10 wants to say something, and you're next.

11 BOARD MEMBER HOAG: Just a thought or a question.

12 This Board finds itself interpreting all kinds of
13 criterias, standards, rules, laws, in setting discharge
14 requirements and in promulgating NPDES permits. Why can't
15 we simply make what we believe is the right interpretation
16 of the language of 88-63 and find that this is under the
17 exemption clause; MUN does not apply to this receiving
18 water?

19 CHAIRPERSON HART: Yes. I promised Carl and
20 then, Soapy, you're next.

21 BOARD MEMBER MULHOLLAND: No.

22 BOARD MEMBER LONGLEY: First of all, the comment
23 has been made and I think a very valid one that Betsy
24 Jennings possibly by her language and Roberta Larson
25 pointed out there may be language in the earlier version

1 of the Basin Plan. There appears to me there is things we
2 need to find out before we make a decision on this short
3 of going through a Basin Plan amendment that may make
4 things easier.

5 I would suggest that we go through the rest of
6 this hearing and set that aside and maybe postpone a
7 decision on this until the next meeting. And at the next
8 meeting, discuss only the municipal. Go ahead and take
9 care of the rest, but then take care of the municipal at
10 the next meeting after.

11 EXECUTIVE OFFICER CREEDON: Can I just point out,
12 contrary to -- Bobbie, I want you to know I have a lot of
13 respect for you. And I have real problems with this, too.
14 But it's the way our language is written.

15 In Section 2 of the Basin Plan where we
16 established the uses, both for ground water and for
17 surface water, we specifically identify Resolution 88-63
18 where we make the blanket designation to water bodies. We
19 don't have exceptions. And then the implementation policy
20 tells us exactly what we have to do in order to change
21 that designation. So it is in both the uses section,
22 section chapter 2 and in chapter 4 of our Basin Plan for
23 both surface and groundwater.

24 BOARD MEMBER LONGLEY: And the alternative I
25 would suggest would be that we go ahead and proceed with

1 it, adopt it today. But then give staff directions to
2 and -- maybe we might, as part of that adoption, consider
3 doing a basin plan amendment. That would be up to this
4 Board obviously.

5 But also I think there needs to be some more
6 research into this. Apparently, Ms. Jennings had some
7 opinions, and I would like to know precisely what those
8 opinions are. Having worked with Betsy for many years, I
9 have a lot of respect for her, too.

10 STAFF COUNSEL COUPE: I'll make one comment in
11 response to the memo that Betsy wrote back in '94. With
12 all respect to Betsy, there was a huge sucking sound when
13 she left the State Board and retired a year or so ago.

14 With that said, I think some of the conclusions
15 that she put forward in the memo back in '94, quite
16 frankly, I don't think would necessarily be legal in the
17 context of subsequent litigation that's happened since
18 1994. And in particular, as I think we may have
19 referenced in the response to comments -- or if we didn't
20 reference it in the response to comments -- and I was
21 hoping not to bring up the tributary rule, but I'm going
22 to bring up the tributary rule anyway.

23 To the extent that there is any hydrological
24 connection between this constructed ag drain and some
25 water that does have a municipal beneficial use, it's my

1 understanding that the water flows from the constructed ag
2 drain to Sutter Bypass, which does have a specific non-MUN
3 use and that subsequently that the water flows to the
4 Sacramento River, which specifically has a municipal use
5 designation to the extent that there is any hydrological
6 connection between the Sacramento River and that
7 constructed ag drain I would argue that the tributary rule
8 applies.

9 CHAIRPERSON HART: Okay then. I think we need --
10 we do have other -- I actually have other cards on this,
11 but I've gotten totally off my list. Other interested
12 parties? Because I don't see CSPA here. Is CSPA here? I
13 don't see CSPA here.

14 Debbie Webster from CVCWA.

15 MS. WEBESTER: Thank you. I really appreciate
16 this Chair Hart.

17 And I don't mean to be rude, because right after
18 this, I'm going to leave because I have a nine-year-old
19 that is hopefully getting picked up VERSUS abandoned. So
20 I will be booking.

21 This discussion highly interests me. I
22 apologize, because I would like to stay more for the
23 discussion.

24 Debbie Webster, I'm the Executive Officer of the
25 Central Valley Clean Water Association. So thank you.

1 First, I'd like to go on the record by supporting
2 many of the late changes that staff proposed, especially
3 in regard to moving the compliance schedules within the
4 permit and the changes they made with regard to hardness.

5 I do want to speak about two aspects. We've been
6 talking a lot about this MUN designation. This is very
7 important. I so appreciate the discussion that has
8 happened with this. I so appreciate where the Board is
9 going with this, because it is so important.

10 So what you do, what decision you make, and
11 whether it's to go back where we think the sources of
12 drinking water policy provides the exception or to go
13 where you did with Colusa and ask the Regional Board
14 versus a small facility to do a de-designation, which is a
15 significant expense and requirement, it needs to happen.
16 Because, well, it just needs to happen.

17 So now I'm going to go back to another subject.
18 On the averaging period for THMs, the Board put in there
19 that THMs are a CTR constituent. They are not a CTR
20 constituent. There are THMs that are CTR constituents,
21 and the permit contains two effluent limits based on those
22 CTR constituents.

23 As such, it is appropriate through the SIP that
24 they get daily and monthly limits. However, total THMs is
25 not. And even the staff report -- and I've got an

1 underline/strike-out version on page F-41 identifies that
2 the total THM is a primary MCL. This MCL is based upon a
3 70-year exposure. And as such, in other permits and up
4 until this permit has had an annual averaging period.

5 If we turn to on the same underlike/strike-out
6 F-56 of the permit, it talks about Basin Plan objective
7 MCLs. And it basically says that the limits are going to
8 be applied either as monthly averages, daily averages, or
9 annual average effluent limitations depending on the
10 average period of the objective.

11 And I would submit to you that for total THMs,
12 the average period that's appropriate is an annual limit.
13 By making this -- by putting it as a daily and a monthly,
14 you make it much more stringent than it ever has to be.
15 There are limits that protect that are based upon the CTR,
16 and those are appropriately so. But this is not one that
17 is.

18 So therefore, what we're asking in this permit
19 that the annual limit of 80 micrograms per liter, which is
20 the primary MCL, be put in there for THMs, but not putting
21 them as a daily and monthly limit.

22 So thank you. I'll be happy to answer any
23 questions. But otherwise, I'll skedaddle.

24 CHAIRPERSON HART: Any questions for Ms. Webster?
25 No.

1 I hope your child isn't abandoned and you aren't
2 charged a million dollars in fees for overtime. Okay.

3 Could staff please provide us with a response on
4 the total THMs when they are ready?

5 NPDES PROGRAM MANAGER MESSINA: Yes. This is
6 Diana Messina.

7 Total THMs are made up of four CTR constituents.
8 And because of that, we have arrived to the conclusion
9 with the assistance of our legal counsel that total THMs
10 are a CTR constituent. And we have the state
11 implementation policy that directs us how to implement CTR
12 criteria for CTR constituents in an NPDES permit.

13 Now, there is not a numerical criteria in the CTR
14 for total THMs. And we do look to other standards to
15 implement this CTR constituents.

16 So other than that, I don' know if David wants to
17 pitch if or if he's busy there. But we have identified
18 that the total THMs are a CTR constituent. So with that,
19 we have to follow the SIP. The SIP requires us to put
20 monthly and daily effluent limitations in the permit.

21 CHAIRPERSON HART: So the fact that total THMs
22 themselves are not listed as a CTR constituent is not a
23 problem for staff or counsel?

24 EXECUTIVE OFFICER CREEDON: Arsenic fits the
25 definition or the description of Ms. Messina's and

1 applying the SIP is appropriate. But for the THM, there
2 is not a THM criteria in the CTR. So I don't think we're
3 bound, although --

4 CHAIRPERSON HART: It just --

5 EXECUTIVE OFFICER CREEDON: We're not bound by
6 the SIP for that constituent, even though the individual
7 components are parts of them that make up the THM happen
8 to be individual components identified in the CTR.

9 CHAIRPERSON HART: So we're not bound to do it to
10 make it --

11 EXECUTIVE OFFICER CREEDON: I don't think so, but
12 I'll let -- Lori wants to speak on it.

13 SENIOR STAFF COUNSEL OKUN: Total THMs aren't a
14 SIP constituent, but they are a pollutant that has an
15 objective. And EPA's regulations for permitting require
16 that limitations be expressed on a daily and monthly
17 basis, unless doing so is impracticable.

18 For secondary MCLs, which are based on
19 aesthetics, mostly taste and odor, the Board has taken the
20 position that using shorter than annual averaging periods,
21 in some cases, not all cases, is impracticable because it
22 results in unnecessarily stringent limits.

23 For primary MCLs, like total THMs that are based
24 on human health, EPA guidance is inconsistent with the
25 position it's impracticable to express those limits based

1 on shorter averaging periods.

2 The four THM constituents that are SIP
3 constituents also have criteria that are derived in the
4 SIP based on long-term exposure risks. So in that
5 respect, they're indistinguishable from other MCLs or
6 human health based objectives.

7 And so the question is: Can you take the
8 position that it's impracticable to express those as
9 shorter limits.

10 BOARD MEMBER LONGLEY: Shorter limits or --

11 SENIOR STAFF COUNSEL OKUN: Shorter averaging
12 periods?

13 BOARD MEMBER LONGLEY: They're asking for a year.

14 SENIOR STAFF COUNSEL OKUN: I'm sorry. The
15 question is whether it's impracticable to express those
16 based on shorter averaging periods, because if it's
17 impracticable to use monthly and daily limits, then that
18 argues in favor of expressing it as an annual limit. And
19 that's what the Board has done for secondary MCLs.

20 CHAIRPERSON HART: So have we ever done it for
21 primary MCLs?

22 SENIOR STAFF COUNSEL OKUN: No.

23 CHAIRPERSON HART: Okay. Not on any permit we --
24 no. Okay.

25 EXECUTIVE OFFICER CREEDON: It's usually only

1 associated with secondary where we go with annual. But
2 nitrate is a primary that usually comes up. And certainly
3 we don't do annual for nitrates. So we rarely look at the
4 other primary MCLs, because they're covered by the CTR.

5 I'm looking frantically through mine. I'll ask
6 staff: Did we show reasonable potential for THMs?
7 Because we do have individual THM constituents listed in
8 terms of the 80 that was exceeded.

9 NPDES PROGRAM MANAGER MESSINA: Yes. It was
10 exceeded.

11 CHAIRPERSON HART: Okay. So Carl has made a
12 suggestion that we move forward and --

13 BOARD MEMBER LONGLEY: Well, it would appear at
14 this point that there probably is not -- from what I'm
15 hearing and I respect Roberta Larson greatly. But it
16 would appear that there is not -- not that I don't think
17 we have great staff, too -- that we -- our hands are bound
18 when it comes to the municipal designation, unless we go
19 through a de-designation procedure.

20 And so I would propose -- and I'm very happy with
21 the rest of what -- as I stated earlier, much earlier, I'm
22 very happy with what staff has done with the other changes
23 to the permit and to the Cease and Desist Order. And I
24 would be happy to make a motion that would adopt the Cease
25 and Desist Order and this. But if we ask staff to go

1 forward with a Basin Plan amendment, do whatever it takes
2 to get the municipal out of there, I would presume that
3 until that happens, we have to stick with what's in this.

4 CHAIRPERSON HART: Right.

5 BOARD MEMBER LONGLEY: So we could ask for that.
6 And, obviously, if staff finds that lo and behind there is
7 a something someplace that can get us out of this mess,
8 they'll be back telling us. I doubt they'll find that,
9 unfortunately. That's my thought.

10 CHAIRPERSON HART: Okay. Soapy and then Dan.

11 BOARD MEMBER MULHOLLAND: It seems that it's been
12 pointed out this isn't going to be the only time we're
13 asked to do something that doesn't make sense on this very
14 issue.

15 So I'm wondering in terms of the Basin Plan
16 amendment if we can lump the other ones coming forward so
17 we can look at all of the ones and go for a Basin Plan
18 amendment or we have to do this individually.

19 CHAIRPERSON HART: I think it has to happen
20 individually.

21 BOARD MEMBER MULHOLLAND: Somehow we, the
22 Board -- you're telling me, made this insane law and --

23 CHAIRPERSON HART: Our predecessors made this
24 insane law.

25 BOARD MEMBER MULHOLLAND: So to tell me that you

1 can't undo that drives me crazy.

2 If you're saying you can't ever undo anything

3 when you make a mistake, that does not ring true to me
4 with anything I believe. If you're telling me it can only
5 be done through a Basin Plan amendment and only be done at
6 great expense one exclusion at a time, I want to say to
7 staff counsel, come up with a better plan, because I can't
8 buy that. And I can't vote for this under that scenario.
9 I mean, that's like saying you can't overturn anything in
10 our country, and I don't buy that.

11 CHAIRPERSON HART: Well stated, Soapy.

12 And Dan and then Carl.

13 BOARD MEMBER ODENWELLER: I was thinking back
14 over my tenure of the Board, and I seem to recall a permit
15 that was adopted five or six years ago. Involved a small
16 community -- mining community in the foothills on the west
17 side of the San Joaquin Valley down south. And it had a
18 water body that went through the main street of town and
19 it was designated municipal. And the Board waved it --
20 the representation of the applicant that nobody had ever
21 seen a fish in the river, because nobody ever seen any
22 water in the channel in recent times.

23 And so we, as I recall, changed the designation
24 at that time. Now, that might have been before some of
25 these decisions were made. But I have a recollection of

1 an action like that that I found curious at the time.

2 BOARD MEMBER LONGLEY: It was a mercury mine

3 southern coast range in our hydrological region. I forget
4 the name of it.

5 CHAIRPERSON HART: In that instance, I'm not
6 recalling that instance specifically. But if there was no
7 water in it, I think that's a factual distinction that
8 probably has some bearing.

9 EXECUTIVE OFFICER CREEDON: That would not be the
10 MUN designation. Maybe there was an opportunity because
11 staff -- it wasn't designated downstream, and staff may
12 have. I don't know the circumstances to that. I don't
13 remember that at all.

14 But this is a little different in the fact the
15 blanket application, which this Board chose to apply when
16 it brought it into the Basin Plan. So it's a little
17 different circumstance I think. I don't know the case
18 you're speaking about.

19 CHAIRPERSON HART: Go ahead.

20 BOARD MEMBER LONGLEY: I have a question for
21 Counsel Coupe. And Lori, don't chime in.

22 CHAIRPERSON HART: This is not a test, David.

23 BOARD MEMBER LONGLEY: If we went -- if this
24 Board back in 1988 put something in the Basin Plan that is
25 causing all of this nuisance, why can't the Board doing

1 something with that?

2 CHAIRPERSON HART: Why can't we retract that
3 decision?

4 BOARD MEMBER LONGLEY: Exactly.

5 CHAIRPERSON HART: Because I'm thinking this
6 Board is ready to do that.

7 STAFF COUNSEL COUPE: Again, at the point of
8 sounding really repetitive, the ability to do that in
9 State Board orders, including Vacaville, and I think the
10 subsequent order made it clear the Board can't
11 self-implement a change in the municipal use designation
12 for a water body through a permitting action. They have
13 to specifically go through a Basin Plan amendment process
14 to do that.

15 BOARD MEMBER LONGLEY: But that's what I'm
16 saying. We could go through it and get at what Soapy was
17 talking about. If we would change some language that
18 would drop certain of these communities out that -- or not
19 community -- water bodies out that have just because of
20 this blanket order -- in other words, we would stipulate
21 which kinds of water bodies don't fall into the municipal
22 use.

23 STAFF COUNSEL COUPE: Certainly, if the Board
24 wants to re-visit the specific language as it exists in
25 the Basin Plan and make a determination as to particular

1 water bodies that it may want to choose to exempt from the
2 municipal use designation that's provided in the sources
3 of drinking water policy, they certainly have the
4 discretion to do that. But that would be a long --
5 probably be a long process.

6 BOARD MEMBER LONGLEY: What I'm hearing you say
7 is we would go water body by water body. That's not what
8 I'm suggesting. I'm suggesting criteria in the Basin Plan
9 that would remove certain bodies of water from the
10 municipal designation.

11 EXECUTIVE OFFICER CREEDON: Dr. Longley, we did
12 do that with the groundwater component when we
13 implemented. For some reason, the Board back then chose
14 not to do that same process for surface water. I'm
15 assuming it can be. But I don't know if that means we can
16 grandfather in all those other water bodies that have
17 already been designated by previous action by this Board.
18 And I guess David can weigh in on that.

19 STAFF COUNSEL COUPE: I just want to point out
20 that would also be a very significant action on behalf of
21 the Board if they wanted to pursue that course of action.
22 And I would -- quite frankly, I need to do quite a bit of
23 research to determine when, how, and under what conditions
24 the Board could be willing to entertain something like
25 that in the form of a Basin Plan amendment.

1 BOARD MEMBER LONGLEY: I personally -- as one
2 Board member, I think we need to do it. Because look at
3 the time we're wasting just on -- not wasting, but that
4 we're spending on this item. And it goes and it comes
5 back time and time again.

6 Speaking as one Board member, I suspect what the
7 feeling up here is totally.

8 CHAIRPERSON HART: Sandra is next and then Dan.

9 BOARD MEMBER MERAZ: I just want to say I agree
10 with Mr. Longley and Soapy. But I wasn't here in '89, but
11 I guess I was here when we made this Basin Plan.

12 CHAIRPERSON HART: No.

13 BOARD MEMBER MERAZ: This one here that we're
14 talking about. So --

15 CHAIRPERSON HART: No.

16 BOARD MEMBER MERAZ: No, I won't take the blame
17 here. I was worried. I thought I had something to do
18 with it.

19 Anyway, there's so many things I read and heard.
20 And I'm usually very quiet do my own thinking. But I
21 think that we need to do what we're supposed to do and
22 maybe look at all of this, like Soapy and Mr. Longley have
23 said. Since I'm not at fault here, I just --

24 CHAIRPERSON HART: Dan.

25 BOARD MEMBER ODENWELLER: Sandra, you're right on

1 scheduling for developing your voice as a Board member.
2 It takes a couple three years to get up to speed.

3 I will point out that doing that is going to
4 involve a significant CEQA effort. And CalSPA is probably
5 going to go crazy over it. But that's neither here nor
6 there. If we got to do it, we've got to do it.

7 I also reminiscing over here on old permits
8 recall one up by Clear Lake that involved a mine and a
9 stretch of stream that had a section that was designated
10 and a section that wasn't designated. And we made those
11 decisions here. So I just have to figure out if I can
12 find the files.

13 CHAIRPERSON HART: Yes, Lyle.

14 BOARD MEMBER HOAG: If this Board were to act
15 today to direct staff to develop -- essentially develop a
16 work plan for modification of the basin plan, then what
17 are the appropriate alternative actions that we could
18 consider for this particular order today or in the near
19 future? We need to do something to let these folks go
20 home and finish their construction project. What do we do
21 then?

22 EXECUTIVE OFFICER CREEDON: This is a problem,
23 because they would take this permit and then move forward
24 to try to design. What you've heard today, for them to
25 get this permit will cost money for them to do the design.