


DOWNEY BRAND LLP

1 DOWNEY BRAND LLP  
2 MELISSA A. THORME (SBN 151278)  
3 621 Capitol Mall, 18th Floor  
4 Sacramento, CA 95814-4686  
5 Telephone: (916) 520-5376  
6 Facsimile: (916) 520-5776

7 Attorneys for Petitioner



8 BEFORE THE

9 CALIFORNIA STATE WATER RESOURCES CONTROL BOARD

10 In the Matter of the Camarillo Sanitary )  
11 District's Petition for Review of Action and )  
12 Failure to Act by the California Regional )  
13 Water Quality Control Board, Los Angeles )  
14 Region, in Adopting Order Nos. R4-2014- )  
15 0062 and R4-2011-0126-A02 for the )  
16 Camarillo Sanitary District Water Reclamation )  
17 Plant. )

PETITION FOR REVIEW;  
PRELIMINARY POINTS AND  
AUTHORITIES IN SUPPORT OF  
PETITION (WATER CODE  
SECTIONS 13320 and 13321 (stay  
requested))

18 Petitioner Camarillo Sanitary District ("District"), in accordance with section 13320 of the  
19 Water Code, hereby petitions the State Water Resources Control Board ("SWRCB" or "State  
20 Board") to review Order Nos. R4-2014-0062 and R4-2011-0126-A02 of the California Regional  
21 Water Quality Control Board, Los Angeles Region ("RWQCB" or "Regional Board") reissuing the  
22 National Pollutant Discharge Elimination System ("NPDES") Permit for the Camarillo Sanitary  
23 District Water Reclamation Plant ("Camarillo WRP") and an accompanying Time Schedule Order  
24 ("TSO"). Copies of Order Nos. R4-2014-0062 and R4-2011-0126-A02 are attached to this Petition  
25 as Exhibits A and B, respectively. A copy of this Petition has been sent to the RWQCB. The  
26 issues and a summary of the bases for the Petition follow. At such time as the full administrative  
27 record is available and any other material has been submitted, the District will file a more detailed  
28 memorandum in support of the Petition.<sup>1</sup>

<sup>1</sup> The State Board's regulations require submission of a memorandum of points and authorities in support of a petition, and this document is intended to serve as a preliminary memorandum. However, it is impossible to prepare a thorough memorandum or a memorandum that is entirely useful to the reviewer in the absence of the complete administrative record, which is not yet available.

1 **FACTUAL BACKGROUND**

2 The Camarillo WRP discharges wastewater to Conejo Creek, which was previously  
3 regulated by Order No. R4-2003-0079 (as revised by Order No. R4-2004-0121) and National  
4 Pollutant Discharge Elimination System (NPDES) Permit No. CA0053597 adopted on June 5,  
5 2003, and expired on May 10, 2008. Concurrent with adoption of Order No. R4-2003-0079, this  
6 Regional Board adopted TSO No. R4-2003-0080, which prescribed interim effluent limits for  
7 chloride. The terms and conditions of the current NPDES order were administratively continued  
8 and will remain in effect until the new permit becomes effective on July 1, 2014.

9 Prior to the permit being issued in 2003, the District filed a petition for review on April 29,  
10 2002, with the State Board of specific effluent limitations and requested a stay. The State Board  
11 issued Order No. WQO 2002-0017 on October 17, 2002, approving a "Stipulation for Order  
12 Issuing Stay" staying the chloride effluent limitations. The remaining petition issues, related to the  
13 Regional Board's failure to extend interim chloride limits, were held in abeyance for three years.

14 Subsequently, on July 7, 2003, the District filed a petition of the newly adopted permit with  
15 the State Board seeking, *inter alia*, review of the chloride effluent limitations in Order No. R4-  
16 2003-0079 and TSO No. R4-2003-0080, and later formally requested that the State Water Board  
17 issue a stay of those limitations.

18 On October 20, 2003, the District, the City of Thousand Oaks, the City of Simi Valley and  
19 the Regional Board entered into a stipulation entitled Stipulation for Further Order Issuing  
20 Stay, which stayed the final chloride effluent limitations in the NPDES permits, as well as related  
21 provisions pertaining to chloride limits in the TSOs, for those three wastewater treatment plants.  
22 Specific to the Camarillo WRP, the stipulation stayed the final chloride effluent limitations in  
23 Order No. R4-2003-0079 and the interim chloride effluent limitations in TSO No. R4-2003-  
24 0080. On November 19, 2003, the State Board adopted Order WQO 2003-0019 approving the  
25 stipulation for stay.

26 On April 2, 2007, the Regional Board's Executive Officer administratively issued TSO No.  
27 R4-2007-0010 for the Camarillo WRP. The TSO, which expired on January 31, 2011, contained  
28

1 performance-based interim effluent limitations for Total Dissolved Solids (“TDS”) and sulfate,  
2 calculated using the ninety-fifth percentile of the Camarillo WRP’s effluent data from August 2003  
3 through May 2006. An interim effluent limitation for chloride was not provided in TSO No. R4-  
4 2007-0010 because the State Board-stipulated stay for chloride remained in effect.

5 On April 3, 2008, tentative waste discharge requirements prepared for the Camarillo WRP  
6 and for other wastewater treatment plants in the Calleguas Creek watershed were provided to  
7 interested persons and comments were solicited. However, Regional Board staff ultimately chose  
8 not to take those tentative waste discharge requirements to the Regional Board for consideration at  
9 that time.

10 On April 14, 2011, the Regional Board held a hearing to consider adoption of the proposed  
11 tentative NPDES permit for the Camarillo WRP. However, the District testified that the interim  
12 effluent limits for salts (such as TDS, sulfate and chloride), which were based upon the interim  
13 Waste Load Allocations (“WLAs”) in the Calleguas Creek Watershed Salinity Total Maximum  
14 Daily Load (“Salts TMDL”) set equal to the 95th percentile concentration of available discharge  
15 data (*see* Order No. R4-2007-016, Attachment A at pg. 6), would be unattainable during the period  
16 of time in which the Permittee has committed to constructing and finishing capital improvement  
17 projects to comply with the WLAs specified in the Salts TMDL. The District requested higher  
18 performance-based interim effluent limits, stating that the concentrations of chloride, TDS, and  
19 sulfate in their potable water supply have increased since the time that the Salts TMDL was  
20 developed.<sup>2</sup> The Regional Board directed its staff to pursue alternatives with the District to resolve  
21 salts issues while implementing the regional salinity management pipeline solution.

22 The Regional Board has recognized the District’s conditions are unique because:

23 a. The District’s discharge is located a few miles upstream of a tidally-influenced reach of  
24 Calleguas Creek;

25 b. The District has worked cooperatively and effectively for many years to develop a  
26

27 <sup>2</sup> The Salts TMDL stated that “POTW allocations can be adjusted upwards when imported water supply chloride  
28 concentrations exceed 80 mg/L and discharges from the POTW exceed the WLA.” Order No. R4-2007-016,  
Attachment A at pg. 5.

1 regional solution to remedy salt and other water quality impairments through the Calleguas Creek  
2 Watershed program – all without being mandated to do so in any permit; and,

3 c. The ultimate watershed solution involves desalting groundwater and building a regional  
4 brine line that will resolve surface water impairments as well as improve groundwater quality in  
5 the watershed. (*See accord* TSO, Order No. R4-2011-0126-A02 at pg. 6.) A TSO was issued to  
6 the District in 2011 with performance-based interim limits for TDS and sulfate, but not for chloride  
7 since the stipulated stay for chloride remained in place.

8 In adopting the current Permit and revising the 2011 TSO, the Regional Board ignored this  
9 entire history and the proactive approaches taken by the District and the other publicly owned  
10 treatment works (“POTWs”) in the watershed and the efforts undertaken to create watershed  
11 solutions. Instead, the Regional Board imposed final effluent limitations for which the District  
12 cannot consistently comply. This Petition seeks to undo the adage that “no good deed goes  
13 unpunished.”

14 The District seeks Permit and TSO modifications that recognize the Watershed Approach  
15 touted by the Regional Board (Permit at pg. F-19) and to prevent the District from being in  
16 compliance jeopardy. If these issues are not remedied, the future of the watershed approach in  
17 California may be severely impaired because all benefits to such an approach were eradicated in  
18 this Permit.

19 **1. NAME, ADDRESS, TELEPHONE NUMBER AND EMAIL ADDRESS (IF  
20 AVAILABLE) OF PETITIONER:**

21 Lucie McGovern  
22 Camarillo Sanitary District  
23 601 Carmen Drive, P.O. Box 248  
24 Camarillo, CA 93011-0248  
25 Telephone: (805) 388-5334 / [lmcgovern@ci.camarillo.ca.us](mailto:lmcgovern@ci.camarillo.ca.us)

26 All correspondence related to this petition should also be sent to:

27 Melissa Thorme  
28 Downey Brand LLP  
621 Capitol Mall, 18th Floor  
Sacramento, CA 95814-4686  
Telephone: (916) 520-5376 / [mthorme@downeybrand.com](mailto:mthorme@downeybrand.com)

1 **2. THE SPECIFIC ACTION OR INACTION OF THE REGIONAL BOARD WHICH**  
2 **THE STATE BOARD IS REQUESTED TO REVIEW:**

3 Petitioner seeks review of Order Nos. R4-2014-0062 and R4-2011-0126-A02, which  
4 reissue NPDES Permit No. CA0053597 (the "Permit") and amend a TSO for the Camarillo  
5 Sanitary District. The specific Permit requirements which the District requests the State Board  
6 review include the following:

- 7 (A) Improper final numeric effluent limitations for salts without necessary compliance  
8 schedules authorized by the applicable TMDLs.
- 9 (B) Inclusion of numeric "Pass" and "% Effect" chronic toxicity limits mandating the  
10 use of the Test of Significant Toxicity (TST), which are contrary to State Board  
11 precedent and the implementation provisions of the Calleguas Watershed Toxicity  
12 TMDL.
- 13 (C) Other Improper and Problematic Effluent Limitations.
- 14 (D) Unnecessary and Burdensome Monitoring and Reporting Requirements.
- 15 (E) Improper Miscellaneous Provisions.

16 The State Board is also requested to review the Regional Board's actions in adopting the  
17 Permit and TSO for compliance with due process, the California Water Code, the California  
18 Administrative Procedures Act ("APA," Cal. Gov't Code, section 11340 *et seq.*), the California  
19 Environmental Quality Act ("CEQA," Cal. Public Resources Code, section 21000 *et seq.*) in its  
20 environmental checklists for the TMDLs adopted and implemented in these permits, the Policy for  
21 Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of  
California (SIP), and EPA regulations, as applicable.

22 **3. THE DATE ON WHICH THE REGIONAL BOARD ACTED, OR REFUSED TO**  
23 **ACT:**

24 The Regional Board adopted the Permit and TSO on May 8, 2014 in Simi Valley,  
25 California.

1 **4. A FULL AND COMPLETE STATEMENT OF THE REASONS THE ACTION OR**  
 2 **FAILURE TO ACT WAS INAPPROPRIATE OR IMPROPER:**

3 The District's preliminary statement of points and authorities is set forth in Section 7  
 4 below. The District may supplement this statement upon receipt and review of the hearing  
 5 transcript and the full administrative record, which must include the records for each of the TMDLs  
 6 implemented in this Permit to be able to determine whether the Permit is consistent with the  
 7 TMDLs. While Section 7 details the reasons why the actions by the Regional Board were  
 8 inappropriate and improper, the two main issues in this Petition relate to salinity and toxicity limits.

9 The reasons that the Regional Board's action to include final effluent limitations for salinity  
 10 in the Permit was inappropriate or improper include, but are not limited to, the following:

- 11 a. Inconsistency with the Clean Water Act and Basin Plan provisions, including the  
 12 Salts TMDL<sup>3</sup>;
- 13 b. Ignoring the Watershed Approach to water quality regulation; and
- 14 c. Placing the District in compliance jeopardy unnecessarily by including final effluent  
 15 limitations without compliance schedules approved in the applicable TMDL.

16 The reasons that the Regional Board's action to include the Permit's numeric chronic  
 17 toxicity effluent limitations based on a Pass/Fail approach using the Test of Significant Toxicity  
 18 (TST) guidance methodology was inappropriate or improper include, but are not limited to, the  
 19 following:

- 20 a. Premature until the State Water Board adopts a statewide Toxicity Plan or Policy;
- 21 b. Inconsistent with the applicable Calleguas Creed Watershed Toxicity, Chlorpyrifos  
 22 and Diazinon TMDL (April 25, 2005) ("Toxicity TMDL")<sup>4</sup>;
- 23 d. Improperly based on EPA guidance, not promulgated EPA regulation and methods;
- 24 e. Inclusion of unlawful and inappropriate Maximum Daily limits for Chronic  
 25 Toxicity; and

26 <sup>3</sup> To the extent that any TMDL discussed in this Petition is itself unlawful or includes requirements contrary to law,  
 27 the District also challenges the TMDL as applied for the first time in this Permit.

28 <sup>4</sup> The Toxicity TMDL may itself be unlawful, be unsupported by evidence, or include requirements contrary to law.  
 The Toxicity TMDL was based on listing data from 1992 and 1993, taken long before ammonia control technology  
 was implemented at the local POTWs and before substantial Best Management Practices ("BMPs") were in place with  
 municipal stormwater and agricultural discharges. The Toxicity TMDL specifically states that "No additional data  
 were reviewed during the water quality assessments in 1998 and 2002 for this reach." Toxicity TMDL at pgs. 17-20.

1 f. Improper determination that numeric limits are required.

2 In Section 7, the District asserts that provisions of Order Nos. R4-2014-0062 and R4-2011-  
3 0126-A02 are inconsistent with the law and otherwise inappropriate for various reasons, including:  
4 failure to comply with the Porter-Cologne Water Quality Control Act (Cal. Water Code, section  
5 13000 *et seq.*); failure to comply with CEQA and the APA; inconsistency with the Water Quality  
6 Control Plan, Los Angeles Region (“Basin Plan”), including amendments made to incorporate  
7 various TMDLs; inconsistency with the Clean Water Act (33 U.S.C. § 1251 *et seq.*) and its  
8 implementing regulations (40 C.F.R. Parts 122, 123, 130, 131, 133, and 136); absence of findings  
9 supporting the provisions of the Order; the inclusion of findings not supported by the evidence; and  
10 other grounds that may be or have been asserted by the District or the other permittees at the same  
11 hearing, whose testimony and comments were incorporated by reference by the District.

12 **5. THE MANNER IN WHICH THE PETITIONER IS AGGRIEVED:**

13 The District is aggrieved because the challenged requirements contained in the Permit are  
14 unnecessary, inconsistent with law, infeasible to consistently comply with, and may place the  
15 District in enforcement jeopardy from civil and even criminal enforcement actions or from third  
16 party citizen suits under the Clean Water Act. The District has already suffered through a large  
17 Mandatory Minimum Penalties (“MMP”) complaint and settlement for \$864,000,<sup>5</sup> of which the  
18 majority of the penalties were for salts. The imposition of such penalties when a watershed-based  
19 solution was in the process of being designed and implemented represents a waste of  
20 taxpayer/ratepayer funds both at the state and local levels. The District is further aggrieved  
21 because many of the effluent limits and requirements were imposed without adequate justification  
22 and legal authority and without any demonstrated water quality or other public benefit. The  
23 District is also aggrieved by the fact that all of the time, effort, and resources being spent on the  
24 watershed process effectively became a wasted effort by the adoption of this Permit, which failed

25  
26  
27 <sup>5</sup> Enforcement is not theoretical in this case. In Settlement Agreement and Stipulation for Order No. \$2-2012-0138-M,  
28 \$394,500 of the MMP penalties went to the Cleanup and Abatement Account and \$469,500 went to a Supplemental  
Environmental Program (“SEP”). Of the alleged violations, approximately 114 were for TDS, 45 were for sulfate, 28  
were for boron (since there was inexplicably a daily maximum of 1 mg/L for this long-term MCL-based objective), and  
3 were for chloride (for daily maximum limit of 190 mg/L prior to the issuance of the stay in 2003).

1 to acknowledge the teamwork that went into the TMDL implementation plan and compliance  
2 schedule.

3 **6. THE SPECIFIC ACTION THE PETITIONER REQUESTS THAT THE STATE OR**  
4 **REGIONAL BOARD TAKE:**

5 Petitioner seeks an Order by the State Board that will modify or remand Order Nos. R4-  
6 2014-0062 and R4-2011-0126-A02 to the Regional Board for revisions that:

7 A. Remove all final numeric effluent limitations for salinity constituents (chloride,  
8 sulfate, and Total Dissolved Solids (“TDS”)) and insert compliance schedules in the Permit  
9 where authorized by TMDLs to ensure that the watershed approach has time to be fully  
10 implemented.

11 B. Remove all numeric “Pass” and “% Effect” chronic toxicity limits mandating the  
12 use of the Test of Significant Toxicity (“TST”), along with all related findings and  
13 requirements, and replace those provisions with the previous narrative effluent limitation  
14 for chronic toxicity and trigger of 1 TUc (and related provisions) consistent with State  
15 Water Board precedent and the implementation provisions of the Calleguas Watershed  
16 Toxicity TMDL.

17 C. Remove all limits without demonstrated reasonable potential, and other limits  
18 inconsistent with federal law requirements.

19 D. Remove all unnecessary and burdensome monitoring requirements.

20 E. Correct the miscellaneous issues raised by the District.

21 **7. A STATEMENT OF POINTS AND AUTHORITIES IN SUPPORT OF LEGAL**  
22 **ISSUES RAISED IN THE PETITION:**

23 **A. Improper Salinity Final Effluent Limits without Compliance Schedules in the**  
24 **Permit.**

25 The Permits contains final effluent limits for salinity constituents (chloride, sulfate, and  
26 TDS) equivalent to final WLAs from the Salts TMDL or the water quality objective applied end-  
27 of-pipe. There are several references in the Permit and TSO to the Camarillo WRP’s inability to  
28 comply with these final effluent limits and the need for interim limits. *See* Permit at pgs. F-25 to F-  
26, TSO at pgs. 5-7, ¶¶ 16-23. The initial justification for placing these infeasible final limits in the  
27 Permit was because the TMDL was not approved pursuant to Section 303(c) of the Clean Water  
28

1 Act.<sup>6</sup> Then, the justification was changed to be that “the City [sic] has not submitted sufficient  
 2 information to justify the inclusion of a compliance schedule for chloride pursuant to the  
 3 Compliance Schedule Policy or federal regulations.” (See Regional Board’s response to the  
 4 District’s comments at pg. 48). Therefore, interim limits and compliance schedules were included  
 5 in a separate TSO. The District asked that the interim limits established in the District’s TSO, while  
 6 higher than the WLAs in the Salts TMDL, be found to be consistent with the Salts TMDL  
 7 requirements and moved from the TSO to the Permit. The District also asked that the final numeric  
 8 effluent limitations be removed from the Permit as unattainable in the near term. Neither of these  
 9 requests was granted.

10 1. **Salinity Final Numeric Effluent Limits Need Not be Included in the**  
 11 **Permits.**

12 On May 1, 2014, the Regional Board requested supplemental comments on alternatives to  
 13 including final limits in order to address the watershed approach for salinity control. The District  
 14 provided those comments and cited to the United States Supreme Court case of *Arkansas v.*  
 15

---

16 <sup>6</sup> The Tentative Order’s Fact Sheet at Section VI.B.7., Compliance Schedules, stated that “since the Salts TMDL was  
 17 approved by EPA under CWA § 303(d), instead of 303(c), the interim WLAs and the compliance schedule cannot be  
 18 included in the NPDES Order.” This sentence was legally incorrect and ultimately removed because approval under  
 19 section 303(c) is not required. See 33 U.S.C. §1313(e)(3)(A) and (F)(compliance schedules under the non-  
 20 discretionary EPA approval [“shall approve”] requirements of the Continuing Planning Process in section (e), not  
 21 section (c)). Federal rules (40 C.F.R. §122.47(a)), Regional Board Basin Plans, and the State Water Board’s  
 Compliance Schedule Policy, Res. No. 2008-0025, expressly allows compliance schedules, including those for  
 TMDLs, in permits. In addition, implementation plans for TMDLs are not subject to EPA review and approval as  
 water quality standards (see 40 C.F.R. §131.5(a)), approval is required only of the TMDL itself (33 U.S.C.  
 §1313(d)(1)(D)(2), (e)(3)(C)):

22 6) c) A Water Board may establish a compliance schedule that exceeds ten years in a permit that ... has a  
 23 permit limitation that implements or is consistent with the waste load allocations specified in a TMDL that is  
 24 established through a Basin Plan amendment, *provided that the TMDL implementation plan contains a*  
*compliance schedule or implementation schedule.* (See State Water Resources Control Board Res. No. 2008-  
 0025, POLICY FOR COMPLIANCE SCHEDULES IN NATIONAL POLLUTANT DISCHARGE  
 ELIMINATION SYSTEM PERMITS at pg. 5. (italics added).)

25 Finally, the State Board Compliance Schedule Policy came after many of the TMDLs at issue in this Petition and did  
 26 not supersede “existing compliance schedule provisions in TMDL implementation plans that are in effect as of the  
 27 effective date of Resolution No. 2008-0025. (See SWRCB Res. No. 2008-0025 at pg. 7, para. 11; see also  
 28 Administrative Update of the Water Quality Control Plan for the Los Angeles Region – Chapter 3: “Water Quality  
 Objectives”, Los Angeles Regional Board, February 19, 2013 at pg. 10.) Because implementation plans are created  
 under state law, these plans become effective when approved by the Office of Administrative Law and have  
 independent applicability as regulations.

1 *Oklahoma*, where the Court recognized “the Clean Water Act vests in the EPA and the States broad  
2 authority to develop long-range, area-wide programs to alleviate and eliminate existing pollution.”  
3 *Arkansas v. Oklahoma*, 503 U.S. 91, 108 (1992).

4 The District also pointed to *Communities for a Better Environment*, where the court found  
5 that an enforceable “schedule of compliance” leading to the adoption of final effluent limitations  
6 designed to achieve water quality standards (such as at the completion of a TMDL) constituted an  
7 acceptable WQBEL for purposes of the Clean Water Act. (*Communities for a Better Environment*,  
8 *supra*, 109 Cal.App.4th at pp.1106-1107.) Since a TMDL is adopted because water quality  
9 standards are not being met and includes a plan and a process for coming into compliance with  
10 those standards at the end of the TMDL compliance schedule, it is not appropriate to include final  
11 numeric effluent limitations that are essentially the water quality objective at end of pipe until the  
12 plan and the process included in the TMDL is complete. Therefore, the final numeric effluent  
13 limitations should be referenced in a finding and a narrative effluent limitation could be imposed  
14 requiring participation in the implementation of the TMDL that, along with the interim limits in the  
15 TMDL, would work to hold the status quo on the point sources while the other components of the  
16 plan and the process for improvements on a watershed level scale are implemented. As previously  
17 stated, the definition of “effluent limitation” in the Clean Water Act refers to “*any restriction*,” and  
18 may include a “*schedule of compliance*.” (33 U.S.C. § 1362(11); 40 C.F.R. §122.2.)

19 The *Communities for a Better Environment* case also held that “numeric effluent limitations  
20 are not legally required.” 109 Cal. App. 4th at 1106. So a narrative effluent limitation to maintain  
21 the status quo along with a compliance schedule implementing the interim limits while the TMDL  
22 schedule is completed is “consistent with the assumptions” of the TMDL that has a long term  
23 schedule, understanding that the issues of addressing salinity holistically in the watershed will take  
24 time. Imposing final numeric effluent limitations based on the standard that is acknowledged  
25 won’t be met until TMDL implementation is complete will impose liability and/or extraordinary  
26 treatment requirements on the permittees that “may become unnecessary” because the watershed  
27 programs ultimately are intended to “provide assimilative capacity for the point source discharges.”  
28 109 Cal. App. 4th at 1103. “The TMDL program considers all pollutant sources within a

1 watershed and focuses on a watershed-wide solution to the impairment.” SWRCB Order No.  
2 2001-0006 at 23. “A TMDL is ‘derived from *and complies with*’ the applicable water quality  
3 standard.” *Id.* at 24 (emphasis added). Thus, it only makes sense that “[p]ermit findings ... reflect  
4 that final water quality-based effluent limitations ... will be derived from wasteload allocations in  
5 the applicable TMDL” after completion of the compliance schedule (*id.* at 25), and that those  
6 allocations apply after the plan and the process have been implemented on a watershed basis.

7 “The continuing planning process established by section 303(e) of the CWA provides a  
8 good framework for implementing TMDLs....” *See* EPA HQ Memorandum from Robert  
9 Perciasepe to Regional Administrators on “New Policies for Establishing and Implementing Total  
10 Maximum Daily Loads (TMDLs),” (1997); *see also* 33 U.S.C. §1313(e)(3)(A) and (F)(compliance  
11 schedules under the non-discretionary EPA approval [“shall approve”] requirements of the  
12 Continuing Planning Process in section (e), not section (c)). According to the Ninth Circuit Court  
13 of Appeal, Section 303(e), requires each State to have a “continuing planning process,” and gives  
14 some operational force to the prior information-gathering provisions [under §303(d)]. *Pronsolino*  
15 *v. Nastri*, 291 F.3d 1123, 1128 (9th Cir. 2002). The EPA must approve a State's continuing  
16 planning process if it “will result in plans for all navigable waters within such State” that include,  
17 *inter alia*, effluent limitations, TMDLs, area-wide waste management plans for nonpoint sources of  
18 pollution, and plans for “adequate implementation, including schedules of compliance....” *Id.*  
19 *citing* 33 U.S.C. §303(e)(3). The Court held that the upshot of this intricate scheme is that the  
20 CWA leaves to the States the responsibility of developing plans to achieve water quality standards,  
21 while providing federal funding to aid in the implementation of the state plans. *Id.* at 1128-29  
22 *citing* *Dombeck*, 172 F.3d at 1097; 33 U.S.C. §303(e); 33 U.S.C. §319(h), 33 U.S.C. §1329(h)  
23 (providing for grants to States to combat nonpoint source pollution). TMDLs are primarily  
24 informational tools that allow the States to proceed from the identification of waters requiring  
25 additional planning to the required plans. *Id.* at 1129 *citing* *Alaska Center for the Environment v.*  
26 *Browner*, 20 F.3d 981, 984-85 (9th Cir.1994). As such, TMDLs serve as a link in an  
27 implementation chain that includes federally-regulated point source controls, state or local plans  
28 for point and nonpoint source pollution reduction, and assessment of the impact of such measures

1 on water quality, all to the end of *eventually* attaining water quality goals for the nation's waters. *Id.*  
2 at 1129, 1137 (“the basic purpose for which the § 303(d) list and TMDLs are compiled, the  
3 *eventual attainment* of state-defined water quality standards.” (emphasis added)).

4 States must implement TMDLs only to the extent that they seek to avoid losing federal  
5 grant money; no pertinent statutory provision otherwise requires implementation of Section 303  
6 plans or providing for their enforcement. *Id.* at 1140 *citing* CWA §309, 33 U.S.C. §1319; CWA  
7 §505, 33 U.S.C. §1365. The nature of the allocations and of the implementing controls remains up  
8 to the States. *Id.* at fn. 19; *see also* Water Code §13242 (requiring implementation plans, including  
9 time schedules for compliance, for all water quality objectives). EPA has no authority for approval  
10 of TMDL or Water Code section 13242 implementation plans and has no say as to whether States  
11 include compliance schedules authorized under those plans in the permits.

12 The State Water Board’s Compliance Schedule Policy expressly allows compliance  
13 schedules, including those for TMDLs, in permits “*provided that the TMDL implementation plan*  
14 *contains a compliance schedule or implementation schedule.*” (See State Board Res. No. 2008-  
15 0025, Compliance Schedule Policy at pg. 5 (italics added).)

16 “If a compliance schedule is within the term of the permit, the final effluent limitations are  
17 included in the permit provisions. If the compliance schedule exceeds the length of the permit, the  
18 final effluent limitations are included in the permit findings. In the latter case, the findings include:  
19 (1) the water quality to be achieved, (2) the reason the final water quality-based effluent limitation  
20 is not being incorporated into the permit as an enforceable effluent limitation at this time; (3) a  
21 statement that it is the intent of the Regional Board to include, in a subsequent permit revision, the  
22 final water quality-based effluent limitations as an enforceable limitation.... The permit findings  
23 also state the appropriate enforcement actions that may be taken by the Regional Board if the  
24 interim limitations and requirements are not met.” SWRCB, *Report in Support of U.S.*  
25 *Environmental Protection Agency’s Review of California’s Continuing Planning Process* (May  
26 2001) at 30. Since under the Salinity TMDL, compliance with the TMDL targets will be based on  
27 a 15-year implementation schedule, this exceeds the length of a permit and justifies inclusion of a  
28 compliance schedule in lieu of final limits. SWRCB Res. No. 2008-0033, para. 6.

1 The TMDL resolution (No. R4-2007-016) for the Salinity TMDL expressly recognized that:  
 2 Economic considerations were considered and are reflected in an implementation program  
 3 that is flexible and allows 15 years for POTWs... to comply with the final allocations."  
 (Para. 19.)

4 Interim limits are included to allow time for dischargers to put in place implementation  
 5 measures necessary to achieve final waste load allocations. (Attachment A at 6.)

6 Finally, the schedule states that 15 years from the effective date of the TMDL...

7 The TMDL was incorporated into the Basin Plan as required by federal regulation, as was  
 8 the associated implementation schedule. 40 C.F.R. §130.6(c)(1) and (6). All NPDES permits must  
 9 "ensure consistency with the requirements of a Water Quality Management Plan [Basin Plan]." 40  
 10 C.F.R. §122.44(d)(6). Thus, all permits must be consistent with the TMDL and schedules adopted  
 11 therein that were made part of the Los Angeles Region's Basin Plan.<sup>7</sup>

12 Each of these citations argues strongly against the Regional Board's assertion that final  
 13 numeric effluent limitations for TMDL-controlled constituents need to be imposed and met before  
 14 the end of the TMDL compliance schedule. Such an interpretation renders the TMDL's  
 15 compliance schedule completely superfluous.<sup>8</sup> The Regional Board clearly agreed in the Salinity  
 16 TMDL to provide the POTWs in the Calleguas Watershed with adequate time for compliance. The  
 17 Regional Board should not now renege on that agreement by violating the express terms of the  
 18 Basin Plan amendment it specifically agreed upon and adopted.

19 **2. Ample Authority Exists to Include the Compliance Schedule in the Permit.**

20 Providing compliance schedules based on an approved TMDL in a TSO rather than in the  
 21 Permit contradicts the established policies and laws discussed above, and places the District in  
 22 compliance jeopardy for infeasible final numeric effluent limitations. Because TSOs do not amend  
 23

24 <sup>7</sup> Only when reasonable potential exists do the effluent limitations need to be "consistent with the assumptions and  
 25 requirements of any available wasteload allocation for the discharge prepared by the State and approved by EPA  
 pursuant to 40 CFR 130.7." 40 C.F.R. §122.44(d)(1)(vii). Regional Board staff's contrary interpretation ignores that  
 26 this section only applies "[w]hen developing water quality based effluent limits under this paragraph." *Id.*

27 <sup>8</sup> "It is an accepted canon of statutory interpretation that we must interpret the statutory phrase as a whole, giving effect  
 28 to each word and not interpreting the provision so as to make other provisions meaningless or superfluous." *U.S. v.*  
*144,774 pounds of Blue King Crab*, 410 F.3d 1131, 1134 -1135 (9th Cir. 2005); *see also Northwest Environmental*  
*Advocates v. City of Portland*, 56 F.3d 979, 983 (9th Cir. 1995)(rejecting plaintiffs' proposed permit interpretation in  
 part because "this reasoning would require the court to read [certain provisions] out of the permit altogether.")

1 the Permit, the District could still be subject to liability for failure to comply with final effluent  
2 limitations if the interim limits are not included or referenced in the permit. To avoid this  
3 unnecessary liability, the Permit should be modified to include all interim limits and compliance  
4 schedules within the Permit. Compliance schedules are allowed if a State has clearly authorized  
5 them in its water quality standards or indicated in its implementing regulations (e.g., basin plan  
6 amendments) that it intends to allow them. *See In the Matter of Star-Kist Caribe, Inc.*, 3 E.A.D.  
7 172, 175-77 (1990); *see also* EPA Memo from James Hanlon, EPA Office of Wastewater  
8 Management to Alexis Strauss, Water Division, EPA Region 9 (May 10, 2007) at pg. 1.

9 California has clearly authorized compliance schedules as Water Code section 13050  
10 mandates that water quality control plans (i.e., Basin Plans) include a program of implementation  
11 needed for the achievement of water quality objectives. Water Code section 13242(b) makes clear  
12 that every implementation plan must include “a time schedule for actions to be taken” and section  
13 13263(c) expressly authorizes time schedules in permits. Many TMDLs, including the Salts  
14 TMDL, are created as implementation plans under section 13242 for water quality objectives that  
15 have not been attained. *See* State Board Res. No. 2008-0033 (Salts TMDL, at para. 4 - “The State  
16 Water Board finds that in amending the Basin Plan to establish this TMDL, the Los Angeles Water  
17 Board complied with the requirements set forth in sections 13240, 13242, and 13269 of the  
18 California Water Code.”); State Board Res. No. 2006-0078 (Metals TMDL at para. 13 - “The State  
19 Water Board finds that the Basin Plan amendment is in conformance with Water Code section  
20 13240, which specifies that Regional Water Quality Control Boards may revise Basin Plans; and  
21 section 13242, which requires a program of implementation of water quality standards.”) Because  
22 these compliance schedules are authorized by State law, and the TMDLs and implementation plans  
23 have been approved under State law, the compliance schedules are authorized for inclusion in the  
24 Permit.

25 Each TMDL is adopted and incorporated into the Basin Plan as an amendment to that plan,  
26 becoming a State regulation and law. As a part of State law, the Basin Plan, the TMDL, *and its*  
27 *schedule provisions* must be implemented *in NPDES permits*. *See EPA v. California ex rel.*  
28 *SWRCB*, 426 U.S. 200, 221, n. 36 (1976) (implicitly sanctioning a State’s individualized effluent

1 limitations and permit conditions, such as compliance schedules); 33 U.S.C. §1362 (defining the  
2 term “effluent limitation” to include “schedules of compliance”). An implementation schedule in a  
3 TMDL reflects the Board’s determination (with full opportunity for public participation) of what is  
4 reasonable for that pollutant after a focused analysis on the complexity of the pollutant problem  
5 and the feasibility of compliance. Thus, the implementation schedule in a TMDL provides the  
6 authority for inclusion of a compliance schedule in an NPDES permit. *See id.*; *see also* Santa Ana  
7 Regional Water Board, Basin Plan Amendment Workshop packet at page 9 – Authorization for  
8 Schedules of Compliance in NPDES permits (Item 10, February 25, 2000).

9 For these reasons, interim limits associated with TMDL compliance schedules must be  
10 included within the Permit instead of in the TSO. A failure to do so unreasonably subjects the  
11 District to federal enforcement (by EPA or citizen groups) for non-compliance with final effluent  
12 limitations that should be time deferred under the TMDL’s adopted implementation plan.

13 **3) The Permit Ignores the Watershed Approach Adopted into the TMDL.**

14 The Regional Board’s action to ignore the requirements and implementation plan for the  
15 Salts TMDL ignores the outcomes of the robust and complex stakeholder process spearheaded by  
16 the District and other POTWs in the area to develop a meaningful watershed solution to the various  
17 water quality concerns facing the Calleguas Creek Watershed. One of the goals of the Salts TMDL  
18 was to establish a procedure to address drought conditions and to reasonably protect beneficial uses  
19 while still accounting for increased salt loads in the incoming water supply. The process allows for  
20 the POTWs to offset increased effluent concentrations by removing salt load from another source  
21 (like groundwater desalting) and the wasteload allocations included an adjustment factor (“AF”)  
22 that allows for consideration of this process. However, implementing this AF process requires the  
23 development of watershed infrastructure and projects that are not yet in place. Until those projects  
24 are completed, an AF cannot be calculated and the final limits cannot be met or appropriately  
25 adjusted. The Salts TMDL provided a compliance schedule that would allow time to implement  
26 these projects and develop a watershed solution to bring the entire watershed into a salt balance at  
27 the end of the schedule.  
28

1           The POTW discharges cannot be considered independently of the watershed solutions.  
2   Until the full watershed solution is implemented and the infrastructure addressing source water is  
3   constructed, the current drought conditions will cause increased salt concentrations in POTW  
4   effluent that cannot be predicted or be reasonably or feasibly addressed through actions conducted  
5   at the water reclamation plants. The purpose of the TMDL was to provide the time and structure  
6   necessary to develop the watershed solutions and POTWs should be given the time provided in the  
7   TMDL to ensure they do not exceed final effluent limitations, particularly during the current  
8   drought conditions, prior to the construction of watershed solutions needed to offset increased salt  
9   loads and reasonably protect beneficial uses.

10           The watershed effort is complicated and will take time. "There are four key structural  
11   elements to the regional implementation plan: Regional Salinity Management Conveyance  
12   (:RSMC"), water conservation, water softeners, and Best Management Practices for irrigated  
13   agriculture. Sub-watershed implementation includes Renewable Water Resource Management  
14   Program for the Southern Reaches and Northern Reach Renewable Water Management Plan.  
15   Responsible parties must comply with load and waste load allocations for salts in the Calleguas  
16   Creek Watershed within 15 years of approval." *See accord* SWRCB Staff Report for Resolution  
17   No. 2008-0033; Res. No. 2008-0033 at para. 6 ("Compliance with the targets will be based on a  
18   15-year implementation schedule.")

19           Based on the increasing salts effluent concentrations due to the drought and changing water  
20   supply, and for consistency with the Salts TMDL, the District requested interim limits and a  
21   compliance schedule be included in the Permit for chloride, TDS, and sulfate. Interim limits are  
22   required "to allow time for dischargers to put in place implementation measures necessary to  
23   achieve final waste load allocations." *See Attachment A to Regional Board Res. No. R4-2007-016*  
24   at pg. 6. The requested schedule was as follows:

25   //

26   //

27   //

28

Description	End Date
Build a connection from CSD's WRP to the Calleguas Municipal Water District brine line under Phase 2A	December 2014
Discharge from CSD to Brine Line	December 2015
Improve water supply through construction of Northeast Pleasant Valley (NPV) Desalter and its connection to SMP	December 2015
Evaluate effectiveness of the NPV Desalter and the connection to the SMP for reducing salts in the effluent	December 2017
If necessary, implement water softener outreach and source control strategies	December 2020, if necessary

Only part of this schedule was included, and only in the TSO; not in the Permit. In addition, the TSO requires the District to "Achieve full compliance with the final effluent limitations as soon as possible, but no later than December 31, 2015, the date by which Camarillo SD committed to achieve compliance for TDS and sulfate contained in Order No. R4-2014-0062." Although the District anticipates that it can comply with the schedule above, the District cannot meet final effluent limitations until at least the time that the District can implement more recycling and move the remaining discharge to the RSMC. While flows remain to the creek, the final numeric effluent limitations in the Permit are inappropriate and should be removed until the Salts TMDL is fully implemented.

The interim limits required adjustment as well because the interim WLAs in the Salts TMDL should not have been set at the 95th percentile of *historic* discharge data. That conservative estimate does not leave enough of an allowance to take into account recent water conservation and drought conditions. Additionally, the assumptions of the TMDL authorize the use of *recent and current* performance data to calculate interim limits. The Salts TMDL recognizes that: "The monthly average interim limits are set based on the 95<sup>th</sup> percentile of available discharge data." See Attachment A to Regional Board Res. No. R4-2007-016 at pg. 6. Thus, the interim limits in the Salts TMDL are unreasonable and unsupportable and should be modified to account for more recent data and current facts related to the drought and changing water supply.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

4) The TMDL does not Require Wet Weather or Concentration-Based Limits for Salts.

The wet weather effluent limitations for TDS, sulfate and chloride in Table 4 should be deleted because there is no reasonable potential for the effluent to cause or contribute to an exceedance of the applicable water quality objectives for salts during wet weather. *See* Permit Fact Sheet, Section IV.C.2.b.vi. and vii. on pages F-25 and F-27. The Permit states that, during wet weather, the limits for TDS, sulfate, boron, and chloride are based on the water quality objectives found in Basin Plan Table 3-8 on page 3-12. *Id.* However, as noted in the dry weather definition of the Permit states that: “Any discharges from the Facility during wet weather would be assimilated by these large storm flows and would not cause exceedances of water quality objectives.” *See* Permit at Section VII.O. on page 30 (emphasis added). Therefore, no reasonable potential exists during wet weather for the applicable water quality objectives to be exceeded and no effluent limitation is required during wet weather. 40 C.F.R. §122.44(d)(1)(i) and (iii). These limits must be removed.

Additionally, the Salts TMDL specifically identified that only dry weather allocations were needed to address any identified impairments. *See* Order No. R4-2007-016, Attachment A at pg. 6 (“WLAs shown in table below apply to POTWs during dry weather when the flows in the receiving water are below the 96th percentile flow.”). Therefore, only dry weather effluent limitations are needed to implement the Salts TMDL WLAs. Inclusion of wet weather limits was an abuse of discretion as unnecessary and not authorized by the TMDL or federal regulations if no reasonable potential exists. 40 C.F.R. §122.44(d)(1).

In addition, the Salts TMDL does not require final concentration-based limits. The Salts TMDL stated that “The POTWs and non-storm water NPDES permits shall achieve WLAs, which shall be expressed as NPDES mass-based effluent limitation in accordance with federal regulations and state policy on water quality control” at the completion date “15 years after effective date of the TMDL.” (No. R4-2007-016 at pg. 22, Table 7-22.2 (emphasis added).) Notwithstanding this clear statement, the Permit contains concentration-based wet weather limits. *See* Permit at pg. 6, Table 4. Inclusion of concentration-based limits is not required by federal law. *See* 40 C.F.R.

1 §122.45(f). Although such inclusion is discretionary, the Regional Board failed to provide  
 2 adequate findings and evidence and to conduct the requisite Water Code section 13263/13241  
 3 analysis specifically targeted at imposing these limits, which are more stringent than required by  
 4 federal law.<sup>9</sup> For these reasons, the wet weather concentration-based limits must be removed from  
 5 the Permit.

6 **B. Improper Chronic Toxicity Limits**

7 Numeric chronic toxicity effluent limitations are listed in Provision IV.A.1.a., Table 4, on  
 8 p. 8 of the Permit as “Pass” as a Median Monthly Effluent Limitation (“MMEL”) and “Pass or  
 9 %Effect <50” as a Maximum Daily Effluent Limitation (“MDEL”). These terms are defined in  
 10 Provision VII.J. (i.e., Compliance Determination, Chronic Toxicity) on pg. 29 of Permit and are  
 11 said to be determined based on the Test of Significant Toxicity (TST) approach as described in a  
 12 2010 EPA guidance document (National Pollutant Discharge Elimination System Test of  
 13 Significant Toxicity Implementation Document (EPA 833-R-10-003, 2010), which is not part of an  
 14 approved, promulgated Part 136 method. These effluent limitations are not consistent with State  
 15 Board Orders or the Toxicity TMDL and the District requests that they be removed and replaced by  
 16 a narrative toxicity effluent limitation consistent with State Board precedential orders and with the  
 17 Toxicity TMDL.

18  
 19 1) **The Chronic Toxicity Limits are Premature until the State Water Board  
 20 Adopts a Statewide Toxicity Policy.**

21 On September 16, 2003, the State Water Board adopted Order No. WQO 2003-0012, in  
 22 response to petitions filed by the County Sanitation Districts No. 2 of Los Angeles County and  
 23 Santa Monica Baykeeper for the Los Coyotes and Long Beach Water Reclamation Plant NPDES  
 24 permits [SWRCB/OCC File Nos. A-1496 and A-1496(a)]. In 2003, in its precedential Order No.  
 25 WQO 2003-0012, the State Water Board found that the use of final numeric effluent limitations in  
 26

27 <sup>9</sup> While the Regional Board added a new section VIII to the Fact Sheet, this analysis is very generic and although it  
 28 discusses the factors in Water Code section 13241 generally, there is no analysis of any particular limit that is being  
 reviewed or justified.

1 permits for POTWs, particularly those that discharge to inland surface waters, is an issue of  
2 statewide importance that should be addressed in a statewide plan or policy. In addition, the State  
3 Water Board replaced the numeric chronic toxicity effluent limitations with a narrative chronic  
4 toxicity limitation until a statewide toxicity policy is adopted. The District's 2003 Permit was  
5 modified to coincide with the requirements of State Board Order No. WQO 2003-0012.

6 The State Water Board has not yet adopted its anticipated statewide policy for chronic  
7 toxicity. As such, the inclusion of new numeric chronic toxicity effluent limitations using a new  
8 test method (the TST) lacks adequate authority, violates State Water Board precedent, and  
9 represents an abuse of discretion.

10 The Regional Board alleges on page 8 of the response to comments for Camarillo that  
11 because more than ten years and two permit cycles have passed, the Regional Board can "exercise  
12 its own discretion" to ignore SWRCB precedential orders. Although the main issue on whole  
13 effluent toxicity ("WET") limits was decided by the State Board in WQO 2003-0012 in 2003, this  
14 decision was later upheld and followed in subsequent State Board Orders, No. WQ 2008-08 (City  
15 of Davis) and WQ 2012-0001 (City of Lodi). The 2012 Lodi order at page 22 recognized that  
16 "[t]he Board previously addressed this issue in a precedential decision" and has "concluded that a  
17 numeric effluent limitation for chronic toxicity was not appropriate in the permit under review, but  
18 that the permit had to include a narrative effluent limitation for chronic toxicity." In the Lodi case,  
19 the State Water Board determined that the discharge had the reasonable potential to cause or  
20 contribute to an excursion above the Basin Plan's narrative toxicity objective. Therefore, on  
21 remand, the Central Valley Water Board was ordered to "amend Order No. R5-2007-0113 to add  
22 an appropriate narrative chronic toxicity limitation." *See also* State Water Board Order No. WQ  
23 2008-0008 at pgs. 5-7 (concluding that a numeric effluent limitation for chronic toxicity is not  
24 appropriate at this time.)

25 Thus, at least three (3) precedential State Water Board orders mandate a narrative chronic  
26 toxicity limit, all of which are being violated by the Permit. All the District and the other  
27 permittees asked for was that the Regional Board follow this binding precedent and include a  
28 narrative effluent limitation, consistent with the Basin Plan's narrative objective, along with a

1 trigger for additional testing based on 1 TUc, which is consistent with the Toxicity TMDL (which  
2 does not require that either a numeric effluent limitation or the TST methodology be prescribed).  
3 Doing otherwise unnecessarily places the permittees in compliance jeopardy.

4 Moreover, the fact that the Regional Board has included numeric toxicity limits and the  
5 TST in other permits does not *de facto* make this action legal. In fact, one of the permits cited by  
6 the Regional Board as “precedent” was the permit for Calleguas Municipal Water District, which is  
7 currently pending review by the State Board and cannot be used as authority for the current permits  
8 (particularly when that was an Ocean Plan, not Basin Plan, based permit). The other permits cited  
9 are not permits for POTWs and have different influent and effluent that are not comparable to  
10 domestic wastewater. State Board Order No. WQO 2003-0012 held at page 10 (emphasis added):

11 “Because the influent can consist largely of domestic wastewater over which the District  
12 has little or no control, we find that a numeric effluent limitation should not have been used  
13 ... for chronic toxicity. It is not feasible, at least initially, to impose numeric effluent  
14 limitations since it will result in a permit violation whenever there is toxicity in the effluent,  
15 even if the cause were from the domestic influent, the District had no basis for knowing the  
16 cause, and the District was pursuing the cause and its elimination through vigorous  
17 compliance with stringent TRE requirements.

18 Thus, stormwater or boatyard discharge permits are not exactly comparable to POTW  
19 permits and were not the subject of Order No. WQO 2003-0012. For these reasons, because  
20 numeric chronic toxicity effluent limitations based on “Pass/Fail” and “% Effect” are inconsistent  
21 with binding State Board precedent, these limits should be removed from the Permit and replaced  
22 with a narrative chronic toxicity limit.

23 **2) The Chronic Toxicity Limits are Inconsistent with the Calleguas**  
24 **Watershed Toxicity TMDL.**

25 The Toxicity TMDL was developed through a collaborative, stakeholder-led process, which  
26 created the technical analyses leading to the Regional Board staff’s recommended TMDL. This  
27 TMDL addresses water quality impairments of Calleguas Creek, including its tributaries, segments  
28 and Mugu Lagoon, caused by toxicity, sediment toxicity, and two organophosphate pesticides,  
chlorpyrifos and diazinon. *See accord* Calleguas Creek Watershed Toxicity TMDL Staff  
Memorandum at pg. 1. EPA approved the TMDL on March 14, 2006, and in its approval letter

1 stated that EPA was not taking action on the implementation plans provided with the TMDLs, but  
2 generally concurred with the State's proposed implementation approaches.

3 The Permit attempts to regulate chronic toxicity through "Pass/Fail" or "% effect" limits  
4 based on the TST methodology, even though the definitions contained in the Toxicity TMDL  
5 clearly mandate the use of chronic toxicity units (TUc) using the NOEC, as follows:

6 "To meet the narrative toxicity objective, a numeric toxicity target of 1 chronic toxicity unit  
7 (1 TUc) is established.... Equation 1 describes the calculation of a TUc.

8 **Equation 1** TUc=Toxicity Unit Chronic = 100/NOEC (no observable effects  
9 concentration)

10 The NOEC (no observable effects concentration) is defined in USEPA's Technical Support  
11 Document (TSD) as 'the highest concentration of toxicant, in terms of percent effluent, to  
12 which the test organisms are exposed, that causes no observable effect, with the sample  
13 concentration expressed as a percentage.... [NOEC] was the selected alternative as it is  
14 consistent with current Los Angeles Regional Board and USEPA NPDES permitting  
15 practice. If the Regional Board revises NPDES permits to calculate a TUc using inhibition  
16 concentrations (ICs) or other point estimate methodology, the Regional Board may  
17 reconsider the numeric target." (Toxicity TMDL at pg. 53.)

18 As noted above, "the toxicity target in water is set to equal a toxicity unit." (Toxicity  
19 TMDL at pg. 107.) EPA approved of this approach. See EPA Letter, June 9, 2005 ("In particular,  
20 the proposal to set 1 TUc (Toxicity Unit Chronic) as the target to explain unknown toxicity is in  
21 accordance with 40 CFR 130.2(i).") Regional Board staff agreed. See Response to Comments  
22 Total Maximum Daily Load for Toxicity, Chlorpyrifos, and Diazinon in Calleguas Creek its  
23 Tributaries and Mugu Lagoon, June 10, 2005 at Comment 2.2 ("Staff agree that the target of 1TUc  
24 is appropriate for this TMDL.").

25 Although the Regional Board's response to comments on the Permit claimed that "The  
26 [Toxicity] TMDL imposes numeric WLAs for chronic toxicity on POTWs" (Response to  
27 Comments at pg. 9 (April 30, 2014)), the Toxicity TMDL Technical Report that provides the  
28 scientific and technical support for that TMDL states that it does not include any Waste Load  
Allocations ("WLAs") for chronic toxicity. Instead, the Toxicity TMDL Technical Report states  
that "[t]hese toxicity targets can not be divided into portions and allocated to sources." (Toxicity  
TMDL Technical Report at pgs. 107 and 114; see also Response to Peer Review by Dr. Mel Suffit

1 dated May 11, 2005, at pg. 18 (“The authors realized the futility of the use of a TMDL for water  
 2 column toxicity. The reviewer wholeheartedly agrees...”) “Additionally, the loading capacity of a  
 3 stream with regard to a toxicant causing unknown toxicity in water and/or sediment is inherently  
 4 unknown and can not be allocated. As such, a toxicity allocation equal to the numeric targets will  
 5 be set at the base of each of the subwatersheds<sup>10</sup> ... [which] provides a mechanism to address all  
 6 dischargers contributing to in-stream toxicity as individual dischargers may additively cause an in-  
 7 stream exceedance of the toxicity targets.” (Toxicity TMDL Technical Report at pg. 114.) If no  
 8 wasteload allocation for each POTW exists, then no effluent limitations are required to be  
 9 “consistent with the assumptions and requirements of any available wasteload allocation.” (See  
 10 Response to Comments at pg. 9 (April 30, 2014) *citing* 40 C.F.R. §122.44(d)(1)[(vii)(B)].) The  
 11 Regional Board apparently mistakenly presumed that the discussion in the Toxicity TMDL that the  
 12 “WLAs established for the three major POTWs in this TMDL will be implemented through  
 13 NPDES permit limits” applied to toxicity, not just diazinon and chlorpyrifos. (Toxicity TMDL  
 14 Technical Report at pg. 122.) However, the previous discussion demonstrates that there was not  
 15 intended to be a WLA for toxicity. Instead, the Toxicity TMDL anticipated that “[t]he toxicity  
 16 numeric target [of 1 TUc] will be implemented as a trigger mechanism for initiation of the  
 17 TRE/TIE process as outlined in USEPA’s *Understanding and Accounting for Method Variability in*  
 18 *Whole Effluent Toxicity Applications Under the National Pollutant Discharge Elimination System*  
 19 *Program* (2000b) and current NPDES permits held by dischargers to the CCW.”<sup>11</sup> (Toxicity

20  
 21  
 22 <sup>10</sup> This intent was not made clear in the TMDL Resolution, which states: “A wasteload allocation of 1.0 TUc is  
 23 allocated to the major point sources (POTWs) discharging to the Calleguas Creek Watershed.” (Regional Board Res.  
 24 No. R4-2005-009 at pg. 4. The District believes that the Resolution must be read to be consistent with the findings and  
 evidence contained in the TMDL Technical Report and applied at the base of each of the sub-watersheds. Otherwise,  
 there is no technical basis for these WLAs and they are subject to challenge as applied.

25 <sup>11</sup> The Regional Board tries to argue that the language in the Implementation Plan, which states: “The toxicity WLAs  
 26 will be implemented in accordance with US EPA, State Board and Regional Board resolutions, guidance and policy at  
 the time of permit issuance or renewal” (Res. R4-2005-009 at pgs. 7-8), trumps the mandate that the target be  
 implemented as a trigger. However, guidance and policy cannot supersede adopted regulations and Basin Plan  
 27 amendments. In addition, the TMDL Resolution itself states that “if other information supporting other methods [for  
 evaluating toxicity] becomes available, the Regional Board may reconsider this TMDL and revise the water toxicity  
 numeric target.” (Res. R4-2005-009 at pgs. 8-9.) This language, included at the request of the District and others (see  
 28 Letter from the Camarillo Sanitary District, Thousand Oaks, Simi Valley, Camrosa Sanitary District, and Ventura  
 County Water Works District #1 (June 10, 2005)), was intended to address the situation present here; namely where the

1 TMDL Technical Report at pgs. 122 and 114; Regional Board Res. No. R4-2005-009 at pg. 7;  
2 Response to Peer Review by Dr. Mel Suffit dated May 11, 2005, at pg. 21 (“Water column toxicity  
3 targets are included to provide a method for triggering future investigations of the causes of  
4 toxicity.”); Response to Comments Total Maximum Daily Load for Toxicity, Chlorpyrifos, and  
5 Diazinon in Calleguas Creek its Tributaries and Mugu Lagoon, June 10, 2005 at Comments 5.1 and  
6 16.8 (“The toxicity target will be incorporated into NPDES permits according to current policy  
7 which is to use toxicity exceedances as a trigger to conduct further toxicity testing and TIEs as  
8 warranted.”) This trigger approach is also consistent with the express terms of the Los Angeles  
9 Basin Plan’s narrative toxicity objective, which specifies that “Effluent limits for specific toxicants  
10 can be established by the Regional Boards to control toxicity identified under Toxicity  
11 Identification Evaluations (TIEs).” (Toxicity TMDL Technical Report at pg. 15; Basin Plan at 3-  
12 17.)

13 Thus, for the reasons provided, the Regional Board adopted effluent limits in the Permit for  
14 chronic toxicity that are inconsistent with the Toxicity TMDL and Basin Plan. For this reason, the  
15 Permit’s chronic toxicity provisions must be modified to be consistent with the intent of the  
16 Toxicity TMDL and implemented as a trigger for a TIE/TRE.

17 3) **The Chronic Toxicity Requirements are Improperly Based on EPA**  
18 **Guidance, Not Promulgated EPA Regulations.**

19 The Permit makes it very clear that the monitoring must use only approved Part 136  
20 methods, properly promulgated by EPA. (Permit at pg. D-4, Provision III.A. (“Monitoring results  
21 must be conducted according to test procedures under 40 C.F.R. part 136...”)(emphasis added);  
22 Permit at pg. E-6, note 2 to Table E-2 (“Pollutants shall be analyzed using the analytical methods  
23 described in Part 136.”)(emphasis added); *see also* 40 C.F.R. §122.44(i)(iv)(monitoring to be done  
24 according to test procedures approved under 40 C.F.R. Part 136); 40 C.F.R. §136.1(a).)

25  
26  
27 Regional Board would like to implement the toxicity objective through another method (a pass/fail method using the  
28 TST), it should revise the TMDL to modify the 1 TUc target.

1 Using the TST, instead of the prescribed TUC and the NOEC method specified in the Part  
2 136 methods at 40 C.F.R. §136.3(a), Table 1A, footnote 27, is inconsistent with Part 136, which  
3 mandates the use of USEPA's 2002 Methods (EPA 821-R-02-013). The 2002 Methods do not  
4 mention the TST or provide that the TST may be used as an approved method. A 2010 EPA  
5 Guidance document cannot overrule promulgated regulations. In addition, EPA made some  
6 changes to WET test methods in its 2012 modifications to the *Promulgated Guidelines*  
7 *Establishing Test Procedures for the Analysis of Pollutants under the Clean Water Act: Analysis*  
8 *and Sampling Procedures: Final Rule*, 77 Fed. Reg. 29758-29846 (May 18, 2012), but did not  
9 incorporate the TST even though it had been available as guidance for two years. This evidences  
10 an intent to not formally approve use of the TST.

11 Thus, the aquatic toxicity testing provisions in 40 C.F.R. Part 136 only specifically list  
12 LC<sub>50</sub>, percent effluent, NOEC/NOEL, and IC<sub>25</sub> under Parameter and Units for acute and chronic  
13 aquatic toxicity testing. See 40 C.F.R. §136.3(a), Table IA, footnote 27 (referencing *Short-Term*  
14 *Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater*  
15 *Organisms*, EPA-821-R-02-012, Fifth Edition, October 2002. Additionally, both the 2012 Final  
16 Rule and the 2002 promulgated method manual fails to describe, endorse, or recommend the use of  
17 the TST for statistical analysis.<sup>12</sup> *Id.* While the 2002 Rule acknowledged that “the statistical  
18 methods recommended in this manual are not the only possible methods of statistical analysis,” the  
19 Rule’s “recommended statistical methods described in the method manuals were selected because  
20 they are (1) applicable to most of the different toxicity test data sets for which they are  
21 recommended, (2) powerful statistical tests, (3) hopefully ‘easily’ understood by nonstatisticians,  
22 and (4) amenable to use without a computer, if necessary.” 67 Fed. Reg. 69964.

23 Although the TST is a relatively new analytical tool for WET, bioequivalence  
24 testing/alternative null hypothesis testing has been a widely used statistical method in other  
25 contexts for many decades. In fact, peer-reviewed publications proposed the use of bio-equivalency  
26

27 <sup>12</sup> The 2002 Rule does express a preference for point estimation techniques (IC<sub>25</sub>) over hypothesis testing approaches  
28 for calculating endpoints for effluent toxicity tests under the NPDES Permitting Program. 67 Fed. Reg. 69957 and 69958.

1 in aquatic toxicity testing as early as 1995 (Erickson and McDonald) – seven (7) years *before* the  
2 2002 promulgation of the EPA-recognized and approved methods. Therefore, even with direct  
3 understanding of the TST/bioequivalence statistical methods, EPA promulgated the current toxicity  
4 methods with a recommendation and strong preference for the use of point estimation for NPDES  
5 compliance monitoring and a strong *rejection* of pass/fail analyses, as follows:

6 a) The Federal Register Vol. 67, No. 223, Tuesday November 19, 2002 contains the Final  
7 Rule ratifying approval of several whole effluent toxicity methods in 40 C.F.R. Part 136.  
8 Page 69958 of that Federal Register states the following: “As previously stated in the  
9 method manuals (USEPA, 1993; USEPA, 1994a; USEPA, 1994b) and EPA’s Technical  
10 Support Document (USEPA, 1991), EPA recommends the use of point estimation  
11 techniques over hypothesis testing approaches for calculating endpoints for effluent toxicity  
12 tests under the NPDES Permitting Program.” [emphasis not added]

11 b) The USEPA manual “Short-Term Methods for Estimating the Chronic Toxicity of  
12 Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms”  
13 (EPA/600/600/R-95/136) (August 1995) states the following on pg. 8: “2.2 *Types of Tests*  
14 2.2.3 *Use of pass/fail tests consisting of a single effluent concentration (e.g., the  
15 receiving water concentration or RWC) and a control is not recommended.*” [emphasis  
16 included in the original manual text]

15 The recent Alternative Test Procedure (“ATP”) letter produced by the Regional Board at  
16 the Permit adoption hearing (although requested prior to that date and available to the Water  
17 Boards after March 17, 2014), ignores these previous EPA recommendations.

18 The Regional Board’s response to comments on the Permit at page 10 of 52 for Camarillo  
19 stated:

20 “In 2014, in response to the State Water Board’s request to use the TST hypothesis testing  
21 approach in NPDES permits, USEPA determined—based on the evidence presented in the  
22 State Water Board’s request—that the results of TST tests and NOEC-LOEC tests—are  
23 acceptably equivalent under the ATP process at 40 CFR 136 for all NPDES permits issued  
24 by State and Regional Water Boards.”

24 It appears that the Regional Board relied on the granting of a “Limited Use Alternative Test  
25 Procedure” under 40 C.F.R. §136.5. This approach allows “Any person may request the Regional  
26 Alternate Test Procedure (ATP) Coordinator or permitting authority to approve the use of an  
27 alternate test procedure in the Region.” (40 C.F.R. §136.5(a).) However, it is not clear that a State  
28 can request such an approach since the request must first be sent to the State. (*Id.* at subd. (b).)

1 Moreover, it is not clear that this “Limited Use” ATP would be legal to apply broadly (statewide)  
2 when it could be deemed to be a “final agency action” undertaken without any formal notice or any  
3 opportunity for public comment. Furthermore, an ATP appears to be for use by a discharger or lab  
4 requesting an alternative method and it is not clear that dischargers can be *REQUIRED* to use an  
5 ATP. It is difficult to see how the State or EPA could legally object to any permittee continuing to  
6 use the standard prescribed 2002 test methods (NOEC or IC25) if the standard methods and the  
7 ATP produce “acceptably equivalent” results as claimed. *See* 67 Fed. Reg. 69955 (2002)(“these  
8 methods, including the modifications in today’s rule, are applicable for use in NPDES permits”).

9 On February 12, 2014, the State Board asked for EPA approval of “a two-concentration test  
10 design when using the Test of Significant Toxicity (TST) hypothesis testing approach” “[p]ursuant  
11 to Code of Federal Regulations, title 40, section 136.4.” *See* SWRCB ATP Request Letter from  
12 Renee Spear to Eugenia McNaughton, EPA Region 9 (Feb. 12, 2014) at pg. 1. Section 136.4 is for  
13 *nationwide use* and must be submitted to EPA Headquarters in Washington, D.C., not to EPA  
14 Region 9 in San Francisco. Nevertheless, EPA Region 9, in turn and in record time, approved a  
15 *limited use* ATP statewide under Section 136.5. *See* EPA ATP Approval Letter from Eugenia  
16 McNaughton, Ph.D. to Renee Spear, SWRCB (March 17, 2014)(emphasis added). The request and  
17 approval are under different regulatory provisions, making the approval unlawful.

18 Further, the ATP is suspect as it was not submitted by a discharger or a laboratory, but by  
19 the State Board after receiving the two-concentration method using the TST from EPA. This self-  
20 dealing to avoid a full-blown regulatory process is contrary to law and policy. The ATP process  
21 was designed to “encourage organizations *external to EPA* to develop and submit for approval new  
22 analytical methods.” *See Guide to Method Flexibility and Approval of EPA Water Methods*, EPA  
23 Office of Water (Dec. 1996) at pg. 77. All but a single lab, single discharger ATP (i.e., Tier 1)  
24 must go through rulemaking. For Tier 2 and 3 new methods (multi-lab), “EPA will begin the  
25 rulemaking process.” *Id.* at pgs. 80-82. Furthermore, EPA acknowledges that it currently has no  
26 approved protocols for reviewing or approving a WET ATP. *Id.* at 93 (“EPA is developing a  
27 protocol for approval of new and modified (alternate) WET methods....”; *see also*  
28 <http://water.epa.gov/scitech/methods/cwa/atp/questions.cfm> (last accessed 5/30/2014)(stating

1 “Note: The EPA does not have a protocol for toxicity testing [ATP] under EPA’s Whole Effluent  
2 Toxicity (WET) program.”).

3 Finally, an ATP for WET is contrary to federal regulations. “Method Modifications” are  
4 explicitly *prohibited* for “Method-Defined Analytes” by 40 C.F.R. section 136.6(b)(3), which  
5 states (with emphasis added): “(3) Restrictions. An analyst may not modify an approved Clean  
6 Water Act analytical method for a method-defined analyte.” EPA has previously declared that  
7 WET is a Method-Defined Analyte. *See* 67 Fed. Reg. 69965 (“toxicity is inherently defined by the  
8 measurement system (a ‘method-defined analyte’) and toxicity cannot be independently measured  
9 apart from a toxicity test.”); *see also* Brief of Respondents EPA, *et al.*, in *Edison Electric Institute,*  
10 *et al., v. USEPA*, Case No. No. 96-1062 (D.C.Cir. 2004) at 44-45 and 78 *citing* Response to  
11 Comments at 219-20, J.A. XX; 67 Fed. Reg. 69,965. (“Because toxicity is defined and measured  
12 by its effect on living organisms, whole effluent toxicity is considered a method-defined analyte  
13 (i.e., it cannot be measured independently from a toxicity test). Thus, WET test results cannot be  
14 independently confirmed by comparing the results to a known concentration of toxicity.”).  
15 Therefore, WET methods cannot be modified without formally amending 40 CFR Part 136.

16 For these reasons, and the others provided herein, all references to the Pass/Fail or % Effect  
17 limits based on the TST must be removed from the Permit.

18 a) Use of an ATP Cannot Be Mandated over Promulgated Methods.

19 Even assuming *arguendo* that the ATP was proper, EPA Region 9 went further, beyond  
20 approving the ATP, to *mandate* use of the two-concentration TST by stating that this ATP “will  
21 apply to all new or revised NPDES permits issued by the State Water Board and Regional Water  
22 Quality Control Boards and any EPA-issued California permits that include whole effluent toxicity  
23 provisions.” *See* EPA ATP Approval Letter from Eugenia McNaughton, Ph.D. to Renee Spear,  
24 SWRCB (March 17, 2014)(emphasis added). Neither EPA nor the Regional Water Board has the  
25 authority to impose the TST until that method has been promulgated by EPA as an approved  
26 method under Part 136. Analytical results obtained by using a non-promulgated method cannot be  
27 used for NPDES compliance determination purposes until that method has been incorporated into  
28 40 C.F.R. Part 136. *See accord* Permit at E-19 (“Analysis under this section is for monitoring

1 purposes only. Analytical results obtained for this study will not be used for compliance  
2 determination purposes, since the methods have not been incorporated into 40 CFR part 136.”)  
3 Similarly, the particular number of dilutions in a dilution series cannot be mandated. 67 Fed. Reg.  
4 69956 (“no one particular dilution series is required.”)

5 This mandate also contradicts a June 18, 2010 EPA Headquarters memo accompanying the  
6 TST Implementation Document, from James Hanlon, the Director of the EPA Office of  
7 Wastewater Management, which stated: “The TST approach does not preclude the use of existing  
8 recommendations for assessing WET data provided in EPA’s 1991 Water Quality-based Technical  
9 Support Document (TSD) which remain valid for use by EPA Regions and the States.” Thus, all  
10 the TST can be used for is additional information, similar to the extra PCB and CEC monitoring  
11 (discussed elsewhere in this petition) where samples are required using a non-promulgated method  
12 – however, the difference is for PCBs and CECs, that extra data is not being used for compliance  
13 determination processes. See Permit at pg. E-9, footnote 13; and pg. E-19.

14 b) EPA Guidance cannot Overrule Promulgated Regulations.

15 Footnote 15 on page 8 of the Permit states that the inclusion of a numeric effluent limitation  
16 for toxicity is based on two current EPA guidance documents:

- 17 • *National Pollutant Discharge Elimination System Test of Significant Toxicity*  
18 *Implementation Document* (EPA 833-R-10-003, June 2010) (2010 TST guidance  
19 document), and
- 20 • *EPA Regions 8, 9 and 10 Toxicity Training Tool* (January 2010) (Training Tool),  
21 <http://cfpub.epa.gov/npdes/wqbasedpermitting/wet.cfm>.

22 These documents cannot be used to justify the Permit’s requirements because these  
23 guidance documents do not mandate use of the TST, or require the inclusion of a numeric effluent  
24 limitation for toxicity. Appendix D of the 2010 TST guidance document includes example permit  
25 language for either a trigger or an effluent limitation. The Training Tool also discusses both permit  
26 triggers and effluent limitations for toxicity. In the Training Tool, numeric effluent limitations are  
27 only needed in cases where there is reasonable potential and even if there is reasonable potential,  
28

1 effluent limitations for toxicity are not needed if chemical specific effluent limitations are included  
2 for the pollutants identified as causing the toxicity (Section 2.5, page 31).<sup>13</sup>

3 Camarillo WRP does not have reasonable potential for toxicity, and the causative pollutants  
4 (ammonia, chlorpyrifos, and diazinon) that were determined to potentially be the cause of toxicity  
5 in the effluent during the Toxicity TMDL development process are all assigned effluent limitations  
6 within the permit. As a result, the Regional Board can point to nothing in either of the guidance  
7 documents cited that *mandates* the use of numeric effluent limitations for toxicity.

8 Additionally, the 2010 TST guidance document is merely *guidance* that may be changed at  
9 any time as policies and directions change. Importantly, the disclaimer in that guidance document  
10 specifically notes that the document is not “a permit or a regulation itself.” The TST guidance  
11 document clearly states that:

12 “The document does not and cannot impose any legally binding requirements on EPA,  
13 states, NPDES permittees, or laboratories conducting or using WET testing for permittees  
14 (or for states in evaluating ambient water quality). EPA could revise this document without  
public notice to reflect changes in EPA policy and guidance.”<sup>14</sup>

15 The other document cited is merely part of a training tool that is not even published guidance.

16 Although EPA often tries to regulate by guidance, courts have frowned upon this practice  
17 as aptly described in *Appalachian Power Co. v. EPA*, 208 F.3d. 1015, 1020 (D.C. Cir. 2000). The  
18 district court in the *Appalachian Power* case found fault in EPA’s regulating by setting aside the  
19 guidance in its entirety. (*Id.* at p. 1028.) “If an agency acts as if a document issued at headquarters  
20 is controlling in the field, if it treats the document in the same manner as it treats a legislative rule,  
21 if it bases enforcement actions on the policies or interpretations formulated in the document, if it  
22 leads private parties or State permitting authorities to believe that it will declare permits invalid

23  
24  
25 <sup>13</sup> If State water quality standards contain only narrative water quality criteria for WET and it is documented in the  
26 record for the permit (i.e., fact sheet or statement of basis) that chemical specific water quality-based effluent  
27 limitations (“WQBELs”) are sufficient to attain and maintain the narrative water quality criteria, then WQBELs for  
28 WET are not necessary. 40 C.F.R. §122.44(d)(1)(v). Effluent limits are only authorized for the causative toxicant. *See*  
*accord* Los Angeles Basin Plan at pg. 3-17.

<sup>14</sup> USEPA, National Pollutant Discharge Elimination System Test of Significant Toxicity Technical Document. EPA  
833-R-10-004, June 2010 (Exhibit I).

1 unless they comply with the terms of the document, then the agency's document is for all practical  
2 purposes 'binding.'" (*Id.* at p. 1021 [*citations omitted*].)

3 More recent cases have reached the same conclusion in other instances when EPA tried to  
4 impose its will through interpretive rules, such as the 2010 TST guidance. One case related to  
5 invalidating EPA guidance setting forth air quality attainment alternatives. (*NRDC v. U.S. EPA*,  
6 643 F.3d 311 (D.C.Cir. 2011).) Another related to "requirements" contained in letters related to  
7 water quality permitting prohibitions related to blending and mixing zones. In this case, the court  
8 found that EPA not only lacked the statutory authority to impose the guidance regulations on  
9 blending, but also violated the Administrative Procedures Act ("APA"), 5 U.S.C. § 500 et seq., by  
10 implementing the guidance on both issues without first proceeding through the notice and comment  
11 procedures for agency rulemaking. (*Iowa League of Cities v. U.S. EPA*, 711 F.3d 844, 878 (8th  
12 Cir. 2013).) The case law is clear that EPA must regulate through rules and not through informal  
13 guidance. Similar rules apply to the Water Boards, which also cannot regulate by guidance,  
14 particularly where that guidance is contrary to established regulations (e.g., the Toxicity TMDL)  
15 and statewide precedential orders as described above.

16 4) **A Maximum Daily Limit for Chronic Toxicity is Impracticable,**  
17 **Unlawful and Inappropriate.**

18 Federal law only authorizes monthly and weekly average effluent limitations for publicly  
19 owned treatment works (POTWs) without a demonstration that these effluent limitations are  
20 "impracticable." (See 40 C.F.R. §122.45(d)(2)("For continuous discharges all permit effluent  
21 limitations, standards and prohibitions, including those necessary to achieve water quality  
22 standards, shall unless impracticable be stated as: (2) Average weekly and average monthly  
23 limitations for POTWs.)) As described above, the Permit includes an MDEL for chronic toxicity,  
24 which is more stringent than required by federal law and has not been adequately justified with an  
25 impracticability analysis. Therefore, this limitation is contrary to law.<sup>15</sup>

26 \_\_\_\_\_  
27 <sup>15</sup> California courts have already held that daily limits are not allowed unless demonstrated to be impracticable and  
28 these decisions are binding on the Water Boards since not appealed. (*See City of Burbank v. State Water Resources  
Control Board*, 35 Cal. 4th 613, 623, n.6 (2005) (The Supreme Court held: "Unchallenged on appeal and thus not  
affected by our decision are the trial court's rulings that... (2) the administrative record failed to support the specific

1 In addition, a daily maximum limit is unnecessary to protect aquatic life. Chronic toxicity  
2 testing is meant to assess **long-term** impacts to biological communities of organisms, not the  
3 impact of a single day's or week's discharge. Furthermore, use of a daily maximum chronic  
4 toxicity limit to protect against a single discharge event capable of exceeding the objective makes  
5 no sense when a single chronic test itself typically consists of three (3) or more discrete samples  
6 collected over an exposure period of up to nine (9) days. (*See* 67 Fed. Reg. 69953 (2002 Final  
7 WET Rule)("short term methods for estimating chronic toxicity [ ] use longer durations of  
8 exposure (*up to nine days*) to ascertain the adverse effects of an effluent or receiving water on  
9 survival, growth and/or reproduction of the organisms." (emphasis added).) Therefore, a short  
10 term average or daily maximum limit for chronic WET is impracticable and a chronic toxicity limit  
11 (as is recognized for other long-term chronic objectives, such as to protect human health) should be  
12 expressed only in narrative form "There shall be no chronic toxicity in the effluent discharge,"  
13 interpreted as a monthly average, or a median monthly if the monthly average is demonstrated to  
14 be impracticable. (*See accord In the Matter of the Own Motion Review of City of Woodland, Order*  
15 *WQO 2004-0010, 2004 WL 1444973, \*10 (June 17, 2004)* ("Implementing the limits as  
16 instantaneous maxima appears to be incorrect because the criteria guidance value, as previously  
17 stated, is intended to protect against chronic effects." The limits were to be applied as monthly  
18 averages instead); SWRCB Order No. 2003-0012 and EPA Letter to Los Angeles Regional Board  
19 on Long Beach/Los Coyotes Permits at pg.4 (May 31, 2007).)

20 Further, a pass/fail result from a single effluent test provides no indication of actual aquatic  
21 toxicity in the ambient receiving waters. Even EPA explains that:

22 "The agency is concerned that single concentration, pass/fail, toxicity tests do not  
23 provide sufficient concentration-response information on effluent toxicity to determine  
24 compliance. It is the Agency's policy that all effluent toxicity tests include a minimum  
of five effluent concentrations and a control."<sup>16</sup>

25 effluent limitations; (3) the permits improperly imposed daily maximum limits rather than weekly or monthly  
26 averages;...)(emphasis added).) Because no additional analysis has been done for the chronic toxicity limit to  
27 demonstrate the impracticability of monthly and weekly average limits, the Regional Board must be ordered to remove  
the daily maximum limit.

28 <sup>16</sup> See U.S. EPA, *Whole Effluent Toxicity: Guidelines Establishing Test Procedures for the Analysis of Pollutants -*  
*Supplementary Information Document (SID)* at pg. 28 (Oct. 2, 1995).

1 Contrary to EPA regulations and guidance, the Permit includes an MDEL that would result  
2 in an effluent limit violation as a result of a single sample exceedance. Despite a potentially high  
3 effect level needed to exceed the MDEL ( $\geq 0.50$ ), it is inappropriate to assess single sample  
4 violations for chronic toxicity analyses due to the variability and uncertainty inherent in testing  
5 biological organisms for non-lethal endpoints. The single test is highly problematic given that the  
6 TST procedure often inaccurately identifies non-toxic samples as toxic or "Fail." When non-toxic  
7 method blank data from EPA's Inter-laboratory WET Variability Study was re-evaluated using the  
8 TST procedure, the number of false positives increased dramatically. Nearly 15% of all non-toxic  
9 samples were declared "toxic" in the *Ceriodaphnia dubia* reproduction test - four times more than  
10 occurred when using either the NOEC method - and, 7.4 % of all non-toxic samples were declared  
11 "toxic" using the TST procedure to evaluate fathead minnow growth, which is double the rate at  
12 which similar false conclusions occurred when evaluating the same data with the traditional,  
13 promulgated NOEC method.

14 Additionally, the preamble to the 2002 WET Rule says "EPA policy states that 'EPA does  
15 not recommend that the initial response to a single exceedance of a WET limit, causing no known  
16 harm, be a formal enforcement action with a civil penalty.'" 67 Fed. Reg. 69968 *citing* EPA memo  
17 entitled *National Policy Regarding Whole Effluent Toxicity Enforcement* (1995a) (emphasis  
18 added). The appropriate response to a chronic toxicity test indicating the presence of toxicity is not  
19 to declare a violation, but to investigate the cause, starting with follow-up testing to confirm the  
20 initial result. (*See accord* 67 Fed. Reg. 69968 (EPA policy suggests additional testing is an  
21 appropriate initial response to a single WET exceedance); Basin Plan at 3-17 (recommending TIE  
22 to identify cause of toxicity prior to imposing effluent limitation to implement the narrative  
23 Toxicity objective); *see accord* Ocean Plan at pg. 45 (triggering TRE Process).)

24 For all of these reasons, the inclusion of a daily maximum effluent limitation for chronic  
25 toxicity is impracticable, unlawful, and inappropriate. At the very least, the State Water Board  
26 should order that the daily limit for chronic toxicity be removed.



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

limitations are “infeasible.” (40 C.F.R. § 122 44(k)(3); see also State Board Order WQ 2006-0012, p. 16.)

The State Board construes “infeasibility” to refer to “the ability or propriety of establishing” numeric limits. (See State Board Order WQ 2009-0015, p.7; State Board Order WQ 2006-0012, pp. 14-16.) Thus, according to the State Board, feasibility turns on the ability and propriety of establishing numeric effluent limitations, rather than the ability of a discharger to comply.

However, this argument is unfounded and is not supported by case law or by the Board’s own Water Quality Orders. It will nearly always be possible to establish numeric effluent limitations, but there will be many instances in which it will not be feasible for dischargers to comply with such limitations. In those instances, states have the authority to adopt non-numeric effluent limitations.

*Communities for a Better Environment* makes clear that one factor a board may consider in determining whether a numerical effluent limitation is “feasible” is the “ability of the discharger to comply.” (See *Communities for a Better Environment, supra*, 109 Cal.App 4th at pp 1100.) The court expressly approved the regional board’s consideration of this factor in upholding the determination that numeric effluent limits were not “appropriate” for the refinery at issue in that case. (*Id.* at p. 1105 [approving determination that numeric WQBEL was not feasible “for the reasons discussed above,” which included inability of discharger to comply.]

Likewise, in Water Quality Order 2003-0012, the State Board declined to impose numeric effluent limitations [for WET] in a waste discharge permit because of a concern that numeric limitations would not be appropriate.<sup>FN</sup> (State Board Order WQ 2003-0012.)

FN. The Board’s Water Quality Orders indicate a “preference” for determining the “ability and propriety” of establishing numeric effluent limitations in a regulatory setting, e g as part of a basin plan amendment, rather than as part of a permit petition process. (See State Board Order WQ 2003-0012, pp 8-9, State Board Order WQ 2009-0015, p 7 fn 28.) Thus, the Board contends, while the Board may consider dischargers’ ability to comply when deciding whether numeric effluent limitations are “appropriate,” in general, a discharger’s ability to comply should not be considered when setting specific numeric effluent limitations in a permit (See *ibid.* ) However, Water Quality Order 2003-0012 shows that the Board has considered the “ability and propriety” of numeric effluent limitations as part of the permit petition process, at least to give the Board time to address the issue in a regulatory setting (See State Board Order WQ 2003-0012, p 9.)

The Board’s Order in this proceeding cited to WQO 2003-0012 with approval, noting that “it IS possible to have effluent limitations other than numeric effluent limitations [provided] the effluent limitation is enforceable and designed to implement the water quality objective.” (CSPA000398.) The Board remanded the matter to the Regional Board to further consider whether there are feasible alternatives or methods, other than reverse osmosis, that the City could use to achieve the numeric limits. (CSPA000401.)

Accordingly, the Court rejects the argument that in determining the “propriety” of numeric effluent limitations, the Board may not consider the ability (or inability) of the discharger to

1 comply with such limitations. The ability to comply is a critical factor in determining the  
2 “propriety” of numerical limitations.

3 This decision and those cases cited as underlying authority for the decision challenge the  
4 Regional Board’s justification. As these cases proclaim, numeric effluent limitations are not  
5 required by any law or regulation for any constituent. Moreover, numeric limits are particularly  
6 inappropriate for WET because of the inherent inaccuracies of biological testing and the likelihood  
7 of false positive test results that puts the permittee in compliance jeopardy for false failures,  
8 creating a violation when the effluent is not truly “toxic.”

9 The legal validity of numeric chronic toxicity limits using any method (NOEC/IC25/TST)  
10 is questionable. EPA recognizes that the precision of freshwater chronic toxicity tests is generally  
11 in the range of 30-60% in terms of coefficient of variation. *See* 60 Fed. Reg. 53533-4 (Oct. 16,  
12 1995). This variation is similar to a range of non-detect to 2.2 TUc for any particular clean (method  
13 blank) sample, or using a non-technical analogy, is similar to a radar detector registering a stopped  
14 car at any speed from 0-121 miles per hour.

15 In addition, these tests have been shown to have 5-40% false failures (a “fail” under the  
16 TST when there is no actual toxicity), further placing their regulatory usefulness in question and  
17 raising constitutional due process issues in the context of strict liability for permit violations. *See*  
18 Risk Sciences White Paper (2014) submitted to the Regional Board on May 6, 2014.<sup>17</sup> Even EPA  
19 has determined that “the accuracy of toxicity tests cannot be determined.” *See Short Term Methods*  
20 *for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*;  
21 EPA/600/4-91/002 at 139, 193, and 225 (July 1994). Even if there is only a 5% false failure level  
22 (as is set for the TST), this guarantees at least one numeric effluent limit “violation” in the five  
23 year permit term, even though there is no actual toxicity for those incidents. This would be an  
24 enforceable violation, not subject to MMPs per Water Code section 13385(i)(1)(D) if there are  
25

26  
27 <sup>17</sup> Although the Regional Board asked for additional information, the Regional Board excluded some of the submitted  
28 information from the official record even though it directly related to previous comments and addressed numeric limits  
and compliance schedules discussed on the May 1, 2014 teleconference between the permittees and Regional Board  
staff. *See* Regional Board, Notice of Determination (May 7, 2014). This action was also an abuse of discretion.

1 other toxic pollutant limits in the permit, but subject to discretionary and citizen suit enforcement.  
2 No reason exists to put permittees in such compliance jeopardy unnecessarily.

3 Reanalysis of actual WET test data, from a wide variety of real-world samples,  
4 demonstrates that the TST technique consistently “detects” the existence of toxicity more  
5 frequently than the NOEC method, especially for tests with relatively small effect levels. *See State*  
6 *Board, Effluent, Stormwater and Ambient Toxicity Test Drive Analysis of the Test of Significant*  
7 *Toxicity (TST)* (Dec., 2011) (*see e.g.*, Chronic Freshwater results in Table E-1).

8 One should not assume that greater statistical sensitivity equates with improved accuracy in  
9 WET testing. Reanalysis of data from EPA’s inter-laboratory WET variability study indicates that  
10 the TST technique also “detects” toxicity in blank samples at a rate up to three times higher than  
11 the NOEC. (U.S. EPA. *Final Report: Interlaboratory Variability Study of EPA Short-term Chronic*  
12 *and Acute Whole Effluent Toxicity Test Methods*, Vol. 1; EPA-821-B-01-004 (Sept., 2001). Blank  
13 samples are comprised solely of laboratory dilution water that is known to be non-toxic before the  
14 test begins. Such inaccuracies demonstrate that the TST does not provide performance “acceptably  
15 equivalent” to that of the standard methods that were promulgated in 2002. *See Regional Board’s*  
16 *Response to Comments on Permit* at pg. 10.

17 Because of the unreliability and inaccuracy of these biological test methods, strictly  
18 construed numeric (“pass/fail” or “% Effect”) effluent limits for toxicity are inappropriate,  
19 infeasible to comply with, and should not have been imposed.

20 In conclusion, for all the reasons cited in herein, the effluent limits for chronic toxicity in  
21 Table 4 of the Permit should be changed back to the narrative effluent limitation contained in the  
22 last permit with a numeric trigger for additional investigations (e.g., TIE/TRE). No authority exists  
23 for mandating numeric chronic toxicity effluent limitations and particularly not limits of “Pass”, or  
24 “% effect <50” using a non-Part 136 method. As stated above, the Basin Plan Amendment  
25 incorporating the Toxicity TMDL, Resolution No. R4-2005-009 at page 7, expressly stated that the  
26 numeric toxicity targets “would be implemented as a trigger,” so the limit in Table 4 of Provision  
27 IV. and the Compliance Determination for Chronic Toxicity in Provision VII.J. should be adjusted  
28 accordingly. Furthermore, as stated above, the inclusion of numeric chronic toxicity effluent

1 limitations violates the current binding precedent from State Board Order No. WQ 2003-0012.  
2 Finally, since the TST is not an approved Part 136 methodology (or a valid ATP), this method  
3 should not be utilized for compliance purposes unless promulgated as a formal rule by EPA.

4 **C. Other Problematic Effluent and Receiving Water Limitations**

5 **1. Unnecessary Effluent limit for MBAS.**

6 Effluent limits for Methylene Blue Activated Substances (“MBAS”), set as both  
7 concentration and mass as average monthly limits, are included in Table 4 that is set equal to the  
8 drinking water Maximum Contaminant Level (“MCL”) of 0.5 mg/L, even though there is no  
9 municipal drinking water (“MUN”) use designated for the waters to which the District discharges.

10 Neither the effluent nor ambient data exceed the MCL, with a maximum observed effluent  
11 concentration of 0.05 mg/L and a maximum ambient concentration of 0.29 mg/L. Permit at pg. F-7;  
12 District’s Comments on the Permit. Nevertheless, Section IV.C.2.b.ix. of the Tentative Order’s  
13 Fact Sheet (pg. F-27), stated that this effluent limitation “was developed based on the Basin Plan  
14 incorporation of Title 22 Drinking Water Standards... to protect the surface water MUN beneficial  
15 use.” However, as the District pointed out in comments, MUN is not applicable to the surface  
16 receiving waters as is recognized in footnote 1 of Table F-4a (pg. F-14) of the Permit. In the final  
17 Permit, the justification is modified to now state that the limit is needed to “protect the surface  
18 water groundwater recharge (GWR) beneficial use and the groundwater basin’s MUN beneficial  
19 use.” Permit at pg. F-28.

20 MBAS is discussed in Chapter 3 of the Basin Plan in the section covering Regional  
21 Objectives for Inland Surface waters, which clearly states that this objective only applies to  
22 [surface] waters designated MUN, not to waters designated as GWR. Title 22 MCLs are also  
23 referenced under the Groundwater objectives. However, even though groundwater recharge is not  
24 considered an acceptable justification to apply these objectives to the WRP discharge, MBAS is  
25 not even specifically listed in the Tables referenced from Title 22 in Chapter 3 of the Basin Plan in  
26 the section under Groundwater – Chemical Constituents and Radioactivity (Basin Plan, pg. 3-18).  
27 Furthermore, the GWR use is not a recognized or mandatory Clean Water Act use, so protection of  
28 this use is not required by federal law and imposition of this effluent limit for state law purposes

1 requires additional analysis under Water Code sections 13263 and 13241 specific to this limit prior  
2 to imposing any effluent limitation that is more stringent than required by federal law. *City of*  
3 *Burbank v. SWRCB*, 35 Cal. 4<sup>th</sup> 613, 618, 628 (2005). Further, application of MCLs at end of pipe  
4 ignores dilution in receiving waters and removal through soil aquifer treatment. No evidence has  
5 been presented that there is a lack of assimilative capacity in local aquifers that would justify an  
6 end-of-pipe effluent limit for MBAS equal to the MCL.

7 In addition, Section IV.C.2.b.ix. of the Fact Sheet goes on to say that “given the nature of  
8 the Facility which accepts domestic wastewater into the sewer system and treatment plant, and the  
9 characteristics of the pollutants discharges, the discharge has reasonable potential...” This is not  
10 an adequate justification for requiring an effluent limit for MBAS (or any other pollutant without  
11 reasonable potential). The fact that a pollutant may be present in domestic wastewater *influent* in  
12 no way correlates with its potential for being *discharged in the recycled water* at a level that  
13 impacts the beneficial uses of the receiving water, or causes an in-stream exceedance of an  
14 applicable water quality standard. This same reasoning would apply to any constituent that is  
15 regularly detected in wastewater treatment plant influent and, unless the concentration of the  
16 constituent in effluent exceeds water quality criteria, those constituents are not assigned effluent  
17 limits. 40 C.F.R. §122.44(d)(1)(iii). Therefore, for all these reasons, the District requests that the  
18 effluent limit for MBAS be removed as unnecessary.

19 **2. Unnecessary Effluent limits for Chlorinated Pesticides and PCBs.**

20 Table 4 of the Tentative Order contains average monthly and daily maximum  
21 concentration-based effluent limits for chlordane, 4,4-DDD, 4,4-DDE, 4,4-DDT, dieldrin, PCBs  
22 and toxaphene. These effluent limits are based on the WLAs set forth in the Calleguas Creek  
23 Watershed Organochlorine Pesticides, PCB and Siltation TMDL (“OP TMDL”) established in  
24 2005 by the Regional Water Board. Permit at pg. 8, footnote, 13. However, DDT and DDD have  
25 been not detected in the effluent or the receiving water since January 2009. Additionally,  
26 chlordane, 4,4-DDE, dieldrin, PCBs and toxaphene were not detected at all during the time frame  
27 for which data was evaluated for this permit. Therefore, there is no reasonable potential for these  
28 constituents to cause or contribute to a water quality exceedance and the effluent limits should be

1 removed from Table 4. *See accord City of Woodland v. California Regional Water Quality*  
2 *Control Board, Central Valley Region, Alameda County Superior Court Case No. RG04-188200*  
3 (May 16, 2005) at pgs. 4, 13. To address any concern associated with the TMDL, a detected value  
4 of one of these constituents at a level near the applicable WLA could be a trigger for a source  
5 investigation, and detection at or above the applicable WLA could trigger reasonable potential and  
6 the related reopener clause. Permit at pg. 16.

7       The allegation that a reasonable potential analysis is not required when there is a TMDL is  
8 not borne out by careful review of the federal regulations. The federal regulations require effluent  
9 limitations as necessary to achieve water quality standards, including narrative water quality  
10 criteria. 40 C.F.R. §122.44(d)(1). In order to determine whether an effluent limitation is  
11 “necessary,” the permitting authority performs what is known as a “reasonable potential analysis”  
12 or “RPA.” *Id.* at §122.44(d)(1)(i)-(vi). If an effluent limit is necessary, then “when developing  
13 water quality-based effluent limits under this paragraph,” the permitting authority shall ensure that  
14 those effluent limits “are consistent with the assumptions and requirements of any available  
15 wasteload allocations for the discharge prepared by the State and approved by EPA pursuant to 40  
16 CFR 130.7,” which relates to TMDLs. *Id.* at §122.44(d)(1)(vii); §130.7. If there is no reasonable  
17 potential under subdivisions (i) through (vi), then there is no need for consistency with the TMDL  
18 and WLAs under the later subdivision (vii). One subdivision cannot be read to the exclusion of the  
19 other preceding parts. *See supra* footnote 8.

20       The State Implementation Policy (“SIP”) does not change this analysis. Under the SIP, the  
21 permit writer must “conduct the analysis in this section for each priority pollutant with an  
22 applicable criterion or objective, *excluding priority pollutants for which a Total Maximum Daily*  
23 *Load (TMDL) has been developed*, to determine if a water quality-based effluent limitation is  
24 required in the discharger’s permit.” SIP at Section 1.3, pgs. 5-6 (emphasis added). So for  
25 priority pollutants without a TMDL, the permit writer uses the SIP RPA procedure. If there is a  
26 TMDL, then the SIP analysis in Section 1.3 is not required, but the RPA is still mandated under the  
27 federal regulations and the rule that there is no limit required if there is no reasonable potential still  
28 applies.

1                                   **3.        Unnecessary Effluent limits for Boron**

2                   Table 4 of the Tentative Order includes effluent limits for boron of 1 mg/L and 60 pounds  
3 per day as a monthly average. Permit at pg. 6. However, the maximum observed daily effluent  
4 concentration for boron in recent years is 0.82 mg/L and highest monthly average was 0.58 mg/L.  
5 Permit at pg. F-7, Table F-2. Additionally, as noted in the Basin Plan Amendment (R4-2007-016),  
6 boron is not listed in the reach to which the Camarillo WRP discharges and there is no applicable  
7 WLA for boron. Therefore, there should be no effluent limit for boron because there is no  
8 reasonable potential (even though not analyzed by the Regional Board as required under 40 C.F.R.  
9 §122.44(d)(1) in Table F-7) and adequate justification for this limit was not provided.

10                                   **4.        Unnecessary Heptachlor Epoxide Limits**

11                   Heptachlor epoxide has no actual detected effluent data. Table F-7 of the Fact Sheet (on  
12 page F-37) shows heptachlor epoxide as having detected effluent and ambient data, which is  
13 incorrect. See Permit at F-37, Table F-7. The Regional Board's response to comments admits that  
14 the data used was "j-flagged" data, which represents both detected, but not quantified ("DNQ")  
15 effluent and ambient data. These values are *estimated* concentration below the lowest reliable  
16 point on the calibration curve. Thus, these data are not legally defensible and should not be used  
17 for regulatory purposes. See SIP at Section 1.3 (excluding data that are insufficient). Moreover, the  
18 data were from 2007, which is too old to be used for a reasonable potential analysis in 2014 since  
19 changes have been made to the unit processes at the WRP since that time. See Permit at F-12,  
20 Section II.E. In the absence of any showing "that there have been any organochlorine pesticides in  
21 the City's effluent in the three years prior to the date of the Regional Board's Order, there is no  
22 basis to find reasonable potential for these pesticides to be contained in the City's effluent, and the  
23 Regional Board's Order should not contain any limitations on these substances." *City of Woodland*  
24 *v. California Regional Water Quality Control Board, Central Valley Region, Alameda County*  
25 Superior Court Case No. RG04-188200 (May 16, 2005) at pg. 14 (limiting data to last three years  
26 for reasonable potential analysis). For these reasons, the heptachlor epoxide (and any other similar)  
27 limits based on old or j-flagged data should be removed from the Permit.

28

1                   **5.        Unnecessary Radioactivity Limit**

2                   An effluent limitation for general radioactivity is not warranted as there is no demonstrated  
3 reasonable potential and this limit unnecessarily duplicates the discharge prohibition for  
4 radiological waste in III.G. The response to comments states that there is reasonable potential  
5 because radioactivity was detected in the effluent. Regional Board Response to Comments at pg.  
6 32. However, detection of a substance is not enough to provide reasonable potential. The  
7 detection must be at a level with a reasonable potential to cause or contribute to an in-stream  
8 exceedance of the applicable water quality standard. No evidence was provided that a proper  
9 reasonable potential analysis was done for radioactivity, or that radioactivity is an issue in  
10 receiving waters. Therefore, this effluent limit must be removed.

11                   **6.        Unnecessary Mass Limits**

12                   For conventional pollutants, no need exists for both mass limits and 85% removal  
13 requirements as both are not required by either federal or state law. Under federal law, mass limits  
14 are specifically not required for Technology-Based Limits, such as BOD and TSS. The federal  
15 regulations only require concentration-based effluent limits and 85% removal requirements. (See  
16 40 C.F.R. §133.102(a)(1)-(3) and (b)(1)-(3); see e.g., Order No. R2-2012-0051, Table 6 (monthly  
17 and weekly conventional pollutant limits only with no mass limits required).) The only way that  
18 mass limits for BOD and TSS are authorized by the federal regulations is where substituting the  
19 percent removal requirements with a mass loading limit for less concentrated influent wastewater  
20 for separate sewers. (40 C.F.R. §133.103(d).) Since the Regional Board did not substitute mass  
21 limits for the percent removal requirements that are contained in Provision IV.A.3.a., the mass  
22 limits in Table 4 are not justified under federal law.

23                   Finally, the Fact Sheet at page F-40 states that “40 CFR §122.45 (f)(1) requires that except  
24 under certain conditions, all permit limits, standards, or prohibitions be expressed in terms of mass  
25 units. 40 CFR § 122.45(f)(2) allows the permit writer, at its discretion, to express limits in  
26 additional units (e.g., concentration units).” This statement ignores that 40 C.F.R. section  
27 122.45(f)(1) does not require and exempts mass-based effluent limitations for: i) pH, temperature,  
28 radiation, or other pollutants which cannot be appropriately expressed by mass, and ii) “when

1 applicable standards and limitations are expressed in terms of other units of measurement.”  
2 (Emphasis added.) Further, Table 4 includes all limits expressed initially in concentration;  
3 therefore, additional mass limits are not needed or required (except in the case of TMDL-based  
4 mass limits, and then concentration-based limits are not required). Because the technology-based  
5 limits and most water quality-based limits and criteria are expressed in concentration (i.e., “other  
6 units of measure” besides mass), the exception to the requirement for mass limits has been met and  
7 mass limits are not required under federal law. (See *accord* Order No. R1-2013-001 at F-26  
8 (“Because secondary treatment standards for BOD<sub>5</sub> and TSS are expressed in terms of  
9 concentration and percent removal, mass-based effluent limitations for these parameters are not  
10 required. Mass-based effluent limitations for BOD<sub>5</sub> and TSS were included in the previous Order,  
11 but have been removed from this Order...”).<sup>18</sup>) Furthermore, where flow is limited either expressly  
12 in the permit or by design constraints, mass will be limited in accordance with the concentration  
13 cap and the flow limit. The Regional Boards must consistently interpret the regulatory  
14 requirements or equal protection problems arise when similarly situated permittees are treated  
15 differently under the same statutory and regulatory scheme. The Region 1 approach should be  
16 preferred over the Region 4 approach.

17 All mass limits should be removed since not required by federal law. If being imposed  
18 under state law, or the discretionary ability to include mass limits in addition to concentration  
19 based limit under section 122.45(f)(2), then these requirements are more stringent than required by  
20 federal law and have not been adequately justified and nor have all of the considerations under  
21  
22

---

23 <sup>18</sup> See Order No. R1-2013-001 at pgs. F-53 and F-54 (“The previous Order contained mass-based effluent limitations  
24 for BOD<sub>5</sub> and TSS that applied when the Permittee was discharging treated effluent to any of its authorized surface  
25 water discharge points. The draft Order removes mass limitations for discharges of treated wastewater because  
26 Regional Water Board staff misinterpreted the exception in 40 CFR 122.45(f)(2), which states that mass limitations are  
27 not required for (1) pH, temperature, radiation, or other pollutants which cannot be appropriately expressed by mass,  
28 and (2) when applicable standards and limitations are expressed in terms of other units of measure.” Staff should have  
granted exception No. 2, because secondary treatment standards for BOD<sub>5</sub> and TSS in 40 CFR 133.102, on which the  
effluent limitations in previous permits were based, are expressed in concentration and percent removal (i.e., “other  
units of measure”). The relaxation of effluent limitations for BOD<sub>5</sub> and TSS in this Order is permissible under CWA  
section 402(o)(2)(B), because Regional Water Board staff has determined that mass limitations for BOD<sub>5</sub> and TSS  
were applied in the previous permit as a result of a mistaken interpretation of law when issuing the previous permit.”)  
(emphasis added).

1 Water Code section 13263 and 13241 been satisfied for these particular limits. (*See City of*  
2 *Burbank v. State Water Resources Control Board*, 35 Cal. 4th 613, 629 (2005).)

3 No evidence has been cited that mass-based limits are necessary ensure to ensure proper  
4 treatment of a tertiary treatment plant, or that the District has potable or other water available to  
5 dilute its effluent in order to comply with the final effluent concentration limits as suggested on  
6 page F-40, particularly in a drought. In fact, the District meets concentration-based limits much  
7 more stringent than those proposed under federal secondary treatment requirements. 40 C.F.R.  
8 Part 133. Without evidence to support the findings of necessity for these limits that are more  
9 stringent than required by federal law (including the mass limits for BOD and TSS), the mass  
10 limits must be removed.

11 If retained, then the mass limits (even those from TMDLs) need to be calculated based on  
12 design flow to allow for growth. 40 C.F.R. §122.45(b); 44 Fed. Reg. 32864 (June 7, 1979)(when  
13 previously numbered 122.16). Not all of the current mass limits have a reference to footnote 1 to  
14 Table 4, but need to in order to be consistent with EPA regulations. *See also* City of Moscow,  
15 Idaho, NPDES Appeal No. 00-10, 2001 WL 988721 (July 27, 2001) *citing* 40 C.F.R. 122.45(b) and  
16 122.44(d)(1)(vii) (approving the use of design flow rather than the number referenced in the  
17 TMDL because although the regulations require consistency with the WLAs in a TMDL, “they do  
18 not require that the permit limitations that will be finally adopted in a final NPDES permit be  
19 identical to any of the WLAs that may be provided in a TMDL.”).

#### 20 7. Unnecessary Daily Limits

21 There is inadequate justification for daily limits for BOD, TSS, oil & grease or settleable  
22 solids. These limits are inconsistent with federal law (40 C.F.R. §122.44(d)(if no reasonable  
23 potential), 122.45(d)(2)(no daily limits generally for POTWs) and Part 133) and cannot be justified  
24 by the aquatic life protection portions of the SIP. Thus, these limits need to be removed. (*See*  
25 *accord* Order No. R1-2013-0001 at 8 (no daily limits for conventionals).) The Fact Sheet at F-24  
26 states “daily maximum limits cannot be removed because none of the anti-backsliding exceptions  
27 apply.” This is incorrect because several provisions would justify removal of these daily limits,  
28

1 including but not limited to CWA, 33 U.S.C. §1342(o)(1)(compliance with 1314(d)(4)(B)), or  
2 (o)(2)(A)(substantial alterations to plant since last permit), or (o)(2)(B)(ii)(mistake of law).

3 **8. Unnecessary Receiving Water Limits for Temperature**

4 Provision V.A.1.'s prohibition on effluent from altering water temperature by more than 5  
5 degrees may be an unachievable. Permit at pg. 10. When upstream flow conditions are extremely  
6 low, the District's temperature can alter stream by more than 5 degrees. A statement should be  
7 added either in this section or under compliance determination that "When upstream flow is <6 cfs,  
8 the upstream temperature is not representative of natural conditions."

9 **9. Inappropriate Pest Breeding Limitation**

10 One of the Receiving Water Limitations states that the "discharge shall not result in  
11 problems due to breeding of mosquitoes, gnats, black flies, midges, or other pests." Permit at pg.  
12 12, Provision V.A.15. This Receiving Water Limitation for insect control is inappropriate and not  
13 applicable to this highly treated recycled water discharge, and must be removed.

14 **10. Unnecessary Receiving Water Limits where Effluent Limits Prescribed**

15 Both an effluent limitation and a receiving water limitation for temperature, pH, total  
16 residual chlorine, and turbidity are not required. *See* Permit at IV.A.1.a -Table 4, IV.A.3.b. and  
17 A.4.e.; V.A.1., 2., and 6. If the discharge has a reasonable potential for any constituents for which  
18 receiving water limitations are proposed, then the appropriate regulation is an effluent limit. If  
19 there was no reasonable potential, then no regulation of these substances is required. Similarly,  
20 where an effluent limit is being proposed, as in the case of temperature, pH and turbidity, a  
21 duplicative receiving water limitation is unnecessary because the effluent is being adequately  
22 controlled to not cause or contribute to an in-stream exceedance. A similar comment would apply  
23 to the receiving water limitations for toxicity, ammonia, and chlorine. Each of these duplicative  
24 receiving water limitations should be removed to not impose "double jeopardy," i.e., two violations  
25 being imposed for the same discharge violating both types of limitations.

26 **11. Unnecessary Groundwater Limitations**

27 The Groundwater Limitations at Provision V.B. should be deemed "Not Applicable" since  
28 there are no direct discharges to groundwater and all potential incidental discharges are adequately

1 protected by the effluent and receiving water limitations. Groundwater requirements are strictly  
2 State law requirements only and do not belong in a federal NPDES permit that does not directly  
3 regulate groundwater.

4 **D. Unnecessary and Burdensome Monitoring and Reporting Requirements**

5 **1. Sediment Monitoring for Mercury**

6 The requirement for sediment monitoring in Section E.IV.4. (pg. E-10) should be deleted.  
7 Sediment monitoring is not required by the Calleguas Creek Watershed Metals TMDL (“Metals  
8 TMDL”) and it is not possible to monitor sediment through effluent samples. TSS and water  
9 column total mercury samples are sufficient to address the TMDL requirements. It is overly  
10 conservative to assume that the total water load is equal to the suspended sediment load and to  
11 assume that suspended sediment is not the same makeup as bottoms sediments. In its response to  
12 comments (pg.12, Comment C.7.), the Regional Board stated that this requirement is needed to  
13 address the Sediment Toxicity component of the Toxicity TMDL. However, the District does not  
14 discharge to a reach that is impaired with respect to Sediment Toxicity. Sediment Toxicity is being  
15 addressed in the two Reaches that are impaired (i.e., Mugu Lagoon, and lower reach of Calleguas  
16 Creek) through sediment monitoring being conducted there as part of the TMDL Watershed  
17 Monitoring Program. This monitoring is adequate to ensure that any concerns regarding toxicity  
18 are being addressed. For these reasons, the Regional Board has failed to justify the need to include  
19 sediment monitoring pursuant to Water Code section 13267(b) and 13225(c). Measuring TSS and  
20 total mercury in water is all that is needed to meet the Metals TMDL requirements.

21 **2. Excessive Monitoring Requirements**

22 The Calleguas Creek Watershed stakeholder group has been implementing a coordinated  
23 monitoring program for TMDL implementation for over 5 years with no permit requirements  
24 mandating this participation. However, Section I.N. and IX.C of the Monitoring and Reporting  
25 Program now ignores the voluntary efforts of the District and mandates the implementation and  
26 compliance with the Watershed-Wide Monitoring Program, and the submittal of annual progress  
27 reports regarding the implementation of a watershed monitoring program. The watershed TMDL  
28

1 monitoring program is already established and there is no need to submit progress reports detailing  
2 efforts to implement the monitoring program.

3       Additionally, consistent with State Board Resolution 2013-0029 regarding “Reducing Costs  
4 of Compliance while Maintaining Water Quality Protection,” Regional Board staff have been  
5 directed to work with Permittees to identify duplicative or unnecessary monitoring during  
6 reissuance of NPDES permits. Thus, the District requests the following changes to the monitoring  
7 frequencies to reduce unnecessary monitoring:

- 8       • Monitoring under the approved Calleguas Creek Watershed TMDL monitoring program has  
9       established quarterly as the necessary monitoring frequency for determining compliance  
10       with the TMDL requirements. The monitoring frequencies for effluent and receiving water  
11       in Tables E-3a and E-4a for all nitrogen and phosphorus compounds, copper, mercury, and  
12       nickel, should be reduced from monthly to quarterly consistent with the approved TMDL  
13       monitoring program.
- 14       • Because chlorinated pesticides and PCBs (as arochlors) have not been measured at  
15       concentrations above detection limits, the monitoring frequencies listed in Tables E-3a  
16       (Effluent Monitoring) and E-4a (Receiving Water Monitoring requirements) for all these  
17       constituents should be changed from quarterly to semi-annually. Based on historic data,  
18       more frequent monitoring is unnecessary.
- 19       • Inadequate justification has been provided for additional PCB monitoring using an  
20       unapproved method. Permit MRP, IV.A.3., Table E-3a at pg. E-9. As part of the TMDL  
21       monitoring program, PCBs are being monitored using low level detection limits in  
22       receiving water. Monitoring is conducted quarterly at 5 sites with an additional 2 events  
23       conducted during wet weather at each site each year. In five years of monitoring at 5 sites  
24       (i.e., 175 samples), only 3 samples have had results above detected limits. Therefore, this  
25       appears to be monitoring “strictly for monitoring purposes” with no other purpose. In  
26       accordance with State Water Board direction in its Resource Alignment/Cost of  
27       Compliance Initiative to minimize excessive monitoring on municipalities, this should be  
28       removed from the Permit.

1           There are several provisions of the TSO that the District is also challenging and requesting  
2 a stay because of the unreasonable timeframes or lack of need for this information. The challenged  
3 provisions are as follows:

- 4           • Provision in Paragraph 3 on page 11 of the TSO, which requires: “Achieve full compliance  
5 with the final effluent limitations as soon as possible, but no later than December 31, 2015,  
6 the date by which Camarillo SD committed to achieving compliance, for TDS and sulfate  
7 contained in Order No.R4-2014-0062.” This schedule is artificially truncated when the  
8 Salts TMDL provides until December of 2023 for final compliance.
- 9           • Provision in Paragraph 5 on page 11 of the TSO to submit quarterly progress reports, the  
10 first due October 15, 2014, of efforts taken by the Permittee to comply with the final  
11 effluent limitations for TDS and sulfate, and the requirements for the content of those  
12 reports. These reports would be wholly unnecessary if the suggested changes had been  
13 made to the Permit. Given that the tasks needed will take years, not months, quarterly  
14 reports are burdensome and unnecessary.

### 15           3.       Constituents of Emerging Concern (“CEC”) study

16           Provision VI.C.2.b. of the Permit requires the District to “conduct a special study to  
17 investigate the CECs in the effluent discharge.” The paragraph then goes on to describe that the  
18 requirements of the work plan are discussed in the Monitoring and Reporting Program and Fact  
19 Sheet. The Special Study for CECs has not been adequately justified and should be removed. No  
20 “approved” analytical methods exist for the testing of these constituents, so the results from these  
21 unapproved methods are merely estimations that provide no valid data or relevant information.

### 22           4.       Recycling Study “Required” in the Fact Sheet

23           The Tentative Order at Provision VI.C.2.d contained provisions requiring a Recycling  
24 Study. That provision was removed from the final Permit. However, the Fact Sheet at Section  
25 III.C.11. still seems to require such a study (“the Permittee shall investigate... The Permittee shall  
26 submit...”)(emphasis added). *See also* Permit at pg. F-61, Section VIII.G. (“To encourage  
27 recycling, the Permittee is required by this Order to continue to explore the feasibility of recycling  
28 to maximize the beneficial reuse of tertiary treated effluent.”)(emphasis added).

1 A Fact Sheet is not supposed to contain binding provisions, and is merely included to  
2 provide background and rationale for the Permit's provisions. See Permit at pg. 4, Findings II.B  
3 (incorporated into the Permit and "constitutes Findings for this Order.") Therefore, these  
4 seemingly mandatory provisions should be removed from the Fact Sheet or modified to not include  
5 substantive requirements as Findings. If maintained, this section needs to further recognize that the  
6 District is not a city and has no jurisdiction or ability to "investigate the feasibility" of the control  
7 or reuse "storm water and dry-weather urban runoff" besides that falling on its site that is directed  
8 to the WRP's headworks. If the State Board believes that this Finding should be interpreted as a  
9 binding provision, then the District seeks a stay of the mandatory language, which requires the  
10 District to submit a recycled water report 180 days after the effective date of the order and a  
11 separate report 30 days after the completion of a major project, since these deadlines will likely  
12 occur prior to any final administrative determination on the propriety of this language.

13 The Recycling Feasibility Study has not been adequately justified and is unnecessary. The  
14 District is already recycling and has plans for additional recycling. This activity has nothing to do  
15 with an NPDES permit discharge, except to lessen the amount and perhaps eliminate the discharge.  
16 While the District is perfectly happy informally letting the Regional Board know about potential  
17 new recycling opportunities, the requirement to conduct a formal feasibility study and a separate  
18 report after the completion of every major recycling project is unreasonable and has not been  
19 adequately justified under Water Code section 13267(b) or 13225(c). Excessive reporting  
20 requirements are also contrary to the intent of the State Board's Resource Alignment/Cost of  
21 Compliance Initiative to minimize excessive costs for municipalities like the District.

22 **5. Pollution Prevention Plan Requirements in the TSO.**

23 Provision in Paragraph 4 on page 11 of the TSO requires the District to "Submit a Pollution  
24 Prevention Plan (PPP) work plan, with the time schedule for implementation, for approval of the  
25 Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3." The District  
26 has challenged the final numeric salinity effluent limitations and asked for the full compliance  
27 schedule allowed by the TMDL to be included in the Permit. Had that been done, then the  
28 requirements of Water Code section 13263.3 would not have been triggered and no Pollution

1 Prevention Plan (“PPP”) would have been necessary. In addition, a PPP is unnecessary because  
 2 there is already a TMDL in place to address salinity issues. Creation of a PPP is additional work  
 3 that is wholly unnecessary and duplicative of other efforts being undertaken.

4 **E. Miscellaneous Issues**

5 **1. Sanitary Sewer Overflow Provisions**

6 Sewage spills are regulated by the State Water Board’s Sanitary Sewer Overflow (“SSO”)   
 7 Waste Discharge Requirements (“WDRs”), which discourages Regional Boards from issuing   
 8 different requirements in NPDES permits. Paragraph 9 of the SSO WDR states (with emphasis   
 9 added): “Both uniform SSO reporting and a centralized statewide electronic database are needed to   
 10 collect information to allow the State Water Board and Regional Water Quality Control Boards   
 11 (Regional Water Boards) to effectively analyze the extent of SSOs statewide and their potential   
 12 impacts on beneficial uses and public health.” Paragraph 11 also states that “it is the State Water   
 13 Board’s intent that this Order be the primary regulatory mechanism for sanitary sewer systems   
 14 statewide.” Regional Water Boards would need to include findings of necessity for more stringent   
 15 or differing requirements than the SSO WDR, supported by substantial evidence. The Los Angeles   
 16 Regional Board failed to demonstrate why its region needs more stringent requirements besides   
 17 stating that there historically has been a “loss of recreational use in coastal beaches and in Arroyo   
 18 Conejo as a result of major sewer spills.” Regional Board Response to Comments at 41, Permit at   
 19 pg. F-54. This justification is no different than anywhere else in the State where large spills have   
 20 occurred. Therefore, the requirements from other regions should be used in lieu of the proposed   
 21 section 6. f., as follows:

22 “The Permittee has coverage under, and is separately subject to, the requirements of State   
 23 Water Board Order No. 2006-003-DWQ, Statewide General WDRs for Sanitary Sewer   
 24 Systems. As such, the Permittee provides notification and reporting of SSOs in accordance   
 25 with the requirements of Order No. 2006-003-DWQ and WQ 2008-0002-EXEC and any   
 26 revisions thereto for the operation of its wastewater collection system.”

27 *See accord* Order No. R2-2013-0042 at 27, section VI.A.5.a.i.; R5-2012-0115 at 29, section   
 28 VI.C.5.d.

1 The remaining requirements in Section VI.C.6. of the Permit related to sewer spills could  
 2 remain, but should only do so if amended to relate solely to non-sewage spills. Specifically, the  
 3 last sentence in section 6.a. should state: “For certain spills, overflows and bypasses, not including  
 4 sewage spills, the Permittee shall make notifications as required below.” Then all other references  
 5 to sewage in this section should be removed, as follows:

6 a.i. “unauthorized release of ~~sewage or other~~ waste other than sewage”

7 a.ii. – This section is unnecessary and should be removed as it is implemented  
 8 through the SSO WDR.

9 a.iii. “The Permittee shall notify the Regional Water Board of any unauthorized  
 10 release or spill at of sewage from its POTW...”

11 a.iii.(3) “An estimate of the amount of non-sewage or other waste released...”

12 c.i. “As soon as possible, but not later than twenty-four hours after becoming  
 13 aware of an unauthorized discharge of non-sewage or other waste...”

14 c.ii. “Submission to the Regional Water Board of the California Integrated Water  
 15 Quality System (CIWQS) ~~Sanitary Sewer Overflow (SSO)~~ event number shall satisfy this  
 16 requirement. Within 30 days after submitting the preliminary report, the Permittee shall  
 17 submit the final written report to this Regional Water Board. ~~(A copy of the final written~~  
 18 ~~report, for a given incident, already submitted pursuant to a statewide General WDRs for~~  
 19 ~~Wastewater Collection System Agencies (SSO WDR), may be submitted to the Regional~~  
 20 ~~Water Board to satisfy this requirement.)...~~”

21 d. “The Permittee shall develop and maintain a record of all spills, overflows or  
 22 bypasses of raw or partially treated non-sewage waste from its collection system or at its  
 23 treatment plant or from its operations.

24 Remove section 6.d.viii as unrelated to non-sewage spills.

25 Allowing different regions to impose different requirements for similar types of discharges  
 26 is not only inconsistent, but may raise constitutional equal protection issues when similarly situated  
 27 entities under the same law are treated disparately. The only requirements under federal law are  
 28 those contained in Appendix D (Standard Provisions) related to proper operation and maintenance,

1 reporting, and mitigation. 40 C.F.R. §122.41(e), (l), and (d). The Regional Board's response that  
2 it "has discretionary authority in enforcement actions" is no comfort to the District when non-  
3 NPDES requirements suddenly become federally enforceable by third parties by being placed in  
4 the Permit. Because sewer spills that don't reach waters of the United States are adequately  
5 covered by the SSO WDR and those that do are enforceable as unpermitted discharges, these  
6 additional requirements should be removed from the Permit.

7 **2. Permit Effective Date**

8 In accordance with the Memorandum of Agreement between the U.S. EPA and State Water  
9 Board, this permit's effective date should have been 50 days after the adoption date. (See Permit at  
10 pg. 1, Table 3; see also NPDES Memorandum of Agreement between the U.S. Environmental  
11 Protection Agency and the State Board at 22, section I.F.2.a. (Sept. 22, 1989)(NPDES permits  
12 adopted by the Regional Water Board "shall become effective on the 50th day after the date of  
13 adoption, if EPA has made no objection to the permit; if there has been significant public  
14 comment".) To be consistent with the SWRCB's 1989 MOU with EPA on NPDES permitting,  
15 the Permit should have had an effective 50 days from the adoption date. The Regional Board in the  
16 response to comments claimed that, in relation to USEPA's draft Program Quality Review (2014),  
17 "Regional Board staff and USEPA agreed to address the issue by making the effective date fall on  
18 the first of the month following the 50 day period post NPDES permit adoption." Regional Board  
19 Response to Comments at pg. 28 (April 30, 2014). The response further states that "USEPA issued  
20 a new guideline on 'effective date' of permits. The guideline states that staff shall make all permit  
21 effective date and permit date the first day of the month, no less than 30 days following Board  
22 adoption.... This practice has been agreed upon by USEPA and State Water Board and helps  
23 prevent permits issued for five years plus one day." *Id.* at 28. Although the District requested a  
24 copy of this new guideline and State Board agreement, none was provided. Thus, it appears that  
25 the Regional Board once again is relying upon guidance to overrule a signed Memorandum of  
26 Agreement that would need to be modified in writing. If such modifications exist, they need to be  
27 provided to permittees so that everyone is aware of the currently binding requirements.  
28 Alternatively, if such modifications are still being negotiated, the District would suggest that the

1 effective date be 60-90 days after adoption to allow adequate time to petition the permit and  
2 receive a stay prior to the permit becoming effective.

3 **3. 100 Year Flood Protection**

4 There is no authority listed for this 100 year storm protection requirement under state or  
5 federal law. Permit at Provision VI.A.2.c. Without such authority, the inclusion of this  
6 unjustified "Standard Provisions" constitutes an abuse of discretion. The Regional Board's  
7 response to comments states that this provision "is commonly used as a requirement for this  
8 standard provision." Regional Board Response to Comments at pg. 35. However, the fact that it  
9 has been used before does not provide adequate authority for use of this provision in the first place.  
10 Without adequate authority and justification, this provision must be removed.

11 **8. A STATEMENT THAT THE PETITION HAS BEEN SENT TO THE  
12 APPROPRIATE REGIONAL BOARD (AND TO THE DISCHARGER IF NOT THE  
13 PETITIONER):**

14 A true and correct copy of this Petition was mailed by First Class mail on June 4, 2014 to  
15 the Regional Board at the following address:

16 Mr. Sam Unger, Executive Officer  
17 Los Angeles Regional Water Quality Control Board  
320 West Fourth Street, Suite 200  
Los Angeles, CA 90013

18 The Petitioner is the discharger, so no need exists to send a copy to the Discharger.

19  
20 **9. A STATEMENT THAT THE SUBSTANTIVE ISSUES OR OBJECTIONS RAISED  
21 IN THE PETITION WERE RAISED BEFORE THE REGIONAL BOARD, OR AN  
22 EXPLANATION WHY NOT.**

23 The substantive and legal issues raised in this petition were presented to the Regional Board  
24 before the Regional Board acted to adopt the Permit and TSO. The District submitted extensive  
25 comments to the Regional Board on April 14, 2014, and supplemental comments as requested by  
26 the Regional Board staff on April 29 and May 7, 2014. District representatives also appeared and  
27 provided testimony at the adoption hearing on May 8, 2014.  
28

1 **10. REQUEST FOR STAY.**

2 Because of the very real possibility of harm from the imposition of certain effluent  
3 limitations and provisions in the Permit and in the TSO, the District has contemporaneously filed a  
4 Petition for Stay with a supporting declaration and requests that several provisions be stayed before  
5 the effective date of the Permit on July 1, 2014. The District requests the State Board, either on its  
6 own motion or in accordance with 23 C.C.R. §2053(a), issue a stay and modification and tolling of  
7 the compliance deadlines of the following contested provisions of the Permit and TSO:

8 PERMIT, ORDER R4-2014-0062:

9 1. The final numeric wet weather and dry weather effluent limitations for Total  
10 Dissolved Solids (“TDS”), Sulfate, and Chloride. (Permit Provision IV.A.1.a., Table 4 at  
11 pg.6.) The Permit prescribes both concentration and mass limits for these constituents as  
12 Average Monthly Effluent Limits (“AMEL”).

13 2. The final numeric effluent limitations for Chronic Toxicity and the  
14 requirement to use the Test of Significant Toxicity to implement those limits. (Permit  
15 Provision IV.A.1.a., Table 4 at pg. 8 and footnotes 15-17.) The Permit prescribes a  
16 Monthly Median Effluent Limitation (“MMEL”) of “Pass” and a Maximum Daily Effluent  
17 Limitation (“MDEL”) of “Pass or %Effect < 50.”

18 3. The Finding requiring the Permittee to conduct a recycling/reuse feasibility  
19 study, submit a report summarizing its recycled water expansion efforts within 180 days of  
20 the effective date of the Permit, and submit a separate report 30 days after the completion of  
21 a major project. (Permit Fact Sheet Section III.C.11. at pg. F-16, and Section VIII.G. at pg.  
22 F-61.)<sup>19</sup>

23 TSO, ORDER R4-2011-0126-A02:

24 4. Provision in Paragraph 3 on page 11 of the TSO, which requires: “Achieve  
25 full compliance with the final effluent limitations as soon as possible, but no later than  
26

27  
28 <sup>19</sup> If the State Board believes that these are merely non-enforceable findings, then the District will withdraw its stay request.

DOWNEY BRAND LLP

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

December 31, 2015, the date by which Camarillo SD committed to achieving compliance, for TDS and sulfate contained in Order No.R4-2014-0062.”

5. Provision in Paragraph 4 on page 11 of the TSO, which requires the City to “Submit a Pollution Prevention Plan (PPP) work plan, with the time schedule for implementation, for approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3.”

6. Provision in Paragraph 5 on page 11 of the TSO to submit quarterly progress reports, the first due October 15, 2014, of efforts taken by the Permittee to comply with the final effluent limitations for TDS and sulfate, and the requirements for the content of those reports.

Respectfully submitted,

DATED: June 4, 2014

DOWNEY BRAND LLP

By: Melissa A. Thorne  
Melissa A. Thorne  
Attorneys for Camarillo Sanitary District

# **EXHIBIT A**

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION**

320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013  
(213) 576-6600 • Fax (213) 576-6640  
<http://www.waterboards.ca.gov/losangeles/>

**ORDER R4-2014-0062  
NPDES NO. CA0053597**

**WASTE DISCHARGE REQUIREMENTS  
FOR THE CAMARILLO SANITARY DISTRICT  
CAMARILLO WATER RECLAMATION PLANT  
DISCHARGE TO THE CONEJO CREEK VIA OUTFALL 001A & 001B**

The following Permittee is subject to waste discharge requirements (WDRs) set forth in this Order:

**Table 1. Discharger Information**

Discharger/ Permittee	Camarillo Sanitary District (Camarillo SD, Permittee or Discharger)
Name of Facility	Camarillo Water Reclamation Plant (Camarillo WRP or Facility) and its associated wastewater collection system and outfalls
Facility Address	150 Howard Road
	Camarillo, CA 93012
	Ventura County

**Table 2. Discharge Location**

Discharge Point	Effluent Description	Discharge Point Latitude (North)	Discharge Point Longitude (West)	Receiving Water
001A	tertiary treated effluent	34 °, 11', 40" N	119°, 00',00" W	Conejo Creek
001B	tertiary treated effluent	34 °, 11', 40" N	119°, 00',00" W	Conejo Creek

**Table 3. Administrative Information**

This Order was adopted on:	May 8, 2014
This Order shall become effective on:	July 1, 2014
This Order shall expire on:	June 30, 2019
The Permittee shall file a Report of Waste Discharge as an application for renewal of waste discharge requirements in accordance with Title 23, Division 3, Chapter 9 of the California Code of Regulations, and an application for reissuance of a National Pollutant Discharge Elimination System permit in accordance with Title 40, § 122.21(d) of the Code of Federal regulations no later than:	180 days prior to the Order expiration date
The United States Environmental Protection Agency and the California Regional Water Quality Control Board, Los Angeles Region have classified this discharge as follows:	Major

I, Samuel Unger, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on May 8, 2014.

*Samuel Unger*

Samuel Unger, P.E., Executive Officer

**Contents**

I.	Facility Information .....	4
II.	Findings .....	4
III.	Discharge Prohibitions .....	4
IV.	Effluent Limitations and Discharge Specifications .....	5
	A. Effluent Limitations – Discharge Points 001A and 001B .....	5
	1. Final Effluent Limitations – Discharge Points 001A and 001B .....	5
	2. Interim Effluent Limitations – Discharge Point 001A and 001B .....	9
	3. Other Effluent Limitations – Discharge Point 001A and 001B .....	9
	B. Land Discharge Specifications – Not Applicable .....	10
	C. Recycling Specifications – Not Applicable .....	10
V.	Receiving Water Limitations .....	10
	A. Surface Water Limitations .....	10
	B. Groundwater Limitations .....	12
VI.	Provisions .....	12
	A. Standard Provisions .....	12
	B. Monitoring and Reporting Program (MRP) Requirements .....	16
	C. Special Provisions .....	16
	1. Reopener Provisions .....	16
	2. Special Studies, Technical Reports and Additional Monitoring Requirements .....	17
	3. Best Management Practices and Pollution Prevention .....	19
	4. Construction, Operation and Maintenance Specifications .....	20
	5. Special Provisions for Municipal Facilities (Publicly-Owned Treatment Works [POTWs] Only) .....	21
	1. Spill Reporting Requirements .....	22
	2. Compliance Schedules .....	26
VII.	Compliance Determination .....	26

**Tables**

Table 1.	Discharger Information .....	1
Table 2.	Discharge Location .....	1
Table 3.	Administrative Information .....	1
Table 4.	Final Effluent Limitations .....	5
Table 5.	Interim Effluent Limitations .....	9
Table 6.	Compliance Schedule for Final Effluent Limitations .....	26

**Attachments**

Attachment A – Definitions .....	A-1
Attachment B1 – MAP OF CAMARILLO WRP & SURROUNDING AREA .....	B-1
Attachment B2 – MAP OF CAMARILLO WRP .....	B-2
Attachment C – FLOW SCHEMATIC .....	C-1
Attachment D – Standard Provisions .....	D-1
Attachment E – Monitoring and Reporting Program .....	E-1
Attachment F – Fact Sheet .....	F-1
Attachment G – Toxicity Reduction Evaluation (TRE) Work Plan .....	G-1
Attachment H – Biosolids and Sludge Management .....	H-1
Attachment I – Pretreatment Reporting Requirements .....	I-1

## I. FACILITY INFORMATION

Information describing the Camarillo Water Reclamation Plant (Camarillo WRP or Facility) is summarized in Table 1 and in sections I and II of the Fact Sheet (Attachment F). Section I of the Fact Sheet also includes information regarding the Facility's permit application.

## II. FINDINGS

The California Regional Water Quality Control Board, Los Angeles Region (Regional Water Board), finds:

- A. Legal Authorities.** This Order serves as WDRs pursuant to article 4, chapter 4, division 7 of the California Water Code (CWC; commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the United States Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the CWC (commencing with section 13370). It shall serve as an National Pollutant Discharge Elimination System (NPDES) permit for point source discharges from this facility to surface waters.
- B. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for the requirements in this Order, is hereby incorporated into and constitutes Findings for this Order. Attachments A through E and G through I are also incorporated into this Order.
- C. Notification of Interested Parties.** The Regional Water Board has notified the Camarillo Sanitary District (Camarillo SD, Permittee or Discharger) and interested agencies and persons of its intent to prescribe WDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of the notification are provided in the Fact Sheet.
- D. Provisions and Requirements Implementing State Law.** Some of the provisions/requirements in this Order and the MRP are included to implement state law only. These provisions/requirements are not mandated or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies available for NPDES violations.
- E. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to this Order. Details of the Public Hearing are provided in the Fact Sheet.

THEREFORE, IT IS HEREBY ORDERED that this Order supersedes Order R4-2003-0079 (as revised by Order No. R4-2004-0121) except for enforcement purposes, and, in order to meet the provisions contained in Division 7 of the CWC (commencing with section 13000) and regulations adopted thereunder, and the provisions of the CWA and regulations and guidelines adopted thereunder, the Permittee is authorized to discharge from the identified facility and outfalls into waters of the United States and shall comply with the requirements in this Order. This action in no way prevents the Regional Water Board from taking enforcement action for past violations of the previous Order.

## III. DISCHARGE PROHIBITIONS

- A. Discharge of treated wastewater at a location different from that described in this Order is prohibited.
- B. The bypass or overflow of untreated wastewater or wastes to surface waters or surface water drainage courses is prohibited, except as allowed in Standard Provision I.G. of Attachment D, Standard Provisions.
- C. The monthly average effluent dry weather discharge flow rate from the Facility shall not exceed the design capacity.
- D. The Permittee shall not cause degradation of any water supply, except as consistent with State Water Board Resolution No. 68-16.
- E. The treatment or disposal of wastes from the Facility shall not cause pollution or nuisance as defined in section 13050, subdivisions (l) and (m) of the CWC.
- F. The discharge of any substances in concentrations toxic to animal or plant is prohibited.
- G. The discharge of any radiological, chemical, or biological warfare agent or high level radiological waste is prohibited.

**IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS**

**A. Effluent Limitations – Discharge Points 001A and 001B**

**1. Final Effluent Limitations – Discharge Points 001A and 001B**

- a. The Permittee shall maintain compliance with the following effluent limitations at Discharge Points 001A and 001B, with compliance measured at Monitoring Location EFF-001A and EFF-001B as described in the Monitoring and Reporting Program (MRP), Attachment E:

**Table 4. Final Effluent Limitations**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand (BOD <sub>5</sub> 20°C)	mg/L	20	30	45	--	--
	lbs/day <sup>1</sup>	1210	1810	2720	--	--
Total Suspended Solids (TSS)	mg/L	15	40	45	--	--
	lbs/day <sup>1</sup>	910	2420	2720	--	--
pH	standard units	--	--	--	6.5	8.5
Removal Efficiency for BOD and TSS	%	85	--	--		
Oil and Grease	mg/L	10	--	15		
	lbs/day <sup>1</sup>	600	--	910		
Settleable Solids	ml/L	0.1	--	0.3		

<sup>1</sup> The mass emission rates are based on the plant design flow rate of 7.25 MGD, and are calculated as follows: Flow (mgd) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Total Residual Chlorine	mg/L	--	--	0.1		
MBAS	mg/L	0.5	--	--		
	lbs/day <sup>1</sup>	30	--	--		
Boron	mg/L	1	--	--		
	lbs/day <sup>1</sup>	60	--	--		
Total dissolved solids (TDS) (dry weather <sup>2</sup> )	lbs/day	51,400 <sup>3</sup>	--	--		
Total dissolved solids (wet weather <sup>4</sup> )	mg/L	850	--	--		
Sulfate (dry weather <sup>2</sup> )	lbs/day	15,100 <sup>3</sup>	--	--		
Sulfate (wet weather <sup>4</sup> )	mg/L	250	--	--		
Chloride (dry weather <sup>2</sup> )	lbs/day	9,070 <sup>3</sup>	--	--		
Chloride (wet weather <sup>4</sup> )	mg/L	150	--	--		
Ammonia Nitrogen <sup>5</sup>	mg/L	3.5	--	7.8		
	lbs/day <sup>1</sup>	--	--	7.0 x Q <sup>6</sup>		
[Nitrate + Nitrite] (as N)	mg/L	9 <sup>7</sup>	--	--		
Nitrate (as N)	mg/L	9 <sup>7</sup>	--	--		
Nitrite (as N)	mg/L	0.9 <sup>7</sup>	--	--		
Iron	µg/L	300	--	--		
	lbs/day <sup>1</sup>	18	--	--		

<sup>2</sup> Dry weather is defined in the *Salts TMDL* as the condition when the flows in the receiving water are below the 86th percentile flow, as explained in WDR § VII.O.

<sup>3</sup> This limitation is derived from the final Waste Load Allocations (WLAs) in the *Calleguas Creek Watershed Salts Total Maximum Daily Load (Salts TMDL)*, established by the Regional Water Board on October 4, 2007. The *Salts TMDL* which became effective on December 2, 2008, following USEPA's approval. Interim effluent limitations may be provided in a separate Time Schedule Order (TSO).

Consistent with the *Salts TMDL*, these limits apply only during dry weather (as defined in the *Salts TMDL*, as explained in WDR § VII.O).

<sup>4</sup> Wet weather is defined in the *Salts TMDL* as the condition when the flows in the receiving water are greater than or equal to the 86th percentile flow, as explained in WDR § VII.O.

<sup>5</sup> This limitation is derived from the final WLA for ammonia nitrogen, as set forth in the *Nitrogen Compounds and Related Effects TMDL*, established by the Regional Water Board on October 24, 2002. Final WLAs became operative on October 24, 2004.

<sup>6</sup> Q represents the POTW flow at the time the water quality measurement is collected (not to exceed 7.25 MGD) and a conversion factor to lbs/day based on the units of measure for the flow.

<sup>7</sup> This limitation is derived from the final WLA for nitrate nitrogen, nitrite nitrogen, and nitrate plus nitrite nitrogen, as set forth in the *Nitrogen Compounds and Related Effects TMDL*, established by the Regional Water Board on October 24, 2002. Final WLAs became operative on July 16, 2007. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Copper	µg/L	23 <sup>8</sup>	--	42 <sup>8</sup>		
	lbs/day	--	--	0.4 <sup>9</sup>		
Nickel	µg/L	110 <sup>10</sup>	--	276 <sup>10</sup>		
	lbs/day	--	--	0.2 <sup>11</sup>		
Mercury	lbs/month	0.015 <sup>12</sup>	--	--		
Cyanide	µg/L	4.2	--	8.5		
	lbs/day <sup>1</sup>	0.25	--	0.51		
2,3,7,8-TCDD	pg/L	0.0140	--	0.0281		

<sup>8</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL (Metals TMDL)*, established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007. The *Metals TMDL* contains concentration-based WLAs that are expressed in terms of a footnote, which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the *Final Draft Metals and Selenium TMDL Technical Report (Technical Report)*, dated March 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>9</sup> This limitation is derived from the mass-based final WLA, as set forth in the *Metals TMDL*, established by the Regional Water Board on June 8, 2006, for the protection of the lower reaches of Calleguas Creek. The TMDL became effective on March 26, 2007. The mass-based WLA is expressed in terms of a formula that incorporates a Water Effects Ratio (WER). The WLA-based limit was calculated using the 3.69 copper WER approved by the Regional Water Board on November 9, 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>10</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL (Metals TMDL)*, established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007. The *Metals TMDL* contains concentration-based WLAs that are expressed in terms of a footnote, which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the *Final Draft Metals and Selenium TMDL Technical Report (Technical Report)*, dated March 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>11</sup> This mass-based effluent limitation is derived from the mass-based final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006, for the protection of the lower reaches of Calleguas Creek. The TMDL became effective on March 26, 2007. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>12</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006. This limitation is derived from the WLA for mercury, specified in pounds per month, as set forth in said TMDL. The TMDL became effective on March 26, 2007. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Bis(2-ethylhexyl) phthalate	µg/L	4	--	--		
	lbs/day <sup>1</sup>	0.24	--	--		
Aldrin	µg/L	0.00014	--	0.000281		
Alpha-BHC	µg/L	0.013	--	0.026		
Chlordane	µg/L	0.00059 <sup>13</sup>	--	0.0012 <sup>13</sup>		
4,4-DDD	µg/L	0.00084 <sup>13</sup>	--	0.0017 <sup>13</sup>		
4,4-DDE	µg/L	0.00059 <sup>13</sup>	--	0.0012 <sup>13</sup>		
4,4-DDT	µg/L	0.00059 <sup>13</sup>	--	0.0012 <sup>13</sup>		
Dieldrin	µg/L	0.00014 <sup>1</sup>	--	0.00028 <sup>13</sup>		
Heptachlor epoxide	µg/L	0.00011	--	0.00022		
PCBs	µg/L	0.00017 <sup>13</sup>	--	0.00034 <sup>13</sup>		
Toxaphene	µg/L	0.00016 <sup>13</sup>	--	0.00033 <sup>13</sup>		
Chlorpyrifos	µg/L	0.0133 <sup>14</sup>	--	0.024 <sup>14</sup>		
Diazinon	µg/L	0.1 <sup>14</sup>	--	0.1 <sup>14</sup>		
Chronic Toxicity <sup>15, 16</sup>	Pass or Fail, %Effect	Pass <sup>17</sup>	--	Pass or %Effect < 50		

<sup>13</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Organochlorine Pesticide, Polychlorinated Biphenyls (PCB), and Siltation TMDL*, established by the Regional Water Board on July 7, 2005. The limitation is derived from the final WLA as set forth in said TMDL. The TMDL became effective on March 24, 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>14</sup> This limitation is derived from the final WLA as set forth in the *Calleguas Creek Watershed Toxicity TMDL*, established by the Regional Water Board on July 7, 2005. The TMDL became effective on March 24, 2006. Consistent with the TMDL, the final WLA-based limit became operative on March 23, 2008. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>15</sup> The *Calleguas Creek Watershed Toxicity TMDL* includes a WLA of 1.0 TUc for toxicity, which is required to be implemented in accordance with USEPA, State Water Board, and Regional Water Board resolutions, guidance and policy at the time of permit issuance or renewal. The numeric WLA is protective of both the numeric acute toxicity and the narrative toxicity Basin Plan water quality objectives. Consistent with the *Toxicity TMDL Implementation Plan*, this toxicity WLA will be implemented using current USEPA guidance in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, June /2010)* and *EPA Regions 8, 9 and 10 Toxicity Training Tool (January 2010)*, <http://www2.epa.gov/region8/epa-regions-8-9-and-10-toxicity-training-tool-january-2010>.

<sup>16</sup> "Pass" or "Fail" for Median Monthly Effluent Limitation (MMEL). "Pass" or "Fail" and "% Effect" for Maximum Daily Effluent Limitation (MDEL). The MMEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail". The final effluent limitation will apply on the effective date of this Order, since additional time for permit compliance, provided under the 2008 Compliance Schedule Policy, was not offered by the TMDL. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>17</sup> This is a Median Monthly Effluent Limitation.  
Limitations and Discharge Requirements (Adopted: 5/8/2014)

**2. Interim Effluent Limitations – Discharge Point 001A and 001B**

- a. *Metals TMDL*-based Interim limits: Interim Waste Load Allocations (WLAs) are included in the *Metals TMDL* for copper, nickel, and mercury applicable to the Camarillo WRP. However, existing data indicate that the facility can consistently meet the final WLAs for copper, nickel, and mercury. Therefore, no interim effluent limitation will be applied in this permit for copper, nickel and mercury. The Permittee shall maintain compliance with the final effluent limitation for those metals on the effective date of this permit.
- b. *OC Pesticides, PCBs, and Siltation TMDL*-based Interim limits: Interim WLAs are included in the *OC Pesticides, PCBs, and Siltation TMDL* for chlordane, 4,4'-DDD, 4,4'-DDE, 4,4'-DDT, dieldrin, PCBs, and toxaphene applicable to the Camarillo WRP. However, existing data indicate that the facility can consistently meet the final WLAs for the aforementioned parameters. Therefore, no interim effluent limitations will be applied in this permit for those pesticides. The Permittee shall maintain compliance with the final effluent limitations for the above-mentioned parameters on the effective date of this permit.
- c. **Boron, Chloride, Sulfate, and TDS (Salts) TMDL-based Interim limits:** Interim WLAs for Salts are included in the *Calleguas Creek Watershed Salts TMDL*, established by the Regional Water Board on October 4, 2007, and became effective on December 8, 2008. The TMDL interim WLAs were set equal to the 95<sup>th</sup> percentile of available discharge data at the time of TMDL development. However, interim limits based on the interim WLAs have not been incorporated into this NPDES Order because they do not provide adequate relief during the compliance schedule period. The salts concentrations have increased due to changes in the potable water supply for the City of Camarillo and the interim WLA no longer reflect the current 95<sup>th</sup> percentile concentrations. Interim effluent limitations may be provided in a separate Time Schedule Order (TSO), using current representative data.

**Table 5. Interim Effluent Limitations**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
N/A						

**3. Other Effluent Limitations – Discharge Point 001A and 001B**

- a. **Percent Removal:** The average monthly percent removal of BOD 5-day 20°C and TSS shall not be less than 85 percent.
- b. The temperature of the discharge shall not exceed 86°F except when the ambient temperature of the receiving water is higher than 86°F, in which case the temperature of the waste discharged shall not exceed the ambient temperature of the receiving waters.

- c. The radioactivity of the discharge shall not exceed the limits specified in Title 22, chapter 15, article 5, sections 64442 and 64443, of the California Code of Regulations (CCR), or subsequent revisions.
- d. The discharge to water courses shall at all times be adequately disinfected. For the purpose of this requirement, the discharge shall be considered adequately disinfected if: 1) the median number of coliform organisms at some point in the treatment process does not exceed a most probable number (MPN) or colony forming units (CFU) of 2.2 per 100 milliliters utilizing the bacteriological results of the last seven days for which analyses have been completed; 2) the number of coliform organisms does not exceed an MPN or CFU of 23 per 100 milliliters in more than one sample within any 30-day period; and, 3) no sample exceeds 240 MPN or CFU of total coliform bacteria per 100 milliliters. Samples shall be collected at a time when wastewater flow and characteristics are most demanding on treatment facilities and disinfection processes.
- e. For the protection of the water contact recreation beneficial use, the discharge to water courses shall have received adequate treatment, so that the turbidity of the treated wastewater does not exceed any of the following: (a) an average of 2 Nephelometric turbidity units (NTUs) within a 24-hour period; (b) 5 NTUs more than 5 percent of the time (72 minutes) within a 24-hour period; and (c) 10 NTU at any time.
- f. To protect the underlying ground water basins, pollutants shall not be present in the discharge at concentrations that pose a threat to groundwater quality.

**B. Land Discharge Specifications – Not Applicable**

**C. Recycling Specifications – Not Applicable.**

**V. RECEIVING WATER LIMITATIONS**

**A. Surface Water Limitations**

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in Conejo Creek:

1. For waters designated with a warm freshwater habitat (WARM) beneficial use, the temperature of the receiving water at any time or place and within any given 24-hour period shall not be altered by more than 5°F above the natural temperature and shall not be raised above 86°F due to the discharge of effluent at the receiving water station located downstream of the discharge. Natural conditions shall be determined on a case-by-case basis.

If the receiving water temperature, downstream of the discharge, exceeds 86°F as a result of the following:

- a. High temperature in the ambient air; or,
- b. High temperature in the receiving water upstream of the discharge,

then the exceedance shall not be considered a violation.

2. The pH of inland surface waters shall not be depressed below 6.5 or raised above 8.5 as a result of the discharge. Ambient pH levels shall not be changed more than 0.5 units from natural conditions as a result of the discharge. Natural conditions shall be determined on a case-by-case basis.
3. The dissolved oxygen in the receiving water shall not be depressed below 5 mg/L as a result of the discharge.
4. The total residual chlorine shall not exceed 0.1 mg/L in the receiving waters and shall not persist in the receiving water at any concentration that causes impairment of beneficial uses as a result of the discharge.
5. The *Escherichia coli* (*E. coli*) concentration in the receiving water shall not exceed the following, as a result of the discharge:
  - a. Geometric Mean Limits
    - i. *E. coli* density shall not exceed 126/100 mL.
  - b. Single Sample Limits
    - i. *E. coli* density shall not exceed 235/100 mL.
6. Waters shall be free of changes in turbidity that cause nuisance or adversely affect beneficial uses. Increases in natural turbidity attributable to controllable water quality factors shall not exceed the following limits, as a result of the discharge:
  - a. Where natural turbidity is between 0 and 50 NTU, increases shall not exceed 20%, and
  - b. Where natural turbidity is greater than 50 NTU, increases shall not exceed 10%.
7. The discharge shall not produce concentrations of substances in the receiving water that are toxic to or cause detrimental physiological responses in human, animal, or aquatic life.
8. The discharge shall not cause concentrations of contaminants to occur at levels that are harmful to human health in waters which are existing or potential sources of drinking water.
9. The concentrations of toxic pollutants in the water column, sediments, or biota shall not adversely affect beneficial uses as a result of the discharge.
10. The discharge shall not contain substances that result in increases in BOD, which adversely affect the beneficial uses of the receiving waters.
11. Waters discharged shall not contain biostimulatory substances in concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses.
12. The dissolved sulfide concentration of waters in and near sediments shall not be significantly increased above that present under natural conditions as a result of waters discharged.

13. The discharge shall not cause the receiving waters to contain any substance in concentrations that adversely affect any designated beneficial use.
14. The discharge shall not alter the natural taste, odor, or color of fish, shellfish, or other surface water resources used for human consumption.
15. The discharge shall not result in problems due to breeding of mosquitoes, gnats, black flies, midges, or other pests.
16. The discharge shall not result in visible floating particulates, foams, or oil and grease in the receiving waters.
17. The discharge shall not alter the color of the receiving waters; create a visual contrast with the natural appearance of the water; or cause aesthetically undesirable discoloration of the receiving waters.
18. No physical evidence of discharge shall be visible at any time in the water or on beaches, shores, rocks, or structures.
19. The discharge shall not contain any individual pesticide or combination of pesticides in concentrations that adversely affect beneficial uses of the receiving waters. There shall be no increase in pesticide concentrations found in bottom sediments or aquatic life as a result of the discharge.
20. Ammonia shall not be present at levels that, when oxidized to nitrate, pose a threat to groundwater quality.
21. Chronic Toxicity Receiving Water Quality Objective
  - a. There shall be no chronic toxicity in ambient waters as a result of the discharge.
  - b. Receiving water and effluent toxicity testing shall be performed on the same day as close to concurrently as possible.
22. The discharge shall not cause the ammonia water quality objective in the Basin Plan to be exceeded in the receiving waters. Compliance with the ammonia WQOs shall be determined by comparing the receiving water ammonia concentration to the ammonia water quality objective in the Basin Plan. The ammonia water quality objective can also be calculated using the pH and temperature of the receiving water at the time of collection of the ammonia sample.

**B. Groundwater Limitations**

The discharge shall not cause the underlying groundwater to be degraded, exceed WQOs, unreasonably affect beneficial uses, or cause a condition of pollution or nuisance.

**VI. PROVISIONS**

**A. Standard Provisions**

1. The Permittee shall comply with all Standard Provisions included in Attachment D.

- 2. Regional Water Board Standard Provisions.** The Permittee shall comply with the following provisions. In the event that there is any conflict, duplication, or overlap between provisions specified by this Order, the more stringent provision shall apply:
- a. Neither the treatment nor the discharge of pollutants shall create a pollution, contamination, or nuisance as defined by section 13050 of the CWC.
  - b. Odors, vectors, and other nuisances of sewage or sludge origin beyond the limits of the treatment plant site or the sewage collection system due to improper operation of facilities, as determined by the Regional Water Board, are prohibited.
  - c. All facilities used for collection, transport, treatment, or disposal of wastes shall be adequately protected against damage resulting from overflow, washout, or inundation from a storm or flood having a recurrence interval of once in 100 years.
  - d. Collection, treatment, and disposal systems shall be operated in a manner that precludes or impedes public contact with wastewater.
  - e. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer of the Regional Water Board.
  - f. The provisions of this order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
  - g. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation under authority preserved by section 510 of the CWA.
  - h. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities or penalties to which the Permittee is or may be subject to under section 311 of the CWA, related to oil and hazardous substances liability.
  - i. Discharge of wastes to any point other than specifically described in this Order is prohibited.
  - j. The Permittee shall comply with all applicable effluent limitations, national standards of performance, toxic effluent standards, and all federal regulations established pursuant to sections 301, 302, 303(d), 304, 306, 307, 316, 403, and 405 of the federal CWA and amendments thereto.
  - k. These requirements do not exempt the operator of the waste disposal facility from compliance with any other laws, regulations, or ordinances which may be applicable; they do not legalize this waste disposal facility; and they leave unaffected any further restraints on the disposal of wastes at this site which may be contained in other statutes or required by other agencies.
  - l. Oil or oily material, chemicals, refuse, or other polluting materials shall not be stored or deposited in areas where they may be picked up by rainfall and carried

off of the property and/or discharged to surface waters. Any such spill of such materials shall be contained and removed immediately.

- m. A copy of these waste discharge specifications shall be maintained at the discharge Facility so as to be available at all times to operating personnel.
- n. If there is any storage of hazardous or toxic materials or hydrocarbons at this Facility and if the Facility is not manned at all times, a 24-hour emergency response telephone number shall be prominently posted where it can easily be read from the outside.
- o. The Permittee shall file with the Regional Water Board a report of waste discharge at least 120 days before making any proposed change in the character, location or volume of the discharge.
- p. In the event of any change in name, ownership, or control of these waste disposal facilities, the Permittee shall notify the Regional Water Board of such change and shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to the Regional Water Board, 30 days prior to taking effect.
- q. The discharge of any pollutant resulting from the combustion of toxic or hazardous wastes to any waste stream that ultimately discharges to waters of the United States is prohibited, unless specifically authorized elsewhere in this Order.
- r. The Permittee shall notify the Executive Officer in writing no later than 6 months prior to planned discharge of any chemical, other than the products previously reported to the Executive Officer, which may be toxic to aquatic life. Such notification shall include:
  - i. Name and general composition of the chemical,
  - ii. Frequency of use,
  - iii. Quantities to be used,
  - iv. Proposed discharge concentrations, and
  - v. USEPA registration number, if applicable.
- s. Violation of any of the provisions of this Order may subject the Permittee to any of the penalties described herein or in Attachment D of this Order, or any combination thereof, at the discretion of the prosecuting authority; except that only one kind of penalty may be applied for each kind of violation.
- t. Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this Facility, may subject the Permittee to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Permittee to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.

- u. The CWC provides that any person who violates a waste discharge requirement or a provision of the CWC is subject to civil penalties of up to \$5,000 per day, \$10,000 per day, or \$25,000 per day of violation, or when the violation involves the discharge of pollutants, is subject to civil penalties of up to \$10 per gallon per day or \$25 per gallon per day of violation, or some combination thereof, depending on the violation, or upon the combination of violations.
- v. CWC section 13385(h)(i) requires the Regional Water Board to assess a mandatory minimum penalty of three-thousand dollars (\$3,000) for each serious violation. Pursuant to CWC section 13385(h)(2), a "serious violation" is defined as any waste discharge that violates the effluent limitations contained in the applicable waste discharge requirements for a Group II pollutant by 20 percent or more, or for a Group I pollutant by 40 percent or more. Appendix A of 40 CFR § 123.45 specifies the Group I and II pollutants. Pursuant to CWC section 13385.1(a)(1), a "serious violation" is also defined as "a failure to file a discharge monitoring report required pursuant to section 13383 for each complete period of 30 days following the deadline for submitting the report, if the report is designed to ensure compliance with limitations contained in waste discharge requirements that contain effluent limitations."
- w. CWC section 13385(i) requires the Regional Water Board to assess a mandatory minimum penalty of three-thousand dollars (\$3,000) for each violation whenever a person violates a waste discharge requirement effluent limitation in any period of six consecutive months, except that the requirement to assess the mandatory minimum penalty shall not be applicable to the first three violations within that time period.
- x. Pursuant to CWC section 13385.1(d), for the purposes of section 13385.1 and subdivisions (h), (i), and (j) of section 13385, "effluent limitation" means a numeric restriction or a numerically expressed narrative restriction, on the quantity, discharge rate, concentration, or toxicity units of a pollutant or pollutants that may be discharged from an authorized location. An effluent limitation may be final or interim, and may be expressed as a prohibition. An effluent limitation, for these purposes, does not include a receiving water limitation, a compliance schedule, or a best management practice.
- y. CWC section 13387(e) provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this order, including monitoring reports or reports of compliance or noncompliance, or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained in this order shall be punished by a fine of not more than twenty-five thousand dollars (\$25,000); imprisonment pursuant to subdivision (h) of Section 1170 of the Penal Code for 16, 20, or 24 months, or by both that fine and imprisonment. For a subsequent conviction, such a person shall be punished by a fine of not more than twenty-five thousand dollars (\$25,000) per day of violation, by imprisonment pursuant to subdivision (h) of Section 1170 of the Penal Code for two, three, or four years, or by both that fine and imprisonment.

- z. In the event the Permittee does not comply or will be unable to comply for any reason, with any prohibition, effluent limitation, or receiving water limitation of this Order, the Permittee shall notify the Chief of the Watershed Regulatory Section at the Regional Water Board by telephone (213) 576-6616, or by fax at (213) 576-6660 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing to the Regional Water Board within five days, unless the Regional Water Board waives confirmation. The written notification shall state the nature, time, duration, and cause of noncompliance, and shall describe the measures being taken to remedy the current noncompliance and, prevent recurrence including, where applicable, a schedule of implementation. The written notification shall also be submitted via email with reference to CI-1278 to [losangeles@waterboards.ca.gov](mailto:losangeles@waterboards.ca.gov). Other noncompliance requires written notification as above at the time of the normal monitoring report.

**B. Monitoring and Reporting Program (MRP) Requirements**

The Permittee shall comply with the MRP, and future revisions thereto, in Attachment E.

**C. Special Provisions**

**1. Reopener Provisions**

- a. This Order may be modified, revoked and reissued, or terminated for cause, including, but not limited to:
- i. Violation of any term or condition contained in this Order;
  - ii. Obtaining this Order by misrepresentation, or by failure to disclose fully all relevant facts; or
  - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.

The filing of a request by the Permittee for an Order modification, revocation, and issuance or termination, or a notification of planned changes or anticipated noncompliance does not stay any condition of this Order.

- b. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity testing, monitoring of internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.
- c. This Order may be modified, in accordance with the provisions set forth in title 40 of the Code of Federal Regulations (40 CFR) parts 122 and 124 to include requirements for the implementation of a watershed protection management approach.
- d. The Board may modify, or revoke and reissue this Order if present or future investigations demonstrate that the discharge(s) governed by this Order will cause, have reasonable potential to cause, or contribute to adverse impacts on beneficial uses or degradation of the water quality of the receiving waters.
- e. This Order may also be modified, revoked, and reissued or terminated in accordance with the provisions of 40 CFR parts 122.44, 122.62 to 122.64, 125.62,

and 125.64. Causes for taking such actions include, but are not limited to, failure to comply with any condition of this Order, endangerment to human health or the environment resulting from the permitted activity, or acquisition of newly obtained information which would have justified the application of different conditions if known at the time of Order adoption. The filing of a request by the Permittee for an Order modification, revocation and issuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any condition of this Order.

- f. This Order may be modified, in accordance with the provisions set forth in 40 CFR parts 122 to 124, to include new minimum levels (MLs).
- g. If an applicable toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under section 307(a) of the CWA for a toxic pollutant and that standard or prohibition is more stringent than any limitation on the pollutant in this Order, the Regional Water Board may institute proceedings under these regulations to modify or revoke and reissue the Orders to conform to the toxic effluent standard or prohibition.
- h. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments, thereto, the Regional Water Board will revise and modify this Order in accordance with such standards.
- i. This Order may be reopened and modified, to add or revise effluent limitations as a result of future Basin Plan Amendments, such as an update of a water quality objective, or a revision of any of the Calleguas Creek TMDLs.
- j. This Order may be reopened to modify the TDS, sulfate, and chloride final effluent limitations to include an AF, following approval of an AF for the Facility by the Regional Water Board.
- k. This Order may be reopened and modified, to revise effluent limitations as a result of the delisting of a pollutant from the 303(d) list.
- l. This Order may be reopened and modified to revise the chronic toxicity effluent limitation and/or total residual chlorine limitations, to the extent necessary, to be consistent with State Water Board precedential decisions, new policies, a new state-wide plan, new laws, or new regulations.

## 2. **Special Studies, Technical Reports and Additional Monitoring Requirements**

### a. **Calleguas Creek TMDL Monitoring Requirements**

The POTWs within the Calleguas Creek Watershed (CCW) have developed a watershed monitoring program to implement the requirements for monitoring, conducting special studies, and implementing actions to reduce discharges of pollutants covered by the TMDL. This watershed monitoring program has been approved by the Regional Water Board. The responsible parties to the CCW TMDLs have signed a Memorandum of Agreement to jointly fund and complete the implementation of the TMDL Calleguas Creek Watershed Monitoring Program (CCWTMP), which began in August 2008. The CCWTMP was created to better facilitate a coordinated monitoring effort where multiple TMDL monitoring requirements could be addressed via a single program that would carry out and manage all aspects of the monitoring activities. This monitoring

program has been developed to easily integrate new TMDL monitoring efforts as TMDLs are adopted and/or special study monitoring efforts are required.

The CCWTMP Annual Monitoring Report has been submitted since 2009. The annual monitoring reports summarize the monitoring reports for five of the six TMDLs currently effective in the CCW. These TMDLs include nitrogen compounds and related effects, toxicity, organochlorine pesticides and PCBs, metals and selenium, and salts. A separate annual report is submitted for the trash TMDL. These reports were submitted to the Regional Water Board TMDL staff for review.

Since 2009, all sampling has followed the Standard Operating Procedures outlined in the Executive Officer approved *Calleguas Creek Watershed Management Plan Quality Assurance Project Plan (QAPP)*, with the following exception: the methods for the salts compliance monitoring that began on September 9, 2012, are not currently contained in the QAPP but were described in detail in the final Salts Monitoring Approach submitted to the Regional Water Board on June 29, 2012. The QAPP will be revised in 2014 to incorporate the methods, sites, and schedule for compliance salts monitoring described in the final approach document.

In addition, the majority of the TMDLs include requirements for monitoring, conducting special studies, and implementing actions to reduce discharges of pollutants covered by the TMDL. Many of these activities overlap and provide benefits for numerous TMDLs in the watershed. The CCWTMP annual reports included an appendix that summarizes work plan and study submittal dates, dates of responses to comments received by the Regional Water Board, and actions that have been taken to reduce pollutant discharges to the waterbodies. Additionally, the report provides a mechanism for providing the Regional Water Board with required progress reports for some of the TMDLs.

**b. Special Study for Constituents of Emerging Concern (CECs)**

**i. CECs Monitoring Requirement in the Effluent**

- (1). The Permittee shall conduct a special study to investigate the CECs in the effluent discharge. The Permittee shall follow the requirements of the work plan as discussed in the MRP and the Fact Sheet. Analysis under this section is for monitoring purposes only. Analytical results obtained for this study will not be used for compliance determination purposes, since the methods have not been incorporated into 40 CFR part 136.

**c. Treatment Plant Capacity**

The Permittee shall submit a written report to the Executive Officer of the Regional Water Board within 90 days after the "30-day (monthly) average" daily dry-weather flow equals or exceeds 75 percent of the design capacity of waste treatment and/or disposal facilities. The Permittee's senior administrative officer shall sign a letter, which transmits that report and certifies that the Permittee's policy-making body is adequately informed of the report's contents. The report shall include the following:

- i. The average daily flow for the month, the date on which the peak flow occurred, the rate of that peak flow, and the total flow for the day;
- ii. The best estimate of when the monthly average daily dry-weather flow rate will equal or exceed the design capacity of the facilities; and,
- iii. A schedule for studies, design, and other steps needed to provide additional capacity for waste treatment and/or disposal facilities before the discharge flow rate equals the capacity of present units.

This requirement is applicable to those facilities which have not reached 75 percent of capacity as of the effective date of this Order. For those facilities that have reached 75 percent of capacity by that date but for which no such report has been previously submitted, such a report shall be filed within 90 days of the issuance of this Order.

### **3. Best Management Practices and Pollution Prevention**

#### **a. Storm Water Pollution Prevention Plan (SWPPP) – (Not Applicable)**

#### **b. Spill Clean-up Contingency Plan (SCCP)**

Within 90 days of the effective date of this Order, the Permittee is required to submit a SCCP, which describes the activities and protocols to address clean-up of spills, overflows, and bypasses of untreated or partially treated wastewater from the Permittee's collection system or treatment facilities that reach water bodies, including dry channels and beach sands. At a minimum, the plan shall include sections on spill clean-up and containment measures, public notification, and monitoring. The Permittee shall review and amend the plan as appropriate after each spill from the Facility or in the service area of the Facility. The Permittee shall include a discussion in the annual summary report of any modifications to the Plan and the application of the Plan to all spills during the year.

#### **c. Pollutant Minimization Program (PMP)**

Reporting protocols in MRP section X.B.4 describe sample results that are to be reported as Detected but Not Quantified (DNQ) or Not Detected (ND). Definitions for a reported Minimum Level (ML) and Method Detection Limit (MDL) are provided in Attachment A. These reporting protocols and definitions are used in determining the need to conduct a PMP as follows:

The Permittee shall develop and conduct a PMP as further described below when there is evidence (e.g., sample results reported as DNQ when the effluent limitation is less than the MDL; sample results from analytical methods more sensitive than those methods required by this Order; presence of whole effluent toxicity; health advisories for fish consumption; or, results of benthic or aquatic organism tissue sampling) that a pollutant is present in the effluent above an effluent limitation and either of the following is true:

- i. The concentration of the pollutant is reported as DNQ and the effluent limitation is less than the reported ML; or,

- ii. The concentration of the pollutant is reported as ND and the effluent limitation is less than the MDL, using definitions described in Attachment A and reporting protocols described in the MRP.

The goal of the PMP shall be to reduce all potential sources of a pollutant through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost-effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan (PPP), if required pursuant to CWC section 13263.3(d), shall be considered to fulfill the PMP requirements.

The PMP shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:

- i. An annual review and semi-annual monitoring of potential sources of the reportable pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling;
- ii. Quarterly monitoring for the reportable pollutant(s) in the influent to the wastewater treatment system;
- iii. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable pollutant(s) in the effluent at or below the effluent limitation;
- iv. Implementation of appropriate cost-effective control measures for the reportable pollutant(s), consistent with the control strategy; and
- v. An annual status report that shall be sent to the Regional Water Board including:
  - (1). All PMP monitoring results for the previous year;
  - (2). A list of potential sources of the reportable pollutant(s);
  - (3). A summary of all actions undertaken pursuant to the control strategy; and
  - (4). A description of actions to be taken in the following year.

#### 4. Construction, Operation and Maintenance Specifications

- a. Wastewater treatment facilities subject to this Order shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to California Code of Regulations (CCR), title 23, division 3, chapter 26 (CWC sections 13625 – 13633).
- b. The Permittee shall maintain in good working order a sufficient alternate power source for operating the wastewater treatment and disposal facilities. All equipment shall be located to minimize failure due to moisture, liquid spray, flooding, and other physical phenomena. The alternate power source shall be designed to permit inspection and maintenance and shall provide for periodic testing. If such alternate power source is not in existence, the Permittee shall

halt, reduce, or otherwise control all discharges upon the reduction, loss, or failure of the primary source of power.

- c. The Permittee shall provide standby or emergency power facilities and/or storage capacity or other means so that in the event of plant upset or outage due to power failure or other cause, discharge of raw or inadequately treated sewage does not occur.

**5. Special Provisions for Municipal Facilities (Publicly-Owned Treatment Works [POTWs] Only)**

**a. Sludge Disposal Requirements**

- i. All sludge generated at the wastewater treatment plant must be disposed of, treated, or applied to land in accordance with federal regulations contained in 40 CFR part 503. These requirements are enforceable by USEPA.
- ii. The Permittee is separately required to comply with the requirements in State Water Board Order No. 2004-10-DWQ, *General WDRs for the Discharge of Biosolids to Land for Use as a Soil Amendment in Agricultural, Silvicultural, Horticultural and Land Reclamation Activities* for those sites receiving the Permittee's biosolids which a Regional Water Board has placed under this general order, and with the requirements in individual WDRs issued by a Regional Water Board for sites receiving the Permittee's biosolids.
- iii. The Permittee shall separately comply, if applicable, with WDRs issued by other Regional Water Boards to which jurisdiction the biosolids are transported and applied.
- iv. The Permittee shall assure that haulers transporting sludge off site for treatment, storage, use, or disposal take all necessary measures to keep the sludge contained. The Permittee shall maintain and have haulers adhere to a spill clean-up plan. Any spills shall be reported to USEPA and the Regional Water Board or state agency in which the spill occurred. All trucks hauling sludge shall be thoroughly washed after unloading at the field or at the receiving facility.
- v. The Permittee shall furnish this Regional Water Board with a copy of any report submitted to USEPA, the State Water Board or other Regional Water Board, with respect to municipal sludge or biosolids.

**b. Pretreatment Requirements**

- i. The Permittee has developed and implemented a Pretreatment Program that was previously submitted to this Regional Water Board on July 9, 1982.
- ii. Camarillo SD modified its *Industrial Waste Supplement to the Operations Code*, which serves as Camarillo's sewer use ordinance (SUO), on February 14, 2007, by adopting Ordinance No. 76. More recently, in response to the 2013 Pretreatment Compliance Inspection (PCI), the Camarillo SD revised its Enforcement Response Plan (ERP) on January 9, 2014, and its SUO the following month. Camarillo SD Ordinance No. 85,

adopted by the Camarillo SD Board of Directors on February 12, 2014, amended Camarillo's SUO No. 76 by incorporating required components of the pretreatment streamlining regulations. In the coming months, the Permittee plans on conducting a local limits evaluation.

- iii. Any change to the program shall be reported to the Regional Water Board in writing and shall not become effective until approved by the Executive Officer in accordance with procedures established in 40 CFR § 403.18.
- iv. Applications for renewal or modification of this Order must contain information about industrial discharges to the POTW pursuant to 40 CFR § 122.21(j)(6). Pursuant to 40 CFR § 122.42(b) and provision VII.A of Attachment D, Standard Provisions, of this Order, the Permittee shall provide adequate notice of any new introduction of pollutants or substantial change in the volume or character of pollutants from industrial discharges which were not included in the permit application. Pursuant to 40 CFR § 122.44(j)(1), the Permittee shall annually identify and report, in terms of character and volume of pollutants, any Significant Industrial Users discharging to the POTW subject to Pretreatment Standards under section 307(b) of the CWA and 40 CFR § 403.
- v. The Permittee shall comply with requirements contained in Attachment I – Pretreatment Reporting Requirements.

**c. Collection System Requirements**

- i. The Permittee's collection system is part of the system that is subject to this Order. As such, the Permittee must properly operate and maintain its collection system (40 CFR § 122.41(e)). The Permittee must report any non-compliance (40 CFR § 122.41(l)(6) and (7)) and mitigate any discharge from the collection system in violation of this Order (40 CFR § 122.41(d)). See the Order at Attachment D, subsections I.D, V.E, V.H, and I.C., and the following section of this Order.

**6. Spill Reporting Requirements**

**a. Initial Notification**

Although State and Regional Water Board staff do not have duties as first responders, this requirement is an appropriate mechanism to ensure that the agencies that do have first responder duties are notified in a timely manner in order to protect public health and beneficial uses. For certain spills, overflows and bypasses, the Permittee shall make notifications as required below:

- i. In accordance with the requirements of Health and Safety Code section 5411.5, the Permittee shall provide notification to the local health officer or the director of environmental health with jurisdiction over the affected water body of any unauthorized release of sewage or other waste that causes, or probably will cause, a discharge to any waters of the state as soon as possible, but no later than two hours after becoming aware of the release.
- ii. In accordance with the requirements of CWC section 13271, the Permittee shall provide notification to the California Emergency Management Agency

(Cal EMA) of the release of reportable amounts of hazardous substances or sewage that causes, or probably will cause, a discharge to any waters of the state as soon as possible, but not later than two hours after becoming aware of the release. The CCR, Title 23, section 2250, defines a reportable amount of sewage as being 1,000 gallons. The phone number for reporting these releases to the Cal EMA is (800) 852-7550.

- iii. The Permittee shall notify the Regional Water Board of any unauthorized release of sewage from its POTW that causes, or probably will cause, a discharge to a water of the state as soon as possible, but not later than two hours after becoming aware of the release. This initial notification does not need to be made if the Permittee has notified Cal EMA and the local health officer or the director of environmental health with jurisdiction over the affected waterbody. The phone number for reporting these releases of sewage to the Regional Water Board is (213) 576-6657. The phone numbers for after hours and weekend reporting of releases of sewage to the Regional Water Board are (213) 305-2284 and (213) 305-2253.

At a minimum, the following information shall be provided to the Regional Water Board:

- (1). The location, date, and time of the release;
- (2). The route of the spill including the water body that received or will receive the discharge;
- (3). An estimate of the amount of sewage or other waste released and the amount that reached a surface water at the time of notification;
- (4). If ongoing, the estimated flow rate of the release at the time of the notification;
- (5). The name, organization, phone number and email address of the reporting representative; and,
- (6). A certification that the State Office of Emergency Services and the local health officer or directors of environmental health with jurisdiction over the affected water bodies have been notified of the discharge.

**b. Monitoring**

For spills, overflows and bypasses reported under section VI.C.6.a, the Permittee shall monitor as required below:

- i. To define the geographical extent of the spill's impact, the Permittee shall obtain grab samples (if feasible, accessible, and safe) for all spills, overflows or bypasses of any volume that reach any waters of the state (including surface and ground waters). The Permittee shall analyze the samples for total coliform, fecal coliform, E. coli (if fecal coliform test shows positive), enterococcus, and relevant pollutants of concern, upstream and downstream of the point of entry of the spill (if feasible, accessible, and safe). This monitoring shall be done on a daily basis from the time the spill is known until the results of two consecutive sets of bacteriological monitoring indicate the return to the background level or the County Department of Public Health authorizes cessation of monitoring.

**c. Reporting**

The initial notification required under section VI.C.6.a shall be followed by:

- i.** As soon as possible, but not later than twenty-four hours after becoming aware of an unauthorized discharge of sewage or other waste from its wastewater treatment plant to a water of the state, the Permittee shall submit a statement to the Regional Water Board by email at [augustine.anijelo@waterboards.ca.gov](mailto:augustine.anijelo@waterboards.ca.gov). If the discharge is 1,000 gallons or more, this statement shall certify that Cal EMA has been notified of the discharge in accordance with CWC section 13271. The statement shall also certify that the local health officer or director of environmental health with jurisdiction over the affected water bodies has been notified of the discharge in accordance with Health and Safety Code section 5411.5. The statement shall also include at a minimum the following information:

  - (1). Agency, NPDES No., Order No., and MRP CI No., if applicable;
  - (2). The location, date, and time of the discharge;
  - (3). The water body that received the discharge;
  - (4). A description of the level of treatment of the sewage or other waste discharged;
  - (5). An initial estimate of the amount of sewage or other waste released and the amount that reached a surface water;
  - (6). The Cal EMA control number and the date and time that notification of the incident was provided to Cal EMA; and,
  - (7). The name of the local health officer or director of environmental health representative notified (if contacted directly); the date and time of notification; and the method of notification (e.g., phone, fax, email).
- ii.** A written preliminary report five working days after disclosure of the incident is required. Submission to the Regional Water Board of the California Integrated Water Quality System (CIWQS) Sanitary Sewer Overflow (SSO) event number shall satisfy this requirement. Within 30 days after submitting the preliminary report, the Permittee shall submit the final written report to this Regional Water Board. (A copy of the final written report, for a given incident, already submitted pursuant to a statewide General WDRs for Wastewater Collection System Agencies (SSO WDR), may be submitted to the Regional Water Board to satisfy this requirement.) The written report shall document the information required in paragraph d below, monitoring results and any other information required in provisions of the Standard Provisions document including corrective measures implemented or proposed to be implemented to prevent/minimize future occurrences. The Executive Officer for just cause can grant an extension for submittal of the final written report.
- iii.** The Permittee shall include a certification in the annual summary report (due according to the schedule in the MRP) that states that the sewer system emergency equipment, including alarm systems, backup pumps, standby power generators, and other critical emergency pump station

components were maintained and tested in accordance with the Permittee's preventive maintenance plan. Any deviations from or modifications to the plan shall be discussed.

**d. Records**

The Permittee shall develop and maintain a record of all spills, overflows or bypasses of raw or partially treated sewage from its collection system or treatment plant. This record shall be made available to the Regional Water Board upon request and a spill summary shall be included in the annual summary report. The records shall contain:

- i. The date and time of each spill, overflow, or bypass;
- ii. The location of each spill, overflow, or bypass;
- iii. The estimated volume of each spill, overflow, and bypass including gross volume, amount recovered and amount not recovered, monitoring results as required by section VI.C.6.b;
- iv. The cause of each spill, overflow, or bypass;
- v. Whether each spill, overflow, or bypass entered a receiving water and, if so, the name of the water body and whether it entered via storm drains or other man-made conveyances;
- vi. Any mitigation measures implemented;
- vii. Any corrective measures implemented or proposed to be implemented to prevent/minimize future occurrences; and,
- viii. The mandatory information included in SSO online reporting for finalizing and certifying the SSO report for each spill, overflow, or bypass under the SSO WDR.

**e. Activities Coordination**

Although not required by this Order, Regional Water Board also expects the watershed group to continue to work together regarding activities related to desalters, water uses, and the use of the brine line in order to comply with the requirements of this Order, in addition to meeting the deadlines in the Salts TMDL Implementation Plan.

**f. Consistency with SSO WDRs**

The CWA prohibits the discharge of pollutants from point sources to surface waters of the United States unless authorized under an NPDES permit. (33 United States Code sections 1311, 1342). The State Water Board adopted *General Waste Discharge Requirements for Sanitary Sewer Systems*, (WQ Order No. 2006-0003-DWQ; SSO WDR) on May 2, 2006, to provide a consistent, statewide regulatory approach to address sanitary sewer overflows. The SSO WDR requires public agencies that own or operate sanitary sewer systems to apply for coverage under the SSO WDR, develop and implement

sewer system management plans, and report all SSO to the State Water Board's online SSOs database. Regardless of the coverage obtained under the SSO WDR, the Permittee's collection system is part of the POTW that is subject to this NPDES permit. As such, pursuant to federal regulations, the Permittee must properly operate and maintain its collection system (40 CFR § 122.41 (e)), report any non-compliance (40 CFR § 122.41(1)(6) and (7)), and mitigate any discharge from the collection system in violation of this NPDES permit (40 CFR § 122.41(d)).

The requirements contained in this Order in sections VI.C.3.b (SCCP Plan section), VI.C.4 (Construction, Operation and Maintenance Specifications section), and VI.C.6 (Spill Reporting Requirements section) are intended to be consistent with the requirements of the SSO WDR. The Regional Water Board recognizes that there may be some overlap between these NPDES permit provisions and SSO WDR requirements, related to the collection systems. The requirements of the SSO WDR are considered the minimum thresholds (see finding 11 of State Water Board Order No. 2006-0003-DWQ). To encourage efficiency, the Regional Water Board will accept the documentation prepared by the Permittees under the SSO WDR for compliance purposes as satisfying the requirements in sections VI.C.3.b, VI.C.4, and VI.C.6 provided the more stringent provisions contained in this NPDES permit are also addressed. Pursuant to SSO WDR, section D, provision 2(iii) and (iv), the provisions of this NPDES permit supersede the SSO WDR, for all purposes, including enforcement, to the extent the requirements may be deemed duplicative

**7. Compliance Schedules**

There are no compliance schedules included in this NPDES Order.

**Table 6. Compliance Schedule for Final Effluent Limitations**

Task No.	Description	Start Date	End Date
N/A			

**VII. COMPLIANCE DETERMINATION**

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

**A. General**

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the MRP and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Permittee shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

**B. Multiple Sample Data**

When determining compliance with a measure of central tendency (arithmetic mean, geometric mean, median, etc.) of multiple sample analyses and the data set contains one or more reported determinations of DNQ or ND. In those cases, the Permittee shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

**C. Average Monthly Effluent Limitation (AMEL)**

If the average (or when applicable, the median determined by subsection B above for multiple sample data) of daily discharges over a calendar month exceeds the AMEL for a given parameter, this will represent a single violation, though the Permittee may be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AMEL, the Permittee may be considered out of compliance for that calendar month. The Permittee will only be considered out of compliance for days when the discharge occurs. For any one calendar month during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar month with respect to the AMEL.

If the analytical result of a single sample, monitored monthly, quarterly, semiannually, or annually, does not exceed the AMEL for a given parameter, the Permittee will have demonstrated compliance with the AMEL for each day of that month for that parameter.

If the analytical result of any single sample, monitored monthly, quarterly, semiannually, or annually, exceeds the AMEL for any parameter, the Permittee may collect up to four additional samples within the same calendar month. All analytical results shall be reported in the monitoring report for that month. The concentration of pollutant (an arithmetic mean or a median) in these samples estimated from the "Multiple Sample Data Reduction" section above, will be used for compliance determination.

In the event of noncompliance with an AMEL, the sampling frequency for that parameter shall be increased to weekly and shall continue at this level until compliance with the AMEL has been demonstrated.

**D. Average Weekly Effluent Limitation (AWEL)**

If the average of daily discharges over a calendar week exceeds the AWEL for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for each day of that week for that parameter, resulting in 7 days of non-compliance. The average of daily discharges over the calendar week that exceeds the AWEL for a parameter will be considered out of compliance for that week only. If only a

single sample is taken during the calendar week and the analytical result for that sample exceeds the AWEL, the Permittee will be considered out of compliance for that calendar week. For any one calendar week during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar week with respect to the AWEL.

A calendar week will begin on Sunday and end on Saturday. Partial calendar weeks at the end of calendar month will be carried forward to the next month in order to calculate and report a consecutive seven-day average value on Saturday.

**E. Maximum Daily Effluent Limitation (MDEL)**

If a daily discharge exceeds the MDEL for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for that parameter for that one day only within the reporting period. If no sample (daily discharge) is taken over a calendar day, no compliance determination can be made for that day with respect to effluent violation determination, but compliance determination can be made for that day with respect to reporting violation determination.

**F. Instantaneous Minimum Effluent Limitation**

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

**G. Instantaneous Maximum Effluent Limitation**

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

**H. Six-month Median Effluent Limitation**

If the median of daily discharges over any 180-day period exceeds the six-month median effluent limitation for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for each day of that 180-day period for that parameter. The next assessment of compliance will occur after the next sample is taken. If only a single sample is taken during a given 180-day period and the analytical result for that sample exceeds the six-month median, the Permittee will be considered out of compliance for the 180-day period. For any 180-period during which no sample is taken, no compliance determination can be made for the six-month median effluent limitation.

**I. Median Monthly Effluent Limitation (MMEL)**

If the median of daily discharges over a calendar month exceeds the MMEL for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of

compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). However, an alleged violation of the MMEL will be considered one violation for the purpose of assessing State mandatory minimum penalties. If no sample (daily discharge) is taken over a calendar month, no compliance determination can be made for that month with respect to effluent violation determination, but compliance determination can be made for that month with respect to reporting violation determination.

**J. Chronic Toxicity**

The discharge is subject to determination of "Pass" or "Fail" and "Percent Effect" from a single-effluent concentration chronic toxicity test at the discharge IWC using the Test of Significant Toxicity (TST) approach described in National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, 2010), Appendix A, Figure A-1, and Table A-1. The null hypothesis ( $H_0$ ) for the TST approach is: Mean discharge IWC response  $\leq 0.75 \times$  Mean control response. A test result that rejects this null hypothesis is reported as "Pass". A test result that does not reject this null hypothesis is reported as "Fail". The relative "Percent Effect" at the discharge IWC is defined and reported as:  $((\text{Mean control response} - \text{Mean discharge IWC response}) + \text{Mean control response}) \times 100$ .

The Maximum Daily Effluent Limitation (MDEL) for chronic toxicity is exceeded and a violation will be flagged when a chronic toxicity test, analyzed using the TST approach, results in "Fail" and the "Percent Effect" is  $\geq 0.50$ .

The Median Monthly Effluent Limitation (MMEL) for chronic toxicity is exceeded and a violation will be flagged when the median of no more than three independent chronic toxicity tests, conducted within the same calendar month and analyzed using the TST approach, results in "Fail". The MMEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail".

**K. Percent Removal**

The average monthly percent removal is the removal efficiency expressed in percentage across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of pollutant concentrations (C in mg/L) of influent and effluent samples collected at about the same time using the following equation:

$$\text{Percent Removal (\%)} = [1 - (C_{\text{Effluent}}/C_{\text{Influent}})] \times 100 \%$$

When preferred, the Permittee may substitute mass loadings and mass emissions for the concentrations.

**L. Mass and Concentration Limitations**

Compliance with mass and concentration effluent limitations for the same parameter shall be determined separately with their respective limitations. When the concentration of a constituent in an effluent sample is determined to be ND or DNQ, the corresponding mass emission rate determined from that sample concentration shall also be reported as ND or DNQ.

**M. Compliance with single constituent effluent limitations**

Permittees may be considered out of compliance with the effluent limitation if the concentration of the pollutant (see section B "Multiple Sample Data Reduction" above) in the monitoring sample is greater than the effluent limitation and greater than or equal to the RL.

**N. Compliance with effluent limitations expressed as a sum of several constituents**

Permittees are out of compliance with an effluent limitation which applies to the sum of a group of chemicals (e.g., PCB's) if the sum of the individual pollutant concentrations is greater than the effluent limitation. Individual pollutants of the group will be considered to have a concentration of zero if the constituent is reported as ND or DNQ.

**O. Compliance with Calleguas Creek Salts TMDL effluent limitations**

The Camarillo WRP discharges to Conejo Creek, Reach 9B of the Calleguas Creek. Calleguas Creek and its tributaries are on the CWA section 303(d) list as impaired for TDS, Sulfate, Chloride, and Boron. For this discharge, the Calleguas Creek Salts TMDL has established seasonal WLAs for TDS, Sulfate, and Chloride. Federal regulations require that NPDES permits incorporate WQBELs consistent with the requirements and assumptions of any available WLAs.

WLAs established for the Camarillo WRP in the *Salts TMDL* will be implemented through final effluent limitations contained in the NPDES permit and interim effluent limitations may be provided in a separate amended Time Schedule Order. Compliance will be determined through monitoring of final effluent discharge as defined in the NPDES permit. The proposed effluent permit limits will be applied as end-of pipe mass-based monthly average effluent limits. A daily maximum effluent limit is not required because chloride is not expected to have an immediate or acute effect on the beneficial uses. Compliance with the minimum salt export requirements for the Camarillo WRP will be based on the salt export from the subwatershed to which they discharge. The mechanisms for meeting the minimum salt export requirements and for monitoring progress towards meeting those requirements will be included in the monitoring program work plan and approved by the Executive Officer.

Camarillo WRP's mass-based WLAs are calculated as the POTW effluent flow rate multiplied by the water quality objective and include a mass-based adjustment factor (AF) that is subtracted from the product of the flow-rate and the water quality objective. AF is set equal to the difference between the minimum salts export requirement to attain a salt balance in the subject reaches and the actual salts export.

**Dry-weather definition.** The *Salts TMDL* WLAs apply to Camarillo WRP during dry weather, when the flows in the receiving water are below the 86th percentile flow and there is no measurable precipitation. Dry weather conditions exist when flow in Calleguas Creek near California State University Channel Islands (CSUCI) is less than 31 cubic feet per second (cfs) at USGS gauge station 11106550. During wet weather, the loading capacity of the stream is significantly increased by storm water flows with very low salt concentrations. Any discharges from the Facility during wet weather would be assimilated by these large storm flows and would not cause exceedances of water quality objectives. The dry-weather final effluent limitation for Salts will be calculated as follows:

Given: Minimum Salt Export Requirements for Adjustment Factor

Chloride = 1,060 lbs/day  
TDS = 7,920 lbs/day  
Sulfate = 4,610 lbs/day  
Boron = 0 lbs/day

The formula for determining final effluent limitation (dry weather) applied as monthly average is as follows:

Chloride, lbs/day =  $150 \times Q \times AF$   
TDS, lbs/day =  $850 \times Q \times AF$   
Sulfate, lbs/day =  $250 \times Q \times AF$   
Boron, lbs/day =  $1.0 \times Q \times AF$

where;

Q = the Facility's flow at the time the water quality measurement is collected and a conversion factor to lbs/day based on the units of measurement for the flow.  
AF = (minimum salt export requirement – actual salt export)

However, use of AFs are subject to approval by the Regional Water Board, following the demonstration of evidence presented by the Permittee. POTWs wanting to use AFs must apply to the Regional Water Board for approval and submit the following documentation together with their request: water supply chloride concentrations; receiving water chloride concentrations; the effluent mass; and, evidence of increased salt exports to offset the increased discharges from the POTW.

Camarillo WRP is currently not connected to the brine line. However, based on the schedule submitted by Camarillo SD, Camarillo's connection to the brine line should be completed by January 1, 2016. The Camarillo Sanitary District has not applied to the Regional Water Board for an adjustment factor. As a result, the AF term in the formula above is set equal to zero until Camarillo Sanitary District requests and the Regional Board approves an AF for the Camarillo WRP. As a result, the AF term drops out of the equation, and the final effluent limitations are expressed as follows:

Chloride, lbs/day =  $150 \times Q = 150 \times 7.25 \times 8.34 = 9,070$   
TDS, lbs/day =  $850 \times Q = 850 \times 7.25 \times 8.34 = 51,400$   
Sulfate, lbs/day =  $250 \times Q = 250 \times 7.25 \times 8.34 = 15,100$

where:

Q = represents the product of Facility's design capacity and a conversion factor, to convert from MGD to lbs/day.

If an AF is approved, the permit will be reopened to adjust the final effluent limitations to reflect the approved AF.

**Wet-weather definition.** Wet-weather is any day when the flow in the receiving water is equal to or greater than the 86th percentile flow of the receiving water. Wet weather conditions exist when flow in Calleguas Creek at CSUCI is greater than or equal to 31 cfs at USGS gauge station 11106550. The wet-weather final effluent limitations applicable to Camarillo WRP will be as follows:

The wet-weather final effluent limitation for Salts will be applied as follows:

Parameter	Units	Effluent Limitations (Average Monthly)
Chloride	mg/L	150
TDS	mg/L	850
Sulfate	mg/L	250

During this permit cycle, the wet-weather final effluent limitations listed above for TDS, chloride, and sulfate will apply on the effective date of this Order, but a TSO may establish an interim limit and time schedule to achieve compliance with the final effluent limitations. Regional Water Board staff propose to have the TSO adopted concurrently with the NPDES permit renewal Order.

The mass emission rates are based on the plant design flow rate of 7.25 mgd, and are calculated as follows: Flow (mgd) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day.

**P. Compliance with Calleguas Creek Metals TMDL for Mercury in Suspended Solids**

A mass-based limit is developed for mercury expressed in lbs/month. The final waste load allocation for the Camarillo WRP for mercury is based on median monthly mercury effluent concentrations which are currently more stringent than the number targets multiplied by the design flow. The *Metals TMDL* assumes that the total load in water is equal to suspended sediment load. In addition to the water column final effluent monitoring, sediment sampling of mercury in the effluent will need to be implemented, as specified in the Monitoring and Reporting Program, if both the TSS and the mercury final effluent limitations are exceeded.

**Q. Mass Emission Rate**

The mass emission rate shall be obtained from the following calculation for any calendar day:

$$\text{Mass emission rate (lb/day)} = \frac{8.34}{N} \sum_{i=1}^N Q_i C_i$$

$$\text{Mass emission rate (kg/day)} = \frac{3.79}{N} \sum_{i=1}^N Q_i C_i$$

in which 'N' is the number of samples analyzed in any calendar day. 'Q<sub>i</sub>' and 'C<sub>i</sub>' are the flow rate (mgd) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' grab samples, which may be taken in any calendar day. If a composite sample is taken, 'C<sub>i</sub>' is the concentration measured in the composite sample and 'Q<sub>i</sub>' is the average flow rate occurring during the period over which samples are composited.

The daily concentration of all constituents shall be determined from the flow-weighted average of the same constituents in the combined waste streams as follows:

$$\text{Daily concentration} = \frac{1}{Q_t} \sum_{i=1}^N Q_i C_i$$

in which 'N' is the number of component waste streams. 'Q<sub>i</sub>' and 'C<sub>i</sub>' are the flow rate (MGD) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' waste streams. 'Q<sub>t</sub>' is the total flow rate of the combined waste streams.

#### R. Bacterial Standards and Analysis

1. The geometric mean used for determining compliance with bacterial standards is calculated with the following equation:

$$\text{Geometric Mean} = (C_1 \times C_2 \times \dots \times C_n)^{1/n}$$

where n is the number of days samples were collected during the period and C is the concentration of bacteria (MPN/100 mL or CFU/100 mL) found on each day of sampling.

2. For bacterial analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliform, at a minimum, and 1 to 1000 per 100 ml for enterococcus). The detection methods used for each analysis shall be reported with the results of the analyses.
3. Detection methods used for coliforms (total and fecal) shall be those presented in Table 1A of 40 CFR part 136, unless alternate methods have been approved by USEPA pursuant to 40 CFR part 136, or improved methods have been determined by the Executive Officer and/or USEPA.
4. Detection methods used for enterococcus shall be those presented in Table 1A of 40 CFR part 136 or in the USEPA publication EPA 600/4-85/076, Test Methods for Escherichia coli and Enterococci in Water By Membrane Filter Procedure or any improved method determined by the Executive Officer and/or USEPA to be appropriate.

#### S. Single Operational Upset (SOU)

A SOU that leads to simultaneous violations of more than one pollutant parameter shall be treated as a single violation and limits the Permittee's liability in accordance with the following conditions:

1. A SOU is broadly defined as a single unusual event that temporarily disrupts the usually satisfactory operation of a system in such a way that it results in violation of multiple pollutant parameters.
2. A Permittee may assert SOU to limit liability only for those violations which the Permittee submitted notice of the upset as required in Provision V.E.2(b) of Attachment D – Standard Provisions.
3. For purpose outside of CWC section 13385 subdivisions (h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Permittees to assert the SOU limitation of liability, and the manner

of counting violations) shall be in accordance with USEPA Memorandum "Issuance of Guidance Interpreting Single Operational Upset" (September 27, 1989).

4. For purpose of CWC section 13385 (h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Permittees to assert the SOU limitation of liability, and the manner of counting violations) shall be in accordance with CWC section 13385 (f)(2).

## ATTACHMENT A – DEFINITIONS

### **Arithmetic Mean ( $\mu$ )**

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

Arithmetic mean =  $\mu = \Sigma x / n$  where:  $\Sigma x$  is the sum of the measured ambient water concentrations, and  $n$  is the number of samples.

### **Average Monthly Effluent Limitation (AMEL)**

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

### **Average Weekly Effluent Limitation (AWEL)**

The highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

### **Bioaccumulative**

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

### **Biosolids**

Sewage sludge that has been treated and tested and shown to be capable of being beneficially and legally used pursuant to federal and state regulations as a soil amendment for agricultural, silvicultural, horticultural, and land reclamation activities as specified under 40 C.F.R. Part 503.

### **Carcinogenic**

Pollutants are substances that are known to cause cancer in living organisms.

### **Coefficient of Variation (CV)**

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

### **Daily Discharge**

Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

**Detected, but Not Quantified (DNQ)**

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL. Sample results reported as DNQ are estimated concentrations.

**Dilution Credit**

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

**Effluent Concentration Allowance (ECA)**

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

**Enclosed Bays**

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

**Estimated Chemical Concentration**

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

**Estuaries**

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in CWC section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

**Inland Surface Waters**

All surface waters of the state that do not include the ocean, enclosed bays, or estuaries.

**Instantaneous Maximum Effluent Limitation**

The highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

**Instantaneous Minimum Effluent Limitation**

The lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

**Maximum Daily Effluent Limitation (MDEL)**

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

**Median**

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median =  $X_{(n+1)/2}$ . If n is even, then the median =  $(X_{n/2} + X_{(n/2)+1})/2$  (i.e., the midpoint between the n/2 and n/2+1).

**Method Detection Limit (MDL)**

MDL is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in 40 CFR part 136, Attachment B, revised as of July 3, 1999.

**Minimum Level (ML)**

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

**Mixing Zone**

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

**Not Detected (ND)**

Sample results which are less than the laboratory's MDL.

**Persistent Pollutants**

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

**Pollutant Minimization Program (PMP)**

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution

Prevention Plan, if required pursuant to CWC section 13263.3(d), shall be considered to fulfill the PMP requirements.

### **Pollution Prevention**

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in CWC section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State Water Resources Control Board (State Water Board) or Regional Water Board.

### **Reporting Level (RL)**

The RL is the ML (and its associated analytical method) chosen by the Permittee for reporting and compliance determination from the MLs included in this Order, including an additional factor if applicable as discussed herein. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

### **Source of Drinking Water**

Any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

### **Standard Deviation ( $\sigma$ )**

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = \left( \frac{\sum[(x - \mu)^2]}{(n - 1)} \right)^{0.5}$$

where:

x is the observed value;

$\mu$  is the arithmetic mean of the observed values; and

n is the number of samples.


### **Toxicity Reduction Evaluation (TRE)**

TRE is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of Facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)


ATTACHMENT B1 – MAP OF CAMARILLO WRP & SURROUNDING AREA



ATTACHMENT B2 – MAP OF CAMARILLO WRP



ATTACHMENT C – FLOW SCHEMATIC



## ATTACHMENT D – STANDARD PROVISIONS

### I. STANDARD PROVISIONS – PERMIT COMPLIANCE

#### A. Duty to Comply

1. The Permittee must comply with all of the terms, requirements, and conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA), its regulations, and the California Water Code (CWC) and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof. (40 CFR § 122.41(a); California Water Code (CWC) sections 13261, 13263, 13264, 13265, 13268, 13000, 13001, 13304, 13350, 13385.)
2. The Permittee shall comply with effluent standards or prohibitions established under Part 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (Title 40 of the Code of Federal Regulations (40 CFR) § 122.41(a)(1).)

#### B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR § 122.41(c).)

#### C. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR § 122.41(d).)

#### D. Proper Operation and Maintenance

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Permittee only when necessary to achieve compliance with the conditions of this Order. (40 CFR § 122.41(e).)

#### E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR § 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 CFR § 122.5(c).)

#### F. Inspection and Entry

The Permittee shall allow the Regional Water Board, State Water Board, USEPA, and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be

required by law, to (33 U.S.C. section 1318(a)(4)(B); 40 CFR § 122.41(i); CWC sections 13267 and 13383):

1. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (33 U.S.C. section 1318(a)(4)(B)(i); 40 CFR § 122.41(i)(1); CWC sections 13267 and 13383);
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (33 U.S.C. section 1318(a)(4)(B)(ii); 40 CFR § 122.41(i)(2); CWC sections 13267 and 13383);
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (33 U.S.C. section 1318(a)(4)(B)(ii); 40 CFR § 122.41(i)(3); CWC sections 13267 and 13383); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the CWC, any substances or parameters at any location. (33 U.S.C. section 1318(a)(4)(B); 40 CFR § 122.41(i)(4); CWC sections 13267 and 13383)

#### G. Bypass

1. Definitions
  - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR § 122.41(m)(1)(i).)
  - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR § 122.41(m)(1)(ii).)
2. *Bypass not exceeding limitations.* The Permittee may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 CFR § 122.41(m)(2).)
3. *Prohibition of bypass.* Bypass is prohibited, and the Regional Water Board may take enforcement action against a Permittee for bypass, unless (40 CFR § 122.41(m)(4)(i)):
  - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR § 122.41(m)(4)(i)(A));
  - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR § 122.41(m)(4)(i)(B)); and

- c. The Permittee submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR § 122.41(m)(4)(i)(C).)
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 CFR § 122.41(m)(4)(ii).)
5. Notice
  - a. *Anticipated bypass.* If the Permittee knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR § 122.41(m)(3)(i).)
  - b. *Unanticipated bypass.* The Permittee shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR § 122.41(m)(3)(ii).)

#### H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR § 122.41(n)(1).)

1. *Effect of an upset.* An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR § 122.41(n)(2).)
2. *Conditions necessary for a demonstration of upset.* A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR § 122.41(n)(3)):
  - a. An upset occurred and that the Permittee can identify the cause(s) of the upset (40 CFR § 122.41(n)(3)(i));
  - b. The permitted facility was, at the time, being properly operated (40 CFR § 122.41(n)(3)(ii));
  - c. The Permittee submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR § 122.41(n)(3)(iii)); and
  - d. The Permittee complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR § 122.41(n)(3)(iv).)
3. *Burden of proof.* In any enforcement proceeding, the Permittee seeking to establish the occurrence of an upset has the burden of proof. (40 CFR § 122.41(n)(4).)

## II. STANDARD PROVISIONS – PERMIT ACTION

**A. General**

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR § 122.41(f).)

**B. Duty to Reapply**

If the Permittee wishes to continue an activity regulated by this Order after the expiration date of this Order, the Permittee must apply for and obtain a new permit. (40 CFR § 122.41(b).)

**C. Transfers**

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Permittee and incorporate such other requirements as may be necessary under the CWA and the CWC. (40 CFR §§ 122.41(l)(3) and 122.61.)

**III. STANDARD PROVISIONS – MONITORING**

- A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR § 122.41(j)(1).)
- B.** Monitoring results must be conducted according to test procedures under 40 CFR part 136 or, in the case of sludge use or disposal, approved under 40 CFR part 136 unless otherwise specified in 40 CFR part 503 unless other test procedures have been specified in this Order. (40 CFR part 122.41(j)(4); part 122.44(i)(1)(iv).)

**IV. STANDARD PROVISIONS – RECORDS**

- A.** Except for records of monitoring information required by this Order related to the Permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR part 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 CFR § 122.41(j)(2).)
- B.** Records of monitoring information shall include:
1. The date, exact place, and time of sampling or measurements (40 CFR § 122.41(j)(3)(i));
  2. The individual(s) who performed the sampling or measurements (40 CFR § 122.41(j)(3)(ii));
  3. The date(s) analyses were performed (40 CFR § 122.41(j)(3)(iii));
  4. The individual(s) who performed the analyses (40 CFR § 122.41(j)(3)(iv));
  5. The analytical techniques or methods used (40 CFR § 122.41(j)(3)(v)); and

6. The results of such analyses. (40 CFR § 122.41(j)(3)(vi).)
- C. Claims of confidentiality for the following information will be denied (40 CFR § 122.7(b)):
1. The name and address of any permit applicant or Permittee (40 CFR § 122.7(b)(1)); and
  2. Permit applications and attachments, permits and effluent data. (40 CFR § 122.7(b)(2).)

## V. STANDARD PROVISIONS – REPORTING

### A. Duty to Provide Information

The Permittee shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Permittee shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR § 122.41(h); Wat. Code, section 13267 and 13383.)

### B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR § 122.41(k).)
2. *Signatory requirements for a municipality, State, Federal, or other public agency.* All applications submitted to the Regional Water Board shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR § 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR § 122.22(b)(1));
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR § 122.22(b)(2)); and
  - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 CFR § 122.22(b)(3).)

4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR § 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations." (40 CFR § 122.22(d).)

#### **C. Monitoring Reports**

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR § 122.41(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 CFR § 122.41(l)(4)(i).)
3. If the Permittee monitors any pollutant more frequently than required by this Order using test procedures approved under 40 CFR § 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 CFR § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR § 122.41(l)(4)(iii).)

#### **D. Compliance Schedules**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR § 122.41(l)(5).)

#### **E. Twenty-Four Hour Reporting**

1. The Permittee shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is

expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR § 122.41(l)(6)(i).)

2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR § 122.41(l)(6)(ii)):
  - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR § 122.41(l)(6)(ii)(A).)
  - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR § 122.41(l)(6)(iii).)

#### F. Planned Changes

The Permittee shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 CFR § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements under § 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1). (40 CFR § 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR § 122.41(l)(1)(iii).)

#### G. Anticipated Noncompliance

The Permittee shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with this Order's requirements. (40 CFR § 122.41(l)(2).)

#### H. Other Noncompliance

The Permittee shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR § 122.41(l)(7).)

#### I. Other Information

When the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Permittee shall promptly submit such facts or information. (40 CFR § 122.41(l)(8).)

## VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13268, 13385, 13386, and 13387.
- B. The CWA provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the CWA, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the CWA, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The CWA provides that any person who *negligently* violates sections 301, 302, 306, 307, 308, 318, or 405 of the CWA, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the CWA, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the CWA, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two years, or both. Any person who *knowingly* violates such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both. Any person who *knowingly* violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the CWA, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the CWA, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions (40 CFR § 122.41(a)(2); CWC section 13385 and 13387).
- C. Any person may be assessed an administrative penalty by the Administrator of USEPA, the Regional Water Board, or State Water Board for violating section 301, 302, 306, 307, 308, 318 or 405 of this CWA, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the CWA. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000. (40 CFR § 122.41(a)(3))
- D. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. (40 CFR § 122.41(j)(5)).

- E. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both. (40 CFR § 122.41(k)(2)).

## VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

### A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 CFR § 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR § 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 CFR § 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR § 122.42(b)(3).)

**ATTACHMENT E – MONITORING AND REPORTING PROGRAM**

**Contents**

I.	General Monitoring Provisions .....	E-2
II.	Monitoring Locations .....	E-5
III.	Influent Monitoring Requirements .....	E-5
	A. Monitoring Location INF-001 .....	E-6
IV.	Effluent Monitoring Requirements .....	E-6
	A. Monitoring Location EFF-001 .....	E-7
V.	Whole Effluent Toxicity (WET) Testing Requirements .....	E-11
VI.	Land Discharge Monitoring Requirements (Not applicable) .....	E-15
VII.	Recycling Monitoring Requirements (not applicable) .....	E-15
VIII.	Receiving Water Monitoring Requirements .....	E-15
	A. Monitoring Locations RSW-001U and RSW-002D .....	E-15
	B. TMDL Stream Flow and Rainfall Monitoring .....	E-18
IX.	Other Monitoring Requirements .....	E-19
	A. Calleguas Creek TMDL Monitoring Requirements .....	E-19
	B. Special Study .....	E-19
	C. Watershed Monitoring .....	E-20
	D. Tertiary Filter Treatment Bypasses .....	E-22
X.	Reporting Requirements .....	E-22
	A. General Monitoring and Reporting Requirements .....	E-22
	B. Calleguas Creek TMDL Monitoring and Reporting Requirements .....	E-23
	C. Self-Monitoring Reports (SMRs) .....	E-23
	D. Discharge Monitoring Reports (DMRs) .....	E-26
	E. Other Reports .....	E-26

**Tables**

Table E-1.	Monitoring Station Locations .....	E-5
Table E-2.	Influent Monitoring .....	E-6
Table E-3a.	Effluent Monitoring .....	E-7
Table E-3b	Salts Monitoring and Reporting Requirements .....	E-10
Table E-3c.	Effluent Monitoring .....	E-11
Table E-4a.	Receiving Water Monitoring Requirements .....	E-15
Table E-4b	TMDL Stream Flow and Rainfall Monitoring Requirements .....	E-19
Table E-5.	CEC Monitoring Requirements .....	E-19
Table E-6.	Monitoring Periods and Reporting Schedule .....	E-24

## ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP), CI-1278

Section 308(a) of the federal Clean Water Act and sections 122.41(h), (j), (l), 122.44(i), and 122.48 of Title 40 of the Code of Federal Regulations (40 CFR) requires that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) sections 13267 and 13383 also authorizes the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. This MRP establishes monitoring, reporting, and recordkeeping requirements that implement federal and California laws and/or regulations.

### I. GENERAL MONITORING PROVISIONS

- A. All samples shall be representative of the waste discharge under conditions of peak load. Quarterly effluent analyses shall be performed during the months of February, May, August, and November. Semiannual analyses shall be performed during the months of February and August. Annual analyses shall be performed during the month of August. Should there be instances when monitoring could not be done during these specified months, the Permittee must notify the Regional Water Board, state the reason why monitoring could not be conducted, and obtain approval from the Executive Officer for an alternate schedule. Results of quarterly, semiannual, and annual analyses shall be reported as due date specified in Table E-6 of MRP.
- B. Pollutants shall be analyzed using the analytical methods described in 40 CFR parts 136.3, 136.4, and 136.5; or where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. Laboratories analyzing effluent samples and receiving water samples shall be certified by the California Department of Public Health (CDPH) Environmental Laboratory Accreditation Program (ELAP) or approved by the Executive Officer and must include quality assurance/quality control (QA/QC) data in their reports. A copy of the laboratory certification shall be provided in the Annual Report due to the Regional Water Board each time a new certification and/or renewal of the certification is obtained from ELAP.
- C. Water/wastewater samples must be analyzed within allowable holding time limits as specified in 40 CFR § 136.3. All QA/QC analyses must be run on the same dates that samples are actually analyzed. The Permittee shall retain the QA/QC documentation in its files and make available for inspection and/or submit them when requested by the Regional Water Board. Proper chain of custody procedures must be followed and a copy of that documentation shall be submitted with the monthly report.
- D. The Permittee shall calibrate and perform maintenance procedures on all monitoring instruments and to ensure accuracy of measurements, or shall ensure that both equipment activities will be conducted.
- E. For any analyses performed for which no procedure is specified in the United States Environmental Protection Agency (USEPA) guidelines, or in the MRP, the constituent or parameter analyzed and the method or procedure used must be specified in the monitoring report.
- F. Each monitoring report must affirm in writing that "all analyses were conducted at a laboratory certified for such analyses by the CDPH or approved by the Executive Officer and in accordance with current USEPA guideline procedures or as specified in this Monitoring and Reporting Program."

- G. The monitoring report shall specify the USEPA analytical method used, the Method Detection Limit (MDL), and the Reporting Level (RL) [the applicable minimum level (ML) or reported Minimum Level (RML)] for each pollutant. The MLs are those published by the State Water Resources Control Board (State Water Board) in the *Policy for the Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California, (State Implementation Policy or SIP)*, February 9, 2005, Appendix 4. The ML represents the lowest quantifiable concentration in a sample based on the proper application of all method-based analytical procedures and the absence of any matrix interference. When all specific analytical steps are followed and after appropriate application of method specific factors, the ML also represents the lowest standard in the calibration curve for that specific analytical technique. When there is deviation from the method analytical procedures, such as dilution or concentration of samples, other factors may be applied to the ML depending on the sample preparation. The resulting value is the reported ML.
- H. The Permittee shall select the analytical method that provides a ML lower than the permit limit established for a given parameter, unless the Permittee can demonstrate that a particular ML is not attainable, in accordance with procedures set forth in 40 CFR part 136; and obtains approval for a higher ML from the Executive Officer, as provided for in section J, below. If the effluent limitation is lower than all the MLs in Appendix 4, SIP, the Discharge must select the method with the lowest ML for compliance purposes. The Permittee shall include in the Annual Summary Report a list of the analytical methods employed for each test.
- I. The Permittee shall instruct its laboratories to establish calibration standards so that the ML (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Permittee to use analytical data derived from extrapolation beyond the lowest point of the calibration curve. In accordance with section J, below, the Discharger's laboratory may employ a calibration standard lower than the ML in Appendix 4 of the SIP.
- J. In accordance with section 2.4.3 of the SIP, the Regional Water Board Executive Officer, in consultation with the State Water Board's Quality Assurance Program Manager, may establish an ML that is not contained in Appendix 4 of the SIP to be included in the discharger's permit in any of the following situations:
- a. When the pollutant under consideration is not included in Appendix 4, SIP;
  - b. When the Permittee and the Regional Water Board agree to include in the permit a test method that is more sensitive than those specified in 40 CFR part 136;
  - c. When the Permittee agrees to use an ML that is lower than those listed in Appendix 4;
  - d. When the Permittee demonstrates that the calibration standard matrix is sufficiently different from that used to establish the ML in Appendix 4 and proposes an appropriate ML for the matrix; or,
  - e. When the Permittee uses a method, which quantification practices are not consistent with the definition of the ML. Examples of such methods are USEPA-approved method 1613 for dioxins, and furans, method 1624 for volatile organic substances, and method 1625 for semi-volatile organic substances. In such cases, the Permittee, the

Regional Water Board, and the State Water Board shall agree on a lowest quantifiable limit and that limit will substitute for the ML for reporting and compliance determination purposes.

If there is any conflict between foregoing provisions and the SIP, the provisions stated in the SIP (section 2.4) shall prevail.

- K. If the Permittee samples and performs analyses (other than for process/operational control, startup, research, or equipment testing) on any influent, effluent, or receiving water constituent more frequently than required by this MRP using approved analytical methods, the results of those analyses shall be included in the report. These results shall be reflected in the calculation of the average used in demonstrating compliance with limitations set forth in this Order.
- L. The Permittee shall develop and maintain a record of all spills or bypasses of raw or partially treated sewage from its collection system or treatment plant according to the requirements in the WDR section of this Order. This record shall be made available to the Regional Water Board upon request and a spill summary shall be included in the annual summary report.
- M. For all bacteriological analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliform, at a minimum, and 1 to 1000 per 100 ml for *enterococcus*). The detection methods used for each analysis shall be reported with the results of the analyses.
- a. Detection methods used for coliforms (total and fecal) shall be those presented in Table 1A of 40 CFR part 136, unless alternate methods have been approved in advance by the USEPA pursuant to 40 CFR part 136.
  - b. Detection methods used for *E. coli* shall be those presented in Table 1A of 40 CFR part 136 or in the USEPA publication EPA 600/4-85/076, *Test Methods for Escherichia coli and Enterococci in Water By Membrane Filter Procedure*, or any improved method determined by the Regional Water Board to be appropriate.
- N. Since compliance monitoring focuses on the effects of a point source discharge, it is not designed to assess impacts from other sources of pollution (e.g., non-point source run-off, aerial fallout) or to evaluate the current status of important ecological resources on a regional basis.

The Permittee shall participate in the implementation of and comply with the Watershed-wide Monitoring Program. Camarillo SD's responsibilities under the Watershed-wide Monitoring Program are described in the Receiving Water Monitoring Requirements section. To achieve the goals of the Watershed-wide Monitoring Program, revisions to the Receiving Water Monitoring Requirements will be made under the direction of USEPA and the Regional Water Board. The Permittee shall submit annual reports providing the monitoring data collected during the calendar year, as well as an interpretation of the significance of the results with respect to the health of the watershed. Annual reports shall be submitted by July 1<sup>st</sup> of each year. The first annual report covering the period from January 1-December 31, 2014 should be received in the Regional Water Board office by July 1, 2015.

Changes to the compliance monitoring program may be required to fulfill the goals of the watershed-wide monitoring program, while retaining the compliance monitoring component required to evaluate compliance with the NPDES permit. Revisions to the Permittee's program will be made under the direction of the Regional Water Board, as necessary, to accomplish the goal, and may include a reduction or increase in the number of parameters to be monitored, the frequency of monitoring, and/or the number of samples collected.

Until such time when a watershed-wide monitoring program is developed, Camarillo WRP shall implement the monitoring program in section IX.C of this MRP.

**II. MONITORING LOCATIONS**

The Permittee shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

**Table E-1. Monitoring Station Locations**

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
<b>Influent Monitoring Station</b>		
--	INF-001	Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained.
<b>Effluent Monitoring Stations</b>		
001A	EFF-001A	The effluent sampling station shall be located downstream of any inplant return flows and after the final disinfection process, where representative samples of the effluent can be obtained. Under normal conditions, treated effluent is discharged through Discharge Point 001A by gravity flow. Latitude 34°11' 40" and Longitude 119°00'00"
001B	EFF-001B	The effluent sampling station shall be located downstream of any inplant return flows and after the final disinfection process, where representative samples of the effluent can be obtained. Treated effluent is pumped and discharged through Discharge Point 001B when it is not possible to discharge through 001A, due to high water levels in the stream. Latitude 34°11' 40" and Longitude 119°00'00"
<b>Receiving Water Monitoring Stations</b>		
--	RSW-001U	Conejo Creek, 50 feet upstream of Discharge Serial No. 001
--	RSW-002D	Conejo Creek, downstream of Discharge Serial No. 001, at Howard Road crossing
<b>TMDL Dry- and Wet-Weather Flow Monitoring Station</b>		
--	RSW-003D	Salts TMDL stream flow monitoring station at Calleguas Creek near California State University Channel Islands (CSUCI). For the purposes of this permit, this station is also known as RSW-003D (USGS gauge 11106550).

The North latitude and West longitude information in Table 1 are approximate for administrative purposes.

**III. INFLUENT MONITORING REQUIREMENTS**

Influent monitoring is required to:

- Determine compliance with NPDES permit conditions.
- Assess treatment plant performance.
- Assess effectiveness of the Pretreatment Program

**A. Monitoring Location INF-001**

1. The Permittee shall monitor influent to the Facility at INF-001 as follows:

**Table E-2. Influent Monitoring**

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	mgd	recorder	continuous <sup>1</sup>	1
pH	pH unit	grab	weekly	2
Total suspended solids (TSS)	mg/L	24-hour composite	weekly	2
Biochemical oxygen demand (BOD <sub>5</sub> 20°C)	mg/L	24-hour composite	weekly	2
TDS	mg/L	24-hour composite	quarterly	2
Chloride	mg/L	24-hour composite	quarterly	2
Sulfate	mg/L	24-hour composite	quarterly	2
Ammonia as N	mg/L	24-hour composite	quarterly	2
Nitrate plus nitrite as N	mg/L	24-hour composite	quarterly	2
Total nitrogen	mg/L	24-hour composite	quarterly	2
Remaining EPA priority pollutants <sup>3</sup> excluding asbestos	µg/L	24-hour composite/grab for VOCs, and Chromium VI	semiannually	2

**IV. EFFLUENT MONITORING REQUIREMENTS**

Effluent monitoring is required to:

- Determine compliance with National Pollutant Discharge Elimination System (NPDES) permit conditions and water quality standards.
- Assess plant performance, identify operational problems and improve plant performance.

<sup>1</sup> Total daily flow and instantaneous peak daily flow (24-hr basis). Actual monitored flow shall be reported (not the maximum flow, i.e., design capacity).

<sup>2</sup> Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Board. For any pollutant whose effluent limitation is lower than all the MLs specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

<sup>3</sup> Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423. PCB as aroclors shall be analyzed using method EPA 608 and PCB as congeners shall be analyzed using method EPA 1668c.

- Provide information on wastewater characteristics and flows for use in interpreting water quality and biological data.
- Determine reasonable potential analysis for toxic pollutants.

**A. Monitoring Location EFF-001**

1. The Permittee shall monitor the discharge of tertiary-treated effluent at EFF-001A and EFF-001B as follows. Monitoring at EFF-001B is only required when discharge from that outfall is occurring. If more than one analytical test method is listed for a given parameter, the Permittee must select from the listed methods and corresponding Minimum Level:

**Table E-3a. Effluent Monitoring**

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Total waste flow	mgd	recorder	continuous <sup>4</sup>	5
Turbidity	NTU	recorder	continuous <sup>4</sup>	5
Total residual chlorine	mg/L	recorder	continuous <sup>6</sup>	5
Total residual chlorine	mg/L	Grab	daily <sup>7</sup>	5
Total coliform	MPN/100mL or CFU/100mL	Grab	daily <sup>8</sup>	5
Fecal coliform	MPN/100mL or CFU/100mL	Grab	daily <sup>8</sup>	5
E. coli	MPN/100mL or CFU/100mL	Grab	daily <sup>9</sup>	5

<sup>4</sup> Where continuous monitoring of a constituent is required, the following shall be reported:

Total waste flow – Total daily and peak daily flow (24-hour basis);

Turbidity – maximum daily value, total amount of time each day the turbidity exceeded five turbidity units, flow-proportioned average daily value. Grab sample can be used to determine compliance with the 10 NTU limit.

<sup>5</sup> Pollutants shall be analyzed using the analytical methods described in 40 CFR 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Resources Control Board. For any pollutant whose effluent limitation is lower than all the minimum levels (MLs) specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

<sup>6</sup> When chlorination is used, total residual chlorine (TRC) shall be recorded continuously. The recorded data shall be maintained by the Permittee for at least five years. The Permittee shall extract the maximum daily peak, minimum daily, and average daily from the recorded media and shall be made available upon request of the Regional Water Board. The continuous monitoring data are not intended to be used for compliance determination purposes.

<sup>7</sup> When chlorination is used, daily grab samples shall be collected during peak flow at monitoring location EFF-001A and Eff-001B, Monday through Friday only, except for holidays. Analytical results of daily grab samples will be used to determine compliance with total residual chlorine effluent limitation. Furthermore, additional monitoring requirements specified in section IV.A.2. shall be followed.

<sup>8</sup> Daily samples shall be collected Monday through Friday, except for holidays.

<sup>9</sup> E. coli testing shall be conducted only if fecal coliform testing is positive. If the fecal coliform analysis results in no detection, a result of less than (<) the reporting limit for fecal coliform will be reported for E. coli.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Temperature	°F	Grab	weekly	5
pH	pH units	Grab	weekly	5
Settleable solids	mL/L	Grab	weekly	5
Total suspended solids (TSS) <sup>10</sup>	mg/L	24-hour composite	weekly	5
BOD <sub>5</sub> 20°C	mg/L	24-hour composite	weekly	5
Oil and grease	mg/L	Grab	quarterly	5
Dissolved oxygen	mg/L	Grab	monthly	5
Total Dissolved Solids	mg/L	24-hour composite	monthly	5
Sulfate	mg/L	24-hour composite	monthly	5
Chloride	mg/L	24-hour composite	monthly	5
Boron	mg/L	24-hour composite	monthly	5
Ammonia Nitrogen	mg/L	24-hour composite	monthly	5
Nitrite nitrogen	mg/L	24-hour composite	monthly	5
Nitrate nitrogen	mg/L	24-hour composite	monthly	5
Organic nitrogen	mg/L	24-hour composite	monthly	5
Total nitrogen	mg/L	24-hour composite	monthly	5
Total phosphorus	mg/L	24-hour composite	monthly	5
Orthophosphate-P	mg/L	24-hour composite	monthly	5
Surfactants (MBAS)	mg/L	24-hour composite	quarterly	5
Surfactants (CTAS)	mg/L	24-hour composite	quarterly	5
Total hardness (CaCO <sub>3</sub> )	mg/L	24-hour composite	monthly	5
Chronic toxicity <sup>11</sup>	Pass or Fail, % effect	24-hour composite	monthly	5
Arsenic	µg/L	24-hour composite	quarterly	5
Copper	µg/L	24-hour composite	monthly	5
Mercury <sup>10</sup>	µg/L	24-hour composite	monthly	5
Nickel	µg/L	24-hour composite	monthly	5
Cyanide	µg/L	24-hour composite	monthly	5
Bis(2-ethylhexyl)phthalate	µg/L	24-hour composite	monthly	5
Aldrin	µg/L	24-hour composite	quarterly	5
Alpha-BHC	µg/L	24-hour composite	quarterly	5

<sup>10</sup> During each reporting period, if effluent monitoring results show that both the TSS and the Mercury water column final effluent limitations were exceeded, then implementation of the Sediment Monitoring Program is required. Sediment monitoring of the effluent shall begin during the first discharge event following the effluent exceedances.  
 The mercury effluent samples shall be analyzed using EPA method 1631E, per 40 CFR part 136.

<sup>11</sup> The Permittee shall conduct whole effluent toxicity monitoring as outlined in section V. The median monthly summary result shall be reported as "Pass" or "Fail". The Maximum Daily Single Result shall be reported as "Pass or Fail" with a "% Effect". Exactly three independent toxicity tests are required when one toxicity test results in "Fail". The median of three testing results (Fail or Pass) will be used for the determination of compliance with the Median Monthly Effluent Limitation. Please refer to section V.A.7. of this MRP for the accelerated monitoring schedule.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Chlordane	µg/L	24-hour composite	quarterly	5
4,4-DDT	µg/L	24-hour composite	quarterly	5
4,4-DDE	µg/L	24-hour composite	quarterly	5
4,4-DDD	µg/L	24-hour composite	quarterly	5
Dieldrin	µg/L	24-hour composite	quarterly	5
Heptachlor epoxide	µg/L	24-hour composite	quarterly	5
PCBs as arochlors <sup>12</sup>	µg/L	24-hour composite	quarterly	5
PCBs as congeners <sup>13</sup>	µg/L	24-hour composite	semiannually	5, 13
Toxaphene	µg/L	24-hour composite	quarterly	5
Fluoride	mg/L	24-hour composite	semiannually	5
Iron	µg/L	24-hour composite	quarterly	5
Radioactivity (Including gross alpha, gross beta, combined radium-226 and radium-228, tritium, strontium-90 & uranium)	pCi/L	24-hour composite	semiannually	14
2,3,7,8-TCDD <sup>15</sup>	pg/L	24-hour composite	quarterly	5
Perchlorate	µg/L	Grab	annually	16

<sup>12</sup> PCBs is the sum of Aroclor 1016, Aroclor 1221, Aroclor 1232, Aroclor 1242, Aroclor 1248, Aroclor 1254, and Aroclor 1260 when monitoring using USEPA method 608.

<sup>13</sup> PCBs mean the sum of 41 congeners when monitoring using USEPA proposed method 1668c. PCB-18, 28, 37, 44, 49, 52, 66, 70, 74, 77, 81, 87, 99, 101, 105, 110, 114, 118, 119, 123, 126, 128, 138, 149, 151, 153, 156, 157, 158, 167, 168, 169, 170, 177, 180, 183, 187, 189, 194, 201, and 206 shall be individually quantified.

USEPA recommends that until USEPA proposed method 1668c for PCBs is incorporated into 40 CFR 136, Permittees should use for discharge monitoring reports/State monitoring reports: (1) USEPA method 608 for monitoring data, reported as arochlor results, that will be used for assessing compliance with WQBELs established using the WLAs, and (2) USEPA proposed method 1668c for monitoring data, reported as 41 congener results, that will be used for informational purposes for the established TMDL.

<sup>14</sup> Analyze these radiochemicals by the following USEPA methods: method 900.0 for gross alpha and gross beta, method 903.0 or 903.1 for radium-226, method 904.0 for radium-228, method 906.0 for tritium, method 905.0 for strontium-90, and method 908.0 for uranium. Analysis for combined radium-226 & 228 shall be conducted only if gross alpha results for the same sample exceed 15 pCi/L or beta greater than 50 pCi/L. If radium-226 & 228 exceeds the stipulated criteria, analyze for tritium, strontium-90 and uranium.

<sup>15</sup> In accordance with the SIP, the Discharger shall conduct effluent monitoring for the seventeen 2,3,7,8-tetrachlorodibenzo-p-dioxin (2,3,7,8-TCDD or dioxin) congeners in the effluent and in the receiving water Station RSW-001U, located upstream of the discharge point 001. The Discharger shall use the appropriate Toxicity Equivalence Factor (TEF) to determine Toxic Equivalence (TEQ). Where TEQ equals the product between each of the 17 individual congeners' (i) concentration analytical result (C<sub>i</sub>) and their corresponding Toxicity Equivalence Factor (TEF<sub>i</sub>), (i.e., TEQ<sub>i</sub> = C<sub>i</sub> × TEF<sub>i</sub>). Compliance with the dioxin limitation shall be determined by the summation of the seventeen individual TEQs, or the following equation:

$$\text{Dioxin concentration in effluent} = \sum_{i=1}^{17} (\text{TEQ}_i) = \sum_{i=1}^{17} (C_i) (\text{TEF}_i)$$

<sup>16</sup> Emerging chemicals include 1,4-dioxane (USEPA 8270M test method), perchlorate (USEPA 314 test method, or USEPA method 331 if a detection limit of less than 6 µg/L is achieved), 1,2,3-trichloropropane (USEPA

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
1,4-Dioxane	µg/L	Grab	annually	<sup>16</sup>
1,2,3-Trichloropropane	µg/L	Grab	annually	<sup>16</sup>
Methyl tert-butyl-ether (MTBE)	µg/L	Grab	annually	<sup>16</sup>
Remaining EPA priority pollutants <sup>17</sup> excluding asbestos	µg/L	24-hour composite; grab for VOCs	semiannually	<sup>5</sup>

**2. Total Residual Chlorine Additional Monitoring**

Continuous monitoring of total residual chlorine at the current location shall serve as an internal trigger for the increased grab sampling at EFF-001 if either of the following occurs, except as noted in item c:

- a. Total residual chlorine concentration excursions of up to 0.3 mg/L lasting greater than 15 minutes; or
- b. Total residual chlorine concentration peaks in excess of 0.3 mg/L lasting greater than 1 minute.
- c. Additional grab samples need not be taken if it can be demonstrated that a stoichiometrically appropriate amount of dechlorination chemical has been added to effectively dechlorinate the effluent to 0.1 mg/L or less for peaks in excess of 0.3 mg/L lasting more than 1 minute, but not for more than five minutes.

**3. Salts Dry- and Wet-Weather Monitoring and Reporting Requirements**

The Discharger shall determine the applicable wet- or dry-weather flow condition at RSW-003D and the amount of rainfall at the time of effluent sampling. The Discharger shall tabulate the date of sampling, average flow at RSW-003D, amount of rainfall, wet- or dry weather, applicable effluent limitation (wet- or dry-weather), and actual effluent concentration/mass.

**Table E-3b Salts Monitoring and Reporting Requirements**

Parameter	Date of Sampling	Flow (cfs)	Rainfall Amount (inches)	Wet or Dry Weather?	Applicable Effluent Limitation	Actual Effluent Concentration/ Mass
TDS (wet-weather)						
TDS (dry-weather)						
Sulfate (wet-weather)						

504.1, 8260B test method, or USEPA 524.2 in SIM mode), and methyl tert-butyl ether (USEPA 8260B test method or USEPA method 624 if a detection level of less than 5 µg/L is achieved, and if the Permittee received ELAP certification to run USEPA method 624).

<sup>17</sup> Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423.

Parameter	Date of Sampling	Flow (cfs)	Rainfall Amount (inches)	Wet or Dry Weather?	Applicable Effluent Limitation	Actual Effluent Concentration/ Mass
Sulfate (dry-weather)						
Chloride (wet-weather)						
Chloride (dry-weather)						
Boron (wet-weather)						
Boron (dry-weather)						

**4. Sediment Monitoring of Effluent at Monitoring Location EFF-001A and EFF-001B**

The Permittee must sample the discharge at the point following final treatment, prior to entering the receiving water. The exact location of the sampling point must be stipulated in the initial self-monitoring report. All samples shall be tested in accordance with USEPA or ASTM methodologies where such methods exist. Where no USEPA or ASTM methods exist, the State Water Board or Regional Water Board (collectively Water Boards) shall approve the use of other methods. Analytical tests shall be conducted by laboratories certified by the California Department of Public Health in accordance with Water Code Section 13176.

**Table E-3c. Effluent Monitoring**

Parameter	Units	Sample Type	Minimum Sampling Frequency
Mercury	mg/kg	Grab	1/Year *

\* Sediment Monitoring is only required during a reporting period if effluent water column monitoring results for both TSS and Mercury are exceeded. If monitoring is not triggered because both TSS and Mercury limits were not exceeded, then at a minimum, sediment monitoring must occur at least once during the five-year permit term.

**V. WHOLE EFFLUENT TOXICITY (WET) TESTING REQUIREMENTS**

**A. Chronic Toxicity**

**1. Discharge In-stream Waste Concentration (IWC) for Chronic Toxicity**

The chronic toxicity IWC for this discharge is 100 percent effluent.

**2. Sample Volume and Holding Time**

The total sample volume shall be determined by the specific toxicity test method used. Sufficient sample volume shall be collected to perform the required toxicity test. For the receiving water, sufficient sample volume shall also be collected for subsequent TIE studies, if necessary, at each sampling event. All toxicity tests shall be conducted as soon as possible following sample collection. No more than 36 hours shall elapse before the conclusion of sample collection and test initiation.

**3. Chronic Freshwater Species and Test Methods**

If effluent samples are collected from outfalls discharging to receiving waters with salinity <1 ppt, the Permittee shall conduct the following chronic toxicity tests on effluent samples at the in-stream waste concentration for the discharge in accordance with species and test methods in *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA/821/R-02/013, 2002; Table IA, 40 CFR part 136). In no case shall these species be substituted with another test species unless written authorization from the Executive Officer is received.

- a. A static renewal toxicity test with the fathead minnow, *Pimephales promelas* (Larval Survival and Growth Test Method 1000.0).
- b. A static renewal toxicity test with the daphnid, *Ceriodaphnia dubia* (Survival and Reproduction Test Method 1002.01).
- c. A static renewal toxicity test with the green alga, *Selenastrum capricornutum* (also named *Raphidocelis subcapitata*) (Growth Test Method 1003.0).

#### 4. Species Sensitivity Screening

Species sensitivity screening shall be conducted during this permit's first required sample collection. The Permittee shall collect a single effluent sample and concurrently conduct three toxicity tests using the fish, an invertebrate, and the alga species previously referenced. This sample shall also be analyzed for the parameters required for the discharge. The species that exhibits the highest "Percent Effect" at the discharge IWC during species sensitivity screening shall be used for routine monitoring during the permit cycle.

Species sensitivity rescreening is required every 24 months. The Permittee shall rescreen with the fish, an invertebrate, and the alga species previously referenced and continue to monitor with the most sensitive species. If the first suite of rescreening tests demonstrates that the same species is the most sensitive then the rescreening does not need to include more than one suite of tests. If a different species is the most sensitive or if there is ambiguity, then the Permittee shall proceed with suites of screening tests for a minimum of three, but not to exceed five suites.

#### 5. Quality Assurance and Additional Requirements

Quality assurance measures, instructions, and other recommendations and requirements are found in the test methods manual previously referenced. Additional requirements are specified below.

- a. The discharge is subject to determination of "Pass" or "Fail" and "Percent Effect" from a single-effluent concentration chronic toxicity test at the discharge IWC using the Test of Significant Toxicity (TST) approach described in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010), Appendix A, Figure A-1, and Table A-1. The null hypothesis ( $H_0$ ) for the TST approach is: Mean discharge IWC response  $\leq 0.75 \times$  Mean control response. A test result that rejects this null hypothesis is reported as "Pass". A test result that does not reject this null hypothesis is reported as "Fail". The relative "Percent Effect" at the discharge IWC is defined and reported as:  $((\text{Mean control response} - \text{Mean discharge IWC response}) \div \text{Mean control response}) \times 100$ .
- b. The Median Monthly Effluent Limit (MMEL) for chronic toxicity only applies when there is a discharge more than one day in a calendar month period. During such

calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail".

- c. If the effluent toxicity test does not meet all test acceptability criteria (TAC) specified in the referenced test method, then the Permittee must re-sample and re-test within 14 days.
- d. Dilution water and control water, including brine controls, shall be laboratory water prepared and used as specified in the test methods manual. If dilution water and control water is different from test organism culture water, then a second control using culture water shall also be used.
- e. Monthly reference toxicant testing is sufficient. All reference toxicant test results should be reviewed and reported.
- f. The Permittee shall perform toxicity tests on final effluent samples. Chlorine and ammonia shall not be removed from the effluent sample prior to toxicity testing, unless explicitly authorized under this section of the Monitoring and Reporting Program and the rationale is explained in the Fact Sheet (Attachment F).

**6. Preparation of an Initial Investigation TRE Work Plan**

The Permittee shall prepare and submit a copy of the Permittee's initial investigation TRE work plan to the Executive Officer of the Regional Water Board for approval within 90 days of the effective date of this permit. If the Executive Officer does not disapprove the work plan within 60 days, the work plan shall become effective. The Permittee shall use USEPA manual EPA/833B-99/002 (municipal) as guidance, or most current version. At a minimum, the TRE Work Plan must contain the provisions in Attachment G. This work plan shall describe the steps that the Permittee intends to follow if toxicity is detected. At minimum, the work plan shall include:

- a. A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
  - b. A description of the Facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in the operation of the Facility; and,
  - c. If a TIE is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor).
- 7. Accelerated Monitoring Schedule for Median Monthly Summary Result: "Fail" (or Maximum Daily Single Result: "Fail and % Effect  $\geq$ 50").**

The summary result shall be used when there is discharge more than one day in a calendar month. The single result shall be used when there is discharge of only one day in a calendar month.

Within 24 hours of the time the Permittee becomes aware of this result, the Permittee shall implement an accelerated monitoring schedule consisting of four, five-concentration toxicity tests (including the discharge IWC), conducted at approximately two week intervals, over an eight week period. If each of the accelerated toxicity tests results in "Pass", the Permittee shall return to routine monitoring for the next monitoring period. If one of the accelerated toxicity tests results in "Fail", the Permittee shall immediately implement the Toxicity Reduction Evaluation (TRE) Process conditions set forth below.

**8. Toxicity Reduction Evaluation (TRE) Process**

- a. **Preparation and Implementation of Detailed TRE Work Plan.** The Permittee shall immediately initiate a TRE using, according to the type of treatment facility, USEPA manual *Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants* (EPA/833/B-99/002, 1999) and, within 30 days, submit to the Executive Officer a Detailed TRE Work Plan, which shall follow the generic Initial Investigation TRE Work Plan revised as appropriate for this toxicity event. It shall include the following information, and comply with additional conditions set by the Executive Officer:
  - i. Further actions by the Permittee to investigate, identify, and correct the causes of toxicity.
  - ii. Actions the Permittee will take to mitigate the effects of the discharge and prevent the recurrence of toxicity.
  - iii. A schedule for these actions, progress reports, and the final report.
- b. **TIE Implementation.** The Permittee may initiate a TIE as part of a TRE to identify the causes of toxicity using the same species and test method and, as guidance, USEPA manuals: *Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures* (EPA/600/6-91/003, 1991); *Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA/600/R-92/080, 1993); *Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA/600/R-92/081, 1993); and *Marine Toxicity Identification Evaluation (TIE): Phase I Guidance Document* (EPA/600/R-96-054, 1996). The TIE should be conducted on the species demonstrating the most sensitive toxicity response.
- c. Many recommended TRE elements parallel required or recommended efforts for source control, pollution prevention, and storm water control programs. TRE efforts should be coordinated with such efforts. As toxic substances are identified or characterized, the Permittee shall continue the TRE by determining the sources and evaluating alternative strategies for reducing or eliminating the substances from the discharge. All reasonable steps shall be taken to reduce toxicity to levels consistent with toxicity evaluation parameters.
- d. The Permittee shall conduct routine effluent monitoring for the duration of the TRE process. Additional accelerated monitoring and TRE work plans are not required once a TRE is begun.
- e. The Regional Water Board recognizes that toxicity may be episodic and identification of causes and reduction of sources of toxicity may not be successful in all cases. The TRE may be ended at any stage if monitoring finds there is no longer toxicity.

9. Reporting

The Self-Monitoring Report (SMR) shall include a full laboratory report for each toxicity test. This report shall be prepared using the format and content of the test methods manual chapter called Report Preparation, including:

- a. The toxicity test results for the TST approach, reported as "Pass" or "Fail" and "Percent Effect" at the chronic toxicity IWC for the discharge.

- b. Water quality measurements for each toxicity test (e.g., pH, dissolved oxygen, temperature, conductivity, hardness, salinity, chlorine, ammonia).
- c. TRE/TIE results. The Executive Officer shall be notified no later than 30 days from completion of each aspect of TRE/TIE analyses.
- d. Statistical program (e.g., TST calculator, CETIS, etc.) output results for each toxicity test.

**B. Ammonia Removal**

1. Except with prior approval from the Executive Officer of the Regional Water Board, ammonia shall not be removed from bioassay samples. The Permittee must demonstrate the effluent toxicity is caused by ammonia because of increasing test pH when conducting the toxicity test. It is important to distinguish the potential toxic effects of ammonia from other pH sensitive chemicals, such as certain heavy metals, sulfide, and cyanide. The following may be steps to demonstrate that the toxicity is caused by ammonia and not other toxicants before the Executive Officer would allow for control of pH in the test.
  - a. There is consistent toxicity in the effluent and the maximum pH in the toxicity test is in the range to cause toxicity due to increased pH.
  - b. Chronic ammonia concentrations in the effluent are greater than 4 mg/L total ammonia.
  - c. Conduct graduated pH tests as specified in the toxicity identification evaluation methods. For example, mortality should be higher at pH 8 and lower at pH 6.
  - d. Treat the effluent with a zeolite column to remove ammonia. Mortality in the zeolite treated effluent should be lower than the non-zeolite treated effluent. Then add ammonia back to the zeolite-treated samples to confirm toxicity due to ammonia.
2. When it has been demonstrated that toxicity is due to ammonia because of increasing test pH, pH may be controlled using appropriate procedures which do not significantly alter the nature of the effluent, after submitting a written request to the Regional Water Board, and receiving written permission expressing approval from the Executive Officer of the Regional Water Board.

**C. Chlorine Removal**

Except with prior approval from the Executive Office of the Regional Water Board, chlorine shall not be removed from bioassay samples.

**VI. LAND DISCHARGE MONITORING REQUIREMENTS (NOT APPLICABLE)**

**VII. RECYCLING MONITORING REQUIREMENTS (NOT APPLICABLE)**

**VIII. RECEIVING WATER MONITORING REQUIREMENTS**

**A. Monitoring Locations RSW-001U and RSW-002D**

1. The Permittee shall monitor Conejo Creek at RSW-001U through RSW-002D as follows:

**Table E-4a. Receiving Water Monitoring Requirements**

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Total flow	cfs	calculation	monthly	--
Turbidity	NTU	Grab	monthly	18
Temperature	°F	Grab	monthly	18
pH	pH units	Grab	monthly	18
E.Coli	MPN/100ml or CFU/100ml	Grab	monthly	18
Total residual chlorine	mg/L	Grab	monthly <sup>19</sup>	18
Settleable Solids	mL/L	Grab	monthly	18
Total Suspended Solids	mg/L	Grab	monthly	18
BOD <sub>5</sub> 20°C	mg/L	Grab	monthly	18
Oil and grease	mg/L	Grab	quarterly	18
Dissolved oxygen	mg/L	Grab	monthly	18
Total Hardness (CaCO <sub>3</sub> )	mg/L	Grab	monthly <sup>20</sup>	18
Conductivity	µmho/cm	Grab	monthly	18
Total Dissolved Solids	mg/L	Grab	monthly	18
Sulfate	mg/L	Grab	monthly	18
Chloride	mg/L	Grab	monthly	18
Boron	mg/L	Grab	monthly	18
Chronic toxicity	Pass or Fail, % Effect	Grab	quarterly <sup>21</sup>	18
Nitrate nitrogen	mg/L	Grab	monthly	18
Nitrite nitrogen	mg/L	Grab	monthly	18
Ammonia nitrogen	mg/L	Grab	monthly	18
Organic nitrogen	mg/L	Grab	monthly	18
Total kjeldahl nitrogen (TKN)	mg/L	Grab	monthly	18
Total nitrogen	mg/L	Grab	monthly	18
Total phosphorus	mg/L	Grab	monthly	18
Orthophosphate-p	mg/L	Grab	monthly	18
Algal biomass (Chlorophyll a) <sup>22</sup>	mg/L	Grab	annually	18

<sup>18</sup> Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Board. For any pollutant whose effluent limitation is lower than all the MLs specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

<sup>19</sup> Total residual chlorine monitoring is applicable when chlorination process is in operation.

<sup>20</sup> Total hardness shall be sampled at station RSW-001U only.

<sup>21</sup> Chronic toxicity shall be sampled at stations RSW-001U and RSW-002D.

<sup>22</sup> Algal biomass or Chlorophyll a samples shall be collected by obtaining scrapings from the substrate, concurrently with pH, dissolved oxygen, and (macro)invertebrate monitoring. This will be a measure of benthic algae, rather than algae in the water column. Percent cover shall also be reported.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Surfactants (MBAS)	mg/L	Grab	quarterly	18
Surfactants (CTAS)	mg/L	Grab	quarterly	18
Arsenic	µg/L	Grab	quarterly	18
Copper	µg/L	Grab	monthly	18
Mercury	µg/L	Grab	monthly	18
Nickel	µg/L	Grab	monthly	18
Cyanide	µg/L	Grab	monthly	18
Bis(2-ethylhexyl)Phthalate	µg/L	Grab	monthly	18
Aldrin	µg/L	Grab	quarterly	18
Alpha-BHC	µg/L	Grab	quarterly	18
Heptachlor epoxide	µg/L	Grab	quarterly	18
Iron	µg/L	Grab	quarterly	18
Selenium	µg/L	Grab	semiannually	18
Chlorpyrifos	µg/L	Grab	quarterly	18
Diazinon	µg/L	Grab	quarterly	18
Chlordane	µg/L	Grab	quarterly	18
4,4'-DDD	µg/L	Grab	quarterly	18
4,4'-DDE	µg/L	Grab	quarterly	18
4,4'-DDT	µg/L	Grab	quarterly	18
Dieldrin	µg/L	Grab	quarterly	18
PCBs as arochlors <sup>23</sup>	µg/L	Grab	quarterly	18
PCBs as congeners <sup>24</sup>	µg/L	Grab	semiannually	18
Toxaphene	µg/L	Grab	quarterly	18
Antimony	µg/L	Grab	semiannually	18
Beryllium	µg/L	Grab	semiannually	18
Cadmium	µg/L	Grab	semiannually	18
Chromium, III	µg/L	calculation	semiannually	18
Chromium VI	µg/L	Grab	semiannually	18
Lead	µg/L	Grab	semiannually	18
Silver	µg/L	Grab	semiannually	18
Thallium	µg/L	Grab	semiannually	18
Zinc	µg/L	Grab	semiannually	18

<sup>23</sup> PCBs is the sum of Aroclor 1016, Aroclor 1221, Aroclor 1232, Aroclor 1242, Aroclor 1248, Aroclor 1254, and Aroclor 1260 when monitoring using USEPA method 608.

<sup>24</sup> PCBs mean the sum of 41 congeners when monitoring using USEPA proposed method 1668c. PCB-18, 28, 37, 44, 49, 52, 66, 70, 74, 77, 81, 87, 99, 101, 105, 110, 114, 118, 119, 123, 126, 128, 138, 149, 151, 153, 156, 157, 158, 167, 168, 169, 170, 177, 180, 183, 187, 189, 194, 201, and 206 shall be individually quantified.

USEPA recommends that until USEPA proposed method 1668c for PCBs is incorporated into 40 CFR 136, Permittees should use for discharge monitoring reports/State monitoring reports: (1) USEPA method 608 for monitoring data, reported as arochlors results, that will be used for assessing compliance with WQBELs established using the WLAs, and (2) USEPA proposed method 1668c for monitoring data, reported as 41 congener results, that will be used for informational purposes for the established TMDL.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Fluoride	mg/L	Grab	semiannually	18
Barium	µg/L	Grab	semiannually	18
Methoxychlor	µg/L	Grab	semiannually	18
2,3,7,8-TCDD <sup>25</sup>	pg/L	Grab	quarterly	18
1,4-Dioxane	µg/L	Grab	annually	26
Perchlorate	µg/L	Grab	annually	26
1,2,3-Trichloropropane	µg/L	Grab	annually	26
Methyl tert-butyl-ether (MTBE)	µg/L	Grab	annually	26
Remaining EPA priority pollutants <sup>27</sup> excluding asbestos	µg/L	grab	semiannually	18

2. Receiving water samples shall not be taken during or within 48-hours following the flow of rainwater runoff into the Conejo Creek unless it is safe to do so.

**B. TMDL Stream Flow and Rainfall Monitoring**

1. In order to determine the dry- and wet-weather flow conditions in the receiving water, the Permittee shall report the average daily flow at Calleguas Creek near the California State University Channel Islands. For the purposes of this permit, this station is also known as RSW-003D (USGS gauge 11106550). The Permittee shall also report the total daily rainfall from an existing rainfall gauging station located at the University of Channel Islands.

*Calleguas Creek Salts TMDL* has defined dry-weather as the condition in the receiving water when the flows in the receiving waters are below the 86th percentile of the flow and there is no measurable precipitation. The 86<sup>th</sup> percentile of the flow was given in the TMDL staff report. The rainfall precipitation shall be obtained from an existing rainfall gauging station located at the University of Channel Islands. If the gauging stations are not operational, an estimated average daily flow and rainfall may be submitted.

<sup>25</sup> In accordance with the SIP, the Discharger shall conduct effluent monitoring for the seventeen 2,3,7,8-tetrachlorodibenzo-p-dioxin (2,3,7,8-TCDD or dioxin) congeners in the effluent and in the receiving water Stations RSW-001U and RSW-002D. The Discharger shall use the appropriate TEF to determine TEQ. Where TEQ equals the product between each of the 17 individual congeners' (i) concentration analytical result (C<sub>i</sub>) and their corresponding TEF<sub>i</sub>, (i.e., TEQ<sub>i</sub> = C<sub>i</sub> x TEF<sub>i</sub>). Compliance with the dioxin limitation shall be determined by the summation of the seventeen individual TEQs, or the following equation:

$$\text{Dioxin concentration in effluent} = \sum_{i=1}^{17} (\text{TEQ}_i) = \sum_{i=1}^{17} (C_i)(\text{TEF}_i)$$

<sup>26</sup> Emerging chemicals include 1,4-dioxane (USEPA 8270M test method), perchlorate (USEPA 314 test method, or USEPA method 331 if a detection limit of less than 6 µg/L is achieved), 1,2,3-trichloropropane (USEPA 504.1, 8260B test method, or USEPA 524.2 in SIM mode), and methyl tert-butyl ether (USEPA 8260B test method or USEPA method 624 if a detection level of less than 5 µg/L is achieved, and if the Permittee received ELAP certification to run USEPA method 624).

<sup>27</sup> Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423.

**Table E-4b TMDL Stream Flow and Rainfall Monitoring Requirements**

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Average Daily Flow	cubic feet per second (cfs)	On-line data	daily	N/A
Total Daily Rainfall	inches	On-line data	daily	N/A

**IX. OTHER MONITORING REQUIREMENTS**

**A. Calleguas Creek TMDL Monitoring Requirements**

1. The TMDL monitoring program is discussed in section VI.C.2. of the Order.

**B. Special Study**

**1. CEC Monitoring in the Effluent**

In recent years, the Los Angeles Regional Water Board has incorporated monitoring of a select group of man-made chemicals, particularly pesticides, pharmaceuticals and personal care products, known collectively as CECs, into permits issued to publicly-owned treatment works (POTWs) to better understand the propensity, persistence and effects of CECs in our environment. Recently adopted permits in this region contain requirements for CEC effluent monitoring and submittal of a work plan identifying the CECs to be monitored in the effluent, sample type, sampling frequency and sampling methodology. Based on feedback we have received from permittees and our review of the results of a recent CEC-related study by the Southern California Coastal Water Research Project (SCCWRP) and the State Water Board, we have modified our CEC monitoring program to respond to feedback while proceeding to fill identified data gaps without overly burdening any one permittee.

The Permittee shall conduct a special study to investigate the CECs in the effluent discharge as listed in the Table below. These constituents shall be monitored annually for at least two years. The Regional Water Board has determined that two years is an appropriate time period to determine those CECs that are present in POTW effluent. Monitoring results shall be reported as part of the annual report. Analysis under this section is for monitoring purposes only. Analytical results obtained for this study will not be used for compliance determination purposes, since the methods have not been incorporated into 40 CFR part 136.

**Table E-5. CEC Monitoring Requirements**

Parameter	Unit	Reporting Limit	Sample Type	Analytical Method	Minimum Sampling Frequency
17 $\alpha$ -Ethinyl Estradiol	ng/L	0.5	24-hr composite	EDC Steroid	Annually
17 $\beta$ -Estradiol	ng/L	0.5	24-hr composite	EDC Steroid	Annually
Estrone	ng/L	0.5	24-hr composite	EDC Steroid	Annually
Bisphenol A	ng/L	10	24-hr composite	EDC Steroid	Annually

Parameter	Unit	Reporting Limit	Sample Type	Analytical Method	Minimum Sampling Frequency
Nonylphenol & Nonylphenol polyethoxylates	ng/L	100	24-hr composite	EDC Steroid	Annually
Octylphenol & octylphenol polyethoxylates	ng/L	100	24-hr composite	EDC Steroid	Annually
Polybrominated diphenyl ethers (PBDE 28, 47, 99, 100, 153, 154, 183, 209)	ng/L	100 for PBDE 209 and 5 for all others	24-hr composite	PBDEs	Annually
Amoxicillin	ng/L	10	24-hr composite	PPCPs	Annually
Azithromycin	ng/L	10	24-hr composite	PPCPs	Annually
Carbamazepine	ng/L	10	24-hr composite	PPCPs	Annually
Caffeine	ng/L	10	24-hr composite	PPCPs	Annually
N,N-Diethyl-m-toluamide (DEET)	ng/L	10	24-hr composite	PPCPs	Annually
Dilantin	ng/L	10	24-hr composite	PPCPs	Annually
Gemfibrozil	ng/L	10	24-hr composite	PPCPs	Annually
Ibuprofen	ng/L	10	24-hr composite	PPCPs	Annually
Iodinated contrast media (Iopromide)	ng/L	10	24-hr composite	PPCPs	Annually
Sulfamethoxazole	ng/L	10	24-hr composite	PPCPs	Annually
Trimethoprim	ng/L	10	24-hr composite	PPCPs	Annually
TCEP, TCPP and TDCPP	ng/L	10	24-hr composite	PPCPs	Annually
Triclosan	ng/L	10	24-hr composite	PPCPs	Annually
Bifenthrin	ng/L	2	24-hr composite	Pyrethroids	Annually
Permethrin	ng/L	5	24-hr composite	Pyrethroids	Annually
Chlorpyrifos	ng/L	10	24-hr composite	Chlorpyrifos	Annually
Galaxolide	ng/L	10	24-hr composite	Galaxolide	Annually
Diclofenac	ng/L	10	24-hr composite	PPCPs	Annually
Perfluorooctane Sulfonate (PFOS)	ng/L	40	24-hr composite	PFOS	Annually
Fipronil	ng/L	2	24-hr composite	Fipronil	Annually
Meprobamate	ng/L	10	24-hr composite	PPCPs	Annually

### C. Watershed Monitoring

- The goals of the Watershed-wide Monitoring Program for the Calleguas Creek Watershed are to:
  - Determine compliance with receiving water limits;
  - Monitor trends in surface water quality;

- Ensure protection of beneficial uses;
  - Provide data for modeling contaminants of concern;
  - Characterize water quality including seasonal variation of surface waters within the watershed;
  - Assess the health of the biological community; and
  - Determine mixing dynamics of effluent and receiving waters in the estuary.
2. The Permittee shall participate in the implementation of the Watershed-wide Monitoring Program developed by stakeholders and initiated in 2008. Camarillo's responsibilities under the Watershed-wide Monitoring Program are described in the Receiving Water Monitoring Requirements section. To achieve the goals of the Watershed-wide Monitoring Program, revisions to the Receiving Water Monitoring Requirements will be made under the direction of USEPA and the Regional Water Board. The Permittee shall submit annual reports providing the monitoring data collected during the calendar year, as well as an interpretation of the significance of the results with respect to the health of the watershed. Annual reports shall be submitted by July 1<sup>st</sup> of each year. The first annual report covering the period from January 1-December 31, 2014 should be received in the Regional Water Board office by July 1, 2015.
3. In coordination with interested stakeholders in the Calleguas Creek Watershed, the Permittee shall conduct bioassessment program annually in the spring/summer period and include an analysis of the community structure of the instream macroinvertebrate assemblages, the community structure of the instream algal assemblages (benthic diatoms and soft-bodied algae), chlorophyll a and biomass for instream algae, and physical habitat assessment at the random monitoring stations designated by the Calleguas Creek Watershed Monitoring Program.
- a. The bioassessment program shall include an analysis of the community structure of the instream macroinvertebrate assemblages and physical habitat assessment at monitoring stations RSW-001 and RSW-002.
- This program shall be implemented by appropriately trained staff. Alternatively, a professional subcontractor qualified to conduct bioassessments may be selected to perform the bioassessment work for the Permittee. Analyses of the results of the bioassessment monitoring program, along with photographs of the monitoring site locations taken during sample collection, shall be submitted in the corresponding annual report. If another stakeholder, or interested party in the watershed subcontracts a qualified professional to conduct bioassessment monitoring during the same season and at the same location as specified in the MRP, then the Permittee may, in lieu of duplicative sampling, submit the data, a report interpreting the data, photographs of the site, and related QA/QC documentation in the corresponding annual report.
- b. The Permittee must provide a copy of their Standard Operation Procedures (SOPs) for the Bioassessment Monitoring Program to the Regional Water Board upon request. The document must contain step-by-step field, laboratory and data entry procedures, as well as, related QA/QC procedures. The SOP must also include specific information about each bioassessment program including: assessment program description, its organization and the responsibilities of all its personnel; assessment project description and objectives; qualifications of all personnel; and the type of training each member has received.

- c. Field sampling must conform to the SOP established for the California Stream Bioassessment Procedure (CSBP) or more recently established sampling protocols, such as used by the Surface Water Ambient Monitoring Program (SWAMP). Field crews shall be trained on aspects of the protocol and appropriate safety issues. All field data and sample Chain of Custody (COC) forms must be examined for completion and gross errors. Field inspections shall be planned with random visits and shall be performed by the Permittee or an independent auditor. These visits shall report on all aspects of the field procedure with corrective action occurring immediately.
  - d. A taxonomic identification laboratory shall process the biological samples that usually consist of subsampling organisms, enumerating and identifying taxonomic groups and entering the information into an electronic format. The Regional Water Board may require QA/QC documents from the taxonomic laboratories and examine their records regularly. Intra-laboratory QA/QC for subsampling, taxonomic validation and corrective actions shall be conducted and documented. Biological laboratories shall also maintain reference collections, vouchered specimens (the Permittee may request the return of their sample voucher collections) and remnant collections. The laboratory should participate in an (external) laboratory taxonomic validation program at a recommended level of 10% or 20%. External QA/QC may be arranged through the California Department of Fish and Wildlife's Aquatic Bioassessment Laboratory located in Rancho Cordova, California.
4. The Executive Officer of the Regional Water Board may modify Monitoring and Reporting Program to accommodate the watershed-wide monitoring.

#### **D. Tertiary Filter Treatment Bypasses**

1. During any day that filters are bypassed, the Permittee shall monitor the effluent for BOD, suspended solids, and settleable solids, on daily basis, until it is demonstrated that the filter "bypass" has not caused an adverse impact on the receiving water.
2. The Permittee shall maintain chronological log of tertiary filter treatment process bypasses, to include the following:
  - a. Date and time of bypass start and end;
  - b. Total duration time; and,
  - c. Estimated total volume bypassed
3. The Permittee shall submit a written report to the Regional Water Board, according to the corresponding monthly self monitoring report schedule. The report shall include, at a minimum, the information from the chronological log. Results from the daily effluent monitoring, required by D.1. above, shall be verbally reported to the Regional Water Board as the results become available and submitted as part of the monthly SMR.

### **X. REPORTING REQUIREMENTS**

#### **A. General Monitoring and Reporting Requirements**

The Permittee shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.

1. The Permittee shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. If there is no discharge during any reporting period, the report shall so state.
3. Each monitoring report shall contain a separate section titled "Summary of Non-Compliance" which discusses the compliance record and the corrective actions taken or planned that may be needed to bring the discharge into full compliance with waste discharge requirements. This section shall clearly list all non-compliance with discharge requirements, as well as all excursions of effluent limitations.
4. The Permittee shall inform the Regional Water Board well in advance of any proposed construction activity that could potentially affect compliance with applicable requirements.

**B. Calleguas Creek TMDL Monitoring and Reporting Requirements**

The Calleguas Creek Watershed TMDL Monitoring Plan (CCWTMP) is designed to monitor and evaluate the implementation of this TMDL and refine the understanding of metal and selenium loads. CCWTMP is intended to parallel efforts of the Calleguas Creek Watershed Nutrients TMDL, Toxicity TMDL, and OC Pesticide, PCBs, and Sediment TMDL monitoring programs.

The goals of the CCWTMP include: (1) to determine compliance with copper, mercury, nickel, and selenium numeric targets at receiving water monitoring stations and at POTW's discharge; (2) to determine compliance with waste load allocations for copper, mercury, nickel, and selenium at receiving water monitoring stations and at POTW's discharge; (3) to monitor the effect of implementation action by urban, POTW, and agricultural dischargers on in-stream water quality; and (4) to implement the CCWTMP in a manner consistent with other TMDL implementation plans and regulatory actions within the Calleguas Creek watershed.

The Permittee shall submit reports to the Regional Water Board as required by the approved CCWTMP.

(See also section VI.C.2.a of the Order for Monitoring and Reporting Requirements.)

**C. Self-Monitoring Reports (SMRs)**

1. The Permittee shall electronically submit SMRs using the State Water Board's California Integrated Water Quality System (CIWQS) Program website (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS website will provide additional information for SMR submittal in the event there will be a planned service interruption for electronic submittal.
2. The Permittee shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Permittee shall submit monthly, quarterly, semiannual, and annual SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. SMRs are to include all new monitoring results obtained since the last SMR was submitted. If the Permittee monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

**Table E-6. Monitoring Periods and Reporting Schedule**

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	Submit with monthly SMR
Daily	Permit effective date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	Submit with monthly SMR
Weekly	Sunday following permit effective date or on permit effective date if on a Sunday	Sunday through Saturday	Submit with monthly SMR
Monthly	First day of calendar month following permit effective date or on permit effective date if that date is first day of the month	1 <sup>st</sup> day of calendar month through last day of calendar month	By the 15 <sup>th</sup> day of the third month after the month of sampling
Quarterly	Closest of February 1, May 1, August 1, or November 1 following (or on) permit effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31	June 15 September 15 December 15 March 15
Semiannually	Closest of February 1 or August 1 following (or on) permit effective date	January 1 through June 30 July 1 through December 31	September 15 March 15
Annually	January 1 following (or on) permit effective date	January 1 through December 31	April 15

4. Reporting Protocols. The Permittee shall report with each sample result the applicable RL and the current MDL, as determined by the procedure in 40 CFR part 136.

The Permittee shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ. The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy ( $\pm$  a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or "ND."
- d. Permittees are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Permittee

to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.

5. Compliance Determination. Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined above and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional Water Board and State Water Board, the Permittee shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the RL.
6. Multiple Sample Data. When determining compliance with an average monthly effluent limitation (AMEL), average weekly effluent limitation (AWEL), or maximum daily effluent limitation (MDEL) for priority pollutants and more than one sample result is available, the Permittee shall compute the arithmetic mean unless the data set contains one or more reported determinations of DNQ or ND. In those cases, the Permittee shall compute the median in place of the arithmetic mean in accordance with the following procedure:
  - a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
  - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.
7. The Permittee shall submit SMRs in accordance with the following requirements:
  - a. The Permittee shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the Facility is operating in compliance with interim and/or final effluent limitations. The Permittee is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Permittee shall electronically submit the data in a tabular format as an attachment.
  - b. The Permittee shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify instances of non-compliance or exceedances of effluent limitations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
  - c. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D). Paper SMRs should be converted to a Portable Document Format (PDF). Documents that are less than 10 megabytes (MB) should be emailed to [losangeles@waterboards.ca.gov](mailto:losangeles@waterboards.ca.gov). Documents that are 10 MB or larger should be transferred to a disk and mailed to the address listed below: (Reference the reports to Compliance File No. 1278 to facilitate routing to the appropriate staff and file.)

California Regional Water Quality Control Board  
320 West 4th Street, Suite 200  
Los Angeles, CA90013  
Attention: Information Technology Unit.

However, Permittees who have been certified to only submit electronic SMRs to CIWQS should continue doing so, as previously required.

**D. Discharge Monitoring Reports (DMRs)**

1. As described above, at any time during the term of this permit, the State Water Board or Regional Water Board may notify the Permittee to electronically submit DMRs. Until such notification is given specifically for the submittal of DMRs, the Permittee shall submit DMRs in accordance with the requirements described below.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Permittee shall submit the original DMR and one copy of the DMR to the address listed below:

STANDARD MAIL	FEDEX/UPS/ OTHER PRIVATE CARRIERS
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 <sup>th</sup> Floor Sacramento, CA 95814

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1) or on self-generated forms that follow the exact same format of EPA Form 3320-1.

**E. Other Reports**

1. The Permittee shall report the results of any special studies, acute and chronic toxicity testing, TRE/TIE, Pollutant Minimization Program (PMP), and Pollution Prevention Plan required by Special Provisions – section VI.C. The Permittee shall report the progress in satisfaction of compliance schedule dates specified in Special Provisions – VI.C.7. The Permittee shall submit reports in compliance with SMR reporting requirements described in subsection X.B above.

**2. Annual Summary Report**

By April 15 of each year, the Permittee shall submit an annual report containing a discussion of the previous year's influent/effluent analytical results and receiving water monitoring data. The annual report shall contain an overview of any plans for upgrades to the treatment plant's collection system, the treatment processes, or the outfall system. The Permittee shall submit annual report to the Regional Water Board in accordance with the requirements described in subsection X.B.7 above.

Each annual monitoring report shall contain a separate section titled "Reasonable Potential Analysis" which discusses whether or not reasonable potential was triggered for pollutants which do not have a final effluent limitation in the NPDES permit. This section shall contain the following statement: "The analytical results for this sampling period did/ did not trigger reasonable potential." If reasonable potential was triggered, then the following information should also be provided:

- a. A list of the pollutant(s) that triggered reasonable potential;
- b. The Basin Plan or CTR criteria that was exceeded for each given pollutant;
- c. The concentration of the pollutant(s);

- d. The test method used to analyze the sample; and,
  - e. The date and time of sample collection.
3. The Permittee shall submit to the Regional Water Board, together with the first monitoring report required by this permit, a list of all chemicals and proprietary additives which could affect this waste discharge, including quantities of each. Any subsequent changes in types and/or quantities shall be reported promptly.
  4. The Regional Water Board requires the Permittee to file with the Regional Water Board, within 90 days after the effective date of this Order, a technical report on his preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. The technical report should:
    - a. Identify the possible sources of accidental loss, untreated waste bypass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks, and pipes should be considered.
    - b. Evaluate the effectiveness of present facilities and procedures and state when they become operational.
    - c. Describe facilities and procedures needed for effective preventive and contingency plans.
    - d. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule contingent interim and final dates when they will be constructed, implemented, or operational.

**ATTACHMENT F – FACT SHEET**

**Contents**

I.	Permit Information.....	F-3
II.	Facility Description.....	F-5
	A. Description of Wastewater and Biosolids Treatment and Controls.....	F-5
	B. Discharge Points and Receiving Waters.....	F-6
	C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data.....	F-7
	D. Compliance Summary.....	F-11
	E. Planned Changes.....	F-12
III.	Applicable Plans, Policies, and Regulations.....	F-13
	A. Legal Authorities.....	F-13
	B. California Environmental Quality Act (CEQA).....	F-13
	C. State and Federal Laws, Regulations, Policies, and Plans.....	F-13
	D. Impaired Water Bodies on CWA 303(d) List.....	F-17
	E. Other Plans, Policies and Regulations.....	F-17
IV.	Rationale For Effluent Limitations and Discharge Specifications.....	F-21
	A. Discharge Prohibitions.....	F-21
	B. Technology-Based Effluent Limitations (TBELs).....	F-21
	1. Scope and Authority.....	F-21
	2. Applicable TBELs.....	F-22
	C. Water Quality-Based Effluent Limitations (WQBELs).....	F-22
	1. Scope and Authority.....	F-22
	2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	F-23
	3. Determining the Need for WQBELs.....	F-33
	4. WQBEL Calculations.....	F-37
	5. Whole Effluent Toxicity (WET).....	F-43
	D. Final Effluent Limitation Considerations.....	F-45
	1. Anti-Backsliding Requirements.....	F-45
	2. Antidegradation Policies.....	F-46
	3. Stringency of Requirements for Individual Pollutants.....	F-46
	E. Interim Effluent Limitations.....	F-51
	F. Land Discharge Specifications – Not Applicable.....	F-51
	G. Recycling Specifications.....	F-51
V.	Rationale for Receiving Water Limitations.....	F-51
	A. Surface Water.....	F-51
	B. Groundwater.....	F-51
VI.	Rationale for Provisions.....	F-52
	A. Standard Provisions.....	F-52
	B. Special Provisions.....	F-52
	1. Reopener Provisions.....	F-52
	2. Special Studies and Additional Monitoring Requirements.....	F-52
	3. Best Management Practices and Pollution Prevention.....	F-53
	4. Construction, Operation, and Maintenance Specifications.....	F-53
	5. Special Provisions for Municipal Facilities (POTWs Only).....	F-54
	6. Other Special Provisions (Not Applicable).....	F-55
	7. Compliance Schedules.....	F-55
VII.	Rationale for Monitoring and Reporting Requirements.....	F-55
	A. Influent Monitoring.....	F-56

B.	Effluent Monitoring .....	F-56
C.	WET Requirements .....	F-58
D.	Receiving Water Monitoring .....	F-59
	1. Surface Water .....	F-59
	2. Groundwater – (Not Applicable) .....	F-59
E.	Other Monitoring Requirements .....	F-59
	1. Watershed Monitoring and Bioassessment Monitoring .....	F-59
VIII.	Consideration of Need to Prevent Nuisance and California Water Code Section 13241 Factors .....	F-59
IX.	Public Participation .....	F-61
A.	Notification of Interested Parties .....	F-61
B.	Written Comments .....	F-61
C.	Public Hearing .....	F-61
D.	Reconsideration of Waste Discharge Requirements .....	F-62
E.	Information and Copying .....	F-62
F.	Register of Interested Persons .....	F-62
G.	Additional Information .....	F-62

**Tables**

Table F-1.	Facility Information .....	F-3
Table F-2.	Historic Effluent Limitations and Monitoring Data .....	F-7
Table F-4a.	Basin Plan Beneficial Uses – Receiving Waters .....	F-14
Table F-4b.	Basin Plan Beneficial Uses – Ground Waters .....	F-14
Table F-5.	Summary of TBELs .....	F-22
Table F-7.	Summary of Reasonable Potential Analysis .....	F-34
Table F-8.	Summary of WQBELs for Discharge Points 001A and 001B .....	F-41
Table F-9.	Summary of Final Effluent Limitations for Discharge Points 001A and 001B .....	F-47
Table F-10.	Interim Effluent Limitations for Discharge Point 001A and 001B .....	F-51
Table F-11.	Plant Performance Evaluation .....	F-55
Table F-12.	Compliance Schedule Milestone Dates .....	F-55
Table F-13.	Monitoring Frequency Comparison .....	F-56

**ATTACHMENT F – FACT SHEET**

As described in section I, the Regional Water Board incorporates this Fact Sheet as findings of the Regional Water Board supporting the issuance of this Order. This Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Permittees in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Permittee. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Permittee.

**I. PERMIT INFORMATION**

The following table summarizes administrative information related to the Facility.

**Table F-1. Facility Information**

WDID	4A560100001
Discharger/ Permittee	Camarillo Sanitary District
Name of Facility	Camarillo Water Reclamation Plant and its associated wastewater collection system and outfall, City of Camarillo
Facility Address	150 Howard Road
	Camarillo, CA 93012
	Ventura County
Facility Contact, Title and Phone	Mark Richardson, Sanitary Superintendent, (805) 383-5665
Authorized Person to Sign and Submit Reports	Tom Fox, Assistant District Manager, (805) 388-5355
Mailing Address	P.O. Box 248, Camarillo, CA 93011
Billing Address	Same as above
Type of Facility	POTW
Major or Minor Facility	Major
Threat to Water Quality	1
Complexity	A
Pretreatment Program	Y
Recycling Requirements	Producer/User
Facility Permitted Flow	7.25 million gallons per day (mgd)
Facility Design Flow	7.25 mgd
Watershed	Calleguas Creek Watershed
Receiving Water	Conejo Creek
Receiving Water Type	Inland surface water

- A. The Camarillo Sanitary District (Camarillo SD, Permittee or Discharger) owns and operates a publicly-owned treatment works (POTW) comprised of the Camarillo Water Reclamation Plant (Camarillo WRP or Facility) and its associated wastewater collection system and outfalls.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Permittee herein.

- B. The Facility discharges wastewater to Conejo Creek, a water of the United States. The Permittee was previously regulated by Order No. R4-2003-0079 (as revised by Order No. R4-2004-0121) and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0053597 adopted on June 5, 2003, and expired on May 10, 2008. Concurrent with adoption of Order No. R4-2003-0079, this Regional Water Board adopted Time Schedule Order (TSO) No. R4-2003-0080, which prescribed interim effluent limit for chloride. The terms and conditions of the current NPDES order have been automatically continued and remain in effect until new WDRs and NPDES permit are adopted pursuant to this Order. Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.
- C. On July 7, 2003, CSD filed a petition with the State Water Resources Control Board (State Water Board) seeking, in part, review of the chloride effluent limitations in Order No. R4-2003-0079 and TSO No. R4-2003-0080. CSD later requested that the State Water Board issue a stay of those limitations.
- D. On October 20, 2003, CSD, the City of Thousand Oaks, the City of Simi Valley and this Regional Water Board entered into a stipulation entitled *Stipulation for Further Order Issuing Stay*, which stayed the final chloride effluent limitations in the NPDES permits, as well as provisions pertaining to chloride limits in TSOs, for those three wastewater treatment plants. Specifically to the Camarillo WRP, the stipulation stayed the final chloride effluent limitations in Order No. R4-2003-0079 and the interim chloride effluent limitations in TSO No. R4-2003-0080. On November 19, 2003, the State Water Board adopted Order WQO 2003-0019 approving the stipulation.
- E. On April 2, 2007, the Executive Officer administratively issued TSO No. R4-2007-0010 to CSD for its Camarillo WRP. The TSO, which expired on January 31, 2011, contained performance-based interim effluent limitations for total dissolved solids and sulfate, calculated using the ninety-fifth percentile of the Camarillo WRP's effluent data from August 2003 through May 2006. An interim effluent limitation for chloride was not provided in TSO No. R4-2007-0010 because the State Water Board-stipulated stay for chloride remained in effect.
- F. On October 4, 2007, the Regional Water Board adopted Resolution No. R4-2007-016, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) for Calleguas Creek Watershed (Salts TMDL)*. The *Salts TMDL*, which became effective on December 2, 2008, contains interim and final WLAs for the Camarillo WRP, for TDS, Sulfate, Chloride, and Boron. The WLAs for chloride contained in the Regional Water Board's *Salts TMDL* superseded the WLAs for chloride contained in the 2002 USEPA-promulgated *Chloride TMDL*.
- G. The Permittee filed a report of waste discharge (ROWD) and submitted an application for reissuance of its Waste Discharge Requirements (WDRs) and NPDES permit on September 17, 2007. Supplemental information was requested on October 22, 2007, and received on November 8, 2007. A site visit was conducted on March 18, 2008, to observe operations and collect additional data to develop permit limitations and conditions. The application was deemed complete on November 8, 2007, so the NPDES permit was administratively extended. A follow-up inspection was conducted on January 20, 2011.
- H. On April 3, 2008, tentative waste discharge requirements prepared for the Camarillo WRP, and for other wastewater treatment plants in the Calleguas Creek watershed, were provided to interested persons and comments were solicited. However, Regional Water Board staff ultimately chose not to take those tentative waste discharge requirements to the Regional Water Board for consideration since, at that time, the State Water Board was in the process of developing a state-wide policy for chronic toxicity that could impact how the Regional Water

Board implements Resolution No. R4-2005-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Toxicity, Chlorpyrifos, and Diazinon in Calleguas Creek, its Tributaries, and Mugu Lagoon (Toxicity TMDL)*, in these waste discharge requirements. Although the State Water Board's policy/plan for chronic toxicity is still under development, the Regional Water Board is proceeding with the renewal of the NPDES permits for the dischargers in Calleguas Creek Watershed, based on direction received from the State Water Resources Control Board to reduce the NPDES backlog.

- I. The Permittee filed a ROWD and submitted an application for reissuance of its WDRs and NPDES permit on November 5, 2013. On December 5, 2013, Regional Water Board staff deemed the application incomplete and requested supplemental information. On December 18, 2013, the Permittee requested a two-week extension of the January 3, 2014 due date for submittal of the supplemental information. On December 19, 2013, Regional Water Board staff responded to the request letter and extended the deadline as requested by the Permittee. The supplemental information was received on January 16, 2014. The application was deemed complete on February 25, 2014, so the NPDES permit remains administratively extended. A site visit was conducted in March 2014, to observe operations and collect additional data to develop permit limitations and conditions.

## II. FACILITY DESCRIPTION

### A. Description of Wastewater and Biosolids Treatment and Controls

1. The Camarillo WRP is a tertiary wastewater treatment facility with a dry weather design capacity of 7.25 mgd. Untreated wastewater is collected from the City of Camarillo and an unincorporated section of Ventura County. Influent undergoes preliminary treatment through aerated grit removal and mechanical bar screening. Wastewater is then split into two streams, distributing one third of the flow to Plant 1 and two thirds of the flow to Plant 3. The wastewater undergoes primary clarification, nitrification and denitrification for biological nitrogen removal (BNR), secondary clarification, flow equalization, filtration, disinfection using sodium hypochlorite, dechlorination using sodium bisulfite.
2. The Facility serves an estimated population of 46,500 people. The wastewater is a mixture of domestic wastewater and industrial wastewater that is pre-treated pursuant to title 40 of the Code of Federal Regulations (40 CFR) part 403 under the City of Camarillo's Pretreatment Program, which was submitted to the Regional Water Board for approval on July 9, 1982. The City of Camarillo's pretreatment program currently consists of four permitted nondomestic dischargers. All four are classified as significant industrial users (SIUs) pursuant to 40 CFR 403.3(v) and as categorical industrial users (CIUs). One CIU is an electrical and electronic components/semiconductor facility subject to 40 CFR Part 469 Subpart A; one CIU is a metal finisher subject to 40 CFR 433; and the remaining two CIUs are metal molding and casting/aluminum casting facilities subject to 40 CFR Part 464, subpart A. Camarillo SD also has a fats, oils, and grease (FOG) program that was initiated in February 2008, under which food establishments are inspected every year. Camarillo WRP does not accept hauled waste.
3. The following are brief descriptions of the major unit processes, operations, and/or equipment:

**Grit removal and screening:** Grit is a wide assortment of inorganic solids such as pebbles, sand, silt, egg shells, glass, and metal fragments. Grit is removed by aeration.

Larger solids are mechanically removed by using bar screens. This material is collected and disposed of at a landfill.

**Primary clarification:** In the primary clarifiers, solids are settled out and returned to the anaerobic digesters for additional treatment. Primary-treated wastewater is sent to the BNR basins.

**Secondary Clarification:** Wastewater that has received primary clarification enters the activated sludge basins to undergo nitrogen removal using the Modified Ludzak-Ettinger (MLE) process. Wastewater that has undergone the nitrification/denitrification process is sent to the flow equalization basins. Secondary treated wastewater is sent to an equalization basin and is either stored for future treatment, or is sent to the filters.

**Equalization Basins:** Equalization basins allow for adjustments of flow to the filters throughout the day and during storm events. They help the system run closer to a steady state condition.

**Tertiary filtration:** The filtration process is used to remove or reduce suspended or colloidal matter from a liquid stream, by passing the water through AquaDisk tertiary cloth filters. In the case of Camarillo WRP, nylon needle felt is the filtration media. Filters remove the solids that the secondary sedimentation process did not remove, thereby improving the disinfection efficiency and reliability. The maximum loading rate for these filters is 6 gallons per minute per square foot. Filter backwash water is returned to the headworks for treatment.

**Chlorination:** Sodium hypochlorite is used as a disinfectant in the chlorine contact chamber. The disinfecting agent is added to the treated effluent to destroy bacteria, pathogens, and viruses, and to minimize algal growth.

**Dechlorination:** Prior to discharge to Conejo Creek, sodium bisulfite is added to the treated effluent to remove residual chlorine.

**Solids handling:** Grit and bar screenings are hauled off-site for disposal in a landfill. Sludge from secondary clarifiers is pumped either to the MLE process (return activated sludge), or to the aerobic digester for further treatment. Sludge from the drying beds is hauled away to an off-site composting facility.

## B. Discharge Points and Receiving Waters

Under normal conditions, treated wastewater is discharged by gravity flow from Discharge Point 001A to Conejo Creek, a water of the United States, and tributary to Calleguas Creek within Calleguas Creek Watershed. However, when the water level rises in the stream to the extent that discharge point 001A is partially or completely submerged (i.e., during heavy storm events), the final effluent is pumped to Conejo Creek, through Discharge Serial No. 001-B, located approximately 40 feet away from the Discharge Serial No. 001-A. Discharge Serial Points 001-A and 001-B have the same approximate coordinates: Latitude 34° 11' 40" North, Longitude 119° 00' 00" West.

During dry weather (May 1 – October 31), the primary sources of water flow in the receiving waters, downstream of the discharge point, are the Camarillo WRP effluent and other NPDES-permitted discharges, including urban runoff conveyed through the municipal separate storm sewer systems (MS4). Storm water and dry weather urban runoff from MS4

are regulated under an NPDES permit, Waste Discharge Requirements for Municipal Storm Water and Urban Runoff Discharges within the Ventura County Watershed Protection District (formerly known as Ventura County Flood Control District), County of Ventura (Ventura Municipal Permit, NPDES Permit No. CAS004002). The Ventura County Watershed Protection District channelized portions of Calleguas Creek to convey and control floodwater, and to prevent damage to homes located adjacent to the Creek. Calleguas Creek is a water of the United States that conveys floodwater and urban runoff, along with treated waste water. Conejo Creek is unlined at the point of discharge. Groundwater recharge may occur incidentally in these unlined areas of Conejo Creek, and Calleguas Creek, where the underlying sediments may be transmissive to water as well as pollutants. Notwithstanding that segments located further downstream of the discharge are concrete-lined, the watershed supports a diversity of wildlife. Threatened and endangered species such as the peregrine falcon, least tern, light-footed clapper rail, and the brown pelican are found in Calleguas Creek and Mugu Lagoon.

**C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data**

Effluent limitations contained in the existing Order for discharges from Discharge Point 001 (Monitoring Location EFF-001) and representative monitoring data from the term of the previous Order, as reported by the Permittee in the ROWD, are as follows:

**Table F-2. Historic Effluent Limitations and Monitoring Data**

Parameter	Units	Effluent Limitation (Order No. R4-2003-0079 (Amended by Order No. R4- 2004-0121))			Monitoring Data		
		Average Monthly	Ave. Weekly	Max. Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
BOD <sub>5</sub> 20°C	mg/L	20	30	45	2.68	--	4.2
Total Suspended Solids (TSS)	mg/L	15	40	45	2.19	--	3.60
Oil and Grease	mg/L	10	--	15	0	--	2.3
Settleable Solids	ml/L	0.1	--	0.3	<0.1	--	<0.1
Residual Chlorine	mg/L	--	--	0.1	0.00	--	0.00
Total Dissolved Solids	mg/L	850	--	--	1066	--	1170
MBAS	mg/L	0.5	--	--	0.03	--	0.05
CTAS					0.06		1.5
Chloride	mg/L	The State Water Board issued a Stay for the final effluent Chloride limitations.			193	--	300
Sulfate	mg/L	250	--	--	241	--	351
Boron	mg/L	1	--	--	0.58	--	0.82
Fluoride	mg/L	1.4	--	--	0.5	--	0.96
Organic nitrogen (as N)	mg/L	--	--	--	0.86	--	5.77
Nitrate + Nitrite as N	mg/L	10	--	--	5.26	--	7.41
Ammonia as N	mg/L	3.5			1.29	--	1.6
Total kjeldahl nitrogen (TKN)	mg/L				5.26	--	7.41
Ortho phosphate	mg/L				3.37		6.08

Parameter	Units	Effluent Limitation (Order No. R4-2003-0079 (Amended by Order No. R4- 2004-0121))			Monitoring Data		
		Average Monthly	Ave. Weekly	Max. Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Chlorophyll-a	mg/ cm <sup>2</sup>				2.43		18
Turbidity	NTU				0.8	--	8.2
Antimony	µg/L	6	--	--	0.26	--	0.55
Arsenic	µg/L	50	--	--	1.23	--	1.4
Beryllium	µg/L	--	--	--	<0.3	--	<2
Cadmium	µg/L	5	--	--	0.01	--	0.3
Chromium III	µg/L	--	--	--	--	--	--
Chromium VI	µg/L	50	--	--	0.29	--	0.35
Copper	µg/L	1000	--	--	4.8	--	4.8
Lead	µg/L	50	--	--	0.04	--	0.16
Mercury	µg/L	2	--	--	<0.04	--	<0.2
Nickel	µg/L	100	--	--	2.83	--	3
Selenium	µg/L	50	--	--	0.12	--	0.48
Silver	µg/L	50	--	--	0.01	--	0.02
Thallium	µg/L	--	--	--	0.08	--	0.2
Zinc	µg/L	5000	--	--	37.75	--	42
Cyanide	µg/L	3.9	--	9.4	<2	--	<10
Asbestos	µg/L	--	--	--	--	--	--
2,3,7,8-TCDD (Dioxin)	pg/L	--	--	--	< 0.000006	--	<0.000006
Acrolein	µg/L	--	--	--	ND	--	ND
Acrylonitrile	µg/L	--	--	--	< 1.7	--	<5
Benzene	µg/L	--	--	--	< 0.85	--	<5
Bromoform	µg/L	--	--	--	1.1	--	4.2
Carbon Tetrachloride	µg/L	--	--	--	< 0.68	--	<5
Chlorobenzene	µg/L	--	--	--	<0.7	--	<5
Dibromochloromethane	µg/L	--	--	--	6.5	--	24.6
Chloroethane	µg/L	--	--	--	< 0.97	--	< 5
2-chloroethyl vinyl ether	µg/L	--	--	--	<2.8	--	< 10
Chloroform	µg/L	--	--	--	0.13	--	13
Dichlorobromomethane	µg/L	--	--	--	8.9	--	29
1,1-dichloroethane	µg/L	--	--	--	<0.71	--	< 5
1,2-dichloroethane	µg/L	--	--	--	< 0.9	--	<5
1,1-dichloroethylene	µg/L	--	--	--	< 0.67	--	< 5
1,2-dichloropropane	µg/L	--	--	--	< 0.74	--	< 5
1,3-dichloropropylene	µg/L	--	--	--	< 0.97	--	< 5
Ethylbenzene	µg/L	--	--	--	< 0.56	--	< 5
Methyl bromide	µg/L	--	--	--	<1	--	<5
Methyl chloride	µg/L	--	--	--	<1.2	--	<5

Parameter	Units	Effluent Limitation (Order No. R4-2003-0079 (Amended by Order No. R4- 2004-0121))			Monitoring Data		
		Average Monthly	Ave. Weekly	Max. Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Methylene chloride	µg/L	--	--	--	0.04	--	0.17
1,1,2,2-tetrachloroethane	µg/L	--	--	--	< 0.88	--	< 5
Tetrachloroethylene	µg/L	5	--	--	0.3	--	1.2
Toluene	µg/L	--	--	--	< 0.75	--	< 5
Trans 1,2-Dichloroethylene	µg/L	--	--	--	< 0.73	--	< 5
1,1,1-Trichloroethane	µg/L	--	--	--	< 5	--	< 6.4
1,1,2-Trichloroethane	µg/L	--	--	--	< 0.71	--	< 5
Trichloroethylene	µg/L	--	--	--	< 1	--	< 5
Vinyl Chloride	µg/L	--	--	--	< 0.74	--	< 5
2-chlorophenol	µg/L	--	--	--	< 0.53	--	< 4.8
2,4-dichlorophenol	µg/L	--	--	--	< 0.47	--	< 4.8
2,4-dimethylphenol	µg/L	--	--	--	< 0.87	--	< 9.6
4,6-dinitro-o-resol(aka 2-methyl-4,6-Dinitrophenol)	µg/L	--	--	--	< 3.9	--	< 20
2,4-dinitrophenol	µg/L	--	--	--	< 32	--	< 48
2-nitrophenol	µg/L	--	--	--	< 0.48	--	< 48
4-nitrophenol	µg/L	--	--	--	< 13	--	< 48
3-Methyl-4-Chlorophenol (aka 4-chloro- <i>m</i> -cresol)	µg/L	--	--	--	< 0.4	--	< 4.8
Pentachlorophenol	µg/L	--	--	--	< 0.94	--	< 29
Phenol	µg/L	--	--	--	< 0.43	--	< 4.8
2,4,6-trichlorophenol	µg/L	--	--	--	< 0.49	--	< 4.8
Acenaphthene	µg/L	--	--	--	< 0.44	--	< 4.8
Acenaphthylene	µg/L	--	--	--	< 0.42	--	< 4.8
Anthracene	µg/L	--	--	--	< 0.28	--	< 4.8
Benzidine	µg/L	--	--	--	< 18	--	< 96
Benzo(a)Anthracene	µg/L	--	--	--	< 0.32	--	< 4.8
Benzo(a)Pyrene	µg/L	--	--	--	< 0.3	--	< 4.8
Benzo(b)Fluoranthene	µg/L	--	--	--	< 0.31	--	< 4.8
Benzo(ghi)Perylene	µg/L	--	--	--	< 0.34	--	< 4.8
Benzo(k)Fluoranthene	µg/L	--	--	--	< 0.29	--	< 4.8
Bis(2-Chloroethoxy) methane	µg/L	--	--	--	< 0.47	--	< 4.8
Bis(2-Chloroethyl)Ether	µg/L	--	--	--	< 0.48	--	< 4.8
Bis(2-Chloroisopropyl) Ether	µg/L	--	--	--	< 0.5	--	< 4.8

Parameter	Units	Effluent Limitation (Order No. R4-2003-0079 (Amended by Order No. R4- 2004-0121))			Monitoring Data		
		Average Monthly	Ave. Weekly	Max. Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Bis(2-Ethylhexyl) Phthalate	µg/L	4	--	--	1.48	--	5.9
4-Bromophenyl Phenyl Ether	µg/L	--	--	--	< 0.42	--	< 4.8
Butylbenzyl Phthalate	µg/L	--	--	--	< 0.22	--	< 4.8
2-Chloronaphthalene	µg/L	--	--	--	< 0.50	--	< 4.8
4-Chlorophenyl Phenyl Ether	µg/L	--	--	--	< 0.45	--	< 4.8
Chrysene	µg/L	--	--	--	< 0.34	--	< 4.8
Dibenzo(a,h) Anthracene	µg/L	--	--	--	< 0.40	--	< 4.8
1,2-Dichlorobenzene	µg/L	--	--	--	< 0.52	--	< 4.8
1,3-Dichlorobenzene	µg/L	--	--	--	< 0.5	--	< 4.8
1,4-Dichlorobenzene	µg/L	5	--	--	< 0.53	--	< 4.8
3,3'-Dichlorobenzidine	µg/L	--	--	--	<0.099	--	< 20
Diethyl Phthalate	µg/L	--	--	--	< 0.45	--	< 4.8
Dimethyl Phthalate	µg/L	--	--	--	< 0.78	--	< 4.8
Di-n-Butyl Phthalate	µg/L	--	--	--	< 0.32	--	< 4.8
2,4-Dinitrotoluene	µg/L	--	--	--	< 0.35	--	< 4.8
2,6-Dinitrotoluene	µg/L	--	--	--	< 0.34	--	< 4.8
Di-n-Octyl Phthalate	µg/L	--	--	--	< 0.92	--	< 4.8
1,2-Diphenylhydrazine	µg/L	--	--	--	< 0.42	--	< 4.8
Fluoranthene	µg/L	--	--	--	< 0.34	--	< 4.8
Fluorene	µg/L	--	--	--	< 0.38	--	< 4.8
Hexachlorobenzene	µg/L	--	--	--	< 0.36	--	< 4.8
Hexachlorobutadiene	µg/L	--	--	--	< 0.6	--	< 4.8
Hexachlorocyclopentadiene	µg/L	--	--	--	< 0.38	--	< 4.8
Hexachloroethane	µg/L	--	--	--	< 0.5	--	< 4.8
Indeno(1,2,3-cd)Pyrene	µg/L	--	--	--	< 0.32	--	< 4.8
Isophorone	µg/L	--	--	--	< 0.46	--	< 4.8
Naphthalene	µg/L	--	--	--	< 0.46	--	< 4.8
Nitrobenzene	µg/L	--	--	--	< 0.72	--	< 4.8
N-Nitrosodimethylamine	µg/L	--	--	--	< 0.48	--	< 4.8
N-Nitrosodi-n-Propylamine	µg/L	--	--	--	< 0.43	--	< 4.8
N-Nitrosodiphenylamine	µg/L	--	--	--	< 0.35	--	< 4.8
Phenanthrene	µg/L	--	--	--	< 0.32	--	< 4.8
Pyrene	µg/L	--	--	--	< 0.48	--	< 4.8
1,2,4-Trichlorobenzene	µg/L	--	--	--	< 0.52	--	< 4.8

Parameter	Units	Effluent Limitation (Order No. R4-2003-0079 (Amended by Order No. R4- 2004-0121))			Monitoring Data		
		Average Monthly	Ave. Weekly	Max. Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Aldrin	µg/L	--	--	--	< 0.0015	--	< 0.0050
Alpha-BHC	µg/L	--	--	--	< 0.0018	--	< 0.01
Beta-BHC	µg/L	--	--	--	< 0.0031	--	< 0.0050
Gamma-BHC (aka Lindane)	µg/L	0.2	--	--	0.00392	--	0.00392
delta-BHC	µg/L	--	--	--	< 0.0021	--	< 0.02
Chlordane	µg/L	0.1	--	--	< 0.01	--	< 0.08
4,4'-DDT	µg/L	--	--	--	< 0.0031	--	< 0.01
4,4'-DDE	µg/L	0.00059	--	0.0012--	<0.0025	--	<0.05
4,4'-DDD	µg/L	0.00084	--	0.0017	< 0.003	--	< 0.05
Dieldrin	µg/L	--	--	--	<0.0021	--	< 0.01
Alpha-Endosulfan	µg/L	--	--	--	< 0.0017	--	< 0.02
Beta-Endosulfan	µg/L	--	--	--	< 0.0019	--	< 0.01
Endosulfan Sulfate	µg/L	--	--	--	< 0.1	--	< 0.1
Endrin	µg/L	2	--	--	<0.0028	--	<0.01
Endrin Aldehyde	µg/L	--	--	--	< 0.003	--	< 0.01
Heptachlor	µg/L	--	--	--	< 0.0017	--	< 0.01
Heptachlor Epoxide	µg/L	--	--	--	<0.0019	--	<0.01
PCB 1016	µg/L	--	--	--	< 0.05	--	< 0.5
PCB 1221	µg/L	--	--	--	< 0.06	--	< 0.5
PCB 1232	µg/L	--	--	--	< 0.15	--	< 0.5
PCB 1242	µg/L	--	--	--	< 0.07	--	< 0.5
PCB 1248	µg/L	--	--	--	< 0.06	--	< 0.5
PCB 1254	µg/L	0.00017	--	--	< 0.04	--	< 0.5
PCB 1260	µg/L	--	--	--	< 0.04	--	< 0.5
Toxaphene	µg/L	3	--	--	<0.12	--	<0.5
Barium	µg/L	1000	--	--	24.5	--	29
Iron	µg/L	300	--	--	8	--	32
Total trihalomethanes	µg/L	80	--	--	65.2	--	14.7
Methoxychlor	µg/L	40	--	--	<0.0047	--	<0.01
2,4,-D	µg/L	70	--	--	<0.05	--	<2
2,4,5-TP (Silvex)	µg/L	50	--	--	<0.02	--	<1

**D. Compliance Summary**

Prior to the July 14, 2011, adoption of Time Schedule Order (TSO) No. R4-2011-0126, Regional Water Board staff issued enforcement actions in response to violations of the NPDES permit Order No. R4-2003-0079, for the Camarillo WRP, as discussed below.

- On July 1, 2005, the Executive Officer issued Camarillo SD a Notice of Violation (NOV) for violating effluent limitations contained in Board Order No. R4-2003-0079.

- On October 23, 2008, the Regional Water Board issued Expedited Payment Letter (EPL) No. R4-2008-0068-M for the following ninety (90) effluent limitation violations, all which are subject to Mandatory Minimum Penalties (MMPs) in the amount of \$252,000.
- On November 30, 2010, the Regional Water Board issued EPL No. R4-2010-0192-M for the following fifty-six (56) effluent limitation violations, all which are subject to MMPs in the amount of \$168,000.

The Regional Water Board Prosecution Team reached a settlement agreement regarding past violations of final effluent limitations in the NPDES permit. Camarillo SD proposes to do a Supplemental Environmental Project (SEP) as part of the settlement.

On January 30, 2014, the Regional Water Board issued a Notice of Violation for failure to complete the supplemental environmental project under settlement agreement and stipulation for entry of Order No. R4-2012-0138-M. On June 19, 2013, Camarillo SD had submitted a formal request to modify the Stipulated Order, to reduce the number of groundwater monitoring wells to be developed from three to one, because the actual cost of the SEP exceeded the estimated budget of \$469,500 provided by Camarillo SD. However, Regional Water Board denied the request because the proposed modification does not satisfy the requirement of the *SEP Policy*. Full payment of the remaining assessed amount of \$413,935.42 was received on February 26, 2014.

Camarillo SD has had various TSOs. However, from the effective date of TSO No. R4-2011-0126, until the present, Camarillo SD has been able to comply with the following provisions of the TSO:

1. Meet the interim effluent limitations for total dissolved solids (TDS) and sulfate;
2. Submit a for Pollution Prevention Plan work plan; and
3. Submit quarterly updates regarding the progress made.

Camarillo SD proposes to do one or more of the following: decrease the amount of water discharged to surface water by discharging to the regional salinity management pipeline (also referred to as the brine line); increase the amount of recycled water provided to customers; and/or, reduce the salt content of their potable water supply by treating it with reverse osmosis.

While the Permittee continues making progress towards achieving compliance with the final effluent limitations for TDS and sulfate, an additional year is needed to address issues raised during the CEQA process. Therefore, the compliance schedule and milestone dates in TSO No. R4-2011-0126 were amended on September 12, 2013, to accommodate Camarillo SD's request. TSO No. R4-2011-0126-A01 may be amended to include performance-based interim limits for chloride.

#### E. Planned Changes

The Camarillo WRP's treatment system was upgraded in February 2007 to include filtration as a new process. As such, the facility is now considered a tertiary POTW. The facility has also undergone changes with respect to nitrogen removal, in order to comply with the *Nutrient TMDL for Calleguas Creek Watershed*. In the future, the facility plans on eliminating its surface water discharge from Discharge Points 001A & 001B, by expanding its recycled water program and by connecting to the brine line.

### III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the requirements and authorities described in this section.

#### A. Legal Authorities

This Order serves as WDRs pursuant to article 4, chapter 4, division 7 of the California Water Code (CWC; commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the United States Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the CWC (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this Facility to surface waters.

#### B. California Environmental Quality Act (CEQA)

Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of Chapter 3 of CEQA, (commencing with section 21100) of Division 13 of the Public Resources Code.

#### C. State and Federal Laws, Regulations, Policies, and Plans

- 1. Water Quality Control Plan.** The Regional Water Board adopted a Water Quality Control Plan for the Los Angeles Region (Basin Plan) on June 4, 1994 that designates beneficial uses, establishes water quality objectives (WQOs), and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Requirements in this Order implement the Basin Plan. In addition, the Basin Plan implements State Water Board Resolution 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. On May 26, 2000, the USEPA approved the revised Basin Plan except for the implementation plan for potential MUN-designated water bodies. On August 22, 2000, the City of Los Angeles, City of Burbank, City of Simi Valley, and the County Sanitation Districts of Los Angeles County challenged USEPA's water quality standards action in the U.S. District Court. On December 18, 2001, the court issued an order remanding the matter to USEPA to take further action on the 1994 Basin Plan consistent with the court's decision. On February 15, 2002, USEPA revised its decision and approved the 1994 Basin Plan in whole. In its February 15, 2002 letter, USEPA stated:

EPA bases its approval on the court's finding that the Regional Board's identification of waters with an asterisk ("\*") in conjunction with the implementation language at page 2-4 of the 1994 Basin Plan, was intended "to only conditionally designate and not finally designate as MUN those water bodies identified by an (\*) for the MUN use in Table 2-1 of the Basin Plan, without further action." Court Order at p. 4. Thus, the waters identified with an (\*) in Table 2-1 do not have MUN as a designated use until such time as the State undertakes additional study and modifies its Basin Plan. Because this conditional use designation has no legal effect, it does not constitute a new water quality standard subject to EPA review under section 303(c)(3) of the Clean Water Act ("CWA"). 33 U.S.C. § 1313(c)(3).

USEPA's decision has no effect on the MUN designations of groundwater.

Beneficial uses applicable to Conejo Creek are as follows:

**Table F-4a. Basin Plan Beneficial Uses – Receiving Waters**

Hydrologic Unit Code (HUC)	Receiving Water Name	Beneficial Use(s)
180701030105 (formerly Calwater Hydro Unit 403.12)	Calleguas Creek Reach 9B (formerly Conejo Creek)	<u>Existing:</u> industrial service supply (IND), industrial process supply (PROC), agricultural supply (AGR), ground water recharge (GWR), contact (REC-1) and non-contact water recreation (REC-2), warm freshwater habitat (WARM), and wildlife habitat (WILD);  <u>Potential:</u> Municipal and domestic water supply (MUN <sup>1</sup> ).
180701030107 (formerly Calwater Hydro Unit 403.12)	Calleguas Creek Reach 3	<u>Existing:</u> IND, PROC, AGR, GWR, REC-1, REC-2, WARM, and WILD;  <u>Potential:</u> MUN <sup>1</sup> .
180701030107 (formerly Calwater Hydro Unit 403.11)	Calleguas Creek Reach 2	<u>Existing:</u> AG, GWR, freshwater replenishment (FRSH), REC-1, REC-2, WARM, cold freshwater habitat (COLD), WILD, rare, threatened, or endangered species (RARE), and wetland habitat (WET);  <u>Potential:</u> MUN <sup>1</sup> .
180701030107 (formerly Calwater Hydro Unit 403.11)	Calleguas Creek Reach 1 (formerly Mugu Lagoon)	<u>Existing:</u> NAV, REC-2, COMM, EST, marine habitat (MAR), WILD, preservation of biological habitats (BIOL), RARE, MIGR, shellfish harvesting (SHELL), and WET.  <u>Potential:</u> REC-1;

Beneficial uses of the receiving ground waters are as follows:

**Table F-4b. Basin Plan Beneficial Uses – Ground Waters**

Department of Water Resources (DWR) Basin	Receiving Water Name	Beneficial Use(s)				
		MUN	IND	PROC	AGR	AQUA
4-6	Pleasant Valley					
	Confined Aquifer	existing	existing	existing	existing	
	Unconfined Aquifer	potential	existing	existing	existing	
4-4.02	Oxnard					
	Confined Aquifer	existing	existing	existing	existing	
	Unconfined Aquifer	existing	potential		existing	
	Oxnard Forebay	existing	existing	existing	existing	

- National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the

<sup>1</sup> The potential municipal and domestic supply (p\*MUN) beneficial use for the waterbody is consistent with the State Water Resources Control Board Resolution 88-63 and Regional Water Board Resolution No. 89-003; however, the Regional Water Board has only conditionally designated the MUN beneficial use of the surface water and at this time cannot establish effluent limitations designed to protect the conditional designation.

state. The CTR was amended on February 13, 2001. These rules contain federal water quality criteria for priority pollutants.

3. **State Implementation Policy (SIP).** On March 2, 2000, the State Water Board adopted the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
4. **Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards become effective for CWA purposes (40 CFR § 131.21, 65 Federal Register 24641 (April 27, 2000)). Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
5. **Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based effluent limitations (TBELs) and water quality-based effluent limitations (WQBELs) for individual pollutants. The TBELs consist of restrictions on BOD, TSS, oil and grease, settleable solids, turbidity, pH, and percent removal of BOD and TSS. Restrictions on BOD, TSS, oil and grease, settleable solids, turbidity, and pH are discussed in section IV.B.2 of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements that are carried over from the previous permit.  
  
WQBELs have been scientifically derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal water quality standards. All beneficial uses and WQOs contained in the Basin Plan and the Ocean Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 CFR § 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.
6. **Antidegradation Policies.** Federal regulation 40 CFR § 131.12 requires that state water quality standards include an antidegradation policy consistent with the federal antidegradation policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16 ("Statement of Policy with Respect to Maintaining the Quality of the Waters of the State"). Resolution 68-16 is deemed to incorporate the federal antidegradation policy where the federal policy applies under federal law. Resolution 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal

antidegradation policies. The discharges permitted in this Order are consistent with the antidegradation provisions of 40 CFR § 131.12 and State Water Board Resolution 68-16.

7. **Anti-Backsliding Requirements.** Sections 402(o) and 303(d)(4) of the CWA and federal regulations at 40 CFR § 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.
8. **Endangered Species Act (ESA) Requirements.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California ESA (Fish and Game Code, sections 2050 to 2097) or the Federal ESA (16 USC sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The Permittee is responsible for meeting all requirements of the applicable ESA.
9. **Water Rights.** Prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a surface or subterranean stream, the Permittee must file a petition with the State Water Board (State Water Board), Division of Water Rights, and receive approval for such a change. The State Water Board retains the jurisdictional authority to enforce such requirements under CWC section 1211.
10. **Domestic Water Quality.** It is the policy of the State of California that every human being has the right to safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes. This order promotes that policy by requiring discharges to meet maximum contaminant levels developed to protect human health and ensure that water is safe for domestic use.
11. **Water Recycling** - In accordance with statewide policies concerning water reclamation<sup>2</sup>, this Regional Water Board strongly encourages, wherever practical, water recycling, water conservation, and use of storm water and dry-weather urban runoff. The Permittee shall investigate the feasibility of recycling, conservation, and/or alternative disposal methods of wastewater (such as groundwater injection), and/or use of storm water and dry-weather urban runoff. Camarillo Sanitary District has a project under design which will dramatically expand its future recycled water delivery from the Camarillo WRP. The project would entail delivering recycled water to a 40-acre recreational park and to nearby farming operations. The project is scheduled for completion by December 31, 2015. Its goal is to recycle 100% of Camarillo WRP's effluent. The Permittee shall submit a report summarizing its plans for recycled water expansion efforts to the Regional Water Board 180 days after the effective date of this Order and a separate report 30 days after completion of a major project.
12. **Monitoring and Reporting.** 40 CFR § 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP) establishes monitoring and reporting requirements to implement federal and state requirements. This MRP is provided in Attachment E.

<sup>2</sup> See, e.g., CWC sections 13000 and 13550-13557, State Water Board Resolution No. 77-1 (Policy with Respect to Water Reclamation in California), and State Water Board Resolution No. 2009-0011 (Recycled Water Policy).

- 13. Sewage Sludge/Biosolids Requirements.** Section 405 of the CWA and implementing regulations at 40 CFR part 503 require that producers of sewage sludge/biosolids meet certain reporting, handling, and use or disposal requirements. The state has not been delegated the authority to implement this program; therefore, USEPA is the implementing agency. This Order contains sewage sludge/biosolids requirements pursuant to 40 CFR part 503 that are applicable to the Permittee.

**D. Impaired Water Bodies on CWA 303(d) List**

The State Water Board proposed the California 2008-2010 Integrated Report from a compilation of the adopted Regional Water Boards' Integrated Reports containing 303(d) List of Impaired Waters and 305(b) Reports following recommendations from the Regional Water Boards and information solicited from the public and other interested parties. The Regional Water Boards' Integrated Reports were used to revise their 2006 303(d) List. On August 4, 2010, the State Water Board adopted the California 2008-2010 Integrated Report. On November 12, 2010, the USEPA approved California 2008-2010 Integrated Report Section 303(d) List of Impaired Waters requiring Total Maximum Daily Loads (TMDL) for the Los Angeles Region. The 303(d) List can be viewed at the following link:

[http://www.waterboards.ca.gov/water\\_issues/programs/tmdl/integrated2010.shtml](http://www.waterboards.ca.gov/water_issues/programs/tmdl/integrated2010.shtml)

Conejo Creek and Calleguas Creek Estuary are in the California 2008-2010 Integrated Report. The following are the identified pollutants impacting the receiving water:

Calleguas Creek Reach 9A (was lower part of Conejo Creek Reach 1 on 1998 303(d) list)

Pollutants: ChemA (tissue), chlordane (tissue), chlorpyrifos, DDT, diazinon, dieldrin (tissue), endosulfan (tissue), fecal coliform, lindane, nitrate as nitrogen, nitrogen nitrate, polychlorinated biphenyls (PCBs), sulfates, TDS, toxaphene, toxicity, and trash.

Calleguas Creek Reach 3 (Potrero Road upstream to confluence with Conejo Creek on 1998 303(d) List) - Calwater Watershed 40312000

Pollutants: Ammonia, chlordane, chloride, DDT, dieldrin, nitrate and nitrite, polychlorinated biphenyls (PCBs), sedimentation/siltation, total dissolved solids, toxaphene, and trash.

Calleguas Creek Reach 2 (Estuary to Potrero Road - was Calleguas Creek Reaches 1 and 2 on 1998 303(d) List) - Calwater Watershed 40312000

Pollutants: Ammonia, chemA (tissue), chlordane (tissue), dissolved copper, DDT, dieldrin, endosulfan (tissue), fecal coliform, nitrogen, PCBs (tissue), sediment toxicity, sedimentation/siltation, toxaphene (tissue and sediment), and trash.

**E. Other Plans, Policies and Regulations**

1. Sources of Drinking Water Policy. On May 19, 1988, the State Water Board adopted Resolution No. 88-63, Sources of Drinking Water (SODW) Policy, which established a policy that all surface and ground waters, with limited exemptions, are suitable or potentially suitable for municipal and domestic supply. To be consistent with State Water Board's SODW Policy, on March 27, 1989, the Regional Water Board adopted Resolution No. 89-03, Incorporation of Sources of Drinking Water Policy into the Water Quality Control Plans (Basin Plans) – Santa Clara River Basin (4A)/ Los Angeles River Basin (4B).

Consistent with Regional Water Board Resolution No. 89-03 and State Water Board Resolution No. 88-63, in 1994 the Regional Water Board conditionally designated all

inland surface waters in Table 2-1 of the 1994 Basin Plan as existing, intermittent, or potential for Municipal and Domestic Supply (MUN). However, the conditional designation in the 1994 Basin Plan included the following implementation provision: "no new effluent limitations will be placed in Waste Discharge Requirements as a result of these [potential MUN designations made pursuant to the SODW policy and the Regional Water Board's enabling resolution] until the Regional Water Board adopts [a special Basin Plan Amendment that incorporates a detailed review of the waters in the Region that should be exempted from the potential MUN designations arising from SODW policy and the Regional Water Board's enabling resolution]." On February 15, 2002, the USEPA clarified its partial approval (May 26, 2000) of the 1994 Basin Plan amendments and acknowledged that the conditional designations do not currently have a legal effect, do not reflect new water quality standards subject to USEPA review, and do not support new effluent limitations based on the conditional designations stemming from the SODW Policy until a subsequent review by the Regional Water Board finalizes the designations for these waters. This permit is designed to be consistent with the existing Basin Plan.

2. **Title 22 of the California Code of Regulations (CCR Title 22).** The California Department of Public Health (CDPH) established primary and secondary maximum contaminant levels (MCLs) for inorganic, organic, and radioactive contaminants in drinking water. These MCLs are codified in Title 22. The Basin Plan (Chapter 3) incorporates Title 22 primary MCLs by reference. This incorporation by reference is prospective, including future changes to the incorporated provisions as the changes take effect. Title 22 primary MCLs have been used as bases for effluent limitations in WDRs and NPDES permits to protect groundwater recharge beneficial use when that receiving groundwater is designated as MUN. Also, the Basin Plan specifies that "Ground waters shall not contain taste or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses."
3. **Secondary Treatment Regulations.** 40 CFR part 133 of establishes the minimum levels of effluent quality to be achieved by secondary treatment. These limitations, established by USEPA, are incorporated into this Order, except where more stringent limitations are required by other applicable plans, policies, or regulations or to prevent backsliding.
4. **Storm Water.** CWA section 402(p), as amended by the Water Quality Act of 1987, requires NPDES permits for storm water discharges. Pursuant to this requirement, in 1990, USEPA promulgated 40 CFR § 122.26 that established requirements for storm water discharges under an NPDES program. To facilitate compliance with federal regulations, on November 1991, the State Water Board issued a statewide general permit, *General NPDES Permit No. CAS000001 and Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities*. This permit was amended in September 1992 and reissued on April 17, 1997 in State Water Board Order No. 97-03-DWQ to regulate storm water discharges associated with industrial activity. *General NPDES Permit No. CAS000001* was revised on April 1, 2014 and becomes effective on July 1, 2015.  
  
General NPDES permit No. CAS000001 is not applicable to the Camarillo WRP because the facility captures and treats storm water that falls on the premises.
5. **Sanitary Sewer Overflows (SSOs).** The CWA prohibits the discharge of pollutants from point sources to surface waters of the United States unless authorized under an NPDES permit. (33 United States Code (USC) sections 1311 and 1342). The State Water Board adopted General WDRs for Sanitary Sewer Systems, (Water Quality Order No. 2006-0003-DWQ; SSO WDR) on May 2, 2006, to provide a consistent, statewide regulatory approach to address SSOs. The SSO WDR requires public agencies that own or

operate sanitary sewer systems to apply for coverage under the SSO WDR, develop and implement sewer system management plans, and report all SSOs to the State Water Board's online SSO database. Regardless of the coverage obtained under the SSO WDR, the Permittee's collection system is part of the POTW that is subject to this NPDES permit. As such, pursuant to federal regulations, the Permittee must properly operate and maintain its collection system (40 CFR § 122.41 (e)), report any non-compliance (40 CFR § 122.41(1)(6) and (7)), and mitigate any discharge from the collection system in violation of this NPDES permit (40 CFR § 122.41(d)).

The requirements contained in this Order sections VI.C.3.b (Spill Cleanup Contingency Plan section), VI.C.4 (Construction, Operation and Maintenance Specifications section), and VI.C.6 (Spill Reporting Requirements section) are intended to be consistent with the requirements of the SSO WDR. The Regional Water Board recognizes that there may be some overlap between these NPDES permit provisions and SSO WDR requirements, related to the collection systems. The requirements of the SSO WDR are considered the minimum thresholds (see Finding 11 of State Water Board Order No. 2006-0003-DWQ). To encourage efficiency, the Regional Water Board will accept the documentation prepared by the Permittees under the SSO WDR for compliance purposes as satisfying the requirements in sections VI.C.3.b, VI.C.4, and VI.C.6, provided the more stringent provisions contained in this NPDES permit are also addressed. Pursuant to SSO WDR, section D, provision 2(iii) and (iv), the provisions of this NPDES permit supersede the SSO WDR, for all purposes, including enforcement, to the extent the requirements may be deemed duplicative.

6. **Watershed Management** - This Regional Water Board has been implementing a Watershed Management Approach (WMA) to address water quality protection in the Los Angeles Region following the USEPA guidance in *Watershed Protection: A Project Focus* (EPA841-R-95-003, August 1995). The objective of the WMA is to provide a more comprehensive and integrated strategy resulting in water resource protection, enhancement, and restoration while balancing economic and environmental impacts within a hydrologically-defined drainage basin or watershed. The WMA emphasizes cooperative relationships between regulatory agencies, the regulated community, environmental groups, and other stakeholders in the watershed to achieve the greatest environmental improvements with the resources available. The WMA integrates activities across the Regional Water Board's diverse programs, particularly permitting, planning, and other surface water-oriented programs that have tended to operate somewhat independently of each other.

The Regional Water Board has prepared and periodically updates its Watershed Management Initiative Chapter, the latest is updated December 2007. This document contains a summary of the region's approach to watershed management. It addresses each watershed and the associated water quality problems and issues. It describes the background and history of each watershed, current and future activities, and addresses TMDL development. The information can be accessed on our website:  
<http://www.waterboards.ca.gov/losangeles>.

7. **Relevant TMDLs** – Section 303(d) of the CWA requires states to identify water bodies that do not meet water quality standards and then to establish TMDLs for each waterbody for each pollutant of concern. TMDLs identify the maximum amount of pollutants that can be discharged to waterbodies without causing violations of water quality standards.
  - a. **Calleguas Creek Watershed Salts TMDL** - On October 4, 2007, the Regional Water Board adopted Resolution No. R4-2007-016, *Amendment to the Water Quality*

*Control Plant – Los Angeles Region to Incorporate the Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed.* This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on May 20, 2008, November 6, 2008, and December 2, 2008, respectively. This TMDL became effective on December 2, 2008.

- b. **Calleguas Creek Watershed Nitrogen Compounds and Related Effects TMDL** - On October 24, 2002, the Regional Water Board adopted Resolution No. 02-017, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in Calleguas Creek (Nitrogen Compounds TMDL)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on March 19, 2003, June 5, 2003, and June 20, 2003, respectively.
- On September 11, 2008, the Regional Water Board adopted Resolution No. R4-2008-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region through revision of the Waste Load Allocation for the Calleguas Creek Watershed Nitrogen Compounds and Related Effects Total Maximum Daily Load (revised Nitrogen Compounds TMDL)*. This Basin Plan amendment corrects the mass based daily WLAs for ammonia to be used based upon MDEL, and updates the WLAs to be consistent with the current practice of recognizing that the flow is variable. The mass based WLAs for ammonia are corrected to be based on the maximum daily effluent limit, MDEL and the actual POTW effluent flow rate at the time the monitoring is conducted. This Order includes effluent limitations for nitrogen compounds established by the revised *Nitrogen Compounds TMDL* which became effective on October 15, 2009.
- c. **Calleguas Creek Toxicity, Chlorpyrifos, and Diazinon TMDL** - On July 7, 2005, the Regional Water Board adopted Resolution No. R4-2005-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Toxicity, Chlorpyrifos, and Diazinon in Calleguas Creek, its Tributaries, and Mugu Lagoon (Toxicity TMDL)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on September 22, 2005, November 27, 2005, and March 14, 2006, respectively. This Order includes effluent limitations for chlorpyrifos and diazinon established by the *Toxicity TMDL* which became effective on March 24, 2006. The toxicity WLA will be implemented in accordance with USEPA, State Water Board, and Regional Water Board resolutions, guidance, and policy at the time of permit issuance or renewal.
- d. **Calleguas Creek OC Pesticides and PCBs TMDL** - On July 7, 2005, the Regional Water Board adopted Resolution No. R4-2005-010, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Organochlorine Pesticides, Polychlorinated Biphenyls, and Siltation in Calleguas Creek, its Tributaries, and Mugu Lagoon (OC Pesticides and PCBs TMDL)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on September 22, 2005, January 20, 2006, and March 14, 2006, respectively. This Order includes effluent limitations for OC pesticides and PCBs based on the final WLAs established by the *OC Pesticides and PCBs TMDL*, which became effective on March 24, 2006.
- e. **Calleguas Creek Watershed Metals TMDL** - On June 8, 2006, the Regional Water Board adopted Resolution No. R4-2006-012, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Metals for the Calleguas Creek, its Tributaries, and Mugu Lagoon (Metals TMDL)*.

This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on October 25, 2006, February 6, 2007, and March 26, 2007, respectively. This Order includes effluent limitations for metals consistent with the assumptions of the *Metals TMDL* which became effective on March 26, 2007.

- i. Calleguas Creek Copper WER – On November 9, 2006, the Regional Water Board adopted Resolution No. R4-2006-022, *Amendment to the Water Quality Control Plan for the Los Angeles Region Water Effects Ratios (WERs) for Copper in Lower Calleguas Creek and Mugu Lagoon Located in the Calleguas Creek Watershed, Ventura County (Copper WER)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on June 19, 2007, August 16, 2007, and August 23, 2007, respectively. The 3.69 copper WER is protective of the saltwater copper criteria for Reach 1 of Calleguas Creek. Use of the copper WER for the final mass-based WLAs is consistent with the *Metals TMDL*.

#### IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in 40 CFR § 122.44(a) requires that permits include applicable TBELs and standards; and 40 CFR § 122.44(d) requires that permits include WQBELs to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

The variety of potential pollutants found in the Facility discharges presents a potential for aggregate toxic effects to occur. Whole effluent toxicity (WET) is an indicator of the combined effect of pollutants contained in the discharge. Chronic toxicity is a more stringent requirement than acute toxicity. Therefore, chronic toxicity is considered pollutant of concern for protection and evaluation of narrative Basin Plan Objectives.

##### A. Discharge Prohibitions

Effluent and receiving water limitations in this Board Order are based on the CWA, Basin Plan, State Water Board's plans and policies, USEPA guidance and regulations, and best practicable waste treatment technology. This order authorizes the discharge of tertiary-treated wastewater from Discharge Points 001A and 001B only. It does not authorize any other types of discharges.

##### B. Technology-Based Effluent Limitations (TBELs)

###### 1. Scope and Authority

Technology-based effluent limits require a minimum level of treatment for industrial/municipal point sources based on currently available treatment technologies while allowing the Permittee to use any available control techniques to meet the effluent limits. The 1972 CWA required POTWs to meet performance requirements based on available wastewater treatment technology. Section 301 of the CWA established a required performance level--referred to as "secondary treatment"--that all POTWs were required to meet by July 1, 1977. More specifically, section 301(b)(1)(B) of the CWA required that USEPA develop secondary treatment standards for POTWs as defined in section 304(d)(1). Based on this statutory requirement, USEPA developed national secondary treatment regulations which are specified in 40 CFR part 133. These technology-based regulations apply to all POTWs and identify the minimum level of

effluent quality to be attained by secondary treatment in terms of BOD<sub>5</sub>20°C, TSS, and pH.

**2. Applicable TBELs**

This Facility is subject to the technology-based regulations for the minimum level of effluent quality attainable by secondary treatment in terms of BOD<sub>5</sub>20°C, TSS, and pH. However, all TBELs from the previous Order No. R4-2003-0079 (as revised by Order No. R4-2004-0121) are based on tertiary-treated wastewater treatment standards. These effluent limitations have been carried over from the previous Order to avoid backsliding. Further, mass-based effluent limitations are based on a design flow rate of 7.25 mgd. The removal efficiency for BOD and TSS is set at the minimum level attainable by secondary treatment technology. The principal design parameter for wastewater treatment plants is the daily BOD and TSS loading rates and the corresponding removal rate of the system. In applying 40 CFR Part 133 for weekly and monthly average BOD and TSS limitations, the application of tertiary treatment processes results in the ability to achieve lower levels for BOD and TSS than the secondary standards. In addition to the average weekly and average monthly effluent limitations, a daily maximum effluent limitation for BOD and TSS is included in the Order to ensure that the treatment works are not organically overloaded and operate in accordance with design capabilities. The following Table summarizes the TBELs applicable to the Facility:

**Table F-5. Summary of TBELs**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
BOD <sub>5</sub> 20°C	mg/L	20	30	45		
	lbs/day <sup>3</sup>	1200	1800	2700		
TSS	mg/L	15	40	45		
	lbs/day <sup>3</sup>	910	2400	2700		
pH	standard units	--	--	--	6.5	8.5
Removal Efficiency for BOD and TSS	%	85	--	--		

This Facility is also subject to TBELs contained in similar NPDES permits, for similar facilities, based on the treatment level achievable by tertiary-treated wastewater treatment systems. These effluent limitations are consistent with the State Water Board precedential decision, State Water Board Order No. WQ 2004-0010 for the City of Woodland. The Camarillo WRP is able to meet these limitations with the existing treatment processes in place in the POTW.

**C. Water Quality-Based Effluent Limitations (WQBELs)**

**1. Scope and Authority**

CWA section 301(b) and 40 CFR § 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements,

<sup>3</sup> The mass emission rates are based on the plant design flow rate of 7.25 mgd, and are calculated as follows: Flow (mgd) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

expressed as a technology equivalence requirement, that are necessary to achieve water quality standards. The Regional Water Board has considered the factors listed in CWC section 13241 in establishing these requirements. The rationale for these requirements, which consist of tertiary treatment or equivalent requirements or other provisions, is discussed starting from section IV.C.2.

40 CFR § 122.44(d)(1)(i) requires that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established using (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable WQOs and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

## 2. **Applicable Beneficial Uses and Water Quality Criteria and Objectives**

- a. The Basin Plan establishes the beneficial uses for surface water bodies in the Los Angeles region. The beneficial uses of the Conejo Creek affected by the discharge have been described previously in this Fact Sheet.
- b. The Basin Plan also specifies narrative and numeric WQOs applicable to surface water as shown in the following discussions.

### i. **BOD<sub>5</sub>20°C and TSS**

BOD<sub>5</sub>20°C is a measure of the quantity of the organic matter in the water and, therefore, the water's potential for becoming depleted in dissolved oxygen. As organic degradation takes place, bacteria and other decomposers use the oxygen in the water for respiration. Unless there is a steady resupply of oxygen to the system, the water will quickly become depleted of oxygen. Adequate dissolved oxygen levels are required to support aquatic life. Depressions of dissolved oxygen can lead to anaerobic conditions resulting in odors, or, in extreme cases, fish kills.

40 CFR part 133 describes the minimum level of effluent quality attainable by secondary treatment, for BOD and TSS, as:

- The 30-day average shall not exceed 30 mg/L, and
- The 7-day average shall not exceed 45 mg/L.

Camarillo WRP provides tertiary treatment. As such, the BOD and TSS limits in the permit are more stringent than secondary treatment requirements and are based on Best Professional Judgment (BPJ). The Facility achieves solids

removals that are better than secondary-treated wastewater by filtering the effluent.

The monthly average, the 7-day average, and the daily maximum limits cannot be removed because none of the anti-backsliding exceptions apply. Those limits were all included in the previous permit (Order R4-2003-0079 (as revised by Order No. R4-2004-0121)) and the Camarillo WRP has been able to meet both limits (monthly average and the daily maximum), for both BOD and TSS.

In addition to having mass-based and concentration-based effluent limitations for BOD and TSS, the Camarillo WRP also has a percent removal requirement for these two constituents. In accordance with 40 CFR §§ 133.102(a)(3) and 133.102(b)(3), the 30-day average percent removal shall not be less than 85 percent. Percent removal is defined as a percentage expression of the removal efficiency across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of the raw wastewater influent pollutant concentrations to the Facility and the 30-day average values of the effluent pollutant concentrations for a given time period.

ii. **pH**

The hydrogen ion activity of water (pH) is measured on a logarithmic scale, ranging from 0 to 14. While the pH of "pure" water at 25°C is 7.0, the pH of natural waters is usually slightly basic due to the solubility of carbon dioxide from the atmosphere. Minor changes from natural conditions can harm aquatic life. In accordance with 40 CFR § 133.102(c), the effluent values for pH shall be maintained within the limits of 6.0 to 9.0 unless the POTW demonstrates that (1) inorganic chemicals are not added to the waste stream as part of the treatment process, and (2) contributions from industrial sources do not cause the pH of the effluent to be less than 6.0 or greater than 9.0. The effluent limitation for pH in this permit requiring that the wastes discharged shall at all times be within the range of 6.5 to 8.5 is taken from the Basin Plan (page 3-15) which reads "the pH of inland surface waters shall not be depressed below 6.5 or raised above 8.5 as a result of waste discharge."

iii. **Settleable solids**

Excessive deposition of sediments can destroy spawning habitat, blanket benthic (bottom dwelling) organisms, and abrade the gills of larval fish. The limits for settleable solids are based on the Basin Plan (page 3-16) narrative, "Waters shall not contain suspended or settleable material in concentrations that cause nuisance or adversely affect beneficial uses." The numeric limits are empirically based on results obtained from the settleable solids 1-hour test, using an Imhoff cone.

It is impracticable to use a 7-day average limitation, because short-term spikes of settleable solid levels that would be permissible under a 7-day average scheme would not be adequately protective of all beneficial uses. The monthly average and the daily maximum limits cannot be removed because none of the anti-backsliding exceptions apply. The monthly average and daily maximum limits were both included in the previous permit (Order

R4-2003-0079 (as revised by Order No. R4-2004-0121)) and the Camarillo WRP has been able to meet both limits.

iv. **Oil and grease**

Oil and grease are not readily soluble in water and form a film on the water surface. Oily films can coat birds and aquatic organisms, impacting respiration and thermal regulation, and causing death. Oil and grease can also cause nuisance conditions (odors and taste), are aesthetically unpleasant, and can restrict a wide variety of beneficial uses. The limits for oil and grease are based on the Basin Plan (page 3-11) narrative, "Waters shall not contain oils, greases, waxes, or other materials in concentrations that result in a visible film or coating on the surface of the water or on objects in the water, that cause nuisance, or that otherwise adversely affect beneficial uses."

The numeric limits are empirically based on concentrations at which an oily sheen becomes visible in water. It is impracticable to use a 7-day average limitation, because spikes that occur under a 7-day average scheme could cause a visible oil sheen. A 7-day average scheme would not be sufficiently protective of beneficial uses. The monthly average and the daily maximum limits cannot be removed because none of the anti-backsliding exceptions apply. Both limits were included in the previous permit (Order No. R4-2003-0079 (as revised by Order No. R4-2004-0121)) and the Camarillo WRP has been able to meet both limits.

v. **Residual Chlorine**

Disinfection of wastewaters with chlorine produces a chlorine residual. Chlorine and its reaction products are toxic to aquatic life. The limit for residual chlorine is based on the Basin Plan (page 3-9) narrative, "Chlorine residual shall not be present in surface water discharges at concentrations that exceed 0.1 mg/L and shall not persist in receiving waters at any concentration that causes impairment of beneficial uses."

It is impracticable to use a 7-day average or a 30-day average limitation, because it is not as protective as of beneficial uses as a daily maximum limitation is. Chlorine is very toxic to aquatic life and short term exposures of chlorine may cause fish kills.

vi. **Total Dissolved Solids (TDS), Sulfate, and Boron**

During wet weather, the limits for TDS, sulfate, and boron are based on the water quality objectives found in Basin Plan Table 3-8 (page 3-12) for the Calleguas Creek watershed (above Potrero Road) which are: TDS = 850 mg/L, Sulfate = 250 mg/L, and Boron = 1.0 mg/L.

During dry weather, the limits for TDS, sulfate, and boron are based on the WLAs contained in the *Calleguas Creek Salts TMDL*, Resolution No. R4-2007-016, *Amendment to the Water Quality Control Plant – Los Angeles Region to Incorporate the Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed*, adopted by the Regional Water

Board on October 4, 2007. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on May 20, 2008, November 6, 2008, and December 2, 2008, respectively. This TMDL became effective on December 2, 2008.

Water conservation efforts and a change in potable water supply have increased salt concentrations in the Camarillo area. So even though the *Salts TMDL* contains interim WLAs for TDS, chloride, sulfate, those interim WLAs no longer provide sufficient relief during the TMDL-established compliance schedule period. Interim effluent limitations may be established in a separate Time Schedule Order.

i. **Chloride**

The WQO for chloride in the Basin Plan Table 3-8 (page 3-12), for Calleguas Creek Watershed (above Potrero Road) is 150 mg/L. Due to several actions of the Regional Water Board and State Water Board, this water quality objective has not been applied to the Camarillo WRP.

On January 27, 1997, the Regional Water Board adopted Resolution No. 97-02, Amendment to the Basin Plan to incorporate a Policy for Addressing Levels of Chloride in Discharges of Wastewaters. It was approved by the State Water Board in State Water Board Resolution 97-94 and approved by the Office of Administrative Law (OAL) on January 8, 1998. Resolution No. 97-02 served to revise the chloride water quality objective in Calleguas Creek and other surface waters.

On April 13, 1998, the Regional Water Board adopted Order No. 98-027, which amended NPDES Order No. 96-042 for Camarillo WRP to include an interim chloride daily maximum effluent limit of 190 mg/L based on Resolution No. 97-02. This interim limit expired on January 9, 2001.

On December 7, 2000, the Regional Water Board adopted Resolution No. 2000-22, to extend the Interim Chloride Limits for Discharges to Calleguas Creek until March 31, 2001.

On March 22, 2002, USEPA Region 9 established the Calleguas Creek Total Maximum Daily Load for chloride which used the 150 mg/L objective in the Basin Plan to establish a waste load allocation of 2,300 lbs/day for the Camarillo WRP during normal conditions, and a waste load allocation of 2,200 lbs/day for the Camarillo WRP during drought conditions.

On August 14, 2002 the City of Simi Valley (Simi Valley WQCF), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), Camrosa Sanitation District (Camrosa WRP), Ventura County Water Works District No. 1 (Moorpark facility) and the Regional Water Board entered into a "Stipulation for Order Issuing Stay, with Conditions," which stayed the chloride final effluent limitation of 150 mg/L in NPDES Order No. 96-042. The State Water Board adopted WQO 2002-0017, which approved the August 14, 2002 stipulation.

On June 5, 2003, the NPDES permits for the City of Simi Valley (Simi Valley WQCF), Thousand Oaks (Hill Canyon WWTP), and the Camarillo Sanitary District (Camarillo WRP NPDES Order No. R4-2003-0081) were renewed, thereby rescinding the 1996 NPDES Orders, except for enforcement purposes.

The Dischargers petitioned the revised NPDES Orders to the State Water Board, requested an extension of the chloride stay, and asked that the petitions be held in abeyance.

On October 10, 2003, the City of Simi Valley (Simi Valley WQCF), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), and the Regional Water Board entered into a "Stipulation for Further Order Issuing Stay, with Conditions," which stayed the chloride final effluent limitation in NPDES Order No. R4-2003-0081. The State Water Board adopted WQO 2003-0019, which approved the October 10, 2003 stipulation and held the petitions in abeyance for three years (until November 19, 2006). The stay will become inoperative upon the effective date of the NPDES Order No. R4-2014-0062.

On September 28, 2006, the State Water Board granted an extension of the abeyance until July 15, 2008, when the petition would be dismissed without prejudice. The State Water Board, however, has continued granting extensions to the abeyance.

On October 4, 2007, the Regional Water Board adopted the *Calleguas Creek Salts TMDL*, Resolution No. R4-2007-016, *Amendment to the Water Quality Control Plan – Los Angeles Region to Incorporate the Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on May 20, 2008, November 6, 2008, and December 2, 2008, respectively. This TMDL became effective on December 2, 2008.

The Salts TMDL established interim and final WLAs for chloride. During wet weather, the chloride limit will be based on the water quality objective found in Basin Plan Table 3-8 (page 3-12) for the Calleguas Creek watershed (above Potrero Road) which is: Chloride = 150 mg/L. During dry weather, the limit for chloride will be based on the WLAs contained in the *Salts TMDL*.

This Order establishes interim and final effluent limitations for chloride based on the Salts TMDL's WLAs. Water conservation efforts and a change in potable water supply have increased salt concentrations in the Camarillo area. So even though the *Salts TMDL* contains interim WLAs for chloride, that interim WLA no longer provides sufficient relief during the TMDL-established compliance schedule period. Interim effluent limitations may be established in a separate Time Schedule Order.

viii. **Iron**

The previous Order had an effluent limitation of 300 mg/L for iron, which was based on the USEPA document, Quality Criteria for Water 1986 [EPA 440/5-86-001, May 1, 1986], also referred to as the Gold Book, for the protection of GWR beneficial use. 300 µg/L was also the secondary MCL for iron. Since the discharge had reasonable potential to cause to contribute to an exceedance, a limit for iron, based on the 300 µg/L criteria, is prescribed for the protection of the GWR beneficial use in the surface water and for the protection of the MUN beneficial use in the underlying groundwater basins.

ix. **Methylene Blue Activated Substances (MBAS)**

The existing permit effluent limitation of 0.5 mg/l for MBAS was developed based on the Basin Plan incorporation of Title 22, Drinking Water Standards, by reference, to protect the surface water groundwater recharge (GWR) beneficial use and the groundwater basin's MUN beneficial use. Given the nature of the Facility which accepts domestic wastewater into the sewer system and treatment plant, and the characteristics of the pollutants discharged, the discharge has reasonable potential to exceed both the numeric MBAS WQO and the narrative WQO for the prohibition of floating material such as foams and scums. The discharge has tier 3 Reasonable Potential (RP), therefore an effluent limitation is required.

x. **Total Inorganic Nitrogen (NO<sub>2</sub> + NO<sub>3</sub> as N)**

Total inorganic nitrogen is the sum of Nitrate-nitrogen and Nitrite-nitrogen. High nitrate levels in drinking water can cause health problems in humans. Infants are particularly sensitive and can develop methemoglobinemia (blue-baby syndrome). Nitrogen is also considered a nutrient. Excessive amounts of nutrients can lead to other water quality impairments.

(a) **Algae**

Excessive growth of algae and/or other aquatic plants can degrade water quality. Algal blooms sometimes occur naturally, but they are often the result of excess nutrients (i.e., nitrogen, phosphorus) from waste discharges or nonpoint sources. These algal blooms can lead to problems with tastes, odors, color, and increased turbidity and can depress the dissolved oxygen content of the water, leading to fish kills. Floating algal scum and algal mats are also an aesthetically unpleasant nuisance.

The WQO for biostimulatory substances are based on Basin Plan (page 3-8) narrative, "Waters shall not contain biostimulatory substances in concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses," and other relevant information to arrive at a mass based-limit intended to be protective of the beneficial uses, pursuant to 40 CFR § 122.44(d). Total inorganic nitrogen will be the indicator parameter intended to control algae, pursuant to 40 CFR § 122.44(d)(1)(vi)(C).

(b) **Concentration-based limit**

Total inorganic nitrogen (NO<sub>2</sub>-N + NO<sub>3</sub>-N) effluent limitation of 10 mg/L is based on Basin Plan Table 3-8 (page 3-12), for Calleguas Creek Watershed above Potrero Road. However, the Nitrogen Compound TMDL for this Watershed has been in effect since July 16, 2003. Therefore, total inorganic nitrogen effluent limitation of 9 mg/L, which is based on the *Nitrogen Compound TMDL*, will apply in this permit.

(c) **Mass-based limit**

Since the *Nitrogen Compound TMDL* does not specify any mass-based WLA for nitrate plus nitrite as nitrogen, mass based limits are not included for NO<sub>2</sub>-N + NO<sub>3</sub>-N.

xi. **Nitrite as Nitrogen and Nitrate as Nitrogen**

The effluent limit for nitrite as nitrogen ( $\text{NO}_2\text{-N}$ ) of 0.9 mg/L is based on the Calleguas Creek Watershed Nutrient TMDL Waste Load Allocation which was assigned to the Camarillo WRP. The effluent limit for nitrate as nitrogen ( $\text{NO}_3\text{-N}$ ) of 9 mg/L is based on the Calleguas Creek Watershed Nutrient TMDL Waste Load Allocation which was assigned to the Camarillo WRP. Since the TMDL does not specify any mass-based WLA for nitrate as nitrogen or nitrite as nitrogen, mass bases limits are not included for either of the two constituents.

xii. **Total ammonia**

Ammonia is a pollutant routinely found in the wastewater effluent of POTWs, in landfill-leachate, as well as in run-off from agricultural fields where commercial fertilizers and animal manure are applied. Ammonia exists in two forms – un-ionized ammonia ( $\text{NH}_3$ ) and the ammonium ion ( $\text{NH}_4^+$ ). They are both toxic, but the neutral, un-ionized ammonia species ( $\text{NH}_3$ ) is much more toxic, because it is able to diffuse across the epithelial membranes of aquatic organisms much more readily than the charged ammonium ion. The form of ammonia is primarily a function of pH, but it is also affected by temperature and other factors. Additional impacts can also occur as the oxidation of ammonia lowers the dissolved oxygen content of the water, further stressing aquatic organisms. Oxidation of ammonia to nitrate may lead to groundwater impacts in areas of recharge. There is groundwater recharge in these reaches. Ammonia also combines with chlorine (often both are present in POTW treated effluent discharges) to form chloramines – persistent toxic compounds that extend the effects of ammonia and chlorine downstream.

On October 24, 2002, the Regional Water Board adopted Resolution No. 02-017, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in Calleguas Creek*. This Resolution was approved by the State Water Resources Control Board, Office of Administrative Law, and USEPA on March 19, 2003, June 5, 2003, and June 20, 2003, respectively.

On September 11, 2008, the Regional Water Board adopted Resolution No. R4-2008-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region through revision of the Waste Load Allocation for the Calleguas Creek Watershed Nitrogen Compounds and Related Effects Total Maximum Daily Load (revised Nitrogen Compounds TMDL)*. This Basin Plan amendment corrects the mass based daily WLAs for ammonia to be used based upon MDEL, and updates the WLAs to be consistent with the current practice of recognizing that the flow is variable. The mass based WLAs for ammonia are corrected to be based on the maximum daily effluent limit, MDEL and the actual POTW effluent flow rate at the time the monitoring is conducted. This Order includes effluent limitations for nitrogen compounds established by the revised *Nitrogen Compounds TMDL* which became effective on October 15, 2009. *Calleguas Creek Nitrogen Compounds TMDL* has ammonia nitrogen waste load allocations of 7.8 mg/L and 3.5 mg/L as maximum daily and average monthly effluent limitation, respectively. These

waste load allocations will apply as end-of-pipe effluent limitations to the Camarillo WRP.

**xiii. Coliform**

Total and fecal coliform bacteria are used to indicate the likelihood of pathogenic bacteria in surface waters. Given the nature of the Facility, a wastewater treatment plant, pathogens are likely to be present in the effluent in cases where the disinfection process is not operating adequately. As such, the permit contains the following filtration and disinfection TBELs for coliform:

**(1). Effluent Limitations:**

- The 7-day median number of total coliform bacteria at some point at the end of the UV channel, during normal operation of the UV channel, and at the end of the chlorine contact chamber, when backup method is used, must not exceed a Most Probable Number (MPN) or Colony Forming Unit (CFU) of 2.2 per 100 milliliters,
- the number of total coliform bacteria must not exceed an MPN or CFU of 23 per 100 milliliters in more than one sample within any 30-day period; and
- No sample shall exceed an MPN or CFU of 240 total coliform bacteria per 100 milliliters.

These disinfection-based effluent limitations for coliform are for human health protection and are consistent with requirements established by the California Department of Public Health. These limits for coliform must be met at the point of the treatment train immediately following disinfection, as a measure of the effectiveness of the disinfection process.

**(2). The following Receiving Water Limitations shall not be exceeded as a result of wastes discharged:**

- Geometric Mean Limitations
  - E.coli density shall not exceed 126/100 mL.
- Single Sample Limitations
  - E.coli density shall not exceed 235/100 mL.

These receiving water limitations are based on Resolution No. R10-005, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Update the Bacteria Objectives for Freshwaters Designated for Water Contact Recreation by Removing the Fecal Coliform Objective*, adopted by the Regional Water Board on July 8, 2010, and became effective on December 5, 2011.

#### xiv. Temperature

USEPA document, *Quality Criteria for Water 1986* [EPA 440/5-86-001, May 1, 1986], also referred to as the *Gold Book*, discusses temperature and its effects on beneficial uses, such as recreation and aquatic life.

- The Federal Water Pollution Control Administration in 1967 called temperature "a catalyst, a depressant, an activator, a restrictor, a stimulator, a controller, a killer, and one of the most important water quality characteristics to life in water." The suitability of water for total body immersion is greatly affected by temperature. Depending on the amount of activity by the swimmer, comfortable temperatures range from 20°C to 30°C (68 °F to 86 °F).
- Temperature also affects the self-purification phenomenon in water bodies and therefore the aesthetic and sanitary qualities that exist. Increased temperatures accelerate the biodegradation of organic material both in the overlying water and in bottom deposits which makes increased demands on the dissolved oxygen resources of a given system. The typical situation is exacerbated by the fact that oxygen becomes less soluble as water temperature increases. Thus, greater demands are exerted on an increasingly scarce resource which may lead to total oxygen depletion and obnoxious septic conditions. Increased temperature may increase the odor of water because of the increased volatility of odor-causing compounds. Odor problems associated with plankton may also be aggravated.
- Temperature changes in water bodies can alter the existing aquatic community. Coutant (1972) has reviewed the effects of temperature on aquatic life reproduction and development. Reproductive elements are noted as perhaps the most thermally restricted of all life phases assuming other factors are at or near optimum levels. Natural short-term temperature fluctuations appear to cause reduced reproduction of fish and invertebrates.

The Basin Plan lists temperature requirements for the receiving waters. Based on the requirements of the Basin Plan and a white paper developed by Regional Water Board staff entitled *Temperature and Dissolved Oxygen Impacts on Biota in Tidal Estuaries and Enclosed Bays in the Los Angeles Region*, a maximum effluent temperature limitation of 86°F is included in the Order. The white paper evaluated the optimum temperatures for steelhead, topsmelt, ghost shrimp, brown rock crab, jackknife clam, and blue mussel. The new temperature effluent limitation is reflective of new information available that indicates that the 100°F temperature which was formerly used in permits was not protective of aquatic organisms. A survey was completed for several kinds of fish and the 86°F temperature was found to be protective. It is impracticable to use a 7-day average or a 30-day average limitation for temperature, because it is not as protective as of beneficial uses as a daily maximum limitation is. A daily maximum limit is necessary to protect aquatic life and is consistent with the fishable/swimmable goals of the CWA.

Section IV.A.3.b. of the Order contains the following effluent limitation for temperature:

"The temperature of wastes discharged shall not exceed 86°F except as a result of external ambient temperature."

The above effluent limitation for temperature has been quoted in all recent NPDES permits adopted by this Regional Water Board. Section V.A.1. of the Order explains how compliance with the receiving water temperature limitation will be determined.

xv. **Turbidity**

Turbidity is an expression of the optical property that causes light to be scattered in water due to particulate matter such as clay, silt, organic matter, and microscopic organisms. Turbidity can result in a variety of water quality impairments. The effluent limitation for turbidity which reads, "For the protection of the water contact recreation beneficial use, the discharge to water courses shall have received adequate treatment, so that the turbidity of the wastewater does not exceed: (a) a daily average of 2 Nephelometric turbidity units (NTU); (b) 5 NTU more than 5 percent of the time (72 minutes) during any 24 hour period; and (c) 10 NTU at any time" is based on the Basin Plan (page 3-17) and section 60301.320 of Title 22, chapter 3, "Filtered Wastewater" of the CCR.

xvi. **Radioactivity**

Radioactive substances are generally present in natural waters in extremely low concentrations. Mining or industrial activities increase the amount of radioactive substances in waters to levels that are harmful to aquatic life, wildlife, or humans. Section 301(f) of the CWA contains the following statement with respect to effluent limitations for radioactive substances: "Notwithstanding any of other provisions of this Act it shall be unlawful to discharge any radiological, chemical, or biological warfare agent, any high-level radioactive waste, or any medical waste, into the navigable waters." Chapter 4.4 of the CWC contains a similar prohibition under section 13375, which reads as follows: "The discharge of any radiological, chemical, or biological warfare agent into the waters of the state is hereby prohibited." However, rather than an absolute prohibition on radioactive substances, Regional Water Board staff have set the following effluent limit for radioactivity: "Radioactivity of the wastes discharged shall not exceed the limits specified in Title 22, Chapter 15, Article 5, sections 64442 and 64443, of the CCR, or subsequent revisions." The limit is based on the Basin Plan incorporation of Title 22, CCR, *Drinking Water Standards*, by reference, to protect beneficial use. Therefore, the accompanying Order will retain the limit for radioactivity.

c. **CTR and SIP**

The CTR and the SIP specify numeric objectives for toxic substances and the procedures whereby these objectives are to be implemented. The procedures include those used to conduct reasonable potential analysis (RPA) to determine the

need for effluent limitations for priority pollutants. The TSD also specifies procedures to conduct reasonable potential analyses.

### 3. Determining the Need for WQBELs

The Regional Water Board developed WQBELs for ammonia-nitrogen, nitrite-nitrogen, nitrate-nitrogen, nitrite plus nitrite as nitrogen, TDS, sulfate, chloride, boron, copper, nickel, mercury, chlordane, 4,4'-DDD, 4,4'-DDE, 4,4'-DDT, dieldrin, PCBs, toxaphene, chlorpyrifos, diazinon, and chronic toxicity based upon TMDLs. The effluent limitations for these pollutants were established regardless of whether or not there is reasonable potential for the pollutants to be present in the discharge at levels that would cause or contribute to a violation of water quality standards. The Regional Water Board developed water quality-based effluent limitations for these pollutants pursuant to Part 122.44(d)(1)(vii), which does not require or contemplate a reasonable potential analysis. Similarly, the SIP at Section 1.3 recognizes that reasonable potential analysis is not appropriate if a TMDL has been developed.

In accordance with Section 1.3 of the SIP, the Regional Water Board conducted a reasonable potential analysis for each priority pollutant with an applicable criterion or objective to determine if a WQBEL is required in the permit. The Regional Water Board analyzed effluent data to determine if a pollutant in a discharge has a reasonable potential to cause or contribute to an excursion above a state water quality standard. For all parameters that demonstrate reasonable potential, numeric WQBELs are required. The RPA considers water quality criteria from the CTR and NTR, and when applicable, water quality objectives specified in the Basin Plan. To conduct the RPA, the Regional Water Board staff identified the maximum effluent concentration (MEC) and maximum background concentration in the receiving water for each constituent, based on data provided by the Permittee. The monitoring data cover the period from February 2007 to August 2013.

Section 1.3 of the SIP provides the procedures for determining reasonable potential to exceed applicable water quality criteria and objectives. The SIP specifies three triggers to complete a RPA:

Trigger 1 – If the MEC is greater than or equal to the CTR water quality criteria or applicable objective (C), a limitation is needed.

Trigger 2 – If background water quality (B) > C and the pollutant is detected in the effluent, a limitation is needed.

Trigger 3 – If other related information such as CWA 303(d) listing for a pollutant, discharge type, compliance history, then best professional judgment is used to determine that a limit is needed.

Sufficient effluent and ambient data are needed to conduct a complete RPA. If data are not sufficient, the Permittee will be required to gather the appropriate data for the Regional Water Board to conduct the RPA. Upon review of the data, and if the Regional Water Board determines that WQBELs are needed to protect the beneficial uses, the permit will be reopened for appropriate modification.

The RPA was performed for the priority pollutants regulated in the CTR for which data are available. Based on the RPA, pollutants that demonstrate reasonable potential are copper, mercury, nickel, chlordane, chlorpyrifos, diazinon, 4,4'-DDD,

4,4'-DDE, 4,4'-DDT, dieldrin, PCBs, and toxaphene because TMDLs are adopted for these constituents and final WLAs are assigned to the Camarillo WRP.

Cyanide, 2,3,7,8-TCDD, aldrin, alpha-BHC, heptachlor epoxide, and bis(2-ethylhexyl)phthalate show reasonable potential because MEC is greater than C. Iron shows reasonable potential because the receiving water exceeds the criteria and the pollutant was present in the effluent. The following Table summarizes results from RPA.

Table F-7. Summary of Reasonable Potential Analysis

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation?	Reason
1	Antimony	6	0.55	0.6	No	MEC<C, B<C
2	Arsenic	10	2.67	4.7	No	MEC<C
3	Beryllium	4	<0.01	<0.01	No	MEC<C, B<C
4	Cadmium	5	3	0.7	No	MEC<C, B<C
5a	Chromium III	600	3.3	7.6	No	MEC<C, B<C
5b	Chromium VI	50	0.06	0.07	No	MEC<C, B<C
6	<b>Copper</b>	TMDL	10	5.7	YES	TMDL WLA
7	Lead	16	0.16	1.2	No	MEC<C, B<C
8	Mercury	0.051	0.01	0.02	No	MEC<C, B<C
9	<b>Nickel</b>	TMDL	4.8	7.5	YES	TMDL WLA
10	Selenium	5	3.3	4.6	No	MEC<C, B<C
11	Silver	36	0.02	0.018	No	MEC<C, B<C
12	Thallium	2	<0.003	0.01	No	MEC<C, B<C
13	Zinc	248	44.6	25.1	No	MEC<C, B<C
14	<b>Cyanide</b>	5.2	20	4	YES	MEC>C
15	Asbestos	7x10 <sup>6</sup> fibers/L	No sample	No sample	No	N/A
16	<b>2,3,7,8-TCDD (Dioxin)</b>	0.014 pg/L	0.235 pg/L	ND	YES	MEC>C, B<C
17	Acrolein	780	<5	<5	No	MEC<C, B<C
18	Acrylonitrile	0.66	<2	<2	No	MEC<C, B<C
19	Benzene	1	<1	<1	No	MEC<C, B<C
20	Bromoform	360	4.42	1.83	No	MEC<C, B<C
21	Carbon Tetrachloride	0.5	<0.5	<1	No	MEC<C, B<C
22	Chlorobenzene	21,000	<0.05	<0.05	No	MEC<C, B<C
23	Dibromochloromethane	34	24.6	2.69	No	MEC<C, B<C
24	Chloroethane	No criteria	<0.5	<2	No	No criteria
25	2-chloroethyl vinyl ether	No criteria	<0.3	<0.3	No	No criteria
26	Chloroform	No criteria	15	8.26	No	No criteria
27	Dichlorobromomethane	46	24.6	3.54	No	MEC<C, B<C
28	1,1-dichloroethane	No criteria	<0.5	<0.5	No	No criteria
29	1,2-dichloroethane	99	<0.5	<0.5	No	MEC<C, B<C
30	1,1-dichloroethylene	3.2	<0.5	<0.5	No	MEC<C, B<C
31	1,2-dichloropropane	5	<0.5	<0.5	No	MEC<C, B<C
32	1,3-dichloropropylene	0.5	<0.5	<5	No	MEC<C, B<C
33	Ethylbenzene	29,000	<0.5	<0.5	No	MEC<C, B<C
34	Methyl bromide	4,000	<0.5	<0.5	No	MEC<C, B<C
35	Methyl chloride	No criteria	<0.5	<0.5	No	No criteria
36	Methylene chloride	1,600	0.17	<0.5	No	MEC<C, B<C
37	1,1,2,2-	1	<1	<0.5	No	MEC<C, B<C

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation?	Reason
	tetrachloroethane					
38	Tetrachloroethylene	5	2.3	ND	No	MEC<C, B<C
39	Toluene	150	0.95	<0.5	No	MEC<C, B<C
40	Trans 1,2-Dichloroethylene	10	<0.5	<0.5	No	MEC<C, B<C
41	1,1,1-Trichloroethane	200	<0.5	<0.5	No	MEC<C, B<C
42	1,1,2-Trichloroethane	5	<0.5	<0.5	No	MEC<C, B<C
43	Trichloroethylene	5	<0.5	<0.5	No	MEC<C, B<C
44	Vinyl Chloride	525	<0.5	<0.5	No	MEC<C, B<C
45	2-chlorophenol	400	<1	<1	No	MEC<C, B<C
46	2,4-dichlorophenol	790	<1	<1	No	MEC<C, B<C
47	2,4-dimethylphenol	2,300	<1	<1	No	MEC<C, B<C
48	4,6-dinitro-o-resol(aka 2-methyl-4,6-Dinitrophenol)	765	<0.94	<1	No	MEC<C, B<C
49	2,4-dinitrophenol	14,000	<1	<4.7	No	MEC<C, B<C
50	2-nitrophenol	No criteria	<1	<1	No	No criteria
51	4-nitrophenol	No criteria	<1.9	<1	No	No criteria
52	3-Methyl-4-Chlorophenol (aka P-chloro-m-resol)	No criteria	<1	<1	No	No criteria
53	Pentachlorophenol	8.2	<1	<1	No	MEC<C, B<C
54	Phenol	4,600,000	20	<0.94	No	MEC<C, B<C
55	2,4,6-trichlorophenol	6.5	<1	<0.94	No	MEC<C, B<C
56	Acenaphthene	2,700	<0.94	<0.94	No	MEC<C, B<C
57	Acenaphthylene	No criteria	<0.94	<0.94	No	No criteria
58	Anthracene	110,000	<0.94	<0.94	No	MEC<C, B<C
59	Benzidine	0.00054	<0.94	<0.94	No	MEC<C, B<C
60	Benzo(a)Anthracene	0.049	<0.94	<0.94	No	MEC<C, B<C
61	Benzo(a)Pyrene	0.049	<0.94	<0.94	No	MEC<C, B<C
62	Benzo(b)Fluoranthene	0.049	<0.94	<0.94	No	MEC<C, B<C
63	Benzo(ghi)Perylene	No criteria	<0.94	<0.94	No	No criteria
64	Benzo(k)Fluoranthene	0.049	<0.94	<0.94	No	MEC<C, B<C
65	Bis(2-Chloroethoxy) methane	No criteria	<0.94	<0.94	No	No criteria
66	Bis(2-Chloroethyl)Ether	1.4	<0.94	<0.94	No	MEC<C, B<C
67	Bis(2-Chloroisopropyl) Ether	170,000	<0.94	<0.94	No	MEC<C, B<C
68	<b>Bis(2-Ethylhexyl) Phthalate</b>	4.0	86	3.9	YES	MEC>C
69	4-Bromophenyl Phenyl Ether	No criteria	<1	<0.94	No	No criteria
70	Butylbenzyl Phthalate	5,200	<1	<1	No	MEC<C, B<C
71	2-Chloronaphthalene	4,300	<1	<0.94	No	MEC<C, B<C
72	4-Chlorophenyl Phenyl Ether	No criteria	<0.94	<0.94	No	No criteria
73	Chrysene	0.049	<0.94	<0.94	No	MEC<C, B<C
74	Dibenzo(a,h)	0.049	<0.94	<0.94	No	MEC<C, B<C

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation?	Reason
	Anthracene					
75	1,2-Dichlorobenzene	17,000	<0.94	<0.5	No	MEC<C, B<C
76	1,3-Dichlorobenzene	2,600	<0.94	<0.5	No	MEC<C, B<C
77	1,4-Dichlorobenzene	2,600	<0.94	<0.5	No	MEC<C, B<C
78	3-3'-Dichlorobenzidine	0.077	<0.94	<0.94	No	MEC<C, B<C
79	Diethyl Phthalate	120,000	<0.94	<0.94	No	MEC<C, B<C
80	Dimethyl Phthalate	2,900,000	<0.94	<0.94	No	MEC<C, B<C
81	Di-n-Butyl Phthalate	12,000	1	2.2	No	MEC<C, B<C
82	2-4-Dinitrotoluene	9.1	<0.94	<0.94	No	MEC<C, B<C
83	2-6-Dinitrotoluene	No criteria	<0.94	<0.94	No	No criteria
84	Di-n-Octyl Phthalate	No criteria	<0.94	<0.94	No	No criteria
85	1,2-Diphenylhydrazine	0.54	<0.94	<1	No	MEC<C, B<C
86	Fluoranthene	370	<0.94	<0.94	No	MEC<C, B<C
87	Fluorene	14,000	<0.94	<0.94	No	MEC<C, B<C
88	Hexachlorobenzene	0.00077	<0.94	<0.94	No	MEC<C, B<C
89	Hexachlorobutadiene	50	<0.94	<0.94	No	MEC<C, B<C
90	Hexachlorocyclopentadiene	17,000	<0.94	<0.94	No	MEC<C, B<C
91	Hexachloroethane	8.9	<0.94	<0.94	No	MEC<C, B<C
92	Indeno(1,2,3-cd)Pyrene	0.049	<0.94	<0.94	No	MEC<C, B<C
93	Isophorone	600	<0.94	<0.94	No	MEC<C, B<C
94	Naphthalene	No criteria	<0.94	<0.94	No	No criteria
95	Nitrobenzene	1,900	<0.94	<0.94	No	MEC<C, B<C
96	N-Nitrosodimethylamine	8.1	<1	<1	No	MEC<C, B<C
97	N-Nitrosodi-n-Propylamine	1.4	<0.94	<1	No	MEC<C, B<C
98	N-Nitrosodiphenylamine	16	<0.94	<1	No	MEC<C, B<C
99	Phenanthrene	No criteria	<0.94	<1	No	No criteria
100	Pyrene	11,000	<0.94	<1	No	MEC<C, B<C
101	1,2,4-Trichlorobenzene	No criteria	<0.94	<1	No	No criteria
102	<b>Aldrin</b>	0.00014	0.0053	<0.0047	YES	MEC>C
103	<b>Alpha-BHC</b>	0.013	0.024	0.055	YES	MEC>C, B>C
104	Beta-BHC	0.046	0.015	<0.0047	No	MEC<C, B<C
105	Gamma-BHC (aka Lindane)	0.063	0.0081	0.0047	No	MEC<C, B<C
106	delta-BHC	No criteria	<0.008	<0.0047	No	No criteria
107	<b>Chlordane</b>	0.00059	<0.009	<0.0047	YES	TMDL WLA
108	4,4'-DDT	0.00059	0.016	0.0033	YES	TMDL WLA
109	4,4'-DDE	0.00059	<0.0098	<0.0047	YES	TMDL WLA
110	4,4'-DDD	0.00084	0.0075	0.032	YES	TMDL WLA
111	<b>Dieldrin</b>	0.00014	<0.01	<0.0047	YES	TMDL WLA
112	Alpha-Endosulfan	0.056	0.007	<0.0047	No	MEC<C, B<C
113	Beta-Endosulfan	0.056	0.055	<0.0047	No	MEC<C, B<C
114	Endosulfan Sulfate	240	0.0034	<0.0047	No	MEC<C, B<C
115	Endrin	0.036	<0.009	0.0021	No	MEC<C, B<C
116	Endrin Aldehyde	0.81	<0.01	<0.0047	No	MEC<C, B<C
117	Heptachlor	0.00021	<0.002	<0.0047	No	MEC<C, B<C

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc.(B) µg/L	RPA Result - Need Limitation?	Reason
118	Heptachlor Epoxide	0.00011	0.0069	0.0025	YES	MEC>C, B>C
119	PCB 1016	0.00017	<0.5	<0.5	YES	TMDL WLA
120	PCB 1221	0.00017	<0.5	<0.5	YES	TMDL WLA
121	PCB 1232	0.00017	<0.5	<0.5	YES	TMDL WLA
122	PCB 1242	0.00017	<0.5	<0.5	YES	TMDL WLA
123	PCB 1248	0.00017	<0.5	<0.5	YES	TMDL WLA
124	PCB 1254	0.00017	<0.5	<0.5	YES	TMDL WLA
125	PCB 1260	0.00017	<0.5	<0.5	YES	TMDL WLA
126	Toxaphene	0.00075	<0.3	<0.47	YES	TMDL WLA
	Chlorpyrifos		0.0291		YES	TMDL WLA
	Diazinon		ND		YES	TMDL WLA
	Iron	300	166	833	YES	B>C & Detected in effluent

4. **WQBEL Calculations**

a. **Calculation Options.** Once RPA has been conducted using either the TSD or the SIP methodologies, WQBELs are calculated. Alternative procedures for calculating WQBELs include:

- i. Use WLA from applicable TMDL
- ii. Use a steady-state model to derive MDELs and AMELs.
- iii. Where sufficient data exist, use a dynamic model which has been approved by the State Water Board.

b. **TMDL WLA-based limitations**

i. **Calleguas Creek Watershed Metals TMDL.**

• **Copper:**

- Concentration-based final WLAs were established for the Camarillo WRP in the *Metals TMDL*, expressed in terms of a footnote which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the *Final Draft Metals and Selenium TMDL Technical Report (Technical Report)*, dated March 2006. This final effluent limitation will apply on the effective date of this Order because the CTR/SIP compliance schedule authority for CTR criteria has expired. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations, so a TSO for copper is not needed.
- A copper mass-based final WLA was established for the Camarillo WRP in the *Metals TMDL*, in terms of the following formula:

0.12\*WER-0.04, for the protection of the lower reaches of Calleguas Creek. The WLA-based limit was calculated using the 3.69 copper WER approved by the Regional Water Board on November 9, 2006. This final mass-based effluent limitation applies on the effective date of this Order because the CTR/SIP compliance schedule authority for CTR criteria has expired. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations, so a TSO for copper is not needed.

• **Nickel:**

- Concentration-based final WLAs were established for the Camarillo WRP in the *Metals TMDL*, expressed in terms of a footnote which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the *Final Draft Metals and Selenium TMDL Technical Report (Technical Report)*, dated March 2006. This final effluent limitation applies on the effective date of this Order because the CTR/SIP compliance schedule authority for CTR criteria has expired. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations, so a TSO for nickel is not needed.
- A 0.2 lbs/day mass-based nickel final WLA was established in the *Metals TMDL* for the Camarillo WRP, for protection of the saltwater objective in the lower reach. The TMDL became effective on March 26, 2007. This final effluent limitation applies on the effective date of this Order because the CTR/SIP compliance schedule authority for CTR criteria has expired. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitation, so a TSO for nickel is not needed.
- **Mercury:** A mercury mass-based WLA is established for the Camarillo WRP in the *Metals TMDL*. The permit contains a final effluent limitation for mercury consistent with the final WLA.
- **Zinc:** Zinc allocations are not set because current information indicate that numeric targets for zinc are attained. The TMDL implementation plan includes a task to provide State Water Board data to support delisting of zinc. In addition, effluent data demonstrates that the Facility's discharge does not have reasonable potential to cause an exceedance of the applicable water quality objective.
- **Selenium:** Waste load allocations for selenium are not set for POTWs because POTWs do not discharge to reaches listed for selenium.

ii. **OC Pesticide TMDL.**

The *Organochlorine (OC) Pesticide, Polychlorinatedbiphenyls (PCBs), and Siltation TMDL* establishes final WLAs for Chlordane, Dieldrin, 4,4-DDD, 4,4-DDE, 4,4-DDT, PCBs, and Toxaphene. The permit contains final effluent limitations consistent with the final WLAs. These final effluent limitations apply on the effective date of this Order because the CTR/SIP compliance schedule

authority for CTR criteria has expired. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations, so a TSO for these pollutants is not needed.

iii. **Toxicity TMDL**

The *Toxicity TMDL* establishes final WLAs for Chlorpyrifos and Diazinon. The permit contains final effluent limitations consistent with the final WLAs. The *Toxicity TMDL* also establishes a final WLA for Chronic Toxicity, based on the 1 TUc numeric target. The permit contains final effluent limitations consistent with the assumptions of the Toxicity TMDL and consistent with the implementation language which reads, "The toxicity WLAs will be implemented in accordance with USEPA, State Board and Regional Board resolutions, **guidance** (emphasis added) and policy at the time of permit issuance or renewal." The final effluent limitation will apply on the effective date of this Order, since additional time for permit compliance, provided under the 2008 Compliance Schedule Policy, was not offered by the TMDL. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations, so a TSO for chronic toxicity is not needed.

iv. **Nutrient TMDL**

The *Nitrogen Compounds and Related Effects (Nitrogen) TMDL* establishes final WLAs for Ammonia nitrogen, nitrate nitrogen, nitrite nitrogen, and nitrate plus nitrite as nitrogen. The permit contains final effluent limitations consistent with the final WLAs. The final effluent limitation will apply on the effective date of this Order, since the compliance schedule authority under the *Nutrient TMDL* has expired. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations, so a TSO is not needed.

- c. **SIP Calculation Procedure.** Section 1.4 of the SIP requires the step-by-step procedure to "adjust" or convert CTR numeric criteria into AMELs and MDELs, for toxics.

Step 3 of section 1.4 of the SIP (starting on page 6) lists the statistical equations that adjust CTR criteria for effluent variability.

Step 5 of section 1.4 of the SIP (starting on page 8) lists the statistical equations that adjust CTR criteria for averaging periods and exceedance frequencies of the criteria/objectives. This section also reads, "For this method only, maximum daily effluent limitations shall be used for publicly-owned treatment works (POTWs) in place of average weekly limitations."

The RPA was performed for the priority pollutants regulated in the CTR for which data are available. RPA results showed that there is no reasonable potential to exceed the criteria.

d. **Impracticability Analysis**

Federal NPDES regulations contained in 40 CFR § 122.45 continuous dischargers, states that all permit limitations, standards, and prohibitions, including those to achieve water quality standards, shall unless impracticable be stated as maximum

daily and average monthly discharge limitations for all dischargers other than POTWs.

As stated by USEPA in its long standing guidance for developing WQBELs average alone limitations are not practical for limiting acute, chronic, and human health toxic effects.

For example, a POTW sampling for a toxicant to evaluate compliance with a 7-day average limitation could fully comply with this average limit, but still be discharging toxic effluent on one, two, three, or up to four of these seven days and not be meeting 1-hour average acute criteria or 4-day average chronic criteria. For these reason, USEPA recommends daily maximum and 30-day average limits for regulating toxics in all NPDES discharges. For the purposes of protecting the acute effects of discharges containing toxicants (CTR human health for the ingestion of fish), daily maximum limitations have been established in this NPDES permit for mercury because it is considered to be a carcinogen, endocrine disruptor, and is bioaccumulative.

A 7-day average alone would not protect one, two, three, or four days of discharging pollutants in excess of the acute and chronic criteria. Fish exposed to these endocrine disrupting chemicals will be passed on to the human consumer. Endocrine disrupters alter hormonal functions by several means. These substances can:

- mimic or partly mimic the sex steroid hormones estrogens and androgens (the male sex hormone) by binding to hormone receptors or influencing cell signaling pathways.
- block, prevent and alter hormonal binding to hormone receptors or influencing cell signaling pathways.
- alter production and breakdown of natural hormones.
- modify the making and function of hormone receptors.

- e. **Mass-based limits.** 40 CFR § 122.45(f)(1) requires that except under certain conditions, all permit limits, standards, or prohibitions be expressed in terms of mass units. 40 CFR § 122.45(f)(2) allows the permit writer, at its discretion, to express limits in additional units (e.g., concentration units). The regulations mandate that, where limits are expressed in more than one unit, the permittee must comply with both.

Generally, mass-based limits ensure that proper treatment, and not dilution, is employed to comply with the final effluent concentration limits. Concentration-based effluent limits, on the other hand, discourage the reduction in treatment efficiency during low-flow periods and require proper operation of the treatment units at all times. In the absence of concentration-based effluent limits, a permittee would be able to increase its effluent concentration (i.e., reduce its level of treatment) during low-flow periods and still meet its mass-based limits. To account for this, this permit includes mass and concentration limits for some constituents.

Table F-8. Summary of WQBELs for Discharge Points 001A and 001B

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Min.	Instantaneous Max.
Ammonia Nitrogen <sup>4</sup>	mg/L	3.5	--	7.8		
	lbs/day		--	7.0 x Q <sup>5</sup>		
[Nitrate + Nitrite] (as N)	mg/L	9 <sup>6</sup>	--	--		
Nitrate (as N)	mg/L	9 <sup>6</sup>	--	--		
Nitrite (as N)	mg/L	0.96	--	--		
Copper	µg/L	23 <sup>7</sup>	--	42 <sup>7</sup>		
	lbs/day	--	--	0.4 <sup>8</sup>		

<sup>4</sup> This limitation is derived from the final WLA for nitrate nitrogen, nitrite nitrogen, and nitrate plus nitrite nitrogen, as set forth in the Nitrogen Compounds and Related Effects TMDL, established by the Regional Water Board on October 24, 2002. Final WLAs became operative on July 16, 2007. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>5</sup> Q represents the POTW effluent flow at the time of water quality measurement is collected (not to exceed 7.25 MGD) and conversion factor to lb/day based on the units of measurement for the effluent flow.

<sup>6</sup> This limitation is derived from the final WLA for nitrate nitrogen, nitrite nitrogen, and nitrate plus nitrite nitrogen, as set forth in the Nitrogen Compounds and Related Effects TMDL, established by the Regional Water Board on October 24, 2002. Final WLAs became operative on July 16, 2007. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>7</sup> This limitation is derived from the final WLA, as set forth in the Calleguas Creek Watershed Metals TMDL (Metals TMDL), established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007. The Metals TMDL contains concentration-based WLAs that are expressed in terms of a footnote, which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the Final Draft Metals and Selenium TMDL Technical Report (Technical Report), dated March 2006. This final effluent limitation applies on the effective date of this Order because the CTR/SIP compliance schedule authority for CTR criteria has expired. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>8</sup> This limitation is derived from the mass-based final WLA, as set forth in the Metals TMDL, established by the Regional Water Board on June 8, 2006, for the protection of the lower reaches of Calleguas Creek. The TMDL became effective on March 26, 2007. The mass-based WLA is expressed in terms of a formula that incorporates a Water Effects Ratio (WER). The WLA-based limit was calculated using the 3.69 copper WER approved by the Regional Water Board on November 9, 2006. This final mass-based effluent limitation applies on the effective date of this Order because the CTR/SIP compliance schedule authority for CTR criteria has expired. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitations.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Min.	Instantaneous Max.
Nickel	µg/L	110 <sup>9</sup>	--	276 <sup>9</sup>		
	lbs/day	--	--	0.2 <sup>10</sup>		
Mercury	lbs/month	0.015 <sup>11</sup>	--	--		
Cyanide	µg/L	4.2	--	8.5		
	lbs/day	0.25	--	0.51		
Bis(2-ethylhexyl) Phthalate	µg/L	4.0	--	--		
	lbs/day	0.24	--	--		
Aldrin	µg/L	0.00014	--	0.000281		
Alpha-BHC	µg/L	0.013	--	0.026		
Chlordane	µg/L	0.00059 <sup>12</sup>	--	0.0012 <sup>12</sup>		
4,4-DDD	µg/L	0.00084 <sup>12</sup>	--	0.0017 <sup>12</sup>		
4,4-DDE	µg/L	0.00059 <sup>12</sup>	--	0.0012 <sup>12</sup>		
4,4-DDT	µg/L	0.00059 <sup>12</sup>	--	0.0012 <sup>12</sup>		
Dieldrin	µg/L	0.00014 <sup>12</sup>	--	0.00028 <sup>12</sup>		
Heptachlor epoxide	µg/L	0.00011	--	0.00022		
PCBs	µg/L	0.00017 <sup>12</sup>	--	0.00034 <sup>12</sup>		
Toxaphene	µg/L	0.00016 <sup>12</sup>	--	0.00033 <sup>12</sup>		

<sup>9</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL (Metals TMDL)*, established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007. The *Metals TMDL* contains concentration-based WLAs that are expressed in terms of a footnote, which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the *Final Draft Metals and Selenium TMDL Technical Report (Technical Report)*, dated March 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that discharge is currently able to comply with the final WLA-based limitations.

<sup>10</sup> This mass-based effluent limitation is derived from the mass-based final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006, for the protection of the lower reaches of Calleguas Creek. The TMDL became effective on March 26, 2007. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitation.

<sup>11</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006. This limitation is derived from the WLA for mercury, specified in pounds per month, as set forth in said TMDL. The TMDL became effective on March 26, 2007. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitation.

<sup>12</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Organochlorine Pesticide, Polychlorinated Biphenyls (PCB), and Siltation TMDL*, established by the Regional Water Board on July 7, 2005. The limitation is derived from the final WLA as set forth in said TMDL. The TMDL became effective on March 24, 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitation.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Min.	Instantaneous Max.
Chlorpyrifos	µg/L	0.0133 <sup>13</sup>	--	0.024 <sup>13</sup>		
Diazinon	µg/L	0.1 <sup>13</sup>	--	0.1 <sup>13</sup>		
Chronic Toxicity <sup>14, 15</sup>	Pass or Fail, %Effect	Pass <sup>16</sup>	--	Pass or %Effect < 50		

### 5. Whole Effluent Toxicity (WET)

Whole effluent toxicity (WET) testing protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a short or a longer period of time and may measure mortality, reproduction, and growth. A chemical at a low concentration can have chronic effects but no acute effects until it gets to the higher level.

The 2003 permit contained final effluent limitations for both acute toxicity and chronic toxicity. But the 2014 permit only contains final effluent limitations for chronic toxicity, since chronic toxicity is a more stringent requirement than acute toxicity. Removal of the numeric acute toxicity effluent limit from the 2003 permit does not constitute backsliding because the numeric chronic toxicity effluent limits protect the Basin Plan acute toxicity objective and chronic toxicity is the more stringent and sensitive requirement.

For this permit, chronic toxicity in the discharge is evaluated using USEPA's 2010 Test of Significant Toxicity (TST) hypothesis testing approach. Chronic toxicity limitations are expressed as "Pass" or "Fail" for the median monthly summary result and "Pass" or "Fail"

<sup>13</sup> This limitation is derived from the final WLA as set forth in the *Calleguas Creek Watershed Toxicity TMDL*, established by the Regional Water Board on July 7, 2005. The TMDL became effective on March 24, 2006. Consistent with the TMDL, the final WLA-based limit became operative on March 23, 2008. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that discharge is currently able to comply with the final WLA-based limitation, so a TSO is not needed.

<sup>14</sup> The *Calleguas Creek Watershed Toxicity TMDL* includes a WLA of 1.0 TUC for toxicity, which is required to be implemented in accordance with USEPA, State Water Board, and Regional Water Board resolutions, guidance and policy at the time of permit issuance or renewal. The numeric WLA is protective of both the numeric acute toxicity and the narrative toxicity Basin Plan water quality objectives. Consistent with the *Toxicity TMDL Implementation Plan*, this toxicity WLA will be implemented using current USEPA guidance in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, June /2010)* and *EPA Regions 8, 9 and 10 Toxicity Training Tool (January 2010)*, <http://www2.epa.gov/region8/epa-regions-8-9-and-10-toxicity-training-tool-january-2010>.

<sup>15</sup> "Pass" or "Fail" for Median Monthly Effluent Limitation (MMEL). "Pass" or "Fail" and "% Effect" for Maximum Daily Effluent Limitation (MDEL). The MMEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail". The final effluent limitation will apply on the effective date of this Order, since additional time for permit compliance, provided under the 2008 Compliance Schedule Policy, was not offered by the TMDL. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations, so a TSO for chronic toxicity is not needed.

<sup>16</sup> This is a Median Monthly Effluent Limitation.

and "% Effect" for the maximum daily single result. The chronic toxicity effluent limitations are as stringent as necessary to protect the narrative Basin Plan Water Quality Objective for chronic toxicity. Those limitations are also consistent with the chronic toxicity WLA of 1 TUc and the assumptions of the *Calleguas Creek Toxicity TMDL* which went into effect on March 24, 2006, and the implementation language which reads as follows: "The toxicity WLAs will be implemented in accordance with USEPA, State Board and Regional Board resolutions, **guidance** (emphasis added) and policy at the time of permit issuance or renewal."

In January 2010, USEPA published a guidance document titled, "EPA Regions 8, 9 and 10 Toxicity Training Tool," which among other things discusses permit limit expression for chronic toxicity. The document acknowledges that NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both a Maximum Daily Limitation (MDL) and an Average Monthly Limitation (AML) for all dischargers other than POTWs, and as an average weekly limit (AWL) and AML for POTWs. Following Section 5.2.3 of the Technical Support Document (TSD), the use of an AWL is not appropriate for WET. In lieu of an AWL for POTWs, EPA recommends establishing an MDL for toxic pollutants and pollutants in water quality permitting, including WET. This is appropriate for two reasons. The basis for the average weekly requirement for POTWs derives from secondary treatment regulations and is not related to the requirement to assure achievement of WQS. Moreover, an average weekly requirement comprising up to seven daily samples could average out daily peak toxic concentrations for WET and therefore, the discharge's potential for causing acute and chronic effects would be missed. It is impracticable to use an AWL, because short-term spikes of toxicity levels that would be permissible under the 7-day average scheme would not be adequately protective of all beneficial uses. The MDL is the highest allowable value for the discharge measured during a calendar day or 24-hour period representing a calendar day. The permit should contain a condition indicating that the MDL is interpreted as the maximum acute or chronic WET result for that calendar month. The AML is the highest allowable value for the average of daily discharges obtained over a calendar month. For WET, this is the average of individual WET test results for that calendar month. However, in cases where a chronic mixing zone is not authorized, EPA Regions 9 and 10 continue to recommend that the AML for chronic WET should be expressed as a median monthly limit (MML).

Later in June 2010, USEPA published another guidance document titled, Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, June 2010), in which they recommend the following: "Permitting authorities should consider adding the TST approach to their implementation procedures for analyzing valid WET data for their current NPDES WET Program." The TST approach is another statistical option for analyzing valid WET test data. Use of the TST approach does not result in any changes to EPA's WET test methods. Section 9.4.1.2 of USEPA's *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA/821/R-02/013, 2002), recognizes that, "the statistical methods in this manual are not the only possible methods of statistical analysis." The TST approach can be applied to acute (survival) and chronic (sublethal) endpoints and is appropriate to use for both freshwater and marine EPA WET test methods. In 2014, in response to the State Water Board's request to use the TST hypothesis testing approach in NPDES permits, USEPA determined—based on the evidence presented in the State Water Board's request—that the results of TST tests and NOEC-LOEC tests—are acceptably

equivalent under the Alternative Test Procedure (ATP) process at 40 CFR 136 for all NPDES permits issued by State and Regional Water Boards.

The effluent limitation for chronic toxicity was established regardless of whether or not there is reasonable potential for the pollutants to be present in the discharge at levels that would cause or contribute to a violation of water quality standards, since the *Toxicity TMDL* establishes a chronic toxicity WLA for the Camarillo WRP. The Regional Water Board developed water quality-based effluent limitations for these pollutants pursuant to Part 122.44(d)(1)(vii), which does not require or contemplate a reasonable potential analysis. However, the effluent data demonstrates that there is reasonable potential because the chronic toxicity trigger was exceeded three times.

In the past, the State Water Board reviewed the circumstances warranting a numeric chronic toxicity effluent limitation for POTWS when there is reasonable potential with respect to SWRCB/OCC Files A-1496 & A-1496(a) [Los Coyotes/Long Beach Petitions]. On September 16, 2003, at a public hearing, the State Water Board adopted Order No. 2003-0012 deferring the issue of numeric chronic toxicity effluent limitations for POTWS until a subsequent Phase of the SIP is adopted. In the meantime, the State Water Board replaced the numeric chronic toxicity limit with a narrative effluent limitation and a 1 TUc trigger, in the Long Beach and Los Coyotes WRP NPDES permits. Camarillo WRP's NPDES permit contained a similar narrative chronic toxicity effluent limitation, with a numeric trigger for accelerated monitoring, consistent with the State Water Board's precedential Order.

However, many things have changed since the State Water Board adopted its precedential Order in 2003. Namely, the Regional Water Board adopted the *Calleguas Creek Toxicity TMDL* containing a numeric WLA for chronic toxicity for the five POTWS located in the watershed; USEPA published two new guidance documents with respect to chronic toxicity; the Los Angeles Regional Water Board adopted NPDES permits for industrial facilities incorporating TST-based limits for chronic toxicity and has adopted numeric chronic toxicity effluent limits for industrial facilities with TMDL WLAs of 1 TUc; the Santa Ana Regional Water Board adopted an NPDES permit for a POTW incorporating TST-based limits for chronic toxicity; and the State Water Board is in the process of adopting a statewide plan incorporating the TST approach. Based on differences between the facts before the Regional Water Board in 2014 and the facts that were the basis for the State Water Board precedent in 2003, Regional Water Board staff conclude that the State Water Board precedent does not apply.

Never the less, this Order contains a reopener to allow the Regional Water Board to modify the permit in the future, if necessary, to make it consistent with any new policy, plan, law, or regulation.

#### **D. Final Effluent Limitation Considerations**

##### **1. Anti-Backsliding Requirements**

Sections 402(o) and 303(d)(4) of the CWA and federal regulations at 40 CFR § 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. The effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order, with the exception of effluent limitation for arsenic, fluoride, antimony, cadmium, chromium VI,

lead, selenium, silver, zinc, Tetrachloroethylene, 1,4-dichlorobenzene, lindane, Endrin, barium, Methoxychlor, 2,4-D, and 2,4,5-TP (Silvex). Those effluent limitations were removed because the pollutants did not show reasonable potential to exceed the applicable water quality criteria, which constitutes new information and an exception to the general rule against backsliding. This removal of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations. Applicable exceptions to the anti-backsliding requirements justifying removal of certain effluent limitations include a) material and substantial alterations or additions to the permitted facility occurred after permit issuance and b) new information obtained after permit issuance.

Under CWA sections 403(o)(1)/303(d)(4)(B) for waters in attainment, relaxation is consistent with the State's antidegradation policy because the discharge is in compliance with existing water quality objectives for arsenic, fluoride, antimony, cadmium, chromium VI, lead, selenium, silver, zinc, Tetrachloroethylene, 1,4-dichlorobenzene, lindane, endrin, barium, Methoxychlor, 2,4-D, and 2,4,5-TP (Silvex) in Conejo Creek.

## 2. Antidegradation Policies

40 CFR § 131.12 requires that state water quality standards include an antidegradation policy consistent with the federal antidegradation policy. On October 28, 1968, the State Water Board established California's antidegradation policy when it adopted Resolution No. 68-16, *Statement of Policy with Respect to Maintaining the Quality of the Waters of the State*. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The State Water Board has, in State Water Board Order No. 86-17 and an October 7, 1987 guidance memorandum, interpreted Resolution No. 68-16 to be fully consistent with the federal antidegradation policy contained in 40 CFR § 131.12. Similarly, CWA section 303(d)(4)(B) and 40 CFR § 131.12 require that all permitting actions be consistent with the federal antidegradation policy. Together, the state and federal antidegradation policies are designed to ensure that a water body will not be degraded resulting from the permitted discharge. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. Conejo Creek is included on the 303(d) list for many pollutants. The Regional Water Board adopted TMDLs have to attain water quality standards in the receiving waters, at a future date for: salts, pesticides, PCBs, toxicity, and metals. The NPDES permit contains concentration-based and mass-based limits for copper and nickel to protect aquatic life beneficial use from the point of discharge all the way to the sensitive Mugu Lagoon area, downstream of the discharge. The permit also contains concentration-based limitations based on the California Toxics Rule to protect human health and recreational uses in the receiving water. In addition, Camarillo SD is implementing plans to maximize the recycling of its high-quality tertiary-treated effluent and to discontinue its discharge to inland surface waters by connecting to the Calleguas Municipal Water District's brine line. The renewal of the NPDES permit will not lower surface water quality because the conditions in the Order are at least as stringent as the prior Order and because the Camarillo WRP facility is reducing its flow to surface waters. Therefore, discharges permitted in this Order are consistent with the antidegradation provisions of 40 CFR § 131.12 and State Water Board Resolution No. 68-16.

## 3. Stringency of Requirements for Individual Pollutants

This Order contains both TBELs and WQBELs for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD, TSS, pH, and percent removal of BOD and TSS. Restrictions on BOD, TSS and pH are discussed in section IV.B. of the Fact Sheet. This Order's technology-based pollutant restrictions implement the

minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements that are necessary to meet water quality standards.

Water quality-based effluent limitations have been scientifically derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR § 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and WQOs contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 CFR § 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA and the applicable water quality standards for purposes of the CWA.

**Table F-9. Summary of Final Effluent Limitations for Discharge Points 001A and 001B**

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Min.	Instantaneous Max.	
BOD <sub>5</sub> 20°C	mg/L	20	30	45			Existing
	lbs/day <sup>17</sup>	1210	1810	2720			
Total Suspended Solids (TSS)	mg/L	15	40	45			Existing
	lbs/day <sup>17</sup>	910	2420	2720			
pH	standard units	--	--	--	6.5	8.5	Existing
Removal Efficiency for BOD and TSS	%	85	--	--			Existing
Oil and Grease	mg/L	10	--	15			Existing
	lbs/day <sup>17</sup>	600	--	910			
Settleable Solids	ml/L	0.1	--	0.3			Existing
Total Residual Chlorine	mg/L	--	--	0.1			Existing
TDS (dry-weather) <sup>18</sup>	lbs/day	51,400 <sup>19</sup>	--	--			TMDL

<sup>17</sup> The mass emission rates are based on the plant design flow rate of 7.25 mgd, and are calculated as follows:  
Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day.

<sup>18</sup> Dry weather is defined in the Salts TMDL as the condition when the flows in the receiving water are below the 86th percentile flow, as explained in WDR § VII.O.

<sup>19</sup> This limitation is derived from the final Waste Load Allocations (WLAs) in the *Calleguas Creek Watershed Salts Total Maximum Daily Load (Salts TMDL)*, established by the Regional Water Board on October 4, 2007. The *Salts TMDL* which became effective on December 2, 2008, following USEPA's approval. Interim effluent limitations may be provided in a separate Time Schedule Order.

Consistent with the *Salts TMDL*, these limits apply only during dry weather (as defined in the *Salts TMDL*, as explained in WDR § VII.O).

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Min.	Instantaneous Max.	
TDS (wet-weather) <sup>20</sup>	mg/L	850	--	--			Basin Plan
Sulfate (dry-weather) <sup>18</sup>	mg/L	15,100 <sup>19</sup>	--	--			TMDL
Sulfate (wet-weather) <sup>20</sup>	mg/L	250	--	--			Basin Plan
Chloride (dry-weather) <sup>18</sup>	lbs/day	9,070 <sup>19</sup>	--	--			TMDL
Chloride (wet-weather) <sup>20</sup>	mg/L	150	--	--			Basin Plan
Boron	mg/L	1.0	--	--			Basin Plan
MBAS	mg/L	0.5	--	--			Existing
	lbs/day	50	--	--			
Ammonia Nitrogen	mg/L	3.5 <sup>21</sup>	--	7.8 <sup>21</sup>			TMDL
	lbs/day	--	--	7.0 x Q <sup>22</sup>			
Nitrate + Nitrite (as N)	mg/L	9 <sup>23</sup>	--	--			TMDL
	lbs/day	--	--	--			
Nitrate (as N)	mg/L	9 <sup>23</sup>	--	--			TMDL
	lbs/day	--	--	--			
Nitrite (as N)	mg/L	0.9 <sup>23</sup>	--	--			TMDL
	lbs/day	--	--	--			
Arsenic	µg/L	10	--	--			SIP/CTR
	lbs/day	0.6	--	--			
Iron	µg/L	300	--	--			Basin Plan
	lbs/day	18	--	--			
Cyanide	µg/L	4.3	--	8.5			SIP/CTR
	lbs/day	0.45	--	0.89			
Bis(2-ethylhexyl) Phthalate	µg/L	4.0	--	--			Basin Plan
	lbs/day	0.42	--	--			

<sup>20</sup> This wet-weather final effluent limitation shall apply on January 1, 2016, upon the expiration date of TSO No. R4-2011-0126-A02. Any day that does not qualify as dry-weather is wet-weather. See also section VII.O. of this Order for definition of wet-weather.

<sup>21</sup> This limitation is derived from the final WLA for ammonia nitrogen, as set forth in the *Nitrogen Compounds and Related Effects TMDL*, established by the Regional Water Board on October 24, 2002. Final WLAs became operative on October 24, 2004.

<sup>22</sup> Q represents the POTW effluent flow at the time the water quality measurement is collected (not to exceed 7.25 MGD) and a conversion factor to lbs/day based on the units of measure for the flow.

<sup>23</sup> This limitation is derived from the final WLA for nitrate nitrogen, nitrite nitrogen, and nitrate plus nitrite nitrogen, as set forth in the *Nitrogen Compounds and Related Effects TMDL*, established by the Regional Water Board on October 24, 2002. Final WLAs became operative on July 16, 2007.

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Min.	Instantaneous Max.	
Copper	µg/L	23 <sup>24</sup>	--	42 <sup>24</sup>			TMDL
	lbs/day	--	--	0.4 <sup>25</sup>			
Nickel	µg/L	110 <sup>26</sup>	--	276 <sup>26</sup>			TMDL
	lbs/day	--	--	0.2 <sup>27</sup>			
Mercury	lbs/month	0.031 <sup>28</sup>	--	--			TMDL
2,3,7,8-TCDD	pg/L	0.0140	--	0.0281			SIP/CTR
Aldrin	µg/L	0.00014	--	0.000281			SIP/CTR
Alpha-BHC	µg/L	0.013	--	0.026			SIP/CTR
Heptachlor epoxide	µg/L	0.00011	--	0.00022			SIP/CTR

<sup>24</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL (Metals TMDL)*, established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007. The *Metals TMDL* contains concentration-based WLAs that are expressed in terms of a footnote, which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the *Final Draft Metals and Selenium TMDL Technical Report (Technical Report)*, dated March 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>25</sup> This limitation is derived from the mass-based final WLA, as set forth in the *Metals TMDL*, established by the Regional Water Board on June 8, 2006, for the protection of the lower reaches of Calleguas Creek. The TMDL became effective on March 26, 2007. The mass-based WLA is expressed in terms of a formula that incorporates a Water Effects Ratio (WER). The WLA-based limit was calculated using the 3.69 copper WER approved by the Regional Water Board on November 9, 2006. This final mass-based effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>26</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL (Metals TMDL)*, established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007. The *Metals TMDL* contains concentration-based WLAs that are expressed in terms of a footnote, which indicates that the concentration-based final limits will be included in the permits in accordance with NPDES guidance and requirements, but are not calculated as part of the TMDL. WLA-based limits were calculated using the freshwater CTR criteria, consistent with the *Final Draft Metals and Selenium TMDL Technical Report (Technical Report)*, dated March 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>27</sup> This mass-based effluent limitation is derived from the mass-based final WLA, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006, for the protection of the lower reaches of Calleguas Creek. The TMDL became effective on March 26, 2007. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitation.

<sup>28</sup> This final effluent limitation shall apply on the effective date of this permit. According to the Metals TMDL, the mercury (in suspended sediment) effluent limitation, in lbs/month, is assumed that the total load in effluent water is equal to the suspended sediment load. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitation.

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Min.	Instantaneous Max.	
Chlorpyrifos	µg/L	0.0133 <sup>29</sup>	--	0.024 <sup>29</sup>			TMDL
Diazinon	µg/L	0.1 <sup>29</sup>	--	0.1 <sup>29</sup>			TMDL
Chronic Toxicity <sup>30, 31</sup>	Pass or Fail, % Effect	Pass <sup>32</sup>	--	Pass or %Effect < 50			TMDL, TST
Chlordane	µg/L	0.00059 <sup>33</sup>	--	0.0012 <sup>33</sup>			TMDL
4,4'-DDD	µg/L	0.00084 <sup>33</sup>	--	0.0017 <sup>33</sup>			TMDL
4,4'-DDE	µg/L	0.00059 <sup>33</sup>	--	0.0012 <sup>33</sup>			TMDL
4,4'-DDT	µg/L	0.00059 <sup>33</sup>	--	0.0012 <sup>33</sup>			TMDL
Dieldrin	µg/L	0.00014 <sup>33</sup>	--	0.00028 <sup>33</sup>			TMDL
PCBs <sup>34</sup>	µg/L	0.00017 <sup>33</sup>	--	0.00034 <sup>33</sup>			TMDL
Toxaphene	µg/L	0.00016 <sup>33</sup>	--	0.00033 <sup>33</sup>			TMDL

<sup>29</sup> This limitation is derived from the final WLA as set forth in the *Calleguas Creek Watershed Toxicity TMDL*, established by the Regional Water Board on July 7, 2005. The TMDL became effective on March 24, 2006. Consistent with the TMDL, the final WLA-based limit became operative on March 23, 2008. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitation.

<sup>30</sup> The *Calleguas Creek Watershed Toxicity TMDL* includes a WLA of 1.0 TUc for toxicity, which is required to be implemented in accordance with USEPA, State Water Board, and Regional Water Board resolutions, guidance and policy at the time of permit issuance or renewal. The numeric WLA is protective of both the numeric acute toxicity and the narrative toxicity Basin Plan water quality objectives. Consistent with the *Toxicity TMDL Implementation Plan*, this toxicity WLA will be implemented using current USEPA guidance in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, June 2010)* and *EPA Regions 8, 9 and 10 Toxicity Training Tool (January 2010)*, <http://www2.epa.gov/region8/epa-regions-8-9-and-10-toxicity-training-tool-january-2010>.

<sup>31</sup> "Pass" or "Fail" for Median Monthly Effluent Limitation (MMEL). "Pass" or "Fail" and "% Effect" for Maximum Daily Effluent Limitation (MDEL). The MMEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail". The final effluent limitation will apply on the effective date of this Order, since additional time for permit compliance, provided under the 2008 Compliance Schedule Policy, was not offered by the TMDL. Effluent data demonstrates that the Facility's discharge is currently able to comply with the final WLA-based limitations.

<sup>32</sup> This is a Median Monthly Effluent Limitation.

<sup>33</sup> This limitation is derived from the final WLA, as set forth in the *Calleguas Creek Watershed Organochlorine Pesticide, Polychlorinated Biphenyls (PCB), and Siltation TMDL*, established by the Regional Water Board on July 7, 2005. The limitation is derived from the final WLA as set forth in said TMDL. The TMDL became effective on March 24, 2006. This final effluent limitation applies on the effective date of this Order. Effluent data demonstrates that the facility's discharge is currently able to comply with the final WLA-based limitation.

<sup>34</sup> Applies to sum of all congener or isomer or homolog or Aroclor analyses. PCBs shall mean the sum of chlorinated biphenyls whose analytical characteristics resemble those of Aroclor-1016, Aroclor-1221, Aroclor-1232, Aroclor-1242, Aroclor-1248, Aroclor-1254, and Aroclor-1260.

**E. Interim Effluent Limitations**

The State Water Board's Resolution 2008-0025 "Policy for Compliance Schedules in National Pollutant Discharge Elimination System Permits" (Compliance Schedule Policy) requires the Regional Water Board to establish interim numeric effluent limitations in this Order for compliance schedules longer than one year. As discussed in section VI.B.7 of this Fact Sheet, the Regional Water Board is approving a compliance schedule longer than one year for TDS, sulfate, and chloride, but through a separate Time Schedule Order, since the various TMDLs were approved by USEPA under CWA § 303(d). No interim limits are included in this NPDES Order.

**Table F-10. Interim Effluent Limitations for Discharge Point 001A and 001B**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
N/A			--	--		

**F. Land Discharge Specifications – Not Applicable**

**G. Recycling Specifications**

The Permittee currently recycles approximately 43% (591 million gallons per year) of the total treated effluent and plans to increase that amount until it recycles 100% of the treated effluent. Recycled water is used for landscape irrigation and crop irrigation. The production, distribution, and reuse of recycled water are presently regulated under Water Reclamation Requirements (WRR) Order No. R4-2013-0140, adopted by this Regional Board on September 12, 2013.

Camarillo Sanitary District has a project under design which will dramatically expand future recycled water delivery from the Camarillo WRP. The project would entail delivering recycled water to a 40-acre recreational park and to nearby farming operations. The project is scheduled for completion by December 31, 2015. Camarillo Sanitary District's goal is to recycle 100% of Camarillo WRP's effluent.

**V. RATIONALE FOR RECEIVING WATER LIMITATIONS**

**A. Surface Water**

Receiving water limitations are based on WQOs contained in the Basin Plan and are a required part of this Order.

**B. Groundwater**

Limitations in this Order must protect not only surface receiving water beneficial uses, but also, the beneficial uses of underlying groundwater where there is a recharge beneficial use of the surface water. In addition to a discharge to surface water, there is discharge that can impact groundwater. Sections of Conejo Creek and Calleguas Creek, near the Camarillo WRP discharge points, are designated as GWR beneficial use. Surface water from Conejo Creek percolates into the Pleasant Valley Groundwater Basin with MUN beneficial use specified in the Basin Plan. Since groundwater from the Basin is used to provide drinking water to the community, the groundwater aquifers should be protected.

The issue of using MCLs as the basis for establishing final effluent limitations in an NPDES permit, to protect the GWR beneficial use of surface waters and the MUN beneficial use of the groundwater basins, has been addressed by the State Board in its WQO No. 2003-0009, in the *Matter of the Petitions of County Sanitation District No. 2 of Los Angeles and Bill*

*Robinson for Review of Waste Discharge Requirements Order No. R4-2002-0142 and Time Schedule Order No. R4-2002-0143 for the Whittier Narrows Water Reclamation Plant.* The groundwater recharge (GWR) beneficial use is premised on a hydrologic connection between surface waters and groundwater, where the groundwater in this case is designated with an existing MUN beneficial use. Since there are no criteria or objectives specific to the GWR beneficial use, the Los Angeles Regional Water Board's Basin Plan, staff based effluent limitations for the GWR use on the groundwater MUN objectives. By doing so, the Regional Water Board ensures that the use of surface waters to recharge groundwater used as an existing drinking water source is protected. The fact that there are no criteria or objectives specific to the GWR beneficial use does not deprive the Regional Water Board the ability to protect the use. The CWA contemplates enforcement of both beneficial uses as well as criteria in state water quality standards. In California, an NPDES permit also serves as waste discharge requirements under state law.

Reasonable potential analysis was conducted using new data. The analysis showed that the discharge had reasonable potential to exceed the primary MCL for bis(2-ethylhexyl)phthalate and the secondary MCL for iron, therefore, a limit is included in the permit for both pollutants. The effluent limitations are expressed as a monthly average rather than a daily maximum, because it was assumed that the groundwater basins have assimilative capacity for these pollutants. The monthly averaging period is justified because these pollutants are not expected to produce acute effects. Since the discharge has reasonable potential to exceed the MCLs, end-of-pipe final effluent limitations for bis(2-ethylhexyl)phthalate and iron are needed.

## VI. RATIONALE FOR PROVISIONS

### A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR § 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR § 122.42, are provided in Attachment D. The Permittee must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Parts 122.41(a)(1) and (b) through (n) of 40 CFR establish conditions that apply to all state-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Part 123.25(a)(12) of 40 CFR allows the state to omit or modify conditions to impose more stringent requirements. In accordance with 40 CFR § 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR § 122.41(j)(5) and (k)(2) because the enforcement authority under the CWC is more stringent. In lieu of these conditions, this Order incorporates by reference CWC section 13387(e).

### B. Special Provisions

#### 1. Reopener Provisions

This provision is based on 40 CFR part 123. The Regional Water Board may reopen the permit to modify permit conditions and requirements. Causes for modifications include the promulgation of new regulations, modification in sludge use or disposal practices, or adoption of new regulations by the State Water Board or Regional Water Board, including revisions to the Basin Plan.

#### 2. Special Studies and Additional Monitoring Requirements

- a. **Constituent of Emerging Concern (CEC).** In recent years, the Los Angeles Regional Water Board has incorporated monitoring of a select group of man-made chemicals, particularly pesticides, pharmaceuticals and personal care products,

known collectively as CECs, into permits issued to POTWs to better understand the propensity, persistence and effects of CECs in our environment. Recently adopted permits in this region contain requirements for CEC effluent monitoring and submittal of a work plan identifying the CECs to be monitored in the effluent, sample type, sampling frequency and sampling methodology. Based on feedback we have received from permittees and our review of the results of a recent CEC-related study by the Southern California Coastal Water Research Project (SCCWRP) and the State Water Board, we have modified our CEC monitoring program to respond to feedback while proceeding to fill identified data gaps without overly burdening any one permittee.

The Permittee shall conduct a special study to investigate the CECs in the effluent discharge as listed in Table E-5 of the MRP. These constituents shall be monitored annually for at least two years. The Regional Water Board has determined that two years is an appropriate time period to determine those CECs that are present in POTW effluent. Monitoring results shall be reported as part of the annual report. Analysis under this section is for monitoring purposes only. Analytical results obtained for this study will not be used for compliance determination purposes, since the methods have not been incorporated into 40 CFR part 136

- b. **Antidegradation Analysis and Engineering Report for Proposed Plant Expansion.** This provision is based on the State Water Board Resolution No. 68-16, which requires the Regional Water Board in regulating the discharge of waste to maintain high quality waters of the state. The Permittee must demonstrate that it has implemented adequate controls (e.g., adequate treatment capacity) to ensure that high quality waters will be maintained. This provision requires the Permittee to clarify that it has increased plant capacity through the addition of new treatment system(s) to obtain alternative effluent limitations for the discharge from the treatment system(s). This provision requires the Permittee to report specific time schedules for the plants' projects. This provision requires the Permittee to submit report to the Regional Water Board for approval.
- c. **Operations Plan for Proposed Expansion.** This provision is based on section 13385(j)(1)(D) of the CWC and allows a time period not to exceed 90 days in which the Permittee may adjust and test the treatment system(s). This provision requires the Permittee to submit an Operations Plan describing the actions the Permittee will take during the period of adjusting and testing to prevent violations.
- d. **Treatment Plant Capacity.** The treatment plant capacity study required by this Order shall serve as an indicator for the Regional Water Board regarding Facility's increasing hydraulic capacity and growth in the service area.

### 3. **Best Management Practices and Pollution Prevention**

- a. **Pollutant Minimization Program (PMP).** This provision is based on the requirements of section 2.4.5 of the SIP.

### 4. **Construction, Operation, and Maintenance Specifications**

This provision is based on the requirements of 40 CFR § 122.41(e) and the previous Order.

**5. Special Provisions for Municipal Facilities (POTWs Only)**

- a. **Biosolids Requirements.** To implement CWA section 405(d), on February 19, 1993, USEPA promulgated 40 CFR part 503 to regulate the use and disposal of municipal sewage sludge. This regulation was amended on September 3, 1999. The regulation requires that producers of sewage sludge meet certain reporting, handling, and disposal requirements. It is the responsibility of the Permittee to comply with said regulations that are enforceable by USEPA, because California has not been delegated the authority to implement this program. The Permittee is also responsible for compliance with WDRs and NPDES permits for the generation, transport and application of biosolids issued by the State Water Board, other Regional Water Boards, Arizona Department of Environmental Quality or USEPA, to whose jurisdiction the Facility's biosolids will be transported and applied.
- b. **Pretreatment Requirements.** This permit contains pretreatment requirements consistent with applicable effluent limitations, national standards of performance, and toxic and performance effluent standards established pursuant to sections 208(b), 301, 302, 303(d), 304, 306, 307, 403, 404, 405, and 501 of the CWA, and amendments thereto. This permit contains requirements for the implementation of an effective pretreatment program pursuant to section 307 of the CWA; 40 CFR 35 and 403; and/or Title 23, CCR section 2233.
- c. **Spill Reporting Requirements.** This Order established a reporting protocol for how different types of spills, overflow or bypasses of raw or partially treated sewage from its collection system or treatment plant covered by this Order shall be reported to regulatory agencies.

The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order 2006-0003-DWQ (SSO WDR) on May 2, 2006. The Monitoring and Reporting Requirements for the SSO WDR were amended by Water Quality Order WQ 2008-0002-EXEC on February 20, 2008. The SSO WDR requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the SSO WDR. The SSO WDR requires agencies to develop sanitary sewer management plans (SSMPs) and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions.

Furthermore, the SSO WDR contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. Inasmuch that the Permittee's collection system is part of the system that is subject to this Order, certain standard provisions are applicable as specified in Provisions, section VI.C.5. For instance, the 24-hour reporting requirements in this Order are not included in the SSO WDR. The Permittee must comply with both the SSO WDR and this Order. The Permittee and public agencies that are discharging wastewater into the Facility were required to obtain enrollment for regulation under the SSO WDR by December 1, 2006.

In the past, the Los Angeles Regional Water Board has experienced loss of recreational use in coastal beaches and in Arroyo Conejo as a result of major sewage spills. The SSO requirements are intended to prevent or minimize impacts to receiving waters as a result of spills.

- 6. **Other Special Provisions (Not Applicable)**
- 7. **Compliance Schedules**

An NPDES permit must include final effluent limitations that are consistent with CWA section 301 and with 40 CFR § 122.44(d). The State Water Board's Resolution 2008-0025 "Policy for Compliance Schedules in National Pollutant Discharge Elimination System Permits" (Compliance Schedule Policy) allows compliance schedules for new, revised, or newly interpreted WQOs or criteria, or in accordance with a TMDL. All compliance schedules must be as short as possible, and may not exceed ten years from the effective date of the adoption, revision, or new interpretation of the applicable WQO or criterion, unless a TMDL allows a longer schedule. Where a compliance schedule for a final effluent limitation exceeds one year, the Order must include interim numeric effluent limitations for that constituent or parameter, interim requirements and dates toward achieving compliance, and compliance reporting within 14 days after each interim date. The Order may also include interim requirements to control the pollutant, such as pollutant minimization and source control measures.

The permit limitations for TDS, sulfate, and chloride are more stringent than the limitations previously implemented. These new limitations are based on the *Salts TMDL* WLAs that became effective on December 2, 2008. However, since the interim limits are based on current performance, rather than on the *Salts TMDL* Interim WLAs, the interim effluent limitations and the compliance schedule cannot be included in the NPDES Order. Therefore, a compliance schedule for compliance with final effluent limitations for TDS, sulfate, and chloride may be established in a separate Time Schedule Order.

**Table F-11. Plant Performance Evaluation**

Constituent	Average Concentration (mg/L)	Maximum Concentration (mg/L)	95th Percentil Concentration (mg/L)	99 <sup>th</sup> percentile Concentration (mg/L)
N/A				

**Table F-12. Compliance Schedule Milestone Dates**

Task No.	Description	Start Date	End Date
N/A			

The compliance schedule in the TSO is as short as possible. Although the compliance schedule, under the *Salts TMDL*, allowed POTWs to have up to 12 years from the effective date of the TMDL to achieve compliance with the final WLAs for TSD, sulfate, and chloride, Camarillo SD only requested up to December 2015, to comply with the *Salts TMDL* WLAs.

There is no compliance schedule included in Special Provisions section VI.C.7.

**VII. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS**

Section 308(a) of the federal Clean Water Act and sections 122.41(h), (j)-(l), 122.44(i), and 122.48 of Title 40 of the Code of Federal Regulations (40 CFR) require that all NPDES permits specify monitoring and reporting requirements. CWC sections 13267 and 13383 also authorizes the

Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The MRP establishes monitoring, reporting, and recordkeeping requirements that implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this Facility.

**A. Influent Monitoring**

Influent monitoring is required:

- To determine compliance with the permit conditions for BOD<sub>5</sub> 20°C and suspended solids removal rates;
- To assess treatment plant performance;
- To assess the effectiveness of the Pretreatment Program; and,
- As a requirement of the PMP

**B. Effluent Monitoring**

The Permittee is required to conduct monitoring of the permitted discharges in order to evaluate compliance with permit conditions. Monitoring requirements are given in the MRP Attachment E. This provision requires compliance with the MRP, and is based on 40 CFR parts 122.44(i), 122.62, 122.63, and 124.5. The MRP is a standard requirement in almost all NPDES permits (including this Order) issued by the Regional Water Board. In addition to containing definition of terms, it specifies general sampling/analytical protocols and the requirements of reporting spills, violation, and routine monitoring data in accordance with NPDES regulations, the CWC, and Regional Water Board policies. The MRP also contains sampling program specific for the Permittee's wastewater treatment plant. It defines the sampling stations and frequency, pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all pollutants for which effluent limitations are specified. Further, in accordance with section 1.3 of the SIP, a periodic monitoring is required for all priority pollutants defined by the CTR, for which criteria apply and for which no effluent limitations have been established, to evaluate reasonable potential to cause or contribute to an excursion above a water quality standard.

Monitoring for those pollutants expected to be present in the discharge from the Facility, will be required as shown on the MRP and as required in the SIP. Semi-annual monitoring for priority pollutants in the effluent is required in accordance with the Pretreatment requirements.

**Table F-13. Monitoring Frequency Comparison**

Parameter	Monitoring Frequency (2003 Permit)	Monitoring Frequency (2014 Permit)
Total waste flow	continuous	no change
Total residual chlorine	continuous	no change
Turbidity	continuous	no change
Temperature	weekly	no change
pH	weekly	no change
Settleable solids	weekly	no change
Total suspended solids	weekly	no change
Oil and grease	monthly	quarterly
BOD	weekly	no change
Dissolved oxygen	monthly	no change
Total coliform	daily	no change
Fecal Coliform	daily	no change

Parameter	Monitoring Frequency (2003 Permit)	Monitoring Frequency (2014 Permit)
E.coli	not monitored	daily (as necessary)
Total Dissolved Solids	monthly	no change
Sulfate	monthly	no change
Chloride	monthly	no change
Boron	monthly	no change
MBAS	monthly	quarterly
CTAS	monthly	quarterly
Ammonia nitrogen	monthly	no change
Nitrate + nitrite (as nitrogen)	monthly	no change
Nitrite nitrogen	monthly	no change
Organic N	monthly	no change
TKN	monthly	no change
Orthophosphate-P	monthly	no change
Total Hardness (CaCO <sub>3</sub> )	weekly	monthly
Chronic toxicity	monthly	no change
Bis(2-ethylhexyl)phthalate	monthly	no change
Total Nitrogen	monthly	no change
Total Phosphorus	monthly	no change
Algal biomass (Chlorophyll a)	monthly	deleted
Iron	quarterly	quarterly
Fluoride	monthly	semiannually
Antimony	quarterly	semiannually
Arsenic	quarterly	no change
Beryllium	quarterly	semiannually
Cadmium	quarterly	semiannually
Chromium III	quarterly	semiannually
Chromium VI	quarterly	semiannually
Copper	quarterly	monthly
Lead	quarterly	semiannually
Mercury	quarterly	monthly
Nickel	quarterly	monthly
Selenium	quarterly	semiannually
Silver	quarterly	semiannually
Thallium	semiannually	no change
Zinc	quarterly	no change
Cyanide	monthly	no change
2,3,7,8-TCDD (Dioxin)	quarterly	no change
Bromoform	quarterly	semiannually
Dibromochloromethane	quarterly	semiannually
Chloroform	quarterly	semiannually
Bromodichloromethane	quarterly	semiannually
Tetrachloroethylene	quarterly	semiannually
1,4-dichlorobenzene	quarterly	semiannually
Alpha BHC	semiannually	quarterly
N-Nitrosodi-n-propylamine	semiannually	no change

Parameter	Monitoring Frequency (2003 Permit)	Monitoring Frequency (2014 Permit)
Gamma-BHC (Lindane)	quarterly	semiannually
Chlordane	quarterly	no change
4,4'-DDT	semiannually	quarterly
4,4'-DDE	monthly	quarterly
4,4'-DDD	monthly	quarterly
Aldrin	semiannually	quarterly
Dieldrin	semiannually	quarterly
Endrin	quarterly	semiannually
Heptachlor epoxide	semiannually	quarterly
PCBs	semiannually	quarterly
Aroclor 1016	semiannually	quarterly
Aroclor 1221	semiannually	quarterly
Aroclor 1232	semiannually	quarterly
Aroclor 1242	semiannually	quarterly
Aroclor 1248	semiannually	quarterly
Aroclor 1254	monthly	quarterly
Aroclor 1260	semiannually	quarterly
Toxaphene	quarterly	no change
Chlorpyrifos	not monitored	quarterly
Diazinon	not monitored	quarterly
Methoxychlor	quarterly	semiannually
Barium	quarterly	semiannually
2,4-D	quarterly	semiannually
2,4,5-TP (Silvex)	quarterly	semiannually
Total trihalomethanes <sup>35</sup>	quarterly	no change
Ammonium perchlorate	annually	no change
1,4-Dioxane	annually	no change
1,2,3-Trichloropropane	annually	no change
Methyl-tert-butyl-ether (MTBE)	semiannually	semiannually
Remaining USEPA priority pollutant not listed on this Table	semiannually	semiannually

### C. WET Requirements

WET testing protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a short or longer period of time and may measure mortality, reproduction, and growth. Chronic toxicity is a more stringent requirement than acute toxicity. A chemical at a low concentration can have chronic effects but no acute effects until it gets to the higher level. For this permit, chronic toxicity in the discharge is evaluated using USEPA's 2010 Test of Significant Toxicity (TST) hypothesis testing approach. The chronic toxicity effluent limitations are as stringent as necessary to protect the narrative Basin Plan Water Quality Objective for chronic toxicity. Those limitations

<sup>35</sup> Total trihalomethanes shall mean the sum of bromoform, bromodichloromethane, chloroform, and dibromochloromethane.

are also consistent with the assumptions of the *Calleguas Creek Toxicity TMDL* which went into effect on March 24, 2006, and the implementation language which reads as follows: "The toxicity WLAs will be implemented in accordance with USEPA, State Board and Regional Board resolutions, **guidance** (emphasis added) and policy at the time of permit issuance or renewal." The rationale for WET has been discussed extensively in section IV.C.5 of this Fact Sheet.

#### D. Receiving Water Monitoring

##### 1. Surface Water

Receiving water monitoring is required to determine compliance with receiving water limitations and to characterize the water quality of the receiving water.

##### 2. Groundwater – (Not Applicable)

#### E. Other Monitoring Requirements

##### 1. Watershed Monitoring and Bioassessment Monitoring

The goals of the Watershed-wide Monitoring Program including the bioassessment monitoring for the Conejo Creek Watershed are to:

- Determine compliance with receiving water limits;
- Monitor trends in surface water quality;
- Ensure protection of beneficial uses;
- Provide data for modeling contaminants of concern;
- Characterize water quality including seasonal variation of surface waters within the watershed;
- Assess the health of the biological community; and,
- Determine mixing dynamics of effluent and receiving waters in the estuary.

#### VIII. Consideration of Need to Prevent Nuisance and California Water Code Section 13241 Factors.

Some of the provisions/requirements in this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations. As required by CWC section 13263, the Regional Water Board has considered the need to prevent nuisance and the factors listed in CWC section 13241 in establishing the state law provisions/requirements. The Regional Water Board finds, on balance, that the state law requirements in this Order are reasonably necessary to prevent nuisance and to protect beneficial uses identified in the Basin Plan, and the section 13241 factors are not sufficient to justify failing to protect those beneficial uses.

- A. Need to prevent nuisance: The state law requirements in this Order are required to prevent pollution or nuisance as defined in section 13050, subdivisions (l) and (m), of the CWC. Many are also required in accordance with narrative water quality objectives in the Basin Plan. These state requirements include, but are not limited to, groundwater limitations, spill prevention plans, operator certification, sanitary sewer overflow reporting, and requirements for standby or emergency power.

- B. Past, present, and probable future beneficial uses of water:** Chapter 2 of the Basin Plan identifies designated beneficial uses for water bodies in the Los Angeles Region. Beneficial uses of water relevant to this Order are also identified above in Section III.C.1.
- C. Environmental characteristics of the hydrographic unit under consideration, including the quality of water available thereto:** The environmental characteristics are discussed in the Region's Watershed Management Initiative Chapter, as well as available in State of the Watershed reports and the State's CWA Section 303(d) List of impaired waters. The environmental characteristics of the hydrographic unit, including the quality of available water, will be improved by compliance with the requirements of this Order. Additional information on the CCW is available at [http://www.waterboards.ca.gov/losangeles/water\\_issues/programs/regional\\_program/Water\\_Quality\\_and\\_Watersheds/ws\\_calleguas.shtml](http://www.waterboards.ca.gov/losangeles/water_issues/programs/regional_program/Water_Quality_and_Watersheds/ws_calleguas.shtml)
- D. Water quality conditions that could reasonably be achieved through the coordinated control of all factors which affect water quality in the area:** The beneficial uses of the waterbodies in the CCW can reasonably be achieved through the coordinate control of all factors that affect water quality in the area. TMDLs have been developed (as required by the Clean Water Act) for many of the impairments in the watershed. A number of Regional Water Board programs and actions are in place to address the water quality impairments in the watershed, including regulation of point source municipal and industrial discharges with appropriate NPDES permits and non-point source discharges such as irrigated agriculture. All of these regulatory programs control the discharge of pollutants to surface and ground waters to prevent nuisance and protect beneficial uses. These regulatory programs have resulted in watershed solutions and have improved water quality. Generally, improvements in the quality of the receiving waters impacted by the permittee's discharges can be achieved by reducing the volume of discharges to receiving waters (e.g., through increased recycling), reducing pollutant loads through source control/pollution prevention, including operational source control such as public education (e.g., disposal of pesticides, pharmaceuticals, and personal care products into the sewer) and product or materials elimination or substitution, and removing pollutants through treatment.
- E. Economic considerations:** The Permittee did not present any evidence regarding economic considerations related to this Order. However, the Regional Water Board has considered the economic impact of requiring certain provisions pursuant to state law. The additional costs associated with complying with state law requirements are reasonably necessary to prevent nuisance and protect beneficial uses identified in the Basin Plan. Further, the loss of, or impacts to, beneficial uses would have a detrimental economic impact. Economic considerations related to costs of compliance are therefore not sufficient, in the Regional Water Board's determination, to justify failing to prevent nuisance and protect beneficial uses
- F. Need for developing housing within the region:** The Regional Water Board has no evidence regarding the need for developing housing within the region or how the Permittee's discharge will affect that need. The Regional Water Board, however, does not anticipate that these state law requirements will adversely impact the need for housing in the area. The region generally relies on imported water to meet many of its water resource needs. Imported water makes up a vast majority of the region's water supply, with local groundwater, local surface water, and reclaimed water making up the remaining amount. This Order helps address the need for housing by controlling pollutants in discharges, which will improve the quality of local surface and ground water, as well as water available for

recycling and re-use. This in turn may reduce the demand for imported water thereby increasing the region's capacity to support continued housing development. A reliable water supply for future housing development is required by law, and with less imported water available to guarantee this reliability, an increase in local supply is necessary. Therefore, the potential for developing housing in the area will be facilitated by improved water quality.

- G. Need to develop and use recycled water:** The State Water Board's Recycled Water Policy requires the Regional Water Boards to encourage the use of recycled water. In addition, as discussed immediately above, a need to develop and use recycled water exists within the region, especially during times of drought. To encourage recycling, the Permittee is required by this Order to continue to explore the feasibility of recycling to maximize the beneficial reuse of tertiary treated effluent.

## **IX. PUBLIC PARTICIPATION**

The Regional Water Board has considered the issuance of WDRs that will serve as an NPDES permit for Camarillo WRP. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs and has encouraged public participation in the WDR adoption process.

### **A. Notification of Interested Parties**

The Regional Water Board notified the Permittee and interested agencies and persons of its intent to prescribe WDRs for the discharge and provided an opportunity to submit written comments and recommendations. Notification was provided through the following: public notice in daily newspaper <**Describe Notification Process (e.g., newspaper name and date)**>.

The public had access to the agenda and any changes in dates and locations through the Regional Water Board's website at: <http://www.waterboards.ca.gov/losangeles/>.

### **B. Written Comments**

Interested persons were invited to submit written comments concerning tentative WDRs as provided through the notification process. Comments were due either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order, or by email submitted to [losangeles@waterboards.ca.gov](mailto:losangeles@waterboards.ca.gov).

To be fully responded to by staff and considered by the Regional Water Board, the written comments were due at the Regional Water Board office by 5:00 p.m. on April 14, 2014.

### **C. Public Hearing**

The Regional Water Board held a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: May 8, 2014  
Time: 9:00 a.m.  
Location: City of Simi Valley, Council Chambers  
2929 Tapo Canyon Road  
Simi Valley, California

Interested persons were invited to attend. At the public hearing, the Regional Water Board heard testimony pertinent to the discharge, WDRs, and permit. For accuracy of the record, important testimony was requested in writing.

**D. Reconsideration of Waste Discharge Requirements**

Any aggrieved person may petition the State Water Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be received by the State Water Board at the following address within 30 calendar days of the Regional Water Board's action:

State Water Resources Control Board  
Office of Chief Counsel  
P.O. Box 100, 1001 I Street  
Sacramento, CA 95812-0100

For instructions on how to file a petition for review, see  
[http://www.waterboards.ca.gov/public\\_notices/petitions/water\\_quality/wqpetition\\_instr.shtml](http://www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instr.shtml)

**E. Information and Copying**

The ROWD, other supporting documents, and comments received are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (213) 576-6600.

**F. Register of Interested Persons**

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

**G. Additional Information**

Requests for additional information or questions regarding this order should be directed to Veronica Cuevas at (213) 576-6662.

## ATTACHMENT G – TOXICITY REDUCTION EVALUATION (TRE) WORK PLAN

### INFORMATION AND DATA ACQUISITION

#### A. Operations and performance review

1. NPDES permit requirements
  - a. Effluent limitations
  - b. Special conditions
  - c. Monitoring data and compliance history
2. POTW design criteria
  - a. Hydraulic loading capacities
  - b. Pollutant loading capacities
  - c. Biodegradation kinetics calculations/assumptions
3. Influent and effluent conventional pollutant data
  - a. Biochemical oxygen demand (BOD5)
  - b. Chemical oxygen demand (COD)
  - c. Suspended solids (SS)
  - d. Ammonia
  - e. Residual chlorine
  - f. pH
4. Process control data
  - a. Primary sedimentation - hydraulic loading capacity and BOD and SS removal
  - b. Activated sludge - Food-to-microorganism (F/M) ratio, mean cell residence time (MCRT), mixed liquor suspended solids (MLSS), sludge yield, and BOD and COD removal
  - c. Secondary clarification - hydraulic and solids loading capacity, sludge volume index and sludge blanket depth
5. Operations information
  - a. Operating logs
  - b. Standard operating procedures
  - c. Operations and maintenance practices
6. Process sidestream characterization data
  - a. Sludge processing sidestreams
  - b. Tertiary filter backwash
  - c. Cooling water
7. Combined sewer overflow (CSO) bypass data
  - a. Frequency

- b. Volume
- 8. Chemical coagulant usage for wastewater treatment and sludge processing
  - a. Polymer
  - b. Ferric chloride
  - c. Alum

**B. POTW influent and effluent characterization data**

- 1. Toxicity
- 2. Priority pollutants
- 3. Hazardous pollutants
- 4. SARA 313 pollutants,
- 5. Other chemical-specific monitoring results

**C. Sewage residuals (raw, digested, thickened and dewatered sludge and incinerator ash) characterization data**

- 1. EP toxicity
- 2. Toxicity Characteristic Leaching Procedure (TCLP)
- 3. Chemical analysis

**D. Industrial waste survey (IWS)**

- 1. Information on IUs with categorical standards or local limits and other significant non-categorical IUs
- 2. Number of IUs
- 3. Discharge flow
- 4. Standard Industrial Classification (SIC) code
- 5. Wastewater flow
  - a. Types and concentrations of pollutants in the discharge
  - b. Products manufactured
- 6. Description of pretreatment facilities and operating practices
- 7. Annual pretreatment report
- 8. Schematic of sewer collection system

9. POTW monitoring data
  - a. Discharge characterization data
  - b. Spill prevention and control procedures
  - c. Hazardous waste generation
10. IU self-monitoring data
  - a. Description of operations
  - b. Flow measurements
  - c. Discharge characterization data
  - d. Notice of sludge loading
  - e. Compliance schedule (if out of compliance)
11. Technically based local limits compliance reports
12. Waste hauler monitoring data manifests
13. Evidence of POTW treatment interferences (i.e., biological process inhibition)

## ATTACHMENT H – BIOSOLIDS AND SLUDGE MANAGEMENT

### BIOSOLIDS USE AND DISPOSAL REQUIREMENTS

- A. All biosolids generated by the Permittee shall be reused or disposed of in compliance with the applicable portions of:
  - 1. 40 CFR part 503: for biosolids that are land applied, placed in surface disposal sites (dedicated land disposal sites or monofills), or incinerated; 40 CFR part 503 Subpart B (land application) applies to biosolids placed on the land for the purpose of providing nutrients or conditioning the soil for crops or vegetation. 40 CFR part 503 Subpart C (surface disposal) applies to biosolids placed on the land for the purpose of disposal.
  - 2. 40 CFR part 258: for biosolids disposed of in Municipal Solid Waste landfills.
  - 3. 40 CFR part 257: for all biosolids disposal practices not covered under 40 CFR part 258 or 503.
- B. The Permittee is responsible for assuring that all biosolids from its facility are used or disposed of in accordance with 40 CFR part 503, whether the Permittee reuses or disposes of the biosolids itself or transfers them to another party for further treatment, reuse, or disposal. The Permittee is responsible for informing subsequent preparers, applicators, or disposers of the requirements they must meet under 40 CFR part 503.
- C. Duty to mitigate: The Permittee shall take all reasonable steps to prevent or minimize any biosolids use or disposal which may adversely impact human health or the environment.
- D. No biosolids shall be allowed to enter wetland or other waters of the United States.
- E. Biosolids treatment, storage, and use or disposal shall not contaminate groundwater.
- F. Biosolids treatment, storage, and use or disposal shall not create a nuisance such as objectionable odors or flies.
- G. The Permittee shall assure that haulers who transport biosolids off site for further treatment, storage, reuse, or disposal take all necessary measures to keep the biosolids contained.
- H. If biosolids are stored for over two years from the time they are generated, the Permittee must ensure compliance with all the requirements for surface disposal under 40 CFR part 503 Subpart C, or must submit a written request to USEPA with the information in part 503.20 (b), requesting permission for longer temporary storage.
- I. Sewage sludge containing more than 50 mg/kg PCB's shall be disposed of in accordance with 40 CFR part 761.
- J. Any off-site biosolids treatment, storage, use or disposal site operated by the Permittee within Region 4 (Los Angeles Region of RWQCB) that is not subject to its own Waste Discharge Requirements shall have facilities adequate to divert surface runoff from the adjacent area, to

protect the site boundaries from erosion, and to prevent any conditions that would cause drainage from the materials in the disposal site to escape from the site. Adequate protection is defined as protected from at least a 100-year storm and from the highest tidal stage that may occur.

K. Inspection and Entry: The Regional Water Board, USEPA or an authorized representative thereof, upon the presentation of credentials, shall be allowed by the Permittee, directly or through contractual arrangements with their biosolids management contractors, to:

1. enter upon all premises where biosolids are produced by the Permittee and all premises where Permittee biosolids are further treated, stored, used, or disposed, either by the Permittee or by another party to whom the Permittee transfers the biosolids for further treatment, storage, use, or disposal;
2. have access to and copy any records that must be kept under the conditions of this permit or of 40 CFR part 503, by the Permittee or by another party to whom the Permittee transfers the biosolids for further treatment, storage, use, or disposal; and
3. inspect any facilities, equipment (including monitoring and control equipment), practices, or operations used in the production of biosolids and further treatment, storage, use, or disposal by the Permittee or by another party to whom the Permittee transfers the biosolids for further treatment, storage, use, or disposal.

L. Monitoring shall be conducted as follows:

1. Biosolids shall be tested for the metals required in part 503.16 (for land application) or part 503.26 (for surface disposal), using the methods in "Test Methods for Evaluating Solids Waste, Physical/Chemical Methods" (SW-846), as required in 503.8(b)(4), at the following minimum frequencies:

<u>Volume (dry metric tons/year)</u>	<u>Frequency</u>
0 – 290	once per year
290 – 1500	once per quarter
1500 – 15000	once per 60 days
> 15000	once per month

For accumulated, previously untested biosolids, the Discharge shall develop a representative sampling plan, which addresses the number and location of sampling points, and collect representative samples.

Test results shall be expressed in mg pollutant per kg biosolids on a 100% dry weight basis.

Biosolids to be land applied shall be tested for Organic-N, ammonium-N, and nitrate-N at the frequencies required above.

2. Prior to land application, the Permittee shall demonstrate that the biosolids meet Class A or Class B pathogen reduction levels by one of the methods listed in 40 CFR part 503.32. Prior to disposal in a surface disposal site, the Permittee shall demonstrate that the biosolids meet Class B levels or shall ensure that the site is covered at the end of each operating day.

3. For biosolids that are land applied or placed in a surface disposal site, the Permittee shall track and keep records of the operational parameters used to achieve Vector Attraction Reduction requirements in 40 CFR § 503.33 (b).
  4. Class 1 facilities (facilities with pretreatment programs or others designated as Class 1 by the Regional Administrator) and Federal facilities with > 5 mgd influent flow shall sample biosolids for pollutants listed under section 307 (a) of the Act (as required in the pretreatment section of the permit for POTWs with pretreatment programs.) Class 1 facilities and Federal Facilities with > 5 mgd influent flow shall test dioxins/dibenzofurans using a detection limit of < 1 pg/g during their next sampling period if they have not done so within the past 5 years and once per 5 years thereafter.
  5. The biosolids shall be tested annually or more frequently if necessary to determine hazardousness in accordance with California Law.
  6. If biosolids are placed in a surface disposal site (dedicated land disposal site or monofill), a qualified groundwater scientist shall develop a groundwater monitoring program for the site, or shall certify that the placement of biosolids on the site will not contaminate an aquifer.
  7. Biosolids placed in a municipal landfill shall be tested semi-annually by the Paint Filter Test (SW-846, Method 9095) to demonstrate that there are no free liquids.
- M. The Permittee either directly or through contractual arrangements with their biosolids management contractors shall comply with the following 40 CFR part 503 notification requirements:
8. A reuse/disposal plan shall be submitted to USEPA Region IX Coordinator and, in the absence of other state or regional reporting requirements, to the state permitting agency, prior to the use or disposal of any biosolids from this facility to a new or previously unreported site. The plan shall be submitted by the land applier of the biosolids and shall include, a description and a topographic map of the proposed site(s) for reuse or disposal, names and addresses of the applier(s) and site owner(s), and a list of any state or local permits which must be obtained. For land application sites, the plan shall include a description of the crops or vegetation to be grown, proposed nitrogen loadings to be used for the crops, and a groundwater monitoring plan if one exists.
  9. If the Permittee biosolids do not meet 40 CFR § 503.13 Table 3 metals concentration limits, the Permittee must require their land applier to contact the state permitting authority to determine whether bulk biosolids subject to the cumulative pollutant loading rates in 40 CFR § 503.12(b)(2) have been applied to the site since July 20, 1993, and, if so, the cumulative amount of pollutants applied to date, and background concentration, if known. The Permittee shall then notify USEPA Region IX Coordinator of this information.

10. For biosolids that are land applied, the Permittee shall notify the applier in writing of the nitrogen content of the biosolids, and the applier's requirements under 40 CFR part 503, including the requirements that the applier certify that the requirement to obtain information in Subpart A, and that the management practices, site restrictions, and any applicable vector attraction reduction requirements Subpart D have been met. The Permittee shall require the applier to certify at the end of 38 months following application of Class B biosolids that those harvesting restrictions in effect for up to 38 months have been met.
  11. If bulk biosolids are shipped to another State or to Indian Lands, the Permittee must send written notice prior to the initial application of bulk biosolids to the permitting authorities in the receiving State or Indian Land (the USEPA Regional Office for the area and the State/Indian authorities).
  12. Notification of 40 CFR part 503 non-compliance: The Permittee shall require appliers of their biosolids to notify USEPA Region 9 and their state permitting agency of any noncompliance within 24 hours if the non-compliance may seriously endanger health or the environment. For other instances of non-compliance, the Permittee shall require appliers of their biosolids to notify USEPA Region 9 and their state permitting agency of the non-compliance in writing within 10 working days of becoming aware of the non-compliance.
- N. The Permittee shall submit an annual biosolids report to USEPA Region IX Biosolids Coordinator and the Los Angeles Regional Water Quality Control Board by February 19 of each year for the period covering the previous calendar year. The report shall include:
1. The amount of biosolids generated that year, in dry metric tons, and the amount accumulated from previous years.
  2. Results of all pollutant monitoring required in the Monitoring Section above.
  3. Descriptions of pathogen reduction methods, and vector attraction reduction methods, as required in 40 CFR parts 503.17 and 503.27.
  4. Results of any groundwater monitoring or certification by groundwater scientist that the placement of biosolids in a surface disposal site will not contaminate an aquifer.
  5. Names and addresses of land appliers and surface disposal site operators, and volumes applied (dry metric tons).
  6. Names and addresses of persons who received biosolids for storage, further treatment, disposal in a municipal waste landfill, or for other reuse/disposal methods not covered in N.3, above, and volumes delivered to each.
- O. The Permittee shall require all parties contracted to manage their biosolids to submit an annual biosolids report to USEPA Region IX Biosolids Coordinator by February 19 of each year for the period covering the previous calendar year. The report shall include:
1. Names and addresses of land appliers and surface disposal site operators, name, location (latitude/longitude), and size (hectares) of site(s), volumes applied/disposed (dry metric tons) and for land application, biosolids loading rates (metric tons per hectare),

nitrogen loading rates (kg/ha), dates of applications, crops grown, dates of seeding and harvesting and certifications that the requirement to obtain information in 40 CFR § 503.12(e)(2), management practices in § 503.14 and site restrictions in § 503.32(b)(5) have been met.

## ATTACHMENT I – PRETREATMENT REPORTING REQUIREMENTS

The Camarillo Sanitary District (Permittee or District) is required to submit annual Pretreatment Program Compliance Report (Report) to the Regional Water Board and United States Environmental Protection Agency, Region 9 (USEPA). This Attachment outlines the minimum reporting requirements of the Report. If there is any conflict between requirements stated in this attachment and provisions stated in the Waste Discharge Requirements (WDR), those contained in the WDR will prevail.

### A. Pretreatment Requirements

1. The Permittee shall be responsible and liable for the performance of all Control Authority pretreatment requirements contained in 40 CFR part 403, including any subsequent regulatory revisions to part 403. Where part 403 or subsequent revision places mandatory actions upon the Permittee as Control Authority but does not specify a timetable for completion of the actions, the Permittee shall complete the required actions within six months from the issuance date of this permit or the effective date of the part 403 revisions, whichever comes later. For violations of pretreatment requirements, the Permittee shall be subject to enforcement actions, penalties, fines and other remedies by the USEPA or other appropriate parties, as provided in the Act. USEPA may initiate enforcement action against a nondomestic user for noncompliance with applicable standards and requirements as provided in the act.
2. The Permittee shall enforce the requirements promulgated under sections 307(b), 307(c), 307(d) and 402(b) of the Act with timely, appropriate and effective enforcement actions. The Permittee shall cause all nondomestic users subject to federal categorical standards to achieve compliance no later than the date specified in those requirements or, in the case of a new nondomestic user, upon commencement of the discharge.
3. The Permittee shall perform the pretreatment functions as required in 40 CFR part 403 including, but not limited to:
  - a. Implement the necessary legal authorities as provided in 40 CFR § 403.8(f)(1);
  - b. Enforce the pretreatment requirements under 40 CFR parts 403.5 and 403.6;
  - c. Implement the programmatic functions as provided in 40 CFR § 403.8(f)(2); and
  - d. Provide the requisite funding and personnel to implement the pretreatment program as provided in 40 CFR § 403.8(f)(3).
4. The Permittee shall submit annually a report to USEPA Pacific Southwest Region, and the State describing its pretreatment activities over the previous year. In the event the District is not in compliance with any conditions or requirements of this permit, then the District shall also include the reasons for noncompliance and state how and when the District shall comply with such conditions and requirements. This annual report shall cover operations from January 1 through December 31 and is due on April 15 of each year. The report shall contain, but not be limited to, the following information:

- a. A summary of analytical results from representative, flow proportioned, 24-hour composite sampling of the publicly-owned treatment works (POTW) influent and effluent for those pollutants USEPA has identified under section 307(a) of the Act which are known or suspected to be discharged by nondomestic users. This will consist of an annual full priority pollutant scan, with quarterly samples analyzed only for those pollutants detected in the full scan. The District is not required to sample and analyze for asbestos. Sludge sampling and analysis are covered in the sludge section of this permit. The District shall also provide any influent or effluent monitoring data for nonpriority pollutants which the District believes may be causing or contributing to interference or pass through. Sampling and analysis shall be performed with the techniques prescribed in 40 CFR part 136;
- b. A discussion of Upset, Interference or Pass Through incidents, if any, at the treatment plant which the District knows or suspects were caused by nondomestic users of the POTW system. The discussion shall include the reasons why the incidents occurred, the corrective actions taken and, if known, the name and address of the nondomestic user(s) responsible. The discussion shall also include a review of the applicable pollutant limitations to determine whether any additional limitations, or changes to existing requirements, may be necessary to prevent pass through or interference;
- c. An updated list of the District's significant industrial users (SIUs) including their names and addresses, and a list of deletions, additions and SIU name changes keyed to the previously submitted list. The District shall provide a brief explanation for each change. The list shall identify the SIUs subject to federal categorical standards by specifying which set(s) of standards are applicable to each SIU. The list shall also indicate which SIUs are subject to local limitations;
- d. The District shall characterize the compliance status of each SIU by providing a list or table which includes the following information:
  - i. Name of the SIU;
  - ii. Category, if subject to federal categorical standards;
  - iii. The type of wastewater treatment or control processes in place;
  - iv. The number of samples taken by the POTW during the year;
  - v. The number of samples taken by the SIU during the year;
  - vi. For an SIU subject to discharge requirements for total toxic organics, whether all required certifications were provided;
  - vii. A list of the standards violated during the year. Identify whether the violations were for categorical standards or local limits;
  - viii. Whether the facility is in significant noncompliance (SNC) as defined at 40 CFR § 403.8(f)(2)(viii) at any time during the year; and
  - ix. A summary of enforcement or other actions taken during the year to return the SIU to compliance. Describe the type of action, final compliance date, and the amount of fines and penalties collected, if any. Describe any proposed actions for bringing the SIU into compliance.
- e. A brief description of any programs the POTW implements to reduce pollutants from nondomestic users that are not classified as SIUs;

- f. A brief description of any significant changes in operating the pretreatment program which differ from the previous year including, but not limited to, changes concerning the program's administrative structure, local limits, monitoring program or monitoring frequencies, legal authority, enforcement policy, funding levels, or staffing levels;
- g. A summary of the annual pretreatment budget, including the cost of pretreatment program functions and equipment purchases; and
- h. A summary of activities to involve and inform the public of the program including a copy of the newspaper notice, if any, required under 40 CFR § 403.8(f)(2)(viii).

## B. LOCAL LIMITS EVALUATION

1. In accordance with 40 CFR § 122.44(j)(2)(ii), the POTW shall provide a written technical evaluation of the need to revise local limits under 40 CFR § 403.5(c)(1) within 180 days of issuance or reissuance of the NPDES permit.

## C. SIGNATORY REQUIREMENTS AND REPORT SUBMITTAL

1. Signatory Requirements.

The annual report must be signed by a principal executive officer, ranking elected official or other duly authorized employee if such employee is responsible for the overall operation of the POTW. Any person signing these reports must make the following certification [40 CFR § 403.6(a)(2)(ii)]:

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

2. Report Submittal.

An original copy of the Annual Report must be sent to the Pretreatment Program Coordinator of the Regional Water Board and the duplicate copies of the Report must be sent to USEPA through the following addresses:

Information and Technology Unit  
Attn: Pretreatment Program Coordinator  
California Regional Water Quality Control Board, Los Angeles Region  
320 West 4<sup>th</sup> Street, Suite 200  
Los Angeles, CA 90013

Pretreatment Program  
CWA Compliance Office (WTR-7)  
Water Division  
U.S. Environmental Protection Agency, Region IX

CAMARILLO SANITARY DISTRICT  
CAMARILLO WATER RECLAMATION PLANT

ORDER R4-2014-0062  
NPDES NO. CA0053597

75 Hawthorne Street  
San Francisco, CA 94105-3901

# **EXHIBIT B**

STATE OF CALIFORNIA  
 CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
 LOS ANGELES REGION

TIME SCHEDULE ORDER NO. R4-2011-0126-A02

REQUIRING CAMARILLO SANITARY DISTRICT  
 (CAMARILLO WATER RECLAMATION PLANT)  
 TO COMPLY WITH REQUIREMENTS PRESCRIBED IN  
 ORDER NO. R4-2014-0062  
 (NPDES PERMIT NO. CA0053597)

The California Regional Water Quality Control Board, Los Angeles Region (hereafter Regional Water Board) finds:

1. Camarillo Sanitary District (hereafter Camarillo SD or Permittee) owns and operates the Camarillo Water Reclamation Plant (hereafter Camarillo WRP), a tertiary wastewater treatment plant located at 150 East Howard Road, Camarillo, California.
2. The Camarillo WRP discharges tertiary-treated wastewater under waste discharge requirements contained in Order No. R4-2003-0079, adopted by this Regional Water Board on June 5, 2003. Order No. R4-2003-0079 serves as a permit under the National Pollutant Discharge Elimination System (NPDES No. CA0053597) and regulates the discharge of treated wastewater to Conejo Creek, a water of the United States and the State of California, within the Calleguas Creek Watershed (CCW). Order No. R4-2003-0079 expired on May 10, 2008, but has been administratively extended. Order No. R4-2014-0062, renewing the NPDES permit for the Camarillo WRP was adopted by the Regional Water Board following a hearing on May 8, 2014.
3. Eleven of the fourteen reaches of in the CCW were identified on the 2002 and the 2006 Clean Water Act (CWA) Section 303(d) List of water quality limited segments as impaired due to elevated levels of boron, chloride, sulfate, or total dissolved solids (TDS). These constituents are commonly referred to as salts. The reach to which Camarillo SD discharges remains on the most recent 303(d) List, *2010 California List of Water Quality Limited Segments (2010 303(d) List)*, which was approved by the United States Environmental Protection Agency (USEPA) on November 12, 2010. It is grouped under Category 4A of the 2010 303(d) List because the impairments are being addressed by a USEPA-approved TMDL. Salts primarily impact two beneficial uses: agricultural supply (AGR) and ground water recharge (GWR).
4. Order No. R4-2003-0079 prescribes the following final effluent limitations for protection of the AGR and GWR beneficial uses:

Constituent	Units	Effluent Limitations	
		Monthly Average	Daily Maximum
Total dissolved solids (TDS)	mg/L	850	--
	lbs/day	47,900	--
Sulfate	mg/L	250	--

Constituent	Units	Effluent Limitations	
		Monthly Average	Daily Maximum
		lbs/day	14,000
Chloride (routine conditions)	lbs/day	2,300 <sup>1</sup>	--
Chloride (drought conditions)	lbs/day	2,200 <sup>2</sup>	--

The final effluent limitations for TDS and sulfate were based upon Water Quality Objectives in the *Water Quality Control Plan, Los Angeles Region: Basin Plan for the Coastal Watersheds of Los Angeles and Ventura Counties* (Basin Plan). The final effluent limitations for chloride were based upon the Waste Load Allocations (WLAs) promulgated by USEPA in 2002 in the *Calleguas Creek Chloride Total Maximum Daily Load (Chloride TMDL)*.

- Also on June 5, 2003, concurrent with adoption of Order No. R4-2003-0079, this Regional Water Board adopted Time Schedule Order (TSO) No. R4-2003-0080, which prescribed the following interim effluent limit for chloride:

Constituent	Units	Interim Effluent Limitations	
		Monthly Average	Daily Maximum
Chloride	mg/L	--	190
	lbs/day	--	10,700

- On July 7, 2003, the Camarillo SD filed a petition with the State Water Resources Control Board (State Water Board) seeking, in part, review of the chloride effluent limitations in Order No. R4-2003-0079 and TSO No. R4-2003-0080. Camarillo SD later requested that the State Water Board issue a stay of those limitations.
- On October 20, 2003, Camarillo SD, the City of Thousand Oaks, the City of Simi Valley and this Regional Water Board entered into a stipulation entitled *Stipulation for Further Order Issuing Stay*, which stayed the final chloride effluent limitations in the NPDES permits, as well as provisions pertaining to chloride limits in TSOs, for those three wastewater treatment plants. Specifically to the Camarillo WRP, the stipulation stayed the final chloride effluent limitations in Order No. R4-2003-0079 and the interim chloride effluent limitations in TSO No. R4-2003-0080. On November 19, 2003, the State Water Board adopted Order WQO 2003-0019 approving the stipulation.
- On April 2, 2007, the Executive Officer administratively issued TSO No. R4-2007-0010 to the Camarillo SD for its Camarillo WRP. The TSO, which expired on January 31, 2011, contained the following performance-based interim effluent limitations calculated using the

<sup>1</sup> This is the chloride waste load allocation (WLA) under routine conditions, pursuant to the *Calleguas Creek Chloride Total Maximum Daily Load (Chloride TMDL)* promulgated by the United States Environmental Protection Agency (USEPA) on March 22, 2002.

<sup>2</sup> This is the chloride WLA under drought conditions, pursuant to the *Chloride TMDL* promulgated by USEPA on March 22, 2002.

ninety-fifth percentile of the Camarillo WRP's effluent data from August 2003 through May 2006:

Constituent	Units	Interim Effluent Limitations	
		Monthly Average	Daily Maximum
TDS	mg/L	1016	--
	lbs/day	57,200	--
Sulfate	mg/L	265	--
	lbs/day	14,900	--

An interim effluent limitation for chloride was not provided in TSO No. R4-2007-0010 because the stipulated stay on the chloride effluent limitation approved by the State Water Board remained in effect.

9. On October 4, 2007, the Regional Water Board adopted Resolution No. R4-2007-016, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) for Calleguas Creek Watershed (Salts TMDL)*. The *Salts TMDL*, which became effective on December 2, 2008, contains the following interim and final WLAs for the Camarillo WRP:

Constituent	Interim Monthly Average WLA (mg/L)	Final WLA (lb/day) <sup>3</sup>
TDS	1012	850* Q - AF
Sulfate	283	250* Q - AF
Chloride	216	150* Q - AF
Boron	N/A	N/A

The WLAs for chloride contained in the Regional Water Board's *Salts TMDL* superseded the WLAs for chloride contained in the 2002 USEPA-promulgated *Chloride TMDL*.

10. In 2008, tentative waste discharge requirements prepared for the Camarillo WRP, and for other wastewater treatment plants in the Calleguas Creek watershed, were provided to interested persons and comments were solicited. However, Regional Water Board staff ultimately chose not to take those tentative waste discharge requirements to the Regional Water Board for consideration since, at that time, the State Water Board was in the process of developing a state-wide policy for chronic toxicity that could impact how the Regional Water Board implements Resolution No. R4-2005-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Toxicity, Chlorpyrifos, and Diazinon in Calleguas Creek, its Tributaries, and Mugu*

<sup>3</sup> AF represents the adjustment factor, which equals the difference between the minimum salts export requirement and the actual salts export.

Q represents the POTW flow at the time the water quality measurement is collected and a conversion factor to lbs/day based on the units of measurement for the flow.

*Lagoon (Toxicity TMDL)*, in these waste discharge requirements. As of the date of this Order, the State Water Board's policy for chronic toxicity is still under development, which has delayed consideration of a renewed permit for Camarillo WRP and the other wastewater treatment plants in the Calleguas Creek watershed. Accordingly, the Regional Water Board has not incorporated the interim and final WLAs in the *Salts TMDL* as effluent limitations within the NPDES permit for the Camarillo WRP.

11. On December 7, 2010, the Camarillo SD submitted a letter to the Regional Water Board requesting an extension of the TDS and sulfate interim effluent limits in TSO No. R4-2007-0010. The Camarillo SD listed the following reasons to justify their request:
  - a. Camarillo SD's current treatment processes are unable to treat dissolved salts, such as TDS, sulfate, and chloride, in the potable water supply.
  - b. Camarillo SD and other stakeholders within Calleguas Creek Watershed have developed regional solution strategies to address the salt accumulation problem that is impairing surface waters, such as:
    - i. finding locations for brackish groundwater treatment facilities,
    - ii. constructing a regional salinity management pipeline also known as a "brine line", and
    - iii. increasing recycled water usage.

As an attachment to their letter, Camarillo SD submitted tabulated effluent water quality data for TDS and sulfate from January 2007 to October 2010.

12. TSO No. R4-2007-0010 expired on January 31, 2011. At that time, Camarillo SD was not eligible for another TSO under California Water Code (CWC) section 13385(j)(3)(B)(i) that would shield Camarillo SD from mandatory minimum penalties for violations of the final effluent limitations for TDS and sulfate, because Order No. R4-2003-0079 did not contain new, more stringent, or modified effluent limitations when compared to those found in the previous permit.
13. To provide Camarillo SD with higher interim effluent limitations based on the interim WLAs in the *Salts TMDL*, Regional Water Board staff proceeded to prepare a tentative NPDES permit, circulated it for public comment, received comments, responded to those comments, subsequently distributed a revised tentative NPDES permit, and noticed consideration of the permit for renewal at the April 14, 2011, Regional Water Board meeting.
14. On April 14, 2011, the Regional Water Board held a hearing to consider adoption of the proposed tentative NPDES permit for the Camarillo WRP. However, Camarillo SD testified that the interim effluent limits for salts (such as TDS, sulfate and chloride), based upon the interim WLAs in the *Salts TMDL*, would be unattainable during the period of time in which the Permittee has committed to constructing and finishing capital improvement projects to comply with the WLAs specified in the *Salts TMDL*. Camarillo SD requested higher performance-based interim effluent limits, stating that the concentrations of

chloride, TDS, and sulfate in their potable water supply have increased since the time that the *Salts TMDL* was developed. The Regional Water Board directed its staff to pursue alternatives with the Permittee to resolve salts issues while implementing the regional salinity management pipeline solution.

15. On May 6, 2011, Camarillo SD submitted a letter requesting a TSO under CWC section 13385(j)(3)(B)(iii) and included the following supporting documentation:
  - a. A chronology of events that explained the City of Camarillo's unanticipated increase on the reliance of local groundwater as a source of potable water, that resulted from mandatory reductions in water use instituted by Metropolitan Water District (MWD) in July 2009. In order to implement the *Water Supply Action Plan* that was adopted by the MWD Board of Directors, member MWD agencies such as the Calleguas Municipal Water District supplied less imported water to Camarillo. Subsequently, Camarillo relied increasingly more on local groundwater which has a higher salt content than imported water. This ultimately resulted in unavoidable composition changes in Camarillo's potable water, influent and effluent. Consequently, Camarillo SD has exceeded its final effluent limitations by a larger margin;
  - b. Water quality data for its blended potable water supply (consisting of local groundwater from wells and imported water from MWD, the only available sources of potable water available to Camarillo) that showed, in Table 3 of their letter, that average concentrations for TDS, sulfate and chloride increased by 32%, 31%, and 20%, respectively, when comparing data between the periods of January 2004 to December 2006 and January 2007 to March 2011;
  - c. In an attachment to their letter titled *Groundwater vs. Import Water*, Camarillo SD provided quantity data for its blended water supply that showed that the amount of imported water from MWD has been steadily decreasing (by 728 acre-feet a year from 2008 to 2009, and by 1037 acre-feet a year from 2009 to 2010);
  - d. Additional final effluent data for chloride, TDS, and sulfate from November 2010 to March 2011; and,
  - e. Milestones and completion dates for capital improvement projects, which will take longer than thirty days to install and put into operation, including:
    - i. Constructing a connection from Camarillo WRP to Calleguas Municipal Water District's brine line by December 2013, and discharging to the brine line achieving compliance with the salts final effluent limitations between June and December 2014; and
    - ii. Constructing a connection from the Camarillo well desalting facilities to the Calleguas Municipal Water District's brine line by December 2015.
16. On July 10, 2013, Camarillo SD submitted a letter requesting an additional year to complete the milestone deadlines included on page 8 of this TSO. Camarillo SD staff

informed Regional Water Board staff that additional time was needed to: design and construct a metering station for the brine line connection; amend the CEQA document for their project to address comments received during the public review period; conduct additional technical studies; perform biological/habitat fieldwork; gather additional stream flow information; and re-circulate the CEQA document for public comment. Regional Water Board staff evaluated the request and modified completion dates as requested, granting an additional year.

17. Camarillo SD's conditions are unique because:
  - a. Their discharge is located a few miles upstream of a tidally-influenced reach of Calleguas Creek;
  - b. Camarillo SD worked effectively for many years to develop a regional solution to remedy salt impairments; and,
  - c. The solution involves desalting groundwater and building a regional brine line which will resolve surface water impairments as well as improve groundwater quality in the watershed.
  
18. NPDES Order No. R4-2014-0062, adopted by the Regional Water Board on May 8, 2014, prescribes the effluent limitations for TDS, chloride, and sulfate based upon the *Salts TMDL* presented in the Table below.

**Table 1. Final Effluent Limitations**

Parameter	Units	Effluent Limitations		
		Average Monthly	Average Weekly	Maximum Daily
Total dissolved solids (dry weather <sup>4</sup> )	lbs/day	51,400 <sup>5</sup>	--	--

<sup>4</sup> This dry-weather final effluent limitation for chloride shall apply on January 1, 2016. See section VII.O. of the NPDES Order for definition of dry- and wet-weather.

<sup>5</sup> These final effluent limitations are consistent with the following *Salts TMDL* Waste Load Allocations: (850 x Q – AF) for TDS; (250xQ – AF) for sulfate; and (150xQ – AF) for chloride, where:

Q represents the POTW effluent flow at the time the water quality measurement is collected and a conversion factor to lbs/day based on the units of measure for the flow.

AF represents the adjustment factor, which equals the difference between the minimum salts export requirement and the actual salts export. The minimum salts export requirement for Chloride = 460 lbs/day. The AF term is equal to zero since the Regional Board has not approved an AF for a facility. As a result, the AF term drops out of the equation, and the final effluent limitations are expressed as follows:

$$\begin{aligned}
 \text{Chloride, lbs/day} &= 150 \times Q = 150 \times 7.25 \times 8.34 = 9,070 \\
 \text{TDS, lbs/day} &= 850 \times Q = 850 \times 7.25 \times 8.34 = 51,400 \\
 \text{Sulfate, lbs/day} &= 250 \times Q = 250 \times 7.25 \times 8.34 = 15,100
 \end{aligned}$$

Parameter	Units	Effluent Limitations		
		Average Monthly	Average Weekly	Maximum Daily
Total dissolved solids (wet weather <sup>4</sup> )	mg/L	850	--	--
Sulfate (dry weather <sup>4</sup> )	lbs/day	15,100 <sup>5</sup>	--	--
Sulfate (wet weather <sup>4</sup> )	mg/L	250	--	--
Chloride (dry weather <sup>4</sup> )	lbs/day	9,070 <sup>5</sup>	--	--
Chloride (wet weather <sup>4</sup> )	mg/L	150	--	--

19. Upon the effective date of NPDES Order No. R4-2014-0062, the stay for the chloride effluent limitations, associated with the former NPDES permit and TSO, contained in the State Water Board's WQO No. 2003-0019 will dissolve.
20. The Discharger cannot consistently meet the final effluent limitations listed above in Table 1 on their respective compliance dates.
21. On February 13, 2014, the Discharger requested in writing a TSO for TDS, chloride and sulfate, under CWC section 13385(j)(3)(B)(iii) and included supporting documentation indicating that the conditions described in finding 15 still continue.
22. On April 14, 2014, the Discharger requested in writing higher interim limits for salts based on anticipated changes to its potable water supply. Camarillo SD is concerned that the effluent concentrations may exceed final effluent limitations due to the new supply of Colorado River Water which is higher in salt content than State Project Water.
23. Regional Water Board staff requested specific information regarding the change in potable water supply for the City of Camarillo. On April 25, 2014, the Discharger submitted additional data indicating that its potable water supply was going to change to include 40% groundwater and 60% imported water, where the imported water supply would be changing from 100% State Project Water to Metropolitan Water District to 80% State Project Water and 20% Colorado River Water. Correspondence indicated that during 2013, Colorado River Water's concentrations of chloride, TDS, and sulfate are 9.2 mg/L, 241 mg/L, and 152 mg/L higher than State Project Water concentrations, respectively.
24. Section 13300 of the CWC states:  

"Whenever a regional board finds that a discharge of waste is taking place or threatening to take place that violates or will violate requirements prescribed by the regional board, or the state board, or that the waste collection, treatment, or disposal facilities of a discharger are approaching capacity, the board may require the discharger to submit for approval of the board, with such modifications as it may deem necessary, a detailed time schedule of specific actions the discharger shall take in order to correct or prevent a violation of requirements."

25. Based on monitoring data, the Permittee cannot consistently achieve compliance with the final effluent limitations for TDS, chloride, and sulfate in Order No. R4-2014-0062. Accordingly, pursuant to CWC section 13300, a discharge of waste is taking place and/or threatens to take place that violates requirements prescribed by the Regional Water Board.
26. Water Code section 13385, subdivisions (h) and (i), require the Regional Water Board to impose mandatory minimum penalties upon dischargers that violate certain effluent limitations. Section 13385(j)(3) exempts violations of an effluent limitation from mandatory minimum penalties "where the waste discharge is in compliance with either a cease and desist order issued pursuant to Section 13301 or a time schedule order issued pursuant to Section 13300, if all of the [specified] requirements are met." (emphasis added).
27. In accordance with CWC section 13385(j)(3)(B)(iii), the Regional Water Board finds that: (a) unanticipated changes in the quality of the municipal or industrial water supply available to the Permittee are the cause of unavoidable changes in the composition of the waste discharge, (b) the changes in the composition of the waste discharge are the cause of the inability to comply with the final effluent limitations for TDS and sulfate, (c) no alternative water supply is reasonably available to the Permittee, and (d) new or modified measures to control the composition of the waste discharge cannot be designed, installed, and put into operation within 30 calendar days.
28. Since the time schedule for completion of the actions necessary to bring the waste discharge into compliance exceeds one year from the effective date of this TSO, this TSO includes interim requirements and the dates for their achievement. The interim requirements include both interim effluent limitations for TDS, chloride, and sulfate and actions and milestones leading to compliance with the final effluent limitation for these pollutants. This TSO does not exceed five years.
29. This TSO establishes interim effluent limits for TDS and sulfate and requires the Permittee to undertake specific actions to put the Permittee on the path towards compliance with the final effluent limitations for TDS, chloride, and sulfate in Order No. R4-2014-0062. The established time schedule is as short as possible, taking into account the technological, operation, and economic factors that affect the design, development, and implementation of the control measures that are necessary to comply with the final effluent limitations for TDS, chloride, and sulfate. The Permittee is on a path to compliance via the regional salinity management pipeline and associated facilities.
30. The monthly average interim effluent limits for TDS, chloride, and sulfate prescribed in this TSO are performance-based values set at the ninety-fifth percentile, derived from final effluent data, using MINITAB, the same statistical software used in the *Salts TMDL* development.
31. CWC section 13385(j)(3)(D) requires the Permittee to prepare and implement a Pollution Prevention Plan (PPP) pursuant to CWC section 13263.3. Therefore, a PPP will be necessary for TDS and sulfate.

32. A TSO is appropriate in these circumstances to allow time for the Permittee to complete capital improvement projects that will bring the Camarillo WRP into compliance with the final effluent limits for TDS and sulfate. These capital improvement projects cannot be designed, installed, and put into operation within 30 calendar days. The temporary TDS and sulfate exceedances allowed by this TSO are in the public interest given the significant environmental benefits associated with promptly achieving compliance with the final effluent limitations for these pollutants.
33. Pursuant to CWC section 13385(j)(3), full compliance with the requirements of this TSO exempts the Permittee from mandatory minimum penalties only for violations of the final effluent limitations for TDS, chloride, and sulfate in Order No. R4-2014-0062 that occur after the effective date of this TSO.
34. This TSO concerns an existing facility and does not significantly alter the status with respect to the facility. This TSO is also being taken for the protection of the environment. Therefore, issuance of this TSO is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21100, et seq.) in accordance with sections 15301 and 15321(a)(2) of Title 14 of the California Code of Regulations (CCR).
35. The Regional Water Board has notified the Permittee and interested agencies and persons of its intent to issue this TSO concerning compliance with waste discharge requirements. The Regional Water Board, in a public hearing, heard and considered all testimony pertinent to this matter.
36. Any person aggrieved by this action of the Regional Water Board may petition the State Water Board to review the action in accordance with CWC section 13320 and CCR, title 23, sections 2050 and following. The State Water Board must *receive* the petition by 5:00 p.m., 30 days after the Regional Water Board action, except that if the thirtieth day following the action falls on a Saturday, Sunday, or state holiday, the petition must be received by the State Water Board by 5:00 p.m. on the next business day. Copies of the law and regulations applicable to filing petitions may be found on the Internet at [http://www.waterboards.ca.gov/public\\_notices/petitions/water\\_quality](http://www.waterboards.ca.gov/public_notices/petitions/water_quality) or will be provided upon request.

**IT IS HEREBY ORDERED** that, pursuant to CWC section 13300, Camarillo SD, as owner and operator of the Camarillo WRP, shall comply with the requirements listed below to ensure compliance with the final effluent limitations for TDS, chloride, and sulfate contained in Order No. R4-2014-0062:

1. Comply immediately with the following interim effluent limits which will apply all year round, and which shall be deemed effective from May 8, 2014 to December 31, 2017:

Constituent	Units	Monthly Average	Daily Maximum
TDS	mg/L	1242 <sup>6</sup>	--
	lbs/day <sup>7</sup>	75,100	--
Sulfate	mg/L	359 <sup>6</sup>	--
	lbs/day <sup>7</sup>	21,700	--
Chloride	mg/L	351 <sup>8</sup>	--
	lbs/day <sup>7</sup>	21,200	--

If the analytical result of a single sample, monitored monthly, exceeds the monthly average interim effluent limitation for that constituent, Camarillo SD may collect up to four additional samples, at approximately equal intervals during that calendar month, to determine compliance with the monthly average interim effluent limitation.

- Complete the capital improvement projects according to the schedule proposed by Camarillo SD in their letter dated July 10, 2013, as follows:

Item	Completion Date
Build a connection from Camarillo SD's WRP to the Calleguas Municipal Water District brine line under Phase 2A	December 2014
Discharge from Camarillo SD to the brine line	December 2015
Improve water supply through construction of Northeast Pleasant Valley (NPV) Desalter and its connection to the Calleguas Municipal Water District brine line	December 2015
Evaluate effectiveness of the NPV Desalter and the connection to the Calleguas Municipal Water District brine line for reducing salts in the effluent	December 2017

<sup>6</sup> This interim effluent limitation is based on effluent performance data from February 2007 through October 2012 for the Camarillo WRP. Consistent with the procedure contained in *Appendix E of USEPA's Technical Support Document For Water Quality-based Toxics Control (USEPA's TSD)*, the monthly average was set at the 95<sup>th</sup> percentile. The interim limit was derived statistically from a probability plot, using the MINITAB statistical software, Release 14.

<sup>7</sup> The mass emission rates are based on the existing plant design flow rate of 7.25 million gallons per day (mgd), and are calculated as follows: Flow (mgd) x Concentration (mg/L) x 8.34 (conversion factor) = mass emission rate (lbs/day). During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

<sup>8</sup> This interim effluent limitation is based on the maximum effluent concentration (MEC) from January 1, 2001 to March 9, 2014.

3. Achieve full compliance with the final effluent limitations as soon as possible, but no later than December 31, 2015, the date by which Camarillo SD committed to achieving compliance, for TDS and sulfate contained in Order No. R4-2014-0062.
4. Submit a Pollution Prevention Plan (PPP) work plan, with the time schedule for implementation, for approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3.
5. Submit quarterly progress reports of efforts taken by the Permittee towards achieving compliance with the final effluent limits for TDS and sulfate. The reports shall summarize the progress to date, activities conducted during that quarter, and the activities planned for the upcoming quarters. The reports shall also state whether or not Camarillo SD was in compliance with the interim effluent limitations for TDS and sulfate during the reporting period. Each quarterly report shall be received by the Regional Water Board by the 15<sup>th</sup> day of the first month following the reporting period (January 15, April 15, July 15, and October 15). The first progress report shall be received by the Regional Water Board by October 15, 2014, and will cover the months of July 2014 through September 2014.
6. Any person signing a document submitted under this TSO shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”
7. If the Permittee fails to comply with any provision of this TSO, the Regional Water Board may take any further action authorized by law. The Executive Officer, or his/her delegee, is authorized to take appropriate enforcement action pursuant, but not limited to, CWC sections 13350 and 13385. The Regional Water Board may also refer any violations to the Attorney General for judicial enforcement, including injunction and civil monetary remedies.
8. All other provisions of NPDES Order No. R4-2014-0062 not in conflict with this TSO are in full force and effect.
9. The Regional Water Board may reopen this TSO at its discretion or at the request of the Permittee, if warranted. Lack of progress towards compliance with this TSO may be cause for the Regional Water Board to modify the conditions of this TSO.
10. This TSO becomes effective immediately upon adoption by the Regional Water Board. This TSO expires on December 31, 2017.

Camarillo Sanitary District  
Camarillo Water Reclamation Plant  
Time Schedule Order No. R4-2011-0126-A02

NPDES No. CA0053597

I, Samuel Unger, Executive Officer, do hereby certify that the foregoing is a full, true and correct copy of an order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on May 8, 2014.

  
Samuel Unger, P.E.  
Executive Officer

DOWNEY BRAND LLP

1 DOWNEY, BRAND LLP  
2 MELISSA A. THORME  
3 621 Capitol Mall, 18th Floor  
4 Sacramento, CA 95814-4686  
5 Tel.: (916) 520-5376  
6 Fax: (916) 520-5776

7 Special Counsel for Petitioner  
8 CAMARILLO SANITARY DISTRICT

*Personally served  
6/4/14  
3:45pm  
AUC*



9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

BEFORE THE  
CALIFORNIA STATE WATER RESOURCES CONTROL BOARD

)  
) **PETITION FOR STAY AND**  
) **COMPLIANCE SCHEDULE**  
) **MODIFICATION FOR SPECIFIC**  
) **PROVISIONS IN ORDER NOS. R4-2014-**  
) **0062 AND R4-2011-0126-A02 ISSUED BY**  
) **THE CALIFORNIA REGIONAL WATER**  
) **QUALITY CONTROL BOARD, LOS**  
) **ANGELES REGION**  
)  
) **[WATER CODE §13320 and §13321; 23**  
) **C.C.R. §2053]**

**INTRODUCTION**

In accordance with Water Code sections 13320 and 13321, Petitioner Camarillo Sanitary District ("District") hereby requests a stay of specific provisions of Order Nos. R4-2014-0062 (the "Permit") and Order No. R4-2011-0126-A02 (the Time Schedule Order or "TSO") adopted by the California Regional Water Quality Control Board for the Los Angeles Region ("Regional Board") on May 8, 2014. Copies of Order Nos. R4-2014-0062 and R4-2011-0126-A02 are attached as Exhibits A and B, respectively, to the District's Petition for Review filed with the State Water Resources Control Board ("State Board").

These orders contain unreasonable, inappropriate, and illegal requirements, which are the subject of a Petition for Review, submitted to the State Board. Because of the substantial harm to

1 the District and the public interest while the District awaits final resolution of its administrative  
2 appeal, the lack of substantial harm to other interested persons and to the public interest if a stay is  
3 granted, and the substantial questions of fact and law that exist, the State Board should  
4 immediately act to stay the requested provisions of these orders pending full administrative review  
5 of the District's Petition for Review.

6 The District specifically requests that the State Board immediately provide notice in  
7 accordance with 23 Cal. Code Reg. §2053(b) on an expedited basis so that a stay may be granted  
8 before the effective date of the permit on July 1, 2014 and so that the District can avoid the  
9 immediate unnecessary expenditure of public funds and corresponding increases in sewer service  
10 fees, the imposition of discretionary administrative civil or criminal penalties, and third party  
11 lawsuits pending administrative review of the District's Petition for Review.

#### 12 LEGAL AUTHORIZATION

13 Water Code section 13320(e) and section 13321(a) authorize the State Board to issue stays  
14 of provisions in Waste Discharge Requirements ("WDRs"). Section 13320(e) states that: "If a  
15 petition for state board review of a regional board action on waste discharge requirements includes  
16 a request for a state of the waste discharge requirements, the state board shall act on the requested  
17 stay portion of the petition within 60 days of accepting the petition. The board may order any stay  
18 to be in effect from the effective date of the waste discharge requirements." Section 13321(a)  
19 further states: "In the case of a review by the state board under section 13320, the state board, upon  
20 notice and hearing, if a hearing is requested, may stay in whole or in part the effect of the decision  
21 and order of a regional board or of the state board."

22 Under Water Code section 13320(c), the State Board "may direct the appropriate action be  
23 taken by the regional board... take the appropriate action itself, or take any combination of those  
24 actions. In taking any action, the state board is vested with all the powers of the regional boards  
25 under this division." This section provides the authority for the State Board to modify (or direct the  
26 Regional Board to modify) the Permit and TSO provisions and provide additional time for  
27 compliance to take into account the pending related Petition for Review. For example, where a  
28 compliance deadline is due 180 days after the effective date of the Permit, that deadline should be

1 modified to be 180 days after the provision on appeal is upheld (if ultimately upheld). This  
 2 modification merely preserves the status quo and tolls the timing of the deadline.

3 Pursuant to State Board regulations implementing the Water Code, the State Board has the  
 4 duty to issue a stay of provisions contained in the Permit if the District can allege facts and provide  
 5 evidence of: (1) substantial harm to the District or to the public interest if a stay is not granted; (2)  
 6 a lack of substantial harm to other interested persons and to the public interest if a stay is granted;  
 7 and (3) substantial questions of fact or law regarding the disputed action. *See* 23 C.C.R.  
 8 §2053(a)(1)-(3); *see accord* Water Code §13321. Importantly, had the U.S. Environmental  
 9 Protection Agency issued this NPDES Permit instead of the Regional Board, issuance of a stay  
 10 would be mandatory. *See* 40 C.F.R. §124.16(a) (“the effect of the contested permit conditions shall  
 11 be stayed”)(emphasis added). California law must be construed to assure consistency with the  
 12 requirements of the Clean Water Act related to NPDES Permits, under which the above regulation  
 13 was promulgated. *See* Water Code §13372; 23 C.C.R. §2235.2.

#### 14 **FACTUAL AND PROCEDURAL BACKGROUND<sup>1</sup>**

15 The District owns and operates a Water Reclamation Plant (“WRP”), a tertiary treatment  
 16 wastewater facility located at 150 Howard Road in Camarillo, California serving a population of  
 17 46,500 people. Permit at pg. F-5. The Camarillo WRP receives mostly commercial and residential  
 18 wastewater from the local collection system along with industrial wastewater from four (4)  
 19 significant industrial users (“SIUs”). *Id.* The Camarillo WRP discharges tertiary treated  
 20 wastewater to Conejo Creek. Permit at F-4.

21 The Permit, along with an amended Time Schedule Order (“TSO”), was adopted by the  
 22 Regional Board on May 8, 2014 with an effective date of July 1, 2014. In the District’s Petition for  
 23 Review, the District requested the State Board to, either on its own motion or in accordance with  
 24 23 C.C.R. §2053(a), issue a stay of the contested provisions of the Permit and TSO. The purpose  
 25 of this Petition for Stay is to satisfy the requirements of the Water Code and implementing  
 26 regulations at 23 C.C.R. §2053(a).

27 \_\_\_\_\_  
 28 <sup>1</sup> To avoid unnecessary duplication, the District incorporates by reference the Factual Background section set forth in  
 the District’s Petition for Review submitted to the State Board.

**PROVISIONS THE DISTRICT IS REQUESTING BE STAYED/MODIFIED  
PENDING DECISION ON THE PETITION FOR REVIEW**

For reasons set forth herein, the District is requesting the following provisions be stayed pending administrative review of the District's Petition for Review:

**EFFLUENT LIMITATIONS AND IMPLEMENTATION PROVISIONS:**

**PERMIT, ORDER R4-2014-0062:**

1. The final numeric wet weather and dry weather effluent limitations for Total Dissolved Solids ("TDS"), Sulfate, and Chloride. (Permit Provision IV.A.1.a., Table 4 at pg.6 and footnotes 2-4.) The Permit prescribes both concentration and mass limits for these constituents as Average Monthly Effluent Limits ("AMEL").

2. The final numeric effluent limitations for Chronic Toxicity and the requirement to use the two concentration Test of Significant Toxicity to implement those limits. (Permit Provision IV.A.1.a., Table 4 at pg. 8 and footnotes 15-17.) The Permit prescribes a Monthly Median Effluent Limitation ("MMEL") of "Pass" and a Maximum Daily Effluent Limitation ("MDEL") of "Pass or %Effect < 50."

3. The Findings in the Permit's Fact Sheet that seemingly require the Permittee to conduct a recycling/reuse feasibility study.<sup>2</sup> (Permit Fact Sheet Section III.C.11. at pg. F-16 ("The Permittee shall submit a report summarizing its plans for recycled water expansion efforts to the Regional Water Board 180 days after the effective date of this Order and a separate report 30 days after completion of a major project."), and at pg. F-61, Section VIII.G. ("To encourage recycling, the Permittee is required by this Order to continue to explore the feasibility of recycling to maximize the beneficial reuse of tertiary treated effluent.))

**TSO, ORDER R4-2011-0126-A02:**

4. Provision in Paragraph 3 on page 11 of the TSO, which requires: "Achieve full compliance with the final effluent limitations as soon as possible, but no later than December 31,

<sup>2</sup> If the State Board believes these to be merely a non-enforceable findings, then the City withdraws this stay request.

1 2015, the date by which Camarillo SD committed to achieving compliance, for TDS and sulfate  
2 contained in Order No.R4-2014-0062.”

3 5. Provision in Paragraph 4 on page 11 of the TSO, which requires the District to  
4 “Submit a Pollution Prevention Plan (PPP) work plan, with the time schedule for implementation,  
5 for approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section  
6 13263.3.”

7 6. Provision in Paragraph 7 on page 8 of the TSO to submit quarterly progress reports,  
8 the first due October 15, 2014, of efforts taken by the Permittee to comply with the final mass-  
9 based limitation for copper and the final effluent limitation for chloride, and the requirements for  
10 the content of those reports.

11 Although there are many other effluent limitations and provisions being petitioned by the  
12 District, these provisions are the ones most likely to cause significant compliance problems for the  
13 District during the pendency of review of its Petition for Review. Thus, the District was selective  
14 in the issues for which a stay is requested.

#### 15 ARGUMENT

16 **A. THE STATE BOARD HAS THE DUTY TO GRANT A STAY OF PROVISIONS IN THE PERMIT  
17 UPON THE SHOWING OF HARM TO THE DISTRICT, A LACK OF HARM TO THE PUBLIC, AND  
18 SUBSTANTIAL QUESTIONS OF LAW OR FACT.**

19 As discussed herein, the District’s stay request meets the regulatory criteria set forth in 23  
20 C.C.R. §2053(a), which mandates that the requested stay be granted by the State Board upon the  
21 District making the required showings. The District therefore requests that the State Board issue  
22 the requisite public notice so that it may grant the District’s stay request on an expedited basis  
23 before the effective date of the permit on July 1, 2014, so that the District can avoid needlessly  
24 expending limited public resources duplicative of those being spent implementing the applicable  
25 Total Maximum Daily Loads (“TMDLs”), increasing sewer service fees to fund unnecessary  
26 facility upgrades at the water reclamation plant instead of implementing a watershed solution, and  
27 avert detrimental discretionary civil and criminal enforcement of the above-named provisions of  
28 the Permit pending administrative review. *See* 23 C.C.R. §2053.

1 **B. THE DISTRICT SATISFIES THE REGULATORY REQUIREMENTS APPLICABLE TO**  
 2 **STAY REQUESTS.**

3 **1. SUBSTANTIAL HARM TO THE DISTRICT OR TO THE PUBLIC INTEREST**  
 4 **WILL OCCUR IF A STAY IS NOT GRANTED.**

5 The District and the public interest will incur substantial harm if the requested stay is not  
 6 granted by the State Board pending administrative review of the District's Petition for Review. In  
 7 accordance with 23 C.C.R. §2053(a), the following discussion alleges facts and provides evidence  
 8 in support of the District's stay request.

9 **A) SUBSTANTIAL HARM TO THE DISTRICT WILL OCCUR IF A STAY IS**  
 10 **NOT GRANTED.**

11 **1) FINAL EFFLUENT LIMITS FOR SALINITY**

12 The District currently operates an advanced tertiary treatment wastewater facility with  
 13 nitrification, de-nitrification and biological nitrogen removal ("BNR") and a dry weather design  
 14 capacity of 7.25 mgd. Permit at F-5. This level of treatment greatly exceeds the secondary  
 15 treatment requirements of the Clean Water Act. *See* 33 U.S.C. §1311(b)(1)(B); *See* Declaration of  
 16 Bruce Feng ("Feng Decl."), filed herewith as Exhibit A, at ¶ 4. However, even the District's  
 17 advanced facilities are not specifically designed for the removal of many pollutants, including  
 18 salinity, which were included as effluent limitations in the Permit. *Id.*

19 Although a compliance schedule was included in the Calleguas Watershed Salinity Total  
 20 Maximum Daily Load ("Salinity TMDL") through 2023,<sup>3</sup> the Permit still contains final numeric  
 21 effluent limitations for salinity constituents described above without the benefit of the  
 22 corresponding TMDL compliance schedule. Without an adequate compliance schedule, it is  
 23 infeasible and impractical to achieve immediate and full compliance with the new final effluent  
 24 limitations contained in the Permit. *See* Permit at pg. F-7, Table F-2; TSO No. R4-2011-0126-A02  
 25 at pg. 7, para. 20 ("The Discharger cannot consistently meet the final effluent limitations"). A

26 \_\_\_\_\_  
 27 <sup>3</sup> *See* Attachment A to Regional Board Res. No. R4-2007-016, at pg. 22, Table 7-22.2, Implementation Schedule ("The  
 28 POTWs and non-stormwater NPDES Permits shall achieve WLAs, which shall be expressed as NPDES mass-based  
 effluent limitations specified in accordance with federal regulations and state policy on water quality control... 15  
 years after effective date of the TMDL.")

1 compliance schedule is needed, as recognized in the TMDL, to provide for sufficient time to  
2 properly develop and implement the tasks required for compliance with the applicable objectives  
3 on a watershed basis in an orderly, logical, and well planned sequence “linked to the construction  
4 schedule for the Regional Salinity Management Conveyance” (RSMC or brine line). *See*  
5 Attachment A to Regional Board Res. No. R4-2007-016, at pg.17.

6 In extensive comments submitted to the Regional Board, the District asserted that a  
7 compliance period is necessary in order to accommodate the magnitude of work necessary to  
8 comply with the water quality standards in the watershed, and the TMDL recognized that this  
9 would be done, not with final numeric effluent limitations on the treatment plants, but through a  
10 watershed wide approach using de-salters on groundwater, constructing the RSMC to remove salts  
11 from the basin, and implementing agricultural BMPs. *See, e.g.*, District’s Comments submitted on  
12 the Permit and TSO; *see also* Order No. R4-2011-0126-A02 at pg. 6, para. 17.

13 Without a compliance schedule, the District will be forced to work on different tasks in  
14 parallel, including tasks to add treatment to the WRP, which were not anticipated by the adopted  
15 and approved TMDL. *See* Feng Decl. at ¶ 5. For example, the District would have to commit to  
16 design and construct additional treatment at the WRP before other activities, such as the RSMC are  
17 complete and may obviate the need for such POTW treatment (*e.g.*, influent source control). *Id.* It  
18 is impractical to begin construction of costly end-of-pipe treatment options when a plan is already  
19 in place and being implemented to address the actual source of the pollutants, which, if successful,  
20 will render additional end-of-pipe treatment unnecessary. *Id.* The District and the other  
21 stakeholders in the Calleguas Creek Watershed developed a watershed solution to address the salt  
22 accumulation problem that was found to be impairing surface waters, such as:

- 23 i. Finding locations for brackish groundwater treatment facilities;
- 24 ii. Constructing a RSMC, also known as a “brine line”; and
- 25 iii. Increasing recycled water usage. TSO, Order No. R4-2011-0126-A02 at pg.4, para. 11.

26 All of this was ignored by the Regional Board in the Permit even during a declared drought  
27 emergency when there is widespread recognition that source water salinity levels are increasing.  
28 Feng Decl. at ¶ 7. On April 14, 2014, the District requested in writing higher interim limits for

1 salts based on anticipated changes to its potable water supply and supplemental information was  
2 sent to the Regional Board on April 24th. *Id.* The District is concerned that the effluent  
3 concentrations may exceed the proposed interim and will exceed the final effluent limitations due  
4 to the new supply of Colorado River Water which is higher in salt content than State Project  
5 Water.<sup>4</sup> *Id.*; see also TSO, Order No. R4-2011-0126-A02 at pg.7, para. 22.

6 In addition, the District repeatedly requested that the final effluent limitations be included  
7 in a finding in the Permit and that the TMDL compliance schedule be included in the Permit. See  
8 District's Comments on the Permit; Feng Decl. at ¶ 4. As discussed in the TMDL schedule, proper  
9 identification and control of a constituent's source provides the most economical and flexible  
10 method of compliance.

11 Harm can be presumed in this case since similar stays have been in place for the previous  
12 chloride limits in Camarillo Sanitary District's last NPDES permits. On August 14, 2002, a  
13 "Stipulation for Order Issuing Stay, with Conditions" was entered into in the matter denominated  
14 as SWRCB/OCC File A-1474, a petition regarding the various treatment plants owned and  
15 operated by Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo  
16 Sanitary District (Camarillo WRP), Camrosa Water District, Ventura County Water Works District  
17 No. 1, respectively, and the Los Angeles Regional Water Quality Control Board (Regional Board),  
18 regarding certain chloride effluent limitations then applicable to the discharges from the aforesaid  
19 facilities, and the water quality objectives from which those limitations were derived. The State  
20 Board issued WQO 2002-0017, which approved the August 14, 2002 stipulation. See Simi Valley  
21 TSO, Order No. R4-2014-0067 at pg. 2, para. 10.

22 On October 10, 2003, another "Stipulation for Further Order Issuing Stay" was entered into  
23 by Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary  
24 District (Camarillo WRP), and the Regional Board in the matters denominated as SWRCB/OCC  
25 Files A-1577, A-1578, and A-1579. The State Board issued WQO 2003-0019, which approved the

26 \_\_\_\_\_  
27 <sup>4</sup> The District provided water quality data for its blended potable water supply (consisting of local groundwater from  
28 wells and imported water from MWD, the only available sources of potable water available to Camarillo) to the  
Regional Board that showed average concentrations for TDS, sulfate and chloride increased by 32%, 31%, and 20%,  
respectively, when comparing data between the periods of January 2004 to December 2006 and January 2007 to March  
2011. TSO, Order No. R4-2011-0126-A02 at pg.5, para. 15.b.

1 October 10, 2003 stay stipulation and held the petitions in abeyance until November 19, 2006.  
2 The State Board granted several extensions of the abeyance periods in the aforementioned matters  
3 and the stay of the chloride limits remains in place until the new limits under this Permit become  
4 effective. *See accord* TSO, Order No. R4-2011-0126-A02 at pg.7, para. 19.

5 If the District is required to install advanced salinity removal facilities, without the benefit  
6 of the TMDL compliance schedule described above, sewer services fees will have to be  
7 substantially increased to fund a new construction project and the funds used for participation in  
8 the TMDL development process will represent a completely wasted effort. *See* Feng Decl. at ¶¶ 9,  
9 11, 15. The costs to add reverse osmosis (“RO”) for salinity treatment at the WRP is substantial.  
10 Based upon a cost study performed by Montgomery Watson Harza for the County Sanitation  
11 Districts of Los Angeles County and submitted to the Regional Board in June 2002, the capital cost  
12 for the addition of advanced treatment technologies necessary to meet final effluent limitations in  
13 their permits were estimated to range from the tens to the hundreds of millions of dollars depending  
14 on the size of the plant and the treatment train needed (with the highest costs if micro-filtration,  
15 reverse osmosis, and brine disposal were required). Feng Decl. at ¶ 9. The additional annual  
16 operation and maintenance costs necessary to meet the final effluent limitations were estimated to  
17 be in the millions annually, not including brine disposal costs if membrane technologies are  
18 required to comply. *Id.* The District’s facilities and flows are smaller, but the District still  
19 anticipates the costs for planning, pre-design, and CEQA-compliance costs to eventually come into  
20 compliance with the final effluent limitations to be approximately \$25-30 million to build a 3 mgd  
21 RO facility in order to blend the effluent and the RO flows to meet standards and approximately \$1  
22 million annually to operate. Feng Decl. at ¶ 13. These costs are considerable, and should not be  
23 incurred without the benefit of careful analysis. Feng Decl. at ¶ 9.

24 Once expended, these costs are irretrievable and will result in significant rate increases for  
25 area residents even if the RO system is ultimately mothballed as unnecessary. Feng Decl. at ¶ 10.  
26 Given the fact that a separate watershed approach is currently being implemented, the costs of  
27 compliance with these end-of-pipe final effluent limits are wildly disproportionate to any minor  
28 water quality benefits in the short term particularly when the agricultural users of this water have

1 not voiced any complaints about the current salinity levels. *Id.* In this drought, the farmers may be  
2 thankful to have wet water available for use. *Id.*

3 In addition, all during construction and up until the time that the RO system is operation,  
4 the District will potentially be accruing civil penalties. Feng Decl. at ¶ 6. The fact that a TSO  
5 contains interim limits does nothing more than protect against Mandatory Minimum Penalties  
6 (“MMPs”) for the salinity limits. Orders issued by the Regional Board that contain compliance  
7 schedules and interim limits, such as TSOs, do not suspend the final effluent limits and deadlines  
8 contained in the underlying NPDES permit, and do not shield NPDES permit holders from third  
9 party citizen suits pursuant to CWA section 505 for noncompliance with the underlying permit.  
10 *See* 33 U.S.C. §1365; *Citizens for a Better Environment-California v. Union Oil*, 83 F.3d 1111,  
11 1119-1120 (9<sup>th</sup> Cir. 1996). Under this rationale, an entity attempting to comply with final effluent  
12 limitations by complying with the mandates of a TSO would still be vulnerable to discretionary  
13 administrative enforcement by the State or USEPA, and by suits by third parties to enforce the final  
14 effluent limitations. Significantly, the Clean Water Act and the Porter-Cologne Water Quality  
15 Control Act prescribe harsh civil *and criminal* penalties for violations of any NPDES Permit  
16 condition or limitation. *See* 33 U.S.C. §§1319(d) and 1365; Water Code §§13385 and 13387.

17 The Regional Board’s failure to conduct a reasonable potential analysis, and if limits are  
18 required include all compliance schedules and interim limits within the Permit also places the  
19 District in an untenable position, in that the Permit requires immediate compliance where  
20 immediate compliance is unachievable. This is especially arbitrary and unjust in the case of  
21 salinity, where the applicable TMDL included a schedule of compliance until 2023. *See*  
22 Attachment A to Regional Board Res. No. R4-2007-016, at pg. 22. The District has been diligently  
23 working to implement the requirements of the Salinity TMDL, even without such provisions being  
24 included in an enforceable order or permit, and properly relied upon the compliance schedule  
25 contained therein.

26 For the foregoing reasons, the District requests the State Board issue a stay of the final  
27 salinity effluent limitations in the Permit. During the period in which the requested stay is in  
28 effect, the District will comply with the interim limits for salinity set forth in the TSO, unless

1 additional changes are needed and requested to address worsening drought and source water  
2 conditions.

3 **2) FINAL EFFLUENT LIMITATIONS FOR CHRONIC TOXICITY.**

4 When the Regional Board adopted the Permit, the Regional Board failed to comply with  
5 precedential orders regarding the appropriate limitations for chronic toxicity, even though the  
6 Regional Board was aware of these orders. See Permit Fact Sheet at pg. F- 45. The Regional  
7 Board's failure to include a *narrative* effluent limit for chronic toxicity within the Permit not only  
8 ignored State Board precedent, but also ignored the implementation provisions of the Calleguas  
9 Watershed TMDL that states that the chronic toxicity Wasteload Allocations (WLAs) will be based  
10 on chronic toxicity units (TUc) and implemented as a trigger instead of as numeric effluent  
11 limitations. This failure by the Regional Board to follow applicable precedent and TMDL  
12 implementation provisions places the District in immediate jeopardy of being in violation of the  
13 final effluent limitations for chronic toxicity set forth in the Permit on July 1, 2014, the effective  
14 date of the Permit. There is no TSO interim limit to provide MMP protection, and MMPs are not  
15 applicable to toxicity limits if any other toxic pollutants are limited, which is the case for this  
16 Permit. See Permit at pg. 7, Table 4; Wat. Code §13385(i)(1)(D).

17 Notwithstanding the District's objection in its comments and the Petition for Review  
18 regarding the imposition of the final numeric effluent limitations for chronic toxicity, the Regional  
19 Board imposed the limits anyway. It is unclear how the District is expected to comply with these  
20 newly imposed, final effluent limitations since it already has a very high level of treatment, and  
21 still occasionally slightly exceeds the current toxicity trigger of 1 TUc. See Permit Hearing  
22 Presentation of the Regional Board (May 8, 2014) at slide 7 (During the 2003-2014 Permit cycle,  
23 the District exceeded the 1 TUc trigger three times in 2010, 2011, and 2012 with all registering in  
24 the 1.76 to 1.79 range); Feng Decl. at ¶ 16. With the new "Pass" limits, implemented using a two  
25 concentration Test of Significant Toxicity (TST) method that is not approved under 40 C.F.R. Part  
26 136 as a standard method, the District is statistically guaranteed to be in violation of its permit at  
27 least 5% of the time. *Id.* This is an unacceptable situation. The Regional Board's action will  
28

1 unnecessarily result in the District being out of compliance with the final effluent limitations for  
 2 chronic toxicity set forth in the Permit and subject to MMPs and other discretionary penalties  
 3 because the District is statistically guaranteed to fail at least one test in the Permit term even if the  
 4 recycled water is not truly “toxic.” *Id.*

5 For the foregoing reasons, the District requests the State Board to stay the final numeric  
 6 effluent limitations for chronic toxicity set forth in the Permit. During the period in which the  
 7 requested stay is in effect, the District will comply with the narrative toxicity limit in the current  
 8 permit provisions, using 1 TUc as a chronic toxicity trigger for accelerated monitoring and  
 9 potentially a Toxicity Identification Evaluation. Feng Decl. at ¶¶ 16-17.

### 10 3) FINDINGS WITH SUBSTANTIVE PROVISIONS

11 The Fact Sheet for this Permit contains findings that seemingly *require* the District to  
 12 conduct a recycling/reuse feasibility study, submit a report summarizing its recycled water  
 13 expansion efforts within 180 days of the effective date of the Permit, and submit a separate report  
 14 30 days after the completion of a major project.<sup>5</sup> Permit Fact Sheet Section III.C.11. at pg. F-16  
 15 and Section VIII.G., at pg. F-61. A similar provision was removed from the body of the Permit  
 16 prior to adoption, and findings are supposed to be background and justification for the Permit’s  
 17 provisions, not contain substantive provisions. Because it is unclear whether these sections of the  
 18 Fact Sheet contain binding requirements, the District, in an abundance of caution, asks that a stay  
 19 and modification to toll the compliance deadlines be issued for these provisions since the  
 20 timeframe for compliance is too short to obtain administrative review of the need for these studies  
 21 prior to the deadlines passing. If a stay and modification is not granted, the District will be forced  
 22 to quickly undertake the drafting of a costly report that is unduly burdensome since this reporting is  
 23 not adequately justified and is wholly unnecessary. Feng Decl. at ¶ 14. The District will be  
 24 substantially prejudiced by having to expend this effort to evaluate additional reuse options while  
 25 the State Board is considering the Petition for Review that may render the issue moot. *See City of*  
 26 *Manteca v. SWRCB*, Sac. Sup. Ct. Case No. 34-2010-80000492, Judgment Granting Preliminary  
 27

28 <sup>5</sup> If the State Board believes that these are merely non-enforceable findings, then the District withdraws this stay request.

1 Writ of Mandamus, Ruling on Submitted Matter (Oct. 2010) at pg. 12 *citing In the Matter of the*  
2 *Petition of International Business Machines*, Order No. WQ 88-15 at pg. 4 (Dec. 15, 1988).

3 **4) TSO DEADLINE FOR COMPLIANCE**

4 The TSO, Order R4-2011-0126-A02, at Provision 3 on page 11 requires: "Achieve full  
5 compliance with the final effluent limitations as soon as possible, but no later than December 31,  
6 2015, the date by which Camarillo SD committed to achieving compliance, for TDS and sulfate  
7 contained in Order No.R4-2014-0062." The District has challenged the final effluent limitations  
8 and asked for the full compliance schedule allowed by the TMDL to be placed in the Permit along  
9 with performance-based interim limits. Since the deadline contained in this provision may arrive  
10 before a substantive ruling on the District's Petition, the District seeks a stay and an extension of  
11 the time schedule provision in addition to the requested stay on the limits in the Permit. *See accord*  
12 *In the Matter of the Review on Own Motion of Waste Discharge Requirements for Vacaville*, State  
13 Board Order WQO 2002-0015 at 75 ("By staying these schedules, the Board intends that the  
14 schedules not run during the stay period. This means that the effective date of the relevant final  
15 limits will be delayed beyond their existing effective date by a period of time equal to the stay  
16 period."); Wat. Code §13321(a) (allowing stay of the effect of a decision), §13320(c)(State Board  
17 to take appropriate action). If a stay and modification to toll this language are not granted, the  
18 District will be harmed if the final compliance date cannot be met and the District is subject to  
19 enforcement for violating the TSO in addition to the underlying effluent limitations. Feng Decl. at  
20 ¶ 14.

21 **5) TSO REQUIREMENT FOR A POLLUTION PREVENTION PLAN WORKPLAN**

22 The TSO, Order R4-2011--0126-A02, at Provision 4 on page 11 requires the District to  
23 "Submit a Pollution Prevention Plan (PPP) work plan, with the time schedule for implementation,  
24 for approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section  
25 13263.3." The District has challenged the final salinity effluent limitations and asked for the full  
26 compliance schedule allowed by the TMDL to be included in the Permit. Had that been done, then  
27 the requirements of Water Code section 13263.3 would not have been triggered by the MMP law at  
28 Water Code section 13385(j)(3)(D). Since the deadline of August 8, 2014 contained in this

1 provision will arrive before a substantive ruling on the District's Petition, the District seeks a stay  
 2 and an extension of the time schedule provision in addition to the requested stay on the limits in the  
 3 Permit. *See accord In the Matter of the Review on Own Motion of Waste Discharge Requirements*  
 4 *for Vacaville*, State Board Order WQO 2002-0015 at 75 ("By staying these schedules, the Board  
 5 intends that the schedules not run during the stay period. This means that the effective date of the  
 6 relevant final limits will be delayed beyond their existing effective date by a period of time equal to  
 7 the stay period."); Wat. Code §13321(a)(allowing stay of *the effect* of a decision), §13320(c)(State  
 8 Board to take appropriate action). If a stay and modification to toll this language are not granted,  
 9 the District will be harmed by having to spend time and resources to prepare a workplan that might  
 10 otherwise be unnecessary. Feng Decl. at ¶ 14.

11 **6) UNNECESSARY AND BURDENSOME QUARTERLY COMPLIANCE REPORTS**

12 Provision in Paragraph 5 on page 11 of the TSO requires the City to submit quarterly  
 13 progress reports, the first due October 15, 2014, of efforts taken by the City to comply with the  
 14 final effluent limitations for TDS and sulfate, and the requirements for the content of those reports.  
 15 This reporting is wholly unnecessary given that the efforts needed for compliance are spelled out in  
 16 the Salts TMDL and because of other reporting obligations. Feng Decl. at ¶¶ 13-14, 16.

17  
 18 **B) SUBSTANTIAL HARM WILL BE INCURRED BY THE PUBLIC IF A STAY IS NOT**  
 19 **GRANTED.**

20 The general public will also be substantially harmed if the State Board does not grant the  
 21 District's stay request. If the requirements contained in the Permit are not immediately stayed,  
 22 residents and businesses in the District's service area, already under substantial strain from the  
 23 recent recession and other rising utility costs, will be asked to pay for unnecessary costs, and to  
 24 factor an anticipated sewer rate increase into their critical decisions of whether to remain in the  
 25 area, and whether to increase or reduce their workforces. *See* Feng Decl. at ¶¶ 11-13. These  
 26 decisions will begin occurring immediately if a stay is not granted and may have irreversible  
 27 impacts on housing, investment, and employment in the District's service area. *Id.*  
 28

1 To assure compliance with the salinity and toxicity<sup>6</sup> final effluent limits, would likely  
2 require construction and operation of reverse osmosis (or other similar separation technology) for  
3 at least a portion of the District's effluent at a very large cost. Feng Decl. at ¶¶ 9, 13. A 2001  
4 analysis of the economic impacts of the installation of advanced treatment facilities conducted by  
5 the Santa Clarita Valley Joint Sewerage System ("SCVJSS") consultant, M.Cubed, which  
6 concluded that, as a result of the cost increases associated with constructing advanced reverse  
7 osmosis treatment facilities, employment would be reduced in the that District's service area by  
8 approximately 423 jobs, local tax revenue would fall by over \$2.6 million annually, total industry  
9 output would drop by nearly \$55.5 million per year, and total value added would decline by more  
10 than \$26 million annually. *Id.* at ¶12 citing M.Cubed, "Economic Implications of Proposed  
11 NPDES Permits for the Sanitation Districts of Los Angeles County" (May 2001). The compliance  
12 costs, and therefore the economic impacts, from the new Camarillo WRP Permit are expected to be  
13 smaller than those associated with the February 2001 tentative permit for the SCVJSS facilities, but  
14 may include substantial reductions in employment, decreases in total industry output, and declines  
15 in local tax revenue. *Id.* at ¶12.

16 The District's service area is smaller, but proportionately the impacts are still large. In  
17 addition to the monies spent by the District to participate in the Calleguas Creek Watershed  
18 Program with the intent of creating and implementing a watershed solution to avoid having to build  
19 reverse osmosis at the WRP, the District's ratepayers will be asked to fund this new project that  
20 may become wholly unnecessary once the watershed projects are completed. Feng Decl. at ¶13.

21 The local residents have already been asked to pay an inordinate amount for local water  
22 quality-related projects. Feng Decl. at ¶13. Camarillo Sanitary District has thus far spent upwards  
23 of \$40 million in capital expenditures for upgrading to tertiary treatment to produce high quality  
24 recycled water, \$900,000 on TMDL development, and \$1.1 million on TMDL implementation. *Id.*  
25 The City of Camarillo on the water side has funded future capital expenditures of \$50 million on a  
26 groundwater desalter, \$5 million on imported water charges to build the regional brine line. *Id.* The  
27

28 <sup>6</sup> It is not clear that toxicity limits can be met consistently even with the operation of reverse osmosis because of the inherent false failure rate that guarantees failure at least 5% of the time.

1 City of Camarillo on the stormwater side has spent about \$1.3 million on TMDL implementation.  
2 *Id.* The overall watershed group has spent over \$6.6 million on TMDL development, and \$16  
3 million on TMDL implementation. *Id.* In addition, Calleguas Municipal Water District customers  
4 have had to bear the cost to build the brine line of over \$230 million. *Id.* Tacking on additional  
5 costs to this very proactive watershed is not only unnecessary, it is unduly burdensome. *Id.*

6 The forced implementation of costly requirements that may ultimately prove unnecessary,  
7 or the commencement of enforcement actions based on such requirements, is a misdirection of  
8 scarce public resources, and should be avoided in order to prevent substantial harm to the public.  
9 Feng Decl. at ¶14. The adoption of effluent limitations in violation of federal and state law also  
10 causes substantial harm to the public who have a vested interest in the government complying with  
11 its own laws and regulations. *Id.*

12 **2. OTHER INTERESTED PARTIES AND THE PUBLIC WILL NOT INCUR SUBSTANTIAL**  
13 **HARM IF A STAY IS GRANTED.**

14 Other interested persons and the public will not suffer substantial harm if a stay of the  
15 requested requirements is granted by the State Board. Granting a stay of the requested provisions  
16 will not operate to alter or eliminate those provisions. *See* Feng Decl. at ¶15. In addition, the  
17 issuance of the stay will not eliminate or alter any other requirements set forth in the Permit besides  
18 those specifically stayed or temporarily extended. *Id.* Instead, the requested stay will simply  
19 temporarily suspend the necessity to pursue tasks in an illogical manner, and to prematurely  
20 construct costly facility upgrades, resulting in immediate and substantial increases in sewer service  
21 fees and concomitant economic impacts, and to comply with improper requirements that are being  
22 administratively reviewed. *Id.* The requested stay will also temporarily suspend administrative,  
23 civil, and potential criminal liability for non-compliance with requirements that the District 1)  
24 cannot currently meet, or 2) cannot feasibly meet within the timeframes specified, and which may  
25 ultimately be removed from the Permits or modified. *Id.* Thus, issuance of a stay by the State  
26 Board simply suspends the unnecessary imposition of increased sewer service fees, onerous fines,  
27 and penalties that will be passed on to the public via increased sewer rates or special assessments,  
28 and susceptibility to third-party lawsuits pending review of the requested provisions, which may

1 ultimately be removed from the Permit. *Id.* Given that there have been stipulated stays in place for  
2 chloride since 2002 with no adverse effects, there is little to no chance of harm expanding the stay  
3 to additional provisions.

4 In addition, if a stay were issued, the Regional Board's regulatory oversight of the District  
5 will remain unchanged. *See* Feng Decl. at ¶16. All other effluent limitations, monitoring and  
6 reporting requirements, and substantive provisions contained in the Permit and accompanying TSO  
7 will remain in effect, and fully enforceable by the Regional Board. *Id.* Specifically, the Permit will  
8 continue to require the District to operate its facilities in the same manner as before the stay was  
9 issued, and will continue to require the District to monitor and submit detailed reports regarding the  
10 facility's performance and compliance with the limitations in the Permit, including the stayed  
11 limitations. *Id.* Thus, during the period of the requested stay, the District will continue its existing,  
12 protective level of treatment and recycled water production, and will continue to implement source  
13 control efforts and any applicable pretreatment requirements. *See* Feng Decl. at ¶16. Finally, the  
14 issuance of a stay will benefit the public by providing orderly resolution of the issues raised by the  
15 District in this Petition for Stay as well as the District's Petition for Review. *Id.*

16 **3. SUBSTANTIAL QUESTIONS OF FACT OR LAW EXIST.**

17 In addition to the facts and laws discussed herein, the District raised numerous substantial  
18 questions of fact and law regarding provisions contained in the Permit in the Petition for Review  
19 that was filed with the State Board, including whether the challenged limits were legal and  
20 necessary. *See* Feng Decl. at ¶17; *see also* District's Petition for Review. These issues of fact and  
21 law are incorporated herein by reference. The fact that serious questions of fact and law exist  
22 weighs heavily in favor of granting a stay and maintaining the status quo until such disputes can be  
23 resolved. *See Mason v. Superior Court*, 23 Cal.App.3d 913, 916 (1972) ("the purpose of the  
24 various stays which are set forth in the code is maintenance of the status quo").

25 However, in order for the State Board to grasp the importance and gravity of the issues the  
26 District is are grappling with, the following is a summary of the primary factual and legal issues  
27 that are raised in the District's Petition for Review, related to the effluent limitations for which a  
28

1 stay is requested. Other issues related to the monitoring and reporting requirements are detailed  
2 above or in the Petition for Review, and incorporated herein by reference.

3 Numeric Final Salinity Limits

4 The final effluent limitations for salinity in the Permit are inappropriate or improper for the  
5 following reasons:

- 6 a. Inconsistency with the Clean Water Act and Basin Plan provisions, including the  
7 Salts TMDL;
- 8 b. Ignoring the Watershed Approach to water quality regulation; and
- 9 c. Placing the District in compliance jeopardy unnecessarily by including final effluent  
10 limitations without compliance schedules approved in the applicable TMDL.

11 Numeric Chronic Toxicity Limits

12 The Regional Board's action to include the Permit's chronic toxicity effluent limitations  
13 based on a Pass/Fail approach using the two concentration Test of Significant Toxicity guidance  
14 methodology was inappropriate or improper for the following reasons:

- 15 a. Premature until the State Water Board adopts a statewide Toxicity Policy;
- 16 b. Inconsistent with the applicable Calleguas Creed Watershed Toxicity, Chlorpyrifos  
17 and Diazinon TMDL (April 25, 2005) ("Toxicity TMDL");
- 18 d. Improperly based on EPA guidance, not promulgated EPA regulation and methods;
- 19 e. Includes unlawful and inappropriate Maximum Daily limits for Chronic Toxicity;  
20 and
- 21 f. Improperly determination that numeric limits are required.

22 **CONCLUSION**

23 Because the District has alleged facts and provided evidence of the substantial harm to the  
24 District and the public interest while the District awaits final resolution of its administrative appeal,  
25 the lack of substantial harm to other interested persons and to the public interest if a stay is granted,  
26 and the substantial questions of fact and law that exist, the State Board should immediately act to  
27 stay the requested provisions of the Permit pending administrative review of the District's Petition  
28

DOWNEY BRAND LLP


1 for Review. The District specifically requests that the State Board issue public notice in  
2 accordance with 23 C.C.R. §2053(b) on an expedited basis so that the District's stay can be granted  
3 before the Permit's effective date of July 1, 2014, and so the public can avoid the harm alleged  
4 herein pending the State Board's review of the Permit.

5 The District, in concert with the other appealing permittees, has also requested that the  
6 Regional Board enter into a stipulated stay as has been in place for more than 10 years for chloride,  
7 but had not received an answer on that request prior to submission of this Stay Petition. A copy of  
8 the draft Stay Stipulation is attached hereto as Exhibit B.

11 Respectfully Submitted,

12 DATED: June 4, 2014

DOWNEY BRAND LLP

13  
14 By:   
15 MELISSA A. THORME  
16 Attorneys for Petitioner  
17 CAMARILLO SANITARY DISTRICT

28

# **EXHIBIT A**

DOWNEY BRAND LLP

1 DOWNEY, BRAND LLP  
2 MELISSA A. THORME  
3 621 Capitol Mall, 18th Floor  
4 Sacramento, CA 95814-4686  
5 Tel.: (916) 520-5376  
6 Fax: (916) 520-5776

7 Special Counsel for Petitioner  
8 CAMARILLO SANITARY DISTRICT

9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
BEFORE THE  
CALIFORNIA STATE WATER RESOURCES CONTROL BOARD

10 )  
11 )  
12 In the Matter of the Camarillo Sanitary )  
13 District's Petition for Review of Action and )  
14 Failure to Act by the California Regional )  
15 Water Quality Control Board, Los Angeles )  
16 Region, in Adopting Order Nos. R4-2014- )  
17 0062 and R4-2011-0126-A02 for the )  
18 Camarillo Sanitary District Water )  
19 Reclamation Plant. )  
20 )  
21 )  
22 )  
23 )  
24 )  
25 )  
26 )  
27 )  
28 )

**DECLARATION OF BRUCE FENG IN  
SUPPORT OF CAMARILLO SANITARY  
DISTRICT'S PETITION FOR STAY AND  
COMPLIANCE SCHEDULE  
MODIFICATION FOR SPECIFIC  
PROVISIONS IN ORDER NOS. R4-2014-  
0062 AND R4-2011-0126-A02**

I, Bruce Feng, declare:

1. I am the District Manager for the Camarillo Sanitary District (the "District") since 2010. My business address is 150 Howard Road, Camarillo, California 93010. I have personal knowledge of the facts stated herein and, if necessary, could testify thereto.

2. I am responsible for the administration of the District's water reclamation plant ("WRP") programs and the wastewater quality and compliance programs. My duties include reviewing discharge permits, developing technical and policy comments on wastewater and recycling discharge permits and regulations, state and federal legislation, and participating in other regulatory activities such as Water Quality Control Plans, Total Maximum Daily Loads, and state and federal policies.

3. I have a Bachelor's Degree in Civil Engineering from the University of

1 Massachusetts and a Master's in Business Administration (MBA) from California State  
2 University – Long Beach. I am a registered civil engineer. I have held various positions (Public  
3 Works Director, Deputy City Manager, Assistant Community Development Director, etc.) with  
4 the City of Burbank between 1988-2005, Assistant City Manager with the City of Camarillo  
5 between 2005-2010, City Manager with City of Camarillo between 2010 - present.

6 4. In extensive comments submitted to the Regional Water Quality Control Board -  
7 Los Angeles Region ("Regional Board") on the NPDES Permit and Time Schedule Order  
8 ("TSO") for the Camarillo Water Reclamation Plant, the District asserted that the final effluent  
9 limits for chloride, sulfate, and total dissolved solids ("TDS") were not immediately attainable  
10 and alleged substantial questions of law and fact. The District's tertiary treatment system, using  
11 nitrification, denitrification, and biological nutrient removal ("BNR"), exceed the secondary  
12 treatment requirements of the Clean Water Act. Yet, the District's advanced treatment facilities  
13 are not capable of removing substantial amounts of salts, and thus cannot meet the effluent  
14 limitations for salinity in the Permits. The District has asserted that compliance schedules and  
15 interim limits should be provided by the Regional Board in the Permits to allow the District time  
16 to comply with the final effluent limits for chloride, sulfate, and TDS, or, at the least, that the  
17 TSO expressly states that the interim effluent limits modify the final effluent limits contained in  
18 the Permits for the duration of the TSO. Without compliance schedules and interim limits in the  
19 Permits, the Districts will be subject to enforcement liability and potentially liable for citizen suits  
20 for failure to immediately and consistently comply with the challenged final effluent limits in the  
21 Permit.

22 5. Without interim limits and compliance schedules in the Permit, the District would  
23 have to commit to design and construct additional treatment at the WRP before other activities,  
24 such as the Regional Salinity Management Conveyance (RSMC or brine line) are complete and  
25 may obviate the need for such POTW treatment (e.g., influent source control). It is impractical to  
26 begin construction of costly end-of-pipe treatment options when a plan is already in place and  
27 being implemented to address the actual source of the pollutants, which, if successful, will render  
28 additional end-of-pipe treatment unnecessary. The District would have to undertake these

1 activities before the review of the propriety of the new permit limits is complete. Given the many  
2 legal deficiencies with the permit limits being inconsistent with adopted TMDLs and Basin Plan  
3 amendments, it is impractical and a waste of public resources to begin design and construction of  
4 costly end-of-pipe treatment options until this review has been completed, since the outcome may  
5 render additional end-of-pipe treatment unnecessary or may result in focusing on the watershed  
6 approach relying on alternative types and/or levels of treatment or source control activities.

7 6. The installation of additional advanced treatment facilities to meet the final  
8 numeric salinity effluent limits in the Permit cannot be completed and placed in operation by the  
9 effective date of the Permit. At the time the Permit was adopted, the Regional Board was aware  
10 of the inability of the District to comply with the final salinity effluent limits in the Permit. *See*  
11 *TSO No. R4-2011-0126-A02 at pg. 7, para. 20* (“The Discharger cannot consistently meet the  
12 final effluent limitations”). Nevertheless, the Regional Board failed to include necessary  
13 compliance schedules in the Permit for such limits even though a compliance schedule was  
14 authorized in the Calleguas Watershed Salts TMDL. The Regional Board’s failure to include  
15 compliance schedules and interim limits in the Permit places the District in jeopardy of being in  
16 violation of the final effluent limits set forth in the Permit on July 1, 2014, the effective date of  
17 the Permit. The Regional Board’s failure unnecessarily subjects the District to civil and criminal  
18 liability for violations that cannot be avoided pending the construction of facilities necessary to  
19 meet the final salinity effluent limits contained in the Permit, which are not required to be met  
20 until December 8, 2023 under the Salts TMDL.

21 7. All of this is ignored by the Regional Board in the Permit even during a declared  
22 drought emergency when there is widespread recognition that source water salinity levels are  
23 increasing. On April 14, 2014, the District requested in writing higher interim limits for salts  
24 based on anticipated changes to its potable water supply and supplemental information was sent  
25 to the Regional Board on April 24th. The District is concerned that the effluent concentrations  
26 may exceed the proposed interim and will exceed the final effluent limitations due to the new  
27 supply of Colorado River Water which is higher in salt content than State Project Water

28 8. The failure to provide compliance schedules for facility upgrades, disregards the

1 lead times required for facility planning, design, environmental documentation and review under  
2 the California Environmental Quality Act, evaluation and mitigation of potential impacts,  
3 development of construction financing (including debt service and approval of user rates),  
4 construction, and process start-up. A compressed schedule will result in a waste of public funds  
5 by requiring the District to pay premium costs for expedited environmental reviews and  
6 construction.

7         9. If the District is required to begin preparation for the installation of advanced  
8 treatment facilities, without the benefit of the review of possible regulatory relief, like compliance  
9 with the TMDL or a variance for the salinity water quality standards as proposed to be adopted in  
10 the Central Valley, sewer services fees will have to be substantially increased to fund that project.  
11 Based upon a cost study performed for the County Sanitation Districts of Los Angeles County in  
12 2002 by Montgomery Watson Harza, a leading international engineering firm, the capital cost for  
13 the addition of advanced treatment technologies necessary to meet the final chloride effluent  
14 limitations can reach into the hundreds of millions to install a treatment train consisting of micro-  
15 filtration, reverse osmosis, and brine disposal. These estimates do not include costs for possible  
16 site acquisition if needed or flow equalization upstream of the membrane units. The additional  
17 annual operation and maintenance costs necessary to meet the final effluent limitations will also  
18 be in the millions annually. These costs are considerable, and should not be incurred without the  
19 benefit of careful analysis.

20         10. Once expended, these costs are irretrievable and will result in significant rate  
21 increases for area residents even if the RO system is ultimately mothballed as unnecessary.  
22 Given the fact that a separate watershed approach is currently being implemented, the costs of  
23 compliance with these end-of-pipe final effluent limits are wildly disproportionate to any minor  
24 water quality benefits in the short term particularly when the agricultural users of this water have  
25 not voiced any complaints about the current salinity levels. In this drought, the farmers may be  
26 thankful to have wet water available for use.

27         11. In addition to the specific harm to the District discussed herein, and in the  
28 District's Petition for Stay, the general public will also be substantially harmed if the State Board

1 does not grant the District's stay request. If the requirements contained in the Permit are not  
2 immediately stayed, businesses in the District's service area, already under substantial strain from  
3 the recent recession and other increasing utility cost increases, will immediately be forced to  
4 factor anticipated future sewer rate increases into their critical decisions of whether to remain in  
5 the area, and whether to increase or reduce their workforces. These decisions will begin  
6 occurring immediately and may have irreversible impacts on investment and employment in the  
7 service area of the District.

8 12. A 2001 analysis of the economic impacts of the installation of advanced treatment  
9 facilities for the Santa Clarita Valley Joint Sewerage System ("SCVJSS"), which serves a  
10 population of approximately 150,000, conducted by M.Cubed and updated by Advent in October  
11 of 2003, concluded that, as a result of the cost increases associated with constructing advanced  
12 treatment facilities, employment would be reduced in the SCVJSS service area by 423 jobs, total  
13 labor income would decline by about \$15.8 million, local tax revenue would fall by over \$2.6  
14 million annually, total industry output would drop by nearly \$55.5 million per year, and total  
15 value added would decline by more than \$26 million annually. *See* M.Cubed, "Economic  
16 Implications of Proposed NPDES Permits for the Sanitation Districts of Los Angeles County"  
17 (May 2001). Although the District has not done a similar study, the results would likely be  
18 similarly detrimental.

19 13. Using rough estimates, the District anticipates the costs for planning, pre-design,  
20 and CEQA-compliance costs to eventually come into compliance with the final effluent  
21 limitations to be approximately \$25-30 million to build a 3 mgd RO facility in order to blend the  
22 effluent and the RO flows to meet standards and approximately \$1 million annually to operate.  
23 However, the District cannot guarantee compliance until this construction project (or the entirety  
24 of the projects contemplated in the Salts TMDL) are complete. This would be in addition to the  
25 costs that the local residents have already been asked to pay for local water quality-related  
26 projects. Camarillo Sanitary District has thus far spent upwards of \$40 million in capital  
27 expenditures for upgrading to tertiary treatment to produce high quality recycled water, \$900,000  
28 on TMDL development, and \$1.1 million on TMDL implementation. The City of Camarillo on

1 the water side has funded future capital expenditures of \$50 million on a groundwater desalter, \$5  
2 million on imported water charges to build regional brine line. The City of Camarillo on the  
3 stormwater side has spent about \$1.3 million on TMDL implementation. The overall watershed  
4 group has spent over \$6.6 million on TMDL development, and \$16 million on TMDL  
5 implementation. In addition, Calleguas Municipal Water District customers have had to bear the  
6 cost to build the brine line of over \$230 million. Taking on additional costs to this very proactive  
7 watershed is not only unnecessary, it is unduly burdensome.

8 14. The forced implementation of costly requirements that ultimately prove  
9 unnecessary, or the commencement of enforcement actions based on such requirements, is a  
10 misdirection of scarce public resources, and should be avoided to prevent substantial harm to the  
11 public. The adoption of effluent limitations in violation of federal and state law also causes  
12 substantial harm to the public who have a vested interest in the government complying with its  
13 own laws and regulations. Similarly, requirements to prepare studies, reports, or pollution  
14 prevention plans the necessity of which have not been adjudged should be stayed and delayed  
15 until resolution of the appeal of the Permit to avoid unnecessary expenditures and misuse of  
16 limited staff resources. If a stay and modification to toll the challenged deadlines are not granted,  
17 the District will be harmed if the final compliance date cannot be met and the District is subject to  
18 enforcement for violating the TSO in addition to the underlying effluent limitations.

19 15. Granting a stay of the requested provisions will not operate to alter or eliminate  
20 these provisions. Nor will the issuance of the stay eliminate or alter any other requirements set  
21 forth in the Permit. Instead, the requested stay will simply temporarily suspend the necessity to  
22 pursue tasks in an illogical manner, and to prematurely begin to construct costly facility upgrades,  
23 resulting in immediate and substantial increases in sewer service fees and concomitant economic  
24 impacts, to comply with improper or unlawful requirements that are being administratively  
25 reviewed. The requested stay will also temporarily suspend administrative and civil liability for  
26 non-compliance with final effluent limits that the Districts cannot meet, and will be unable to  
27 meet until additional treatment facilities are constructed. Further, a stay will defer actions to begin  
28 design and construction of additional wastewater treatment facilities to meet limits, which may

1 ultimately be replaced or removed from the Permit if the requested changes to the Permit are  
2 authorized by the State Board. Thus, issuance of a stay by the State Board simply suspends the  
3 unnecessary imposition of increased sewer service fees, onerous fines, and penalties that will be  
4 passed on to the public via increased sewer rates or special assessments, and susceptibility to  
5 third-party lawsuits pending review of pending review of the District's Petition for Review.


6 16. The current advanced design of the District's tertiary treatment plant, using  
7 nitrification, denitrification, and BNR, does not allow for immediate compliance with the salinity  
8 effluent limitations in the Permit or with the numeric chronic toxicity effluent limitations in the  
9 Permit due to the statistical guarantee of a 5% false failure rate. If a stay were issued, the  
10 Regional Board's regulatory oversight of the District's WRP will remain unchanged. All other  
11 effluent limitations contained in the Permit will remain in effect, and fully enforceable by the  
12 Regional Board, U.S. EPA, and third parties. Additionally, the Permit will continue to require the  
13 District to operate their facilities in the same manner as before the stay was issued, and will  
14 continue to require the District to monitor and submit detailed reports regarding the facility's  
15 performance and compliance with the limitations in the Permit, including the stayed limitations.  
16 Thus, during the period of the requested stay, the District will continue its existing, protective  
17 level of treatment, and will continue to implement source control efforts and any applicable  
18 pretreatment requirements. Finally, the issuance of a stay will benefit the public by providing  
19 orderly resolution of the issues raised by the District in its Petition for Stay as well as the  
20 District's Petition for Review.

21 17. The District raised numerous and substantial questions of fact and law regarding  
22 provisions contained in the Permit in the Petition for Review that is being filed simultaneously  
23 with the State Board. A stay should be granted. For the duration of the stay of the final salinity  
24 effluent limits and the chronic toxicity limit, the District will agree to comply with the  
25 corresponding interim limits in the TSO and the narrative chronic toxicity effluent limit  
26 implementing through a numeric trigger of 1 TUc for additional monitoring.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

I declare under penalty of perjury pursuant to the laws of the California that the foregoing is true and correct.

Executed this 2nd day of June, 2014 at Camarillo, California.

  
Bruce Feng, Declarant

1373664.1

DOWNEY BRAND LLP

# **EXHIBIT B**

BEFORE THE  
CALIFORNIA STATE WATER RESOURCES CONTROL BOARD

In the Matter of the 2014 Petitions of the ) SWRCB/OCC File A-\_\_\_\_ (Camarillo S.D.)  
City of Simi Valley, City of Thousand Oaks, ) SWRCB/OCC File A-\_\_\_\_ (Thousand Oaks)  
And Camarillo Sanitary District for Review ) SWRCB/OCC File A-\_\_\_\_ (Simi Valley)  
of Action and Failure to Act by the Los )  
Angeles Regional Water Quality Control )  
Board and for Stays/Compliance Schedule ) **STIPULATION FOR**  
Modifications ) **STAY ORDER**  
\_\_\_\_\_ )

RECITALS

1. On August 14, 2002, a "Stipulation for Order Issuing Stay, with Conditions" was entered into in the matter denominated as SWRCB/OCC File A-1474 by Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), Camrosa Water District, Ventura County Water Works District No. 1 and the Los Angeles Regional Water Quality Control Board (Regional Board) regarding certain chloride effluent limitations then applicable to the discharges from the aforesaid facilities.

2. The State Water Resources Control Board issued WQO 2002-0017 on October 17, 2002, which approved the August 14, 2002 stay stipulation.

3. On October 10, 2003, a "Stipulation for Further Order Issuing Stay" was entered into by Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), and the Regional Board in the matters denominated as SWRCB/OCC Files A-1577, A-1578, and A-1579.

4. On November 19, 2003, the State Water Resources Control Board issued WQO 2003-0019, which approved the October 10, 2003 revised stipulated stay of chloride effluent limitations and held the underlying petitions in abeyance until November 19, 2006.

5. The State Board granted several extensions of the abeyance periods in the aforementioned matters until July 15, 2014, when the petitions would be dismissed without prejudice. See SWRCB Abeyance Extension Letters (Aug. 16, 2012) for A-1577, A-1578, and A-1579.

6. On October 4, 2007, the Regional Board adopted Resolution No. 2007-016, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate the TMDL for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed* (Regional Board Salts TMDL), which established final waste load allocations (WLAs) for chloride, sulfate and TDS, provided a compliance schedule, and set interim WLAs for the aforementioned constituents for the duration of the compliance schedule. Upon approval from

the State Board, the Office of Administrative Law (OAL), and USEPA, the Regional Board's Salts TMDL superseded an earlier March 22, 2002 USEPA-promulgated TMDL for chloride.

7. The permittees have actively participated with other stakeholders in the Calleguas Creek Watershed Management Plan Committee to develop a watershed-wide solution to the salts and other water quality-related problems. Those solutions are reflected in the TMDLs for the watershed and the associated implementation plans and compliance schedules.

8. The Regional Board reissued NPDES permits for each of the three facilities described in Recital 1 on May 8, 2014, however final numeric effluent limits that would be derived from the water quality objectives in the Basin Plan or the TMDLs' WLAs cannot yet be consistently met because the implementation activities for the Regional Board TMDLs are not yet complete.

9. Other effluent limitations (chronic toxicity for all permittees and a copper mass limit for Thousand Oaks) and a few other permit and time schedule order requirements also pose compliance problems for which a stay is appropriate until the Permittees' appeals are resolved.

#### STIPULATION

1. The parties stipulate that maintaining the stay of the otherwise applicable chloride effluent limits on the terms and conditions set forth below is appropriate and in the public interest. In addition, the parties stipulate that a broader stay is appropriate and in the public interest given new issues that have arisen related to the most recent permits and time schedule orders. This stipulation shall not, however, constitute or be construed as an admission on any issues of law or fact relevant to the final disposition of the petitions.

2. The parties stipulate to the entry of an Order by the State Water Resources Control Board providing that the stays in place for the petitions for review in Files A-1577, A-1578, and A-1579 shall be deemed to be amended to assert challenges to the chloride limits in the new permit and shall impose a continued stay of the chloride limits along with a stay of the challenged new provisions of the Permits and Time Schedule Orders ("TSOs") as described below:

#### Permits:

- (i) **Camarillo WRP Effluent Limitations** in Provision IV.A.1.a, Table 4, contained in Regional Board Order No. R4-2014-0062 (NPDES NO. CA0053597):
  - a) The 51,400 lbs/day final average monthly dry weather effluent limitation for Total Dissolved Solids ("TDS") and the 850 mg/L final average monthly effluent limitation for TDS under wet weather conditions;
  - b) The 15,100 lbs/day final average monthly dry weather effluent limitation for sulfate and the 250 mg/L final average monthly effluent limitation for sulfate under wet weather conditions;

- c) The 9,070 lbs/day final average monthly dry weather effluent limitation for chloride and the 150 mg/L final average monthly effluent limitation for chloride under wet weather conditions; and
  - d) The “pass” median monthly effluent limitation and “pass or %effect < 50” maximum daily effluent limitation for chronic toxicity.
- (ii) **Thousand Oaks Hill Canyon WWTP Effluent Limitations** in Provision IV.A.1.a, Table 4, contained in Regional Board Order No. R4-2014-0064 (NPDES NO. CA0056294):
- a) The 17,500 lbs/day final average monthly dry weather effluent limitation for chloride and the 150 mg/L final average monthly effluent limitation for chloride under wet weather conditions;
  - b) The 0.4 lbs/day final mass effluent limitation for copper; and
  - c) The “pass” median monthly effluent limitation and “pass or %effect < 50” maximum daily effluent limitation for chronic toxicity.
- (iii) **Simi Valley WQCP Effluent Limitations** in Provision IV.A.1.a, Table 4, contained in Regional Board Order No. R4-2014-0066 (NPDES NO. CA0055221):
- a) The 88,610 lbs/day final average monthly effluent limitation for TDS and the 850 mg/L final average monthly effluent limitation for TDS under wet weather conditions;
  - b) The 26,060 lbs/day final average monthly effluent limitation for sulfate and the 250 mg/L final average monthly effluent limitation for sulfate under wet weather conditions;
  - c) The 15,640 lbs/day final average monthly dry weather effluent limitation for chloride and the 150 mg/L final average monthly wet weather effluent limitation for chloride under wet weather conditions;
  - d) The 104 lbs/day final average monthly effluent limitation for boron and the 1 mg/L final average monthly effluent limitation for boron; and
  - e) The “pass” median monthly effluent limitation and “pass or %effect < 50” maximum daily effluent limitation for chronic toxicity.

**Time Schedule Orders:**

- (i) **Compliance Deadlines:** Stay of Provision in Paragraph 2 on page 7 of the Thousand Oaks TSO, Order No. R4-2014-0065, limiting application of the interim limits for chloride “from May 8, 2014 to January 31, 2015;” and stay of Provision in Paragraph 3 on page 11 of the Camarillo TSO, Order No. R4-2011-0126-A02, which requires: “Achieve full compliance with the final effluent limitations as soon as possible, but no later than December 31, 2015, the date by which Camarillo SD committed to achieving compliance, for TDS and sulfate contained in Order No.R4-2014-0062.”

- (ii) Compliance Schedule: Stay of Provision in Paragraph 3 on page 7 of the Thousand Oaks TSO, Order No. R4-2014-0065, requiring implementation and completion of studies, actions, and milestones according to the schedule included since such a schedule would not be needed if the copper mass-limit had been modified as suggested.
- (iii) Compliance Workplan: Stay of Provision in Paragraph 5 on page 8 of the Thousand Oaks TSO, Order No. R4-2014-0065, which requires: “By August 6, 2014, the Permittee shall submit a work plan for achieving compliance with the final chloride effluent limitations in Order No. R4-2014-0064 to the Regional Water Board.”
- (iv) Pollution Prevention Plan Workplan: Stay of Provision in Paragraph 6 on page 8 of the Thousand Oaks TSO, Order No. R4-2014-0065; in Paragraph 4 on page 11 of the Camarillo TSO, Order No. R4-2011-0126-A02; and in Paragraph 4 on page 7 of the Simi Valley TSO, Order No. R4-2014-0067, which require: “submit a Pollution Prevention Plan (PPP) work plan, with the time schedule for implementation, for approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3.”
- (v) Quarterly Progress Reports: Stay of Provision in Paragraph 7 on page 8 of the Thousand Oaks TSO, Order No. R4-2014-0065; in Paragraph 7 on page 8 of the Camarillo TSO, Order No. R4-2011-0126-A02; and in Paragraph 5 on page 7 of the Simi Valley TSO, Order No. R4-2014-0067, which require submission of quarterly progress reports, the first due October 15, 2014, of efforts taken by the Permittee to comply with the final mass-based limitation for copper and the final effluent limitation for chloride, and the requirements for the content of those reports.

3. The effect of this stay, in accordance with the intent of the parties, is that the interim effluent limitations contained in the TSOs will remain in effect until the petitions for review are completed, and the deadlines contained in the TSOs will be tolled and modified to run from the completion date of the petitions for review, unless a further stay is sought and received from a Superior Court. For chronic toxicity, the previous permit requirements, including a narrative effluent limitation and a 1 TUc trigger for additional monitoring, will remain in place during the pendency of the stay.

4. The parties further stipulate that the Findings in the Permits’ Fact Sheets related to the “requirement” to conduct and/or update and submit a feasibility study related to recycling/water reuse are merely findings, not substantive, enforceable provisions, and thus no stay is necessary for Camarillo (Regional Board Order No. R4-2014-0062 at pg. F-16, Section III.C.11, and pg. F-61, Section VIII.G); Thousand Oaks (Regional Board Order No. R4-2014-0064 at pg. F-16, Section III.C.11, and pg. F-59, Section VIII.G); or Simi Valley (Regional Board Order No. R4-2014-0066 at pg. F-17, Section III.C.11, and pg. F-57, Section VIII.G) .

So stipulated and agreed:


LOS ANGELES REGIONAL WATER  
QUALITY BOARD

DATE: \_\_\_\_\_, 2014

By: \_\_\_\_\_  
Sam Unger, Executive Officer

DATE: June 4, 2014

DOWNEY BRAND LLP

By:   
Melissa Thorne  
Attorneys for Petitioners  
Camarillo Sanitary District, City of  
Thousand Oaks, and City of Simi Valley.