

personally served 6/24/14
3:15pm
Ame



1 DOWNEY BRAND LLP
MELISSA A. THORME (SBN 151278)
2 621 Capitol Mall, 18th Floor
Sacramento, CA 95814-4686
3 Telephone: (916) 520-5376
Facsimile: (916) 520-5776

4 Attorneys for Petitioner

5
6 BEFORE THE
7 CALIFORNIA STATE WATER RESOURCES CONTROL BOARD

8)
9 In the Matter of the City of Simi Valley's)
Petition for Review of Action and Failure to)
10 Act by the California Regional Water Quality)
Control Board, Los Angeles Region, in)
11 Adopting Order Nos. R4-2014-0066 and R4-)
2014-0067 for the Simi Valley Water Quality)
12 Control Plant)

PETITION FOR REVIEW;
PRELIMINARY POINTS AND
AUTHORITIES IN SUPPORT OF
PETITION (WATER CODE
SECTIONS 13320 and 13321 (stay
requested))

DOWNEY BRAND LLP

13)
14)
15 Petitioner the City of Simi Valley ("City"), in accordance with section 13320 of the Water
16 Code, hereby petitions the State Water Resources Control Board ("SWRCB" or "State Board") to
17 review Order Nos. R4-2014-0066 and R4-2014-0067 of the California Regional Water Quality
18 Control Board, Los Angeles Region ("RWQCB" or "Regional Board") reissuing the National
19 Pollutant Discharge Elimination System ("NPDES") Permit for the Simi Valley Water Quality
20 Control Plant ("Simi Valley WQCP") and an accompanying Time Schedule Order ("TSO").
21 Copies of Order Nos. R4-2014-0066 and R4-2014-0067 are attached to this Petition as Exhibits A
22 and B, respectively. A copy of this Petition has been sent to the RWQCB. The issues and a
23 summary of the bases for the Petition follow. At such time as the full administrative record is
24 available and any other material has been submitted, the City will file a more detailed
25 memorandum in support of the Petition.¹

26 _____
27 ¹ The State Board's regulations require submission of a memorandum of points and authorities in support of a petition,
28 and this document is intended to serve as a preliminary memorandum. However, it is impossible to prepare a thorough
memorandum or a memorandum that is entirely useful to the reviewer in the absence of the complete administrative
record, which is not yet available.

1 **FACTUAL BACKGROUND**

2 The drought in the late 1980s increased chloride concentrations in supply waters imported
3 into the Los Angeles Region. This increase, plus salt loading that occurs during beneficial use of
4 supply waters, has made it difficult for many dischargers in the Region to comply with water
5 quality limits for chloride. In 1990, the Regional Water Board adopted Resolution No. 90-04,
6 *Effects of Drought-Induced Water Supply Changes and Water Conservation Measures on*
7 *Compliance with Waste Discharge Requirements within the Los Angeles Region*. This resolution,
8 commonly referred to as the *Drought Policy*, was intended to provide short-term and temporary
9 relief to POTWs who were unable to comply with limits for chloride due to the effects of drought
10 on chloride levels in supply waters imported into the Region. TSO at pgs. 1-2.

11 Chloride levels in supply waters imported into the Region continue to be generally higher
12 than they were before drought conditions in the late 1980s. The high levels of chloride in imported
13 waters appear to be the result of intensifying demands for and utilization of water resources in
14 watersheds that are the sources of supply waters. On January 27, 1997, the Regional Water Board
15 adopted an amendment to the Basin Plan, Resolution 97-02, Amendment to the Water Quality
16 Control Plan to Incorporate a Policy for Addressing Levels of Chloride in Discharges of
17 Wastewaters. This amendment was subsequently approved by the State Water Resources Control
18 Board (Resolution 97-94) and by the Office of Administrative Law on January 9, 1998. The
19 Resolution granted a three-year variance for interim relief to existing dischargers in the Santa Clara
20 River and Calleguas Creek watersheds. On April 13, 1998, the Regional Water Board adopted
21 Order No. 98-027, which amended Order No. 96-043 for Simi Valley WQCP to include an interim
22 chloride daily maximum effluent limit of 190 mg/L based on Resolution 97-02. This interim limit
23 was set to expire on January 9, 2001. TSO at pg. 2.

24 On December 7, 2000, the Regional Water Board adopted Resolution No. 2000-22, to
25 extend the Interim Chloride Limits for Discharges to Calleguas Creek until March 31, 2001. On
26 March 22, 2002, USEPA Region 9 established the Calleguas Creek Total Maximum Daily Load for
27 chloride which used the 150 mg/L objective in the Basin Plan to establish a waste load allocation
28

1 of 10,100 lbs/day for the Simi Valley WQCP during normal conditions, and a waste load allocation
2 of 9,200 lbs/day for the Simi Valley WQCP during drought conditions. TSO at pg. 2.

3 Prior to the permit being re-issued in 2003, the City filed a petition for review on April 29,
4 2002, with the State Board of specific effluent limitations and requested a stay. On August 14,
5 2002 the City of Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP),
6 Camarillo Sanitary District (Camarillo WRP), Camrosa Sanitation District (Camrosa WRP),
7 Ventura County Water Works District No. 1 (Moorpark facility) and the Regional Water Board
8 entered into a "Stipulation for Order Issuing Stay, with Conditions," which stayed the chloride final
9 effluent limitation in NPDES Order No. 96-043. The State Water Board adopted WQO 2002-0017,
10 which approved the August 14, 2002 stipulation. TSO at pg. 2. The remaining petition issues,
11 related to the Regional Board's failure to extend interim chloride limits, were held in abeyance.

12 Subsequently, on July 7, 2003, the City filed a petition of the newly adopted permit with the
13 State Board seeking, *inter alia*, review of the chloride effluent limitations in Order No. R4-2003-
14 0081, and later formally requested that the State Water Board issue a stay of those limitations.

15 On October 20, 2003, the Camarillo Sanitary District, the City of Thousand Oaks, the City
16 of Simi Valley and the Regional Board entered into a stipulation entitled Stipulation for Further
17 Order Issuing Stay, which stayed the final chloride effluent limitations in the NPDES permits, as
18 well as related provisions pertaining to chloride limits in the TSOs, for those three wastewater
19 treatment plants. Specific to the Simi Valley WQCP, the stipulation stayed the final chloride
20 effluent limitations in Order No. R4-2003-0081. On November 19, 2003, the State Board adopted
21 Order WQO 2003-0019 approving the stipulation for stay.

22 On February 13, 2014, the City submitted an email requesting a TSO under CWC
23 section 13385(j)(3)(B)(iii). TSO at pg. 3. On April 14, 2014, the Discharger submitted a written
24 request for higher interim limits for salts based on anticipated changes to its potable water supply.
25 The City expressed concern that the effluent concentrations may exceed final effluent limitations
26 due to the new supply of Colorado River Water, which is higher in salt content than State Project
27 Water. Regional Water Board staff requested specific information from the Permittee regarding
28

1 the change in potable water supply. On or about April 25, 2014, the City submitted additional data
2 indicating that its potable water supply was going to change because of the drought.

3 The Simi Valley WQCP discharges wastewater to Arroyo Simi, which was previously
4 regulated by Order No. R4-2003-0081 and National Pollutant Discharge Elimination System
5 (NPDES) Permit No. CA0055221 adopted on June 5, 2003, and expired on June 5, 2008. Permit at
6 pg. F-4. The terms and conditions of the current NPDES order administratively continued and will
7 remain in effect until the new permit adopted on May 8, 2014, becomes effective on July 1, 2014.

8 In adopting the new Permit and TSO, the Regional Board ignored this entire history and the
9 proactive approaches taken by the City and the other publicly owned treatment works ("POTWs")
10 in the watershed and the efforts undertaken to create watershed solutions. Instead, the Regional
11 Board imposed final effluent limitations for which the City cannot consistently comply. The City
12 seeks Permit and TSO modifications that recognize the Watershed Management Approach touted
13 by the Regional Board (Permit at pg. F-20) and to prevent the City from being in compliance
14 jeopardy. If these issues are not remedied, the future of the watershed approach in California may
15 be severely impaired because all benefits to such an approach were eradicated in this Permit.

16 **1. NAME, ADDRESS, TELEPHONE NUMBER AND EMAIL ADDRESS (IF**
17 **AVAILABLE) OF PETITIONER:**

18 James F. Langley
19 Simi Valley Water Quality Control Plant
20 600 West Los Angeles Avenue
21 Simi Valley, CA93065
22 Telephone: (805) 583-6440
23 jlangleys@simivalley.org

24 All correspondence related to this petition should also be sent to:

25 Melissa Thorne
26 Downey Brand LLP
27 621 Capitol Mall, 18th Floor
28 Sacramento, CA 95814-4686
Telephone: (916) 520-5376
mthorne@downeybrand.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

2. THE SPECIFIC ACTION OR INACTION OF THE REGIONAL BOARD WHICH THE STATE BOARD IS REQUESTED TO REVIEW:

Petitioner seeks review of Order Nos. R4-2014-0066 and R4-2014-0067, which reissue NPDES Permit No. CA0055221, the Permit and TSO for the City of Simi Valley. The specific Permit requirements which the City requests the State Board review include the following:

- (A) Improper final numeric effluent limitations for salts without necessary compliance schedules authorized by the applicable TMDLs.
- (B) Inclusion of numeric “Pass” and “% Effect” chronic toxicity limits mandating the use of the Test of Significant Toxicity (TST), which are contrary to State Board precedent and the implementation provisions of the Calleguas Watershed Toxicity TMDL.
- (C) Other Improper and Problematic Effluent Limitations.
- (D) Unnecessary and Burdensome Monitoring and Reporting Requirements.
- (E) Improper Miscellaneous Provisions.

The State Board is also requested to review the Regional Board’s actions in adopting the Permit and TSO for compliance with due process, the California Water Code, the California Administrative Procedures Act (“APA,” Cal. Gov’t Code, section 11340 et seq.), the California Environmental Quality Act (“CEQA,” Cal. Public Resources Code, section 21000 *et seq.*) in its environmental checklists for the TMDLs adopted and implemented in these permits, the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (SIP), and EPA regulations, as applicable.

3. THE DATE ON WHICH THE REGIONAL BOARD ACTED, OR REFUSED TO ACT:

The Regional Board adopted the Permit and TSO on May 8, 2014 in Simi Valley, California.

4. A FULL AND COMPLETE STATEMENT OF THE REASONS THE ACTION OR FAILURE TO ACT WAS INAPPROPRIATE OR IMPROPER:

The City’s preliminary statement of points and authorities is set forth in Section 7 below. The City may supplement this statement upon receipt and review of the hearing transcript and the

1373764.1

1 full administrative record, which must include the records for each of the TMDLs implemented in
 2 this Permit to be able to determine whether the Permit is consistent with the TMDLs. While
 3 Section 7 details the reasons why the actions by the Regional Board were inappropriate and
 4 improper, the two main issues in this Petition relate to salinity and toxicity limits.

5 The reasons that the Regional Board's action to include final numeric effluent limitations
 6 for salinity in the Permit was inappropriate or improper include, but are not limited to, the
 7 following:

- 8 a. Inconsistency with the Clean Water Act and Basin Plan provisions, including the
 9 Salts TMDL²;
- 10 b. Ignoring the Watershed Approach to water quality regulation; and
- 11 c. Placing the City in compliance jeopardy unnecessarily by including final effluent
 12 limitations without compliance schedules approved in the applicable TMDL.

13 The reasons that the Regional Board's action to include the Permit's chronic toxicity
 14 effluent limitations based on a Pass/Fail approach using the Test of Significant Toxicity (TST)
 15 guidance methodology was inappropriate or improper include, but are not limited to, the following:

- 16 a. Premature until the State Water Board adopts a statewide Toxicity Policy or Plan;
- 17 b. Inconsistent with the applicable Calleguas Creed Watershed Toxicity, Chlorpyrifos
 18 and Diazinon TMDL (April 25, 2005) ("Toxicity TMDL")³;
- 19 d. Improperly based on EPA guidance, not promulgated EPA regulation and methods;
- 20 e. Includes unlawful and inappropriate Maximum Daily limits for Chronic Toxicity;
 and
- 21 f. Improper determination that numeric limits are required.

22 In Section 7, the City asserts that provisions of Order Nos. R4-2014-0066 and R4-2014-
 23 0067 are inconsistent with the law and otherwise inappropriate for various reasons, including:
 24 failure to comply with the Porter-Cologne Water Quality Control Act (Cal. Water Code, section

25 ² To the extent that any TMDL discussed in this Petition is itself unlawful or includes requirements contrary to law,
 the City also challenges the TMDL as applied for the first time in this Permit.

26 ³ The Toxicity TMDL may itself be unlawful, be unsupported by evidence, or include requirements contrary to law.
 27 The Toxicity TMDL was based on listing data from 1992 and 1993, taken long before ammonia control technology
 28 was implemented at the local POTWs and before substantial Best Management Practices ("BMPs") were in place with
 municipal stormwater and agricultural discharges. The Toxicity TMDL specifically states that "No additional data
 were reviewed during the water quality assessments in 1998 and 2002 for this reach." Toxicity TMDL at pgs. 17-20.

1 13000 *et seq.*); failure to comply with CEQA and the APA; inconsistency with the Water Quality
2 Control Plan, Los Angeles Region (“Basin Plan”), including amendments made to incorporate
3 various TMDLs; inconsistency with the Clean Water Act (33 U.S.C. § 1251 *et seq.*) and its
4 implementing regulations (40 C.F.R. Parts 122, 123, 130, 131, 133, and 136); absence of findings
5 supporting the provisions of the Order; the inclusion of findings not supported by the evidence; and
6 other grounds that may be or have been asserted by the City or the other permittees at the same
7 hearing, whose testimony and comments were incorporated by reference by the City.

8 **5. THE MANNER IN WHICH THE PETITIONER IS AGGRIEVED:**

9 The City is aggrieved because the challenged requirements contained in the Permit are
10 unnecessary, inconsistent with law, infeasible to consistently comply with, and may place the City
11 in enforcement jeopardy from civil and even criminal enforcement actions or from third party
12 citizen suits under the Clean Water Act. The imposition of penalties when a watershed-based
13 solution is in the process of being designed and implemented represents a waste of taxpayer/
14 ratepayer funds both at the state and local levels. The City is further aggrieved because many of
15 the effluent limits and requirements were imposed without adequate justification and legal
16 authority and without any demonstrated water quality or other public benefit. The City is also
17 aggrieved by the fact that all of the time, effort, and resources (including millions of dollars)
18 expended on the watershed process were effectively wasted after the adoption of this Permit, which
19 failed to acknowledge the teamwork that went into the TMDL implementation plans and
20 compliance schedules.

21 **6. THE SPECIFIC ACTION THE PETITIONER REQUESTS THAT THE STATE OR**
22 **REGIONAL BOARD TAKE:**

23 Petitioner seeks an Order by the State Board that will modify or remand Order Nos. R4-
24 2014-0066 and R4-2014-0067 to the Regional Board for revisions and will direct the Regional
25 Board to:

26 A. Remove all final effluent limitations for salinity constituents (chloride, sulfate, and
27 Total Dissolved Solids (“TDS”) and boron) and insert compliance schedules in the Permit
28 where authorized by TMDLs to ensure that the watershed approach has time to be fully
implemented.

- 1 B. Remove all numeric "Pass" and "% Effect" chronic toxicity limits mandating the
 2 use of the Test of Significant Toxicity ("TST"), along with all related findings and
 3 requirements, and replace those provisions with the previous narrative effluent limitation
 4 for chronic toxicity and trigger of 1 TUc (and related provisions) consistent with State
 5 Water Board precedent and the implementation provisions of the Calleguas Watershed
 6 Toxicity TMDL.
- 7 C. Remove all limits without demonstrated reasonable potential, and other limits
 8 inconsistent with federal law requirements.
- 9 D. Remove all unnecessary and burdensome monitoring requirements.
- 10 E. Correct the miscellaneous issues raised by the City.

11 **7. A STATEMENT OF POINTS AND AUTHORITIES IN SUPPORT OF LEGAL
 12 ISSUES RAISED IN THE PETITION:**

13 **A. Improper Salinity Final Effluent Limits without Compliance Schedules in the
 14 Permit.**

15 The Permits contains final effluent limits for salinity constituents (chloride, sulfate, TDS,
 16 and boron) equivalent to final WLAs from the Salts TMDL or the water quality objective applied
 17 end-of-pipe. Permit at pg. 6, Table 4. There are several references in the Permit and TSO to the
 18 Simi Valley WQCP's inability to comply with these final effluent limits and the need for interim
 19 limits. *See* Permit at pg. 6, Table F-2, and pgs. F-27 and F-28; TSO at pg. 3, para. 16. However,
 20 these infeasible final limits were included in the Permit first because the TMDL was not approved
 21 pursuant to Section 303(c) of the Clean Water Act,⁴ and then because "the City [sic] has not

22 _____

23 ⁴ The Tentative Order's Fact Sheet at Section VI.B.7., Compliance Schedules, stated that "since the Salts TMDL was
 24 approved by EPA under CWA § 303(d), instead of 303(c), the interim WLAs and the compliance schedule cannot be
 25 included in the NPDES Order." This sentence was legally incorrect and ultimately removed because approval under
 26 section 303(c) is not required. *See* 33 U.S.C. §1313(e)(3)(A) and (F)(compliance schedules under the non-
 27 discretionary EPA approval ["shall approve"] requirements of the Continuing Planning Process in section (e), not
 28 section (c)). Federal rules (40 C.F.R. §122.47(a)), Regional Board Basin Plans, and the State Water Board's
 Compliance Schedule Policy, Res. No. 2008-0025, expressly allows compliance schedules, including those for
 TMDLs, in permits. In addition, implementation plans for TMDLs are not subject to EPA review and approval as
 water quality standards (*see* 40 C.F.R. §131.5(a)), approval is required only of the TMDL itself (33 U.S.C.
 §1313(d)(1)(D)(2), (e)(3)(C)):

6) c) A Water Board may establish a compliance schedule that exceeds ten years in a permit that ... has a
 permit limitation that implements or is consistent with the waste load allocations specified in a TMDL that is
 established through a Basin Plan amendment, *provided that the TMDL implementation plan contains a
 compliance schedule or implementation schedule.* (*See* State Water Resources Control Board Res. No. 2008-
 0025, POLICY FOR COMPLIANCE SCHEDULES IN NATIONAL POLLUTANT DISCHARGE
 ELIMINATION SYSTEM PERMITS at pg. 5. (italics added).)

1 submitted sufficient information to justify the inclusion of a compliance schedule for chloride
2 pursuant to the Compliance Schedule Policy or federal regulations.” (See Regional Board’s
3 response to the District’s comments at pg. 48). Therefore, interim limits and compliance schedules
4 were included in a separate TSO. The City asked that the interim limits established in the City’s
5 TSO be found to be consistent with the Salts TMDL requirements and moved from the TSO to the
6 Permit. The City also asked that the final numeric effluent limitations be removed from the Permit
7 as unattainable in the near term. Neither of these requests was granted.

8 **1. Salinity Final Numeric Effluent Limits Need Not be Included in the**
9 **Permits.**

10 On May 1, 2014, the Regional Board requested supplemental comments on alternatives to
11 including final limits in order to address the watershed approach for salinity control. The City
12 provided those comments and cited to the United States Supreme Court case of *Arkansas v.*
13 *Oklahoma*, where the Court recognized “the Clean Water Act vests in the EPA and the States broad
14 authority to develop long-range, area-wide programs to alleviate and eliminate existing pollution.”
15 *Arkansas v. Oklahoma*, 503 U.S. 91, 108 (1992).

16 The City also pointed to *Communities for a Better Environment*, where the court found that
17 an enforceable “schedule of compliance” leading to the adoption of final effluent limitations
18 designed to achieve water quality standards (such as at the completion of a TMDL) constituted an
19 acceptable WQBEL for purposes of the Clean Water Act. (*Communities for a Better Environment*,
20 *supra*, 109 Cal.App.4th at pp.1106-1107.) Since a TMDL is adopted because water quality
21 standards are not being met and includes a plan and a process for coming into compliance with
22 those standards at the end of the TMDL compliance schedule, it is not appropriate to include final
23 numeric effluent limitations that are essentially the water quality objective at end of pipe until the
24

25 Finally, the State Board Compliance Schedule Policy came after many of the TMDLs at issue in this Petition and did
26 not supersede “existing compliance schedule provisions in TMDL implementation plans that are in effect as of the
27 effective date of Resolution No. 2008-0025. (See SWRCB Res. No. 2008-0025 at pg. 7, para. 11; see also
28 Administrative Update of the Water Quality Control Plan for the Los Angeles Region – Chapter 3: “Water Quality
Objectives”, Los Angeles Regional Board, February 19, 2013 at pg. 10.) Because implementation plans are created
under state law, these plans become effective when approved by the Office of Administrative Law and have
independent applicability as regulations.

1 plan and the process included in the TMDL is complete. Therefore, the final numeric effluent
2 limitations should be referenced in a finding and a narrative effluent limitation could be imposed
3 requiring participation in the implementation of the TMDL that, along with the interim limits in the
4 TMDL, would work to hold the status quo on the point sources while the other components of the
5 plan and the process for improvements on a watershed level scale are implemented. As previously
6 stated, the definition of “effluent limitation” in the Clean Water Act refers to “*any restriction*,” and
7 may include a “*schedule of compliance*.” (33 U.S.C. § 1362(11); 40 C.F.R. §122.2.)

8 The *Communities for a Better Environment* case also held that “numeric effluent limitations
9 are not legally required.” 109 Cal. App. 4th at 1106. So a narrative effluent limitation to maintain
10 the status quo along with a compliance schedule implementing the interim limits while the TMDL
11 schedule is completed is “consistent with the assumptions” of the TMDL that has a long term
12 schedule, understanding that the issues of addressing salinity holistically in the watershed will take
13 time. Imposing final numeric effluent limitations based on the standard that is acknowledged
14 won’t be met until TMDL implementation is complete will impose liability and/or extraordinary
15 treatment requirements on the permittees that “may become unnecessary” because the watershed
16 programs ultimately are intended to “provide assimilative capacity for the point source discharges.”
17 109 Cal. App. 4th at 1103. “The TMDL program considers all pollutant sources within a
18 watershed and focuses on a watershed-wide solution to the impairment.” SWRCB Order No.
19 2001-0006 at 23. “A TMDL is ‘derived from *and complies with*’ the applicable water quality
20 standard.” *Id.* at 24 (emphasis added). Thus, it only makes sense that “[p]ermit findings ... reflect
21 that final water quality-based effluent limitations ... will be derived from wasteload allocations in
22 the applicable TMDL” after completion of the compliance schedule (*id.* at 25), and that those
23 allocations apply after the plan and the process have been implemented on a watershed basis.

24 “The continuing planning process established by section 303(e) of the CWA provides a
25 good framework for implementing TMDLs....” See EPA HQ Memorandum from Robert
26 Perciasepe to Regional Administrators on “New Policies for Establishing and Implementing Total
27 Maximum Daily Loads (TMDLs),” (1997); see also 33 U.S.C. §1313(e)(3)(A) and (F)(compliance
28 schedules under the non-discretionary EPA approval [“shall approve”] requirements of the

1 Continuing Planning Process in section (e), not section (c)). According to the Ninth Circuit Court
2 of Appeal, Section 303(e), requires each State to have a “continuing planning process,” and gives
3 some operational force to the prior information-gathering provisions [under §303(d)]. *Pronsolino*
4 *v. Nastri* 291 F.3d 1123, 1128 (9th Cir. 2002). The EPA must approve a State's continuing
5 planning process if it “will result in plans for all navigable waters within such State” that include,
6 *inter alia*, effluent limitations, TMDLs, area-wide waste management plans for nonpoint sources of
7 pollution, and plans for “adequate implementation, including schedules of compliance...” *Id.*
8 *citing* 33 U.S.C. §303(e)(3). The Court held that the upshot of this intricate scheme is that the
9 CWA leaves to the States the responsibility of developing plans to achieve water quality standards,
10 while providing federal funding to aid in the implementation of the state plans. *Id.* at 1128-29
11 *citing* *Dombeck*, 172 F.3d at 1097; 33 U.S.C. §303(e); 33 U.S.C. §319(h), 33 U.S.C. §1329(h)
12 (providing for grants to States to combat nonpoint source pollution). TMDLs are primarily
13 informational tools that allow the States to proceed from the identification of waters requiring
14 additional planning to the required plans. *Id.* at 1129 *citing* *Alaska Center for the Environment v.*
15 *Browner*, 20 F.3d 981, 984-85 (9th Cir.1994). As such, TMDLs serve as a link in an
16 implementation chain that includes federally-regulated point source controls, state or local plans
17 for point and nonpoint source pollution reduction, and assessment of the impact of such measures
18 on water quality, all to the end of eventually attaining water quality goals for the nation's waters.
19 *Id.* at 1129, 1137 (“the basic purpose for which the § 303(d) list and TMDLs are compiled, the
20 *eventual attainment* of state-defined water quality standards.” (emphasis added)).

21 States must implement TMDLs only to the extent that they seek to avoid losing federal
22 grant money; no pertinent statutory provision otherwise requires implementation of Section 303
23 plans or providing for their enforcement. *Id.* at 1140 *citing* CWA §309, 33 U.S.C. §1319; CWA
24 §505, 33 U.S.C. §1365. The nature of the allocations and of the implementing controls remains up
25 to the States. *Id.* at fn. 19; *see also* Water Code §13242 (requiring implementation plans, including
26 time schedules for compliance, for all water quality objectives). EPA has no authority for approval
27 of TMDL or Water Code section 13242 implementation plans and has no say as to whether States
28 include compliance schedules authorized under those plans in the permits.

1 The State Water Board's Compliance Schedule Policy expressly allows compliance
 2 schedules, including those for TMDLs, in permits "*provided that the TMDL implementation plan*
 3 *contains a compliance schedule or implementation schedule.*" (See State Board Res. No. 2008-
 4 0025, Compliance Schedule Policy at pg. 5 (italics added).)

5 "If a compliance schedule is within the term of the permit, the final effluent limitations are
 6 included in the permit provisions. If the compliance schedule exceeds the length of the permit, the
 7 final effluent limitations are included in the permit findings. In the latter case, the findings include:
 8 (1) the water quality to be achieved, (2) the reason the final water quality-based effluent limitation
 9 is not being incorporated into the permit as an enforceable effluent limitation at this time; (3) a
 10 statement that it is the intent of the Regional Board to include, in a subsequent permit revision, the
 11 final water quality-based effluent limitations as an enforceable limitation.... The permit findings
 12 also state the appropriate enforcement actions that may be taken by the Regional Board if the
 13 interim limitations and requirements are not met." SWRCB, *Report in Support of U.S.*
 14 *Environmental Protection Agency's Review of California's Continuing Planning Process* (May
 15 2001) at 30. Since under the Salinity TMDL, compliance with the TMDL targets will be based on
 16 a 15-year implementation schedule, this exceeds the length of a permit and justifies inclusion of a
 17 compliance schedule in lieu of final limits. SWRCB Res. No. 2008-0033, para. 6.

18 The TMDL resolution (No. R4-2007-016) for the Salinity TMDL expressly recognized that:
 19 Economic considerations were considered and are reflected in an implementation program
 20 that is flexible and allows 15 years for POTWs... to comply with the final allocations."
 (Para. 19.)

21 Interim limits are included to allow time for dischargers to put in place implementation
 22 measures necessary to achieve final waste load allocations. (Attachment A at 6.)

23 Finally, the schedule states that 15 years from the effective date of the TMDL...

24 The TMDL was incorporated into the Basin Plan as required by federal regulation, as was
 25 the associated implementation schedule. 40 C.F.R. §130.6(c)(1) and (6). All NPDES permits must
 26 "ensure consistency with the requirements of a Water Quality Management Plan [Basin Plan]." 40
 27 C.F.R. §122.44(d)(6). Thus, all permits must be consistent with the TMDL and schedules adopted
 28

1 therein that were made part of the Los Angeles Region's Basin Plan.⁵

2 Each of these citations argues strongly against the Regional Board's assertion that final
3 numeric effluent limitations for TMDL-controlled constituents need to be imposed and met before
4 the end of the TMDL compliance schedule. Such an interpretation renders the TMDL's compliance
5 schedule completely superfluous.⁶ The Regional Board clearly agreed in the Salinity TMDL to
6 provide the POTWs in the Calleguas Watershed with adequate time for compliance. The Regional
7 Board should not now renege on that agreement by violating the express terms of the Basin Plan
8 amendment it agreed upon and adopted.

9 **2. Ample Authority Exists to Include the Compliance Schedule in the Permit.**

10 Providing compliance schedules based on an approved TMDL in a TSO rather than in the
11 Permit contradicts the established policies and laws discussed above and places the City in
12 compliance jeopardy for infeasible final numeric effluent limitations. Because TSOs do not amend
13 the Permit, the City could still be subject to liability for failure to comply with final effluent
14 limitations if the interim limits are not included or referenced in the permit. To avoid this
15 unnecessary liability, the Permit should be modified to include all interim limits and compliance
16 schedules within the Permit. Compliance schedules are allowed if a State has clearly authorized
17 them in its water quality standards or indicated in its implementing regulations (e.g., basin plan
18 amendments) that it intends to allow them. *See In the Matter of Star-Kist Caribe, Inc.*, 3 E.A.D.
19 172, 175-77 (1990); *see also* EPA Memo from James Hanlon, EPA Office of Wastewater
20 Management to Alexis Strauss, Water Division, EPA Region 9 (May 10, 2007) at pg. 1.

21 California has clearly authorized compliance schedules as Water Code section 13050
22 mandates that water quality control plans (i.e., Basin Plans) include a program of implementation

24 ⁵ Only when reasonable potential exists do the effluent limitations need to be "consistent with the assumptions and
25 requirements of any available wasteload allocation for the discharge prepared by the State and approved by EPA
pursuant to 40 CFR 130.7." 40 C.F.R. §122.44(d)(1)(vii). Regional Board staff's contrary interpretation ignores that
this section only applies "[w]hen developing water quality based effluent limits under this paragraph." *Id.*

26 ⁶ "It is an accepted canon of statutory interpretation that we must interpret the statutory phrase as a whole, giving effect
27 to each word and not interpreting the provision so as to make other provisions meaningless or superfluous." *U.S. v.*
144,774 pounds of Blue King Crab, 410 F.3d 1131, 1134 -1135 (9th Cir. 2005); *see also Northwest Environmental*
Advocates v. City of Portland, 56 F.3d 979, 983 (9th Cir. 1995)(rejecting plaintiffs' proposed permit interpretation in
28 part because "this reasoning would require the court to read [certain provisions] out of the permit altogether.")

1 needed for the achievement of water quality objectives. Water Code section 13242(b) makes clear
2 that every implementation plan must include “a time schedule for actions to be taken” and section
3 13263(c) expressly authorizes time schedules in permits. Many TMDLs, including the Salts
4 TMDL, are created as implementation plans under section 13242 for water quality objectives that
5 have not been attained. *See* State Board Res. No. 2008-0033 (Salts TMDL, at para. 4 - “The State
6 Water Board finds that in amending the Basin Plan to establish this TMDL, the Los Angeles Water
7 Board complied with the requirements set forth in sections 13240, 13242, and 13269 of the
8 California Water Code.”); State Board Res. No. 2006-0078 (Metals TMDL at para. 13 - “The State
9 Water Board finds that the Basin Plan amendment is in conformance with Water Code section
10 13240, which specifies that Regional Water Quality Control Boards may revise Basin Plans; and
11 section 13242, which requires a program of implementation of water quality standards.”) Because
12 these compliance schedules are authorized by State law, and the TMDLs and implementation plans
13 have been approved under State law, the compliance schedules are authorized for inclusion in the
14 Permit.

15 Each TMDL is adopted and incorporated into the Basin Plan as an amendment to that plan,
16 becoming a State regulation and law. As a part of State law, the Basin Plan, the TMDL, *and its*
17 *schedule provisions* must be implemented in NPDES permits. *See EPA v. California ex rel.*
18 *SWRCB*, 426 U.S. 200, 221, n. 36 (1976) (implicitly sanctioning a State’s individualized effluent
19 limitations and permit conditions, such as compliance schedules); 33 U.S.C. §1362 (defining the
20 term “effluent limitation” to include “schedules of compliance”). An implementation schedule in a
21 TMDL reflects the Board’s determination (with full opportunity for public participation) of what is
22 reasonable for that pollutant after a focused analysis on the complexity of the pollutant problem
23 and the feasibility of compliance. Thus, the implementation schedule in a TMDL provides the
24 authority for inclusion of a compliance schedule in an NPDES permit. *See id.*; *see also* Santa Ana
25 Regional Water Board, Basin Plan Amendment Workshop packet at page 9 – Authorization for
26 Schedules of Compliance in NPDES permits (Item 10, February 25, 2000).

27 For these reasons, interim limits associated with TMDL compliance schedules must be
28 included within the Permit instead of in the TSO. A failure to do so unreasonably subjects the City

1 to federal enforcement (by EPA or citizen groups) for non-compliance with final effluent
2 limitations that should be time deferred under the TMDL's adopted implementation plan.

3 **3) The Permit Ignores the Watershed Approach Adopted into the TMDL.**

4 The Regional Board's action to ignore the requirements and implementation plan for the
5 Salts TMDL ignores the outcomes of the robust and complex stakeholder process spearheaded by
6 the City and other POTWs in the area to develop a meaningful watershed solution to the various
7 water quality concerns facing the Calleguas Creek Watershed. One of the goals of the Salts TMDL
8 was to establish a procedure to address drought conditions and to reasonably protect beneficial uses
9 while still accounting for increased salt loads in the incoming water supply. The process allows for
10 the POTWs to offset increased effluent concentrations by removing salt load from another source
11 (like groundwater desalting) and the wasteload allocations included an adjustment factor ("AF")
12 that allows for consideration of this process. However, implementing this AF process requires the
13 development of watershed infrastructure and projects that are not yet in place. Until those projects
14 are completed, an AF cannot be calculated and the final limits cannot be met or appropriately
15 adjusted. The Salts TMDL provided a compliance schedule that would allow time to implement
16 these projects and develop a watershed solution to bring the entire watershed into a salt balance at
17 the end of the schedule.

18 The POTW discharges cannot be considered independently of the watershed solutions.
19 Until the full watershed solution is implemented and the infrastructure addressing source water is
20 constructed, the current drought conditions will cause increased salt concentrations in POTW
21 effluent that cannot be predicted or be reasonably or feasibly addressed through actions conducted
22 at the water reclamation plants. The purpose of the TMDL was to provide the time and structure
23 necessary to develop the watershed solutions and POTWs should be given the time provided in the
24 TMDL to ensure they do not exceed final effluent limitations, particularly during the current
25 drought conditions, prior to the construction of watershed solutions needed to offset increased salt
26 loads and reasonably protect beneficial uses.

1 The watershed effort is complicated and will take time. "There are four key structural
 2 elements to the regional implementation plan: Regional Salinity Management Conveyance
 3 ["RSMC"], Water Conservation, Water Softeners, and Best Management Practices for Irrigated
 4 Agriculture. Sub-watershed implementation includes Renewable Water Resource Management
 5 Program for the Southern Reaches and Northern Reach Renewable Water Management Plan.
 6 Responsible parties must comply with load and waste load allocations for salts in the Calleguas
 7 Creek Watershed within 15 years of approval." See accord SWRCB Staff Report for Resolution
 8 No. 2008-0033; Res. No. 2008-0033 at para. 6 ("Compliance with the targets will be based on a
 9 15-year implementation schedule.")

10 Based on the increasing salts effluent concentrations due to the drought and changing water
 11 supply, and for consistency with the Salts TMDL, the City requested interim limits and a
 12 compliance schedule be included in the Permit for chloride, TDS, and sulfate. Although the City
 13 requested interim limits for each of the salinity constituents, the TSO only included an interim limit
 14 for chloride. Interim limits are required "to allow time for dischargers to put in place
 15 implementation measures necessary to achieve final waste load allocations." See Attachment A to
 16 Regional Board Res. No. R4-2007-016 at pg. 6. Although an updated schedule was provided, the
 17 schedule in the TSO was as follows:

Description	Start Date	End Date
Conduct Source evaluation study and identify feasible source control strategies.	7/1/2014	7/1/2014
Implement Phase 2 of the Northern Reach Renewal Water Management Plan (NRRMP) implementation plan (i.e., construction of Moorpark Desalter).	1/1/2015	1/1/2015
Implement identified feasible source control strategies.	9/1/2015	12/31/2016
Determine if Optional Special Studies are needed as described in TMDL Basin Plan Amendment and submit workplans. 1. Develop Averaging Periods, Compliance Points 2. Develop Natural Background Exclusion 3. Develop Site Specific Objectives 4. Develop Site Specific Objectives for Drought Conditions	1/1/2018	1/1/2018

Description	Start Date	End Date
The tasks below will be completed after the term of this TSO.		
Submit results of special studies 2 years after EO	2 years after EO approval: Dec 3, 2018	12/3/2020
Implement Phase 4 of the NRRMP implementation plan	3/1/2020	12/1/2023
Achieve WLAs, & WQOs		12/02/2023

This schedule was proposed by the City to justify a compliance schedule in the Permit, not the TSO. Although the City anticipates that it can comply with the schedule above, the City cannot consistently meet final numeric salinity effluent limitations until at least the time that the NRRMP implementation plan is completed, which is not until 2023 per the above schedule. Until that time, the final numeric salinity effluent limitations in the Permit are inappropriate and should be removed.

4) **The TMDL does not Require Wet Weather or Concentration-Based Limits for Salts.**

The wet weather effluent limitations for TDS, sulfate and chloride in Table 4 should be deleted because there is no reasonable potential for the effluent to cause or contribute to an exceedance of the applicable water quality objectives for salts during wet weather. *See* Permit Fact Sheet, Section IV.C.2.b.vi. and vii. on page F-27. The Permit states that, during wet weather, the limits for TDS, sulfate, boron, and chloride are based on the water quality objectives found in Basin Plan Table 3-8 on page 3-12. *Id.* However, as noted in the dry weather definition of the Permit states that: “Any discharges from the Facility during wet weather would be assimilated by these large storm flows and would not cause exceedances of water quality objectives.” *See* Permit at Section VII.O. on page 30 (emphasis added). Therefore, no reasonable potential exists during wet weather for the applicable water quality objectives to be exceeded and no effluent limitation is required during wet weather. 40 C.F.R. §122.44(d)(1)(i) and (iii). These limits must be removed.

Additionally, the Salts TMDL specifically identified that only dry weather allocations were needed to address any identified impairments. *See* Order No. R4-2007-016, Attachment A at pg. 6 (“WLAs shown in table below apply to POTWs during dry weather when the flows in the receiving

1 water are below the 96th percentile flow.”). Therefore, only dry weather effluent limitations are
 2 needed to implement the Salts TMDL WLAs. Inclusion of wet weather limits or limits yearround
 3 (in the case of TDS, sulfate and boron) was an abuse of discretion as unnecessary and not
 4 authorized by the TMDL or federal regulations if no reasonable potential exists.

5 In addition, the Salts TMDL does not require final concentration-based limits. The Salts
 6 TMDL stated that “The POTWs and non-storm water NPDES permits shall achieve WLAs, which
 7 shall be expressed as NPDES mass-based effluent limitation in accordance with federal regulations
 8 and state policy on water quality control” at the completion date “15 years after effective date of
 9 the TMDL.” (No. R4-2007-016 at pg. 22, Table 7-22.2 (emphasis added).) Notwithstanding this
 10 clear statement, the Permit contains a concentration-based wet weather limit for chloride. *See*
 11 Permit at pg. 6, Table 4. Inclusion of concentration-based limits is not required by federal law.
 12 *See* 40 C.F.R. §122.45(f). Although such inclusion is discretionary, the Regional Board failed to
 13 provide adequate findings and evidence and to conduct the requisite Water Code section
 14 13263/13241 analysis specifically targeted at imposing these limits, which are more stringent than
 15 required by federal law.⁷ For these reasons, the wet weather concentration-based limits must be
 16 removed from the Permit.

17 **B. Improper Chronic Toxicity Limits**

18 Chronic toxicity effluent limitations are listed in Provision IV.A.1.a., Table 4, on p. 7 of the
 19 Permit as “Pass” as a Median Monthly Effluent Limitation (“MMEL”) and “Pass or %Effect <50”
 20 as a Maximum Daily Effluent Limitation (“MDEL”). These terms are defined in Provision VII.J.
 21 (i.e., Compliance Determination, Chronic Toxicity) on pg. 25 of the Tentative Order and are said to
 22 be determined based on the Test of Significant Toxicity (TST) approach as described in a 2010
 23 EPA guidance document (National Pollutant Discharge Elimination System Test of Significant
 24 Toxicity Implementation Document (EPA 833-R-10-003, 2010), which is not part of an approved
 25 Part 136 method. These effluent limitations are not consistent with State Board Orders or the
 26

27 ⁷ While the Regional Board added a new section VIII to the Fact Sheet, this analysis is very generic and although it
 28 discusses the factors in Water Code section 13241 generally, there is no analysis of any particular limit that is being
 reviewed or justified.

1 Toxicity TMDL and the City requests that they be removed and replaced by a narrative toxicity
2 effluent limitation consistent with State Board precedential orders and with the Toxicity TMDL.

3
4 **1) The Chronic Toxicity Limits are Premature until the State Water Board**
5 **Adopts a Statewide Toxicity Policy.**

6 On September 16, 2003, the State Water Board adopted Order No. WQO 2003-0012, in
7 response to petitions filed by the County Sanitation Districts No. 2 of Los Angeles County and
8 Santa Monica Baykeeper for the Los Coyotes and Long Beach Water Reclamation Plant NPDES
9 permits [SWRCB/OCC File Nos. A-1496 and A-1496(a)]. In 2003, in its precedential Order No.
10 WQO 2003-0012, the State Water Board found that the use of final numeric effluent limitations in
11 permits for POTWs, particularly those that discharge to inland surface waters, is an issue of
12 statewide importance that should be addressed in a statewide plan or policy. In addition, the State
13 Water Board replaced the numeric chronic toxicity effluent limitations with a narrative chronic
14 toxicity limitation until a statewide toxicity policy is adopted. The City's 2003 Permit was
15 modified to coincide with the requirements of State Board Order No. WQO 2003-0012.

16 The State Water Board has not yet adopted its anticipated statewide policy for chronic
17 toxicity. As such, the inclusion of new chronic toxicity effluent limitations using a new test
18 method (the TST) lacks adequate authority, violates State Water Board precedent, and represents
19 an abuse of discretion.

20 The Regional Board alleges on pages 10-11 of the response to comments for the City of
21 Simi Valley that because more than ten years and two permit cycles have passed, the Regional
22 Board can "exercise its own discretion" to ignore SWRCB precedential orders. Although the main
23 issue on whole effluent toxicity ("WET") limits was decided by the State Board in WQO 2003-
24 0012 in 2003, this decision was later upheld and followed in subsequent State Board Orders, No.
25 WQ 2008-08 (City of Davis) and WQ 2012-0001 (City of Lodi). The 2012 Lodi order at page 22
26 recognized that "[t]he Board previously addressed this issue in a precedential decision" and has
27 "concluded that a numeric effluent limitation for chronic toxicity was not appropriate in the permit
28 under review, but that the permit had to include a narrative effluent limitation for chronic toxicity."

1 In the Lodi case, the State Water Board determined that the discharge had the reasonable potential
2 to cause or contribute to an excursion above the Basin Plan's narrative toxicity objective.⁸
3 Therefore, on remand, the Central Valley Water Board was ordered to "amend Order No. R5-2007-
4 0113 to add an appropriate narrative chronic toxicity limitation." *See also* State Water Board
5 Order No. WQ 2008-0008 at pgs. 5-7 (concluding that a numeric effluent limitation for chronic
6 toxicity is not appropriate at this time.)

7 Thus, at least three (3) precedential State Water Board orders mandate a narrative chronic
8 toxicity limit, all of which are being violated by the Permit. All the City and the other permittees
9 asked for was that the Regional Board follow this binding precedent and include a narrative
10 effluent limitation, consistent with the Basin Plan's narrative objective, along with a trigger for
11 additional testing based on 1 TUC, which is consistent with the Toxicity TMDL (which does not
12 require that either a numeric effluent limitation or the TST methodology be prescribed). Doing
13 otherwise unnecessarily places the permittees in compliance jeopardy.

14 Moreover, the fact that the Regional Board has included numeric toxicity limits and the
15 TST in other permits does not *de facto* make this action legal. In fact, one of the permits cited by
16 the Regional Board as "precedent" was the permit for Calleguas Municipal Water District, which is
17 currently pending review by the State Board and cannot be used as authority for the current permits
18 (particularly when that was an Ocean Plan, not Basin Plan, based permit). The other permits cited
19 are not permits for POTWs and have different influent and effluent that are not comparable to
20 domestic wastewater. State Board Order No. WQO 2003-0012 held at page 10 (emphasis added):

21 "Because the influent can consist largely of domestic wastewater over which the Districts
22 has little or no control, we find that a numeric effluent limitation should not have been used
23 ... for chronic toxicity. It is not feasible, at least initially, to impose numeric effluent
24 limitations since it will result in a permit violation whenever there is toxicity in the effluent,
25 even if the cause were from the domestic influent, the Districts had no basis for knowing
26 the cause, and the Districts was pursuing the cause and its elimination through vigorous
27 compliance with stringent TRE requirements.

28 ⁸ Here, the City does not have reasonable potential for chronic toxicity, so no limit (numeric or narrative) is required.
40 C.F.R. §122.44(d)(1)(iv).

1 Thus, stormwater or boatyard discharge permits are not exactly comparable to POTW
 2 permits and were not the subject of Order No. WQO 2003-0012. For these reasons, because
 3 numeric chronic toxicity effluent limitations based on "Pass/Fail" and "% Effect" are inconsistent
 4 with binding State Board precedent, these limits should be removed from the Permit and replaced
 5 with a narrative chronic toxicity limit.

6 2) **The Chronic Toxicity Limits are Inconsistent with the Calleguas**
 7 **Watershed Toxicity TMDL.**

8 The Toxicity TMDL was developed through a collaborative, stakeholder-led process, which
 9 created the technical analyses leading to the Regional Board staff's recommended TMDL. This
 10 TMDL addresses water quality impairments of Calleguas Creek, including its tributaries, segments
 11 and Mugu Lagoon, caused by toxicity, sediment toxicity, and two organophosphate pesticides,
 12 chlorpyrifos and diazinon. *See accord* Calleguas Creek Watershed Toxicity TMDL Staff
 13 Memorandum at pg. 1. EPA approved the TMDL on March 14, 2006, and in its approval letter
 14 stated that EPA was not taking action on the implementation plans provided with the TMDLs, but
 15 generally concurred with the State's proposed implementation approaches.

16 The Permit attempts to regulate chronic toxicity through "Pass/Fail" or "% effect" limits
 17 based on the TST methodology, even though the definitions contained in the Toxicity TMDL
 18 clearly mandate the use of chronic toxicity units (TUc) using the NOEC, as follows:

19 "To meet the narrative toxicity objective, a numeric toxicity target of 1 chronic toxicity unit
 20 (1 TUc) is established.... Equation 1 describes the calculation of a TUc.

21 **Equation 1** TUc=Toxicity Unit Chronic = 100/NOEC (no observable effects
 concentration)

22 The NOEC (no observable effects concentration) is defined in USEPA's Technical Support
 23 Document (TSD) as 'the highest concentration of toxicant, in terms of percent effluent, to
 24 which the test organisms are exposed, that causes no observable effect, with the sample
 25 concentration expressed as a percentage.... [NOEC] was the selected alternative as it is
 26 consistent with current Los Angeles Regional Board and USEPA NPDES permitting
 27 practice. If the Regional Board revises NPDES permits to calculate a TUc using inhibition
 28 concentrations (ICs) or other point estimate methodology, the Regional Board may
 reconsider the numeric target." (Toxicity TMDL at pg. 53.)

1 As noted above, “the toxicity target in water is set to equal a toxicity unit.” (Toxicity
2 TMDL at pg. 107.) EPA approved of this approach. *See* EPA Letter, June 9, 2005 (“In particular,
3 the proposal to set 1 TUc (Toxicity Unit Chronic) as the target to explain unknown toxicity is in
4 accordance with 40 CFR 130.2(i).”) Regional Board staff agreed. *See* Response to Comments
5 Total Maximum Daily Load for Toxicity, Chlorpyrifos, and Diazinon in Calleguas Creek its
6 Tributaries and Mugu Lagoon, June 10, 2005 at Comment 2.2 (“Staff agree that the target of 1TUc
7 is appropriate for this TMDL.”).

8 Although the Regional Board’s response to comments on the Permit claimed that “The
9 [Toxicity] TMDL imposes numeric WLAs for chronic toxicity on POTWs” (Response to
10 Comments at pg. 11 (April 30, 2014)), the Toxicity TMDL Technical Report that provides the
11 scientific and technical support for that TMDL states that it does not include any Waste Load
12 Allocations (“WLAs”) for chronic toxicity. Instead, the Toxicity TMDL Technical Report states
13 that “[t]hese toxicity targets can not be divided into portions and allocated to sources.” (Toxicity
14 TMDL Technical Report at pgs. 107 and 114; *see also* Response to Peer Review by Dr. Mel Suffit
15 dated May 11, 2005, at pg. 18 (“The authors realized the futility of the use of a TMDL for water
16 column toxicity. The reviewer wholeheartedly agrees...”) “Additionally, the loading capacity of a
17 stream with regard to a toxicant causing unknown toxicity in water and/or sediment is inherently
18 unknown and can not be allocated. As such, a toxicity allocation equal to the numeric targets will
19 be set at the base of each of the subwatersheds⁹... [which] provides a mechanism to address all
20 dischargers contributing to in-stream toxicity as individual dischargers may additively cause an in-
21 stream exceedance of the toxicity targets.” (Toxicity TMDL Technical Report at pg. 114.) If no
22 wasteload allocation for each POTW exists, then no effluent limitations are required to be
23 “consistent with the assumptions and requirements of any available wasteload allocation.” (*See*
24 Response to Comments at pg. 11 (April 30, 2014) *citing* 40 C.F.R. §122.44(d)(1)[(vii)(B)].) The

25 _____
26 ⁹ This intent was not made clear in the TMDL Resolution, which states: “A wasteload allocation of 1.0 TUc is
27 allocated to the major point sources (POTWs) discharging to the Calleguas Creek Watershed.” (Regional Board Res.
28 No. R4-2005-009 at pg. 4. The City believes that the Resolution must be read to be consistent with the findings and
evidence contained in the TMDL Technical Report and applied at the base of each of the sub-watersheds. Otherwise,
there is no technical basis for these WLAs and they are subject to challenge as applied.

1 Regional Board apparently mistakenly presumed that the discussion in the Toxicity TMDL that the
 2 “WLAs established for the three major POTWs in this TMDL will be implemented through
 3 NPDES permit limits” applied to toxicity, not just diazinon and chlorpyrifos. (Toxicity TMDL
 4 Technical Report at pg. 122.) However, the previous discussion demonstrates that there was not
 5 intended to be a WLA for toxicity. Instead, the Toxicity TMDL anticipated that “[t]he toxicity
 6 numeric target [of 1 TUc] will be implemented as a trigger mechanism for initiation of the
 7 TRE/TIE process as outlined in USEPA’s *Understanding and Accounting for Method Variability in*
 8 *Whole Effluent Toxicity Applications Under the National Pollutant Discharge Elimination System*
 9 *Program* (2000b) and current NPDES permits held by dischargers to the CCW.”¹⁰ (Toxicity
 10 TMDL Technical Report at pgs. 122 and 114; Regional Board Res. No. R4-2005-009 at pg. 7;
 11 Response to Peer Review by Dr. Mel Suffit dated May 11, 2005, at pg. 21 (“Water column toxicity
 12 targets are included to provide a method for triggering future investigations of the causes of
 13 toxicity.”); Response to Comments Total Maximum Daily Load for Toxicity, Chlorpyrifos, and
 14 Diazinon in Calleguas Creek its Tributaries and Mugu Lagoon, June 10, 2005 at Comments 5.1 and
 15 16.8 (“The toxicity target will be incorporated into NPDES permits according to current policy
 16 which is to use toxicity exceedances as a trigger to conduct further toxicity testing and TIEs as
 17 warranted.”) This trigger approach is also consistent with the express terms of the Los Angeles
 18 Basin Plan’s narrative toxicity objective, which specifies that “Effluent limits for specific toxicants
 19 can be established by the Regional Boards to control toxicity identified under Toxicity
 20 Identification Evaluations (TIEs).” (Toxicity TMDL Technical Report at pg. 15; Basin Plan at 3-
 21 17.)

22
 23
 24 ¹⁰ The Regional Board tries to argue that the language in the Implementation Plan, which states: “The toxicity WLAs
 25 will be implemented in accordance with US EPA, State Board and Regional Board resolutions, guidance and policy at
 26 the time of permit issuance or renewal” (Res. R4-2005-009 at pgs. 7-8), trumps the mandate that the target be
 27 implemented as a trigger. However, guidance and policy cannot supersede adopted regulations and Basin Plan
 28 amendments. In addition, the TMDL Resolution itself states that “if other information supporting other methods [for
 evaluating toxicity] becomes available, the Regional Board may reconsider this TMDL and revise the water toxicity
 numeric target.” (Res. R4-2005-009 at pgs. 8-9.) This language, included at the request of the City and others (*see*
 Letter from the Camarillo Sanitary District, Thousand Oaks, Simi Valley, Camrosa Sanitary District, and Ventura
 County Water Works District #1 (June 10, 2005)), was intended to address the situation present here; namely where the
 Regional Board would like to implement the toxicity objective through another method (a pass/fail method using the
 TST), it should revise the TMDL to modify or remove the 1 TUc target.

1 Thus, for the reasons provided, the Regional Board adopted effluent limits in the Permit for
2 chronic toxicity that are inconsistent with the Toxicity TMDL and Basin Plan. For this reason, the
3 Permit's chronic toxicity provisions must be modified to be consistent with the intent of the
4 Toxicity TMDL and implemented as a trigger for a TIE/TRE.

5 3) **The Chronic Toxicity Requirements are Improperly Based on EPA**
6 **Guidance, Not Promulgated EPA Regulations.**

7 The Permit makes it very clear that the monitoring must use only approved Part 136
8 methods, properly promulgated by EPA. (Permit at pg. D-4, Provision III.A. ("Monitoring results
9 must be conducted according to test procedures under 40 C.F.R. part 136...")(emphasis added);
10 Permit at pg. E-6, note 2 to Table E-2 ("Pollutants shall be analyzed using the analytical methods
11 described in Part 136.")(emphasis added); *see also* 40 C.F.R. §122.44(i)(iv)(monitoring to be done
12 according to test procedures approved under 40 C.F.R. Part 136); 40 C.F.R. §136.1(a).)

13 Using the TST, instead of the prescribed TUC and the NOEC method specified in the Part
14 136 methods at 40 C.F.R. §136.3(a), Table 1A, footnote 27, is inconsistent with Part 136, which
15 mandates the use of USEPA's 2002 Methods (EPA 821-R-02-013). The 2002 Methods do not
16 mention the TST or provide that the TST may be used as an approved method. A 2010 EPA
17 Guidance document cannot overrule promulgated regulations. In addition, EPA made some
18 changes to WET test methods in its 2012 modifications to the *Promulgated Guidelines*
19 *Establishing Test Procedures for the Analysis of Pollutants under the Clean Water Act: Analysis*
20 *and Sampling Procedures*: Final Rule, 77 Fed. Reg. 29758-29846 (May 18, 2012), but did not
21 incorporate the TST even though it had been available as guidance for two years. This evidences
22 an intent by EPA to not formally approve the TST as a Part 136 method.

23 Thus, the aquatic toxicity testing provisions in 40 C.F.R. Part 136 only specifically list
24 LC₅₀, percent effluent, NOEC/NOEL, and IC₂₅ under Parameter and Units for acute and chronic
25 aquatic toxicity testing. *See* 40 C.F.R. §136.3(a), Table IA, footnote 27 (referencing *Short-Term*
26 *Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater*
27 *Organisms*, EPA-821-R-02-012, Fifth Edition, October 2002. Additionally, both the 2012 Final
28 Rule and the 2002 promulgated method manual fails to describe, endorse, or recommend the use of

1 the TST for statistical analysis.¹¹ *Id.* While the 2002 Rule acknowledged that “the statistical
 2 methods recommended in this manual are not the only possible methods of statistical analysis,” the
 3 Rule’s “recommended statistical methods described in the method manuals were selected because
 4 they are (1) applicable to most of the different toxicity test data sets for which they are
 5 recommended, (2) powerful statistical tests, (3) hopefully ‘easily’ understood by nonstatisticians,
 6 and (4) amenable to use without a computer, if necessary.” 67 Fed. Reg. 69964.

7 Although the TST is a relatively new analytical tool for WET, bioequivalence
 8 testing/alternative null hypothesis testing has been a widely used statistical method in other
 9 contexts for many decades. In fact, peer-reviewed publications proposed the use of bio-equivalency
 10 in aquatic toxicity testing as early as 1995 (Erickson and McDonald) – seven (7) years *before* the
 11 2002 promulgation of the EPA-recognized and approved methods. Therefore, even with direct
 12 understanding of the TST/bioequivalence statistical methods, EPA promulgated the current toxicity
 13 methods with a recommendation and strong preference for the use of point estimation for NPDES
 14 compliance monitoring and a strong *rejection* of pass/fail analyses, as follows:

15 a) The Federal Register Vol. 67, No. 223, Tuesday November 19, 2002 contains the Final
 16 Rule ratifying approval of several whole effluent toxicity methods in 40 C.F.R. Part 136.
 17 Page 69958 of that Federal Register states the following: “As previously stated in the
 18 method manuals (USEPA, 1993; USEPA, 1994a; USEPA, 1994b) and EPA’s Technical
 19 Support Document (USEPA, 1991), EPA recommends the use of point estimation
 20 techniques over hypothesis testing approaches for calculating endpoints for effluent toxicity
 21 tests under the NPDES Permitting Program.” [emphasis not added]

22 b) The USEPA manual “Short-Term Methods for Estimating the Chronic Toxicity of
 23 Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms”
 24 (EPA/600/600/R-95/136) (August 1995) states the following on pg. 8: “2.2 *Types of Tests*
 25 2.2.3 “*Use of pass/fail tests consisting of a single effluent concentration (e.g., the*
 26 *receiving water concentration or RWC) and a control is not recommended.” [emphasis
 27 included in the original manual text]*

28 ¹¹ The 2002 Rule does express a preference for point estimation techniques (IC25) over hypothesis testing approaches
 for calculating endpoints for effluent toxicity tests under the NPDES Permitting Program. 67 Fed. Reg. 69957 and
 69958.

1 The recent Alternative Test Procedure (“ATP”) letter produced by the Regional Board at
2 the Permit adoption hearing (although requested prior to that date and available to the Water
3 Boards after March 17, 2014), ignores these previous EPA recommendations.

4 The Regional Board’s response to comments on the Permit at pages 12-13 for the City of
5 Simi Valley stated:

6 “In 2014, in response to the State Water Board’s request to use the TST hypothesis testing
7 approach in NPDES permits, USEPA determined—based on the evidence presented in the
8 State Water Board’s request—that the results of TST tests and NOEC-LOEC tests—are
9 acceptably equivalent under the ATP process at 40 CFR 136 for all NPDES permits issued
10 by State and Regional Water Boards.”

11 It appears that the Regional Board relied on the granting of a “Limited Use Alternative Test
12 Procedure” under 40 C.F.R. §136.5. This approach allows “Any person may request the Regional
13 Alternate Test Procedure (ATP) Coordinator or permitting authority to approve the use of an
14 alternate test procedure in the Region.” (40 C.F.R. §136.5(a).) However, it is not clear that a State
15 can request such an approach since the request must first be sent to the State. (*Id.* at subd. (b).)
16 Moreover, it is not clear that this “Limited Use” ATP would be legal to apply broadly (statewide)
17 when it could be deemed to be a “final agency action” undertaken without any formal notice or any
18 opportunity for public comment. Furthermore, an ATP appears to be for use by a discharger or lab
19 requesting an alternative method and it is not clear that dischargers can be *REQUIRED* to use an
20 ATP. It is difficult to see how the State or EPA could legally object to any permittee continuing to
21 use the standard prescribed 2002 test methods (NOEC or IC25) if the standard methods and the
22 ATP produce “acceptably equivalent” results as claimed. *See* 67 Fed. Reg. 69955 (2002)(“these
23 methods, including the modifications in today’s rule, are applicable for use in NPDES permits.”).

24 On February 12, 2014, the State Board asked for EPA approval of “a two-concentration test
25 design when using the Test of Significant Toxicity (TST) hypothesis testing approach” “[p]ursuant
26 to Code of Federal Regulations, title 40, section 136.4.” *See* SWRCB ATP Request Letter from
27 Renee Spear to Eugenia McNaughton, EPA Region 9 (Feb. 12. 2014) at pg. 1. Section 136.4 is for
28 *nationwide use* and must be submitted to EPA Headquarters in Washington, D.C., not to EPA
Region 9 in San Francisco. Nevertheless, EPA Region 9, in turn and in record time, approved a

1 *limited use* ATP statewide under Section 136.5. See EPA ATP Approval Letter from Eugenia
2 McNaughton, Ph.D. to Renee Spear, SWRCB (March 17, 2014)(emphasis added). The request and
3 approval are under different regulatory provisions, making the approval unlawful.

4 Further, the ATP is suspect as it was not submitted by a discharger or a laboratory, but by
5 the State Board after receiving the two-concentration method using the TST from EPA. This self-
6 dealing to avoid a full-blown regulatory process is contrary to law and policy. The ATP process
7 was designed to “encourage organizations *external to EPA* to develop and submit for approval new
8 analytical methods.” See *Guide to Method Flexibility and Approval of EPA Water Methods*, EPA
9 Office of Water (Dec. 1996) at pg. 77. All but a single lab, single discharger ATP (i.e., Tier 1)
10 must go through rulemaking. For Tier 2 and 3 new methods (multi-lab), “EPA will begin the
11 rulemaking process.” *Id.* at pgs. 80-82. Furthermore, EPA acknowledges that it currently has no
12 approved protocols for reviewing or approving a WET ATP. *Id.* at 93 (“EPA is developing a
13 protocol for approval of new and modified (alternate) WET methods....”; see also
14 <http://water.epa.gov/scitech/methods/cwa/atp/questions.cfm> (last accessed 5/30/2014)(stating
15 “Note: The EPA does not have a protocol for toxicity testing [ATP] under EPA’s Whole Effluent
16 Toxicity (WET) program.”).

17 Finally, an ATP for WET is contrary to federal regulations. “Method Modifications” are
18 explicitly *prohibited* for “Method-Defined Analytes” by 40 C.F.R. section 136.6(b)(3), which
19 states (with emphasis added): “(3) Restrictions. An analyst may not modify an approved Clean
20 Water Act analytical method for a method-defined analyte.” EPA has previously declared that
21 WET is a Method-Defined Analyte. See 67 Fed. Reg. 69965 (“toxicity is inherently defined by the
22 measurement system (a ‘method-defined analyte’) and toxicity cannot be independently measured
23 apart from a toxicity test.”); see also Brief of Respondents EPA, *et al.*, in *Edison Electric Institute,*
24 *et al., v. USEPA*, Case No. No. 96-1062 (D.C.Cir. 2004) at 44-45 and 78 citing Response to
25 Comments at 219-20, J.A. XX; 67 Fed. Reg. 69,965. (“Because toxicity is defined and measured
26 by its effect on living organisms, whole effluent toxicity is considered a method-defined analyte
27 (i.e., it cannot be measured independently from a toxicity test). Thus, WET test results cannot be
28

1 independently confirmed by comparing the results to a known concentration of toxicity.”).

2 Therefore, WET methods cannot be modified without formally amending 40 CFR Part 136.

3 For these reasons, and the others provided herein, all references to the Pass/Fail or % Effect
4 limits based on the TST must be removed from the Permit.

5 a) Use of an ATP Cannot Be Mandated over Promulgated Methods.

6 Even assuming *arguendo* that the ATP was proper, EPA Region 9 went further, beyond
7 approving the ATP, to *mandate* use of the two-concentration TST by stating that this ATP “will
8 apply to all new or revised NPDES permits issued by the State Water Board and Regional Water
9 Quality Control Boards and any EPA-issued California permits that include whole effluent toxicity
10 provisions.” See EPA ATP Approval Letter from Eugenia McNaughton, Ph.D. to Renee Spear,
11 SWRCB (March 17, 2014)(emphasis added). Neither EPA nor the Regional Water Board has the
12 authority to impose the TST until that method has been promulgated by EPA as an approved
13 method under Part 136. Analytical results obtained by using a non-promulgated method cannot be
14 used for NPDES compliance determination purposes until that method has been incorporated into
15 40 C.F.R. Part 136. See *accord* Permit at pg. E-21 (“Analysis under this section is for monitoring
16 purposes only. Analytical results obtained for this study will not be used for compliance
17 determination purposes, since the methods have not been incorporated into 40 CFR part 136.”)
18 Similarly, the particular number of dilutions in a dilution series cannot be mandated. 67 Fed. Reg.
19 69956 (“no one particular dilution series is required.”)

20 This mandate also contradicts a June 18, 2010 EPA Headquarters memo accompanying the
21 TST Implementation Document, from James Hanlon, the Director of the EPA Office of
22 Wastewater Management, which stated: “The TST approach does not preclude the use of existing
23 recommendations for assessing WET data provided in EPA’s 1991 Water Quality-based Technical
24 Support Document (TSD) which remain valid for use by EPA Regions and the States.” Thus, all
25 the TST can be used for is additional information, similar to the extra PCB and CEC monitoring
26 (discussed elsewhere in this petition) where samples are required using a non-promulgated method
27 – however, the difference is for PCBs and CECs, that extra data is not being used for compliance
28 determination processes. See Permit at pg. E-9, footnote 13; and pg. E-19.

b) EPA Guidance cannot Overrule Promulgated Regulations.

Section VII.J on page 25 of the Permit states that the inclusion of a numeric effluent limitation for toxicity is based on an EPA guidance document:

- *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, June 2010) (2010 TST guidance document), and

This document cannot be used to justify the Permit's requirements because this guidance document does not mandate use of the TST, or require the inclusion of a numeric effluent limitation for toxicity. Appendix D of the 2010 TST guidance document includes example permit language for either a trigger *or* an effluent limitation. The Training Tool also discusses both permit triggers and effluent limitations for toxicity. In the Training Tool, numeric effluent limitations are only needed in cases where there is reasonable potential and even if there is reasonable potential, effluent limitations for toxicity are not needed if chemical specific effluent limitations are included for the pollutants identified as causing the toxicity (Section 2.5, page 31).¹²

Simi Valley WQCP does not have reasonable potential for toxicity, and the causative pollutants (ammonia, chlorpyrifos, and diazinon) that were determined to potentially be the cause of toxicity in the effluent during the Toxicity TMDL development process are all assigned effluent limitations within the permit. As a result, the Regional Board can point to nothing in either of the guidance documents cited that *mandates* the use of numeric effluent limitations for toxicity.

Additionally, the 2010 TST guidance document is merely *guidance* that may be changed at any time as policies and directions change. Importantly, the disclaimer in that guidance document specifically notes that the document is not "a permit or a regulation itself." The TST guidance document clearly states that:

¹² If State water quality standards ("WQS") contain only narrative water quality criteria for WET and it is documented in the record for the permit (i.e., fact sheet or statement of basis) that chemical specific water quality-based effluent limitations ("WQBELs") are sufficient to attain and maintain the narrative water quality criteria, then WQBELs for WET are not necessary. 40 C.F.R. §122.44(d)(1)(v). Effluent limits are only authorized for the causative toxicant. *See accord* Los Angeles Basin Plan at pg. 3-17.

1 “The document does not and cannot impose any legally binding requirements on EPA,
2 states, NPDES permittees, or laboratories conducting or using WET testing for permittees
3 (or for states in evaluating ambient water quality). EPA could revise this document without
public notice to reflect changes in EPA policy and guidance.”¹³

4 The other document cited is merely part of a training tool that is not even published guidance.

5 Although EPA often tries to regulate by guidance, courts have frowned upon this practice
6 as aptly described in *Appalachian Power Co. v. EPA*, 208 F.3d 1015, 1020 (D.C. Cir. 2000). The
7 district court in the *Appalachian Power* case found fault in EPA’s regulating by setting aside the
8 guidance in its entirety. (*Id.* at p. 1028.) “If an agency acts as if a document issued at headquarters
9 is controlling in the field, if it treats the document in the same manner as it treats a legislative rule,
10 if it bases enforcement actions on the policies or interpretations formulated in the document, if it
11 leads private parties or State permitting authorities to believe that it will declare permits invalid
12 unless they comply with the terms of the document, then the agency’s document is for all practical
13 purposes ‘binding.’” (*Id.* at p. 1021 [*citations omitted*].)

14 More recent cases have reached the same conclusion in other instances when EPA tried to
15 impose its will through interpretive rules, such as the 2010 TST guidance. One case related to
16 invalidating EPA guidance setting forth air quality attainment alternatives. (*NRDC v. U.S. EPA*,
17 643 F.3d 311 (D.C.Cir. 2011).) Another related to “requirements” contained in letters related to
18 water quality permitting prohibitions related to blending and mixing zones. In this case, the court
19 found that EPA not only lacked the statutory authority to impose the guidance regulations on
20 blending, but also violated the Administrative Procedures Act (“APA”), 5 U.S.C. § 500 et seq., by
21 implementing the guidance on both issues without first proceeding through the notice and comment
22 procedures for agency rulemaking. (*Iowa League of Cities v. U.S. EPA*, 711 F.3d 844, 878 (8th
23 Cir. 2013).) The case law is clear that EPA must regulate through rules and not through informal
24 guidance. Similar rules apply to the Water Boards, which also cannot regulate by guidance,
25
26

27 ¹³ USEPA, National Pollutant Discharge Elimination System Test of Significant Toxicity Technical Document. EPA
28 833-R-10-004, June 2010 (Exhibit I).

1 particularly where that guidance is contrary to established regulations (e.g., the Toxicity TMDL)
2 and statewide precedential orders as described above.

3 **4) Simi Valley has No Reasonable Potential for Chronic Toxicity.**

4 During the 2003-2014 Permit cycle, the City never exceeded the 1 TUc trigger. *See* Permit
5 Hearing Presentation of the Regional Board (May 8, 2014) at slide 7. In the absence of any
6 showing that toxicity has been present in the City's effluent, there is no basis to find reasonable
7 potential for chronic toxicity in the City's effluent, and the Regional Board's Order should not
8 contain *any* limitations for toxicity. *See accord City of Woodland v. California Regional Water*
9 *Quality Control Board, Central Valley Region, Alameda County Superior Court Case No. RG04-*
10 *188200 (May 16, 2005) at pg. 13.* Thus, no limits for chronic toxicity are justified for Simi Valley
11 and must be removed.

12 **5) A Maximum Daily Limit for Chronic Toxicity is Impracticable,**
13 **Unlawful and Inappropriate.**

14 Assuming arguendo that any chronic toxicity limit is justified, federal law only authorizes
15 monthly and weekly average effluent limitations for publicly owned treatment works (POTWs)
16 without a demonstration that these effluent limitations are "impracticable." (See 40 C.F.R.
17 §122.45(d)(2)("For continuous discharges all permit effluent limitations, standards and
18 prohibitions, including those necessary to achieve water quality standards, shall unless
19 impracticable be stated as: (2) Average weekly and average monthly limitations for POTWs.")) As
20 described above, the Permit includes an MDEL for chronic toxicity, which is more stringent than
21 required by federal law and has not been adequately justified with an impracticability analysis.
22 Therefore, this limitation is contrary to law.¹⁴

23
24
25 ¹⁴ California courts have already held that daily limits are not allowed unless demonstrated to be impracticable and
26 these decisions are binding on the Water Boards since not appealed. (*See City of Burbank v. State Water Resources*
27 *Control Board, 35 Cal. 4th 613, 623, n.6 (2005)* (The Supreme Court held: "Unchallenged on appeal and thus not
28 affected by our decision are the trial court's rulings that... (2) the administrative record failed to support the specific
effluent limitations; (3) the permits improperly imposed daily maximum limits rather than weekly or monthly
averages;...)(emphasis added).) Because no additional analysis has been done for the chronic toxicity limit to
demonstrate the impracticability of monthly and weekly average limits, the Regional Board must be ordered to remove
the daily maximum limit.

1 In addition, a daily maximum limit is unnecessary to protect aquatic life. Chronic toxicity
2 testing is meant to assess long-term impacts to biological communities of organisms, not the
3 impact of a single day's or week's discharge. Furthermore, use of a daily maximum chronic
4 toxicity limit to protect against a single discharge event capable of exceeding the objective makes
5 no sense when a single chronic test itself typically consists of three (3) or more discrete samples
6 collected over an exposure period of up to nine (9) days. (See 67 Fed. Reg. 69953 (2002 Final
7 WET Rule)("short term methods for estimating chronic toxicity [] use longer durations of
8 exposure (*up to nine days*) to ascertain the adverse effects of an effluent or receiving water on
9 survival, growth and/or reproduction of the organisms." (emphasis added).) Therefore, a short
10 term average or daily maximum limit for chronic WET is impracticable and a chronic toxicity limit
11 (as is recognized for other long-term chronic objectives, such as to protect human health) should be
12 expressed only in narrative form "There shall be no chronic toxicity in the effluent discharge,"
13 interpreted as a monthly average, or a median monthly if the monthly average is demonstrated to
14 be impracticable. (See accord *In the Matter of the Own Motion Review of City of Woodland*, Order
15 WQO 2004-0010, 2004 WL 1444973, *10 (June 17, 2004) ("Implementing the limits as
16 instantaneous maxima appears to be incorrect because the criteria guidance value, as previously
17 stated, is intended to protect against chronic effects." The limits were to be applied as monthly
18 averages instead); SWRCB Order No. 2003-0012 and EPA Letter to Los Angeles Regional Board
19 on Long Beach/Los Coyotes Permits at pg.4 (May 31, 2007).)

20 Further, a pass/fail result from a single effluent test provides no indication of actual aquatic
21 toxicity in the ambient receiving waters. Even EPA explains that:

22 "The agency is concerned that single concentration, pass/fail, toxicity tests do not
23 provide sufficient concentration-response information on effluent toxicity to determine
24 compliance. It is the Agency's policy that all effluent toxicity tests include a minimum
of five effluent concentrations and a control."¹⁵

25 Contrary to EPA regulations and guidance, the Permit includes an MDEL that would result
26 in an effluent limit violation as a result of a single sample exceedance. Despite a potentially high

27
28 ¹⁵ See U.S. EPA, *Whole Effluent Toxicity: Guidelines Establishing Test Procedures for the Analysis of Pollutants -
Supplementary Information Document* (SID) at pg. 28 (Oct. 2, 1995).

1 effect level needed to exceed the MDEL (≥ 0.50), it is inappropriate to assess single sample
2 violations for chronic toxicity analyses due to the variability and uncertainty inherent in testing
3 biological organisms for non-lethal endpoints. The single test is highly problematic given that the
4 TST procedure often inaccurately identifies non-toxic samples as toxic or "Fail." When non-toxic
5 method blank data from EPA's Inter-laboratory WET Variability Study was re-evaluated using the
6 TST procedure, the number of false positives increased dramatically. Nearly 15% of all non-toxic
7 samples were declared "toxic" in the *Ceriodaphnia dubia* reproduction test - four times more than
8 occurred when using either the NOEC method - and, 7.4 % of all non-toxic samples were declared
9 "toxic" using the TST procedure to evaluate fathead minnow growth, which is double the rate at
10 which similar false conclusions occurred when evaluating the same data with the traditional,
11 promulgated NOEC method.

12 Additionally, the preamble to the 2002 WET Rule says "EPA policy states that 'EPA does
13 not recommend that the initial response to a single exceedance of a WET limit, causing no known
14 harm, be a formal enforcement action with a civil penalty.'" 67 Fed. Reg. 69968 *citing* EPA memo
15 entitled *National Policy Regarding Whole Effluent Toxicity Enforcement* (1995a) (emphasis
16 added). The appropriate response to a chronic toxicity test indicating the presence of toxicity is not
17 to declare a violation, but to investigate the cause, starting with follow-up testing to confirm the
18 initial result. (*See accord* 67 Fed. Reg. 69968 (EPA policy suggests additional testing is an
19 appropriate initial response to a single WET exceedance); Basin Plan at 3-17 (recommending TIE
20 to identify cause of toxicity prior to imposing effluent limitation to implement the narrative
21 Toxicity objective); *see accord* Ocean Plan at pg. 45 (triggering TRE Process).)

22 For all of these reasons, the inclusion of a daily maximum effluent limitation for chronic
23 toxicity is impracticable, unlawful, and inappropriate. At the very least, the State Water Board
24 should order that the daily limit for chronic toxicity be removed.

25 6) **The Regional Board's Presumptions Regarding Numeric Limits are**
26 **Mistaken.**

27 The Regional Board at page 10 of the response to comments related to toxicity limits
28 mistakenly claims that "[f]ederal regulations establish an explicit presumption that a numeric

1 effluent limitation – rather than a non-numeric effluent limit – is required by the Clean Water Act
 2 to make reasonable further progress toward the goal of eliminating pollutants into the nation’s
 3 waters. Non-numeric effluent limitations may only replace numeric effluent limits in an NPDES
 4 permit if a numeric limit is ‘infeasible.’ (40 C.F.R. §122.44.)”

5 This statement misunderstands the federal regulations and misinterprets case law binding
 6 on the Water Boards. The Clean Water Act generally requires a permit to contain water quality
 7 based effluent limitations (“WQBELs”) whenever the permitting agency determines that pollutants
 8 are or may be discharged at a level which will cause, or have the reasonable potential to cause, or
 9 contribute to, an instream excursion above the allowable concentration of a numeric criterion
 10 within a state water quality standard (40 C F R §122.44(d)(1).)

11 The Court in the case of *City of Tracy v. SWRCB*, Sac. Superior Court Case No. “34-2009-
 12 80000392 (2010)(emphasis added) held the following, which is binding on the Water Boards since
 13 not appealed:

14 As an initial matter, the Court rejects any suggestion that effluent limitations are required to
 15 be numeric. The definition of “effluent limitation” in the Clean Water Act refers to “any
 16 restriction,” and may include a “schedule of compliance” (33 U.S.C. § 1362(11); 40 C.F.R.
 17 §122.2.) The term “schedule of compliance” means a “schedule of remedial measures,”
 including an enforceable sequence of interim requirements leading to compliance with an
 effluent limitation or standard (33 U.S.C. § 1362(17); 40 C.F.R § 122.2.)

18 In *Communities for a Better Environment*, the First Appellate District Court of Appeal
 19 specifically rejected the argument that the federal regulations mandate numeric WQBELs in
 20 all circumstances. Rather, the Court found, Congress intended a “flexible approach”
 21 including alternative effluent control strategies. *Communities for a Better Environment v*
 22 *State Water Resources Control Bd.* (2003) 109 Cal. App 4th 1089, 1105, *Communities for a*
 23 *Better Environment v State Water Resources Control Bd.* (2005) 132 Cal. App 4th 1313,
 1318; *see also Divers’ Environmental Conservation Organization v State Water Resources*
 24 *Control Bd* (2006) 145 Cal.App.4th 246, 262 [following *Communities for a Better*
 25 *Environment.*] Thus, numeric effluent limitations are not necessary to meet the
 26 requirements of the federal Clean Water Act. (*Communities for a Better Environment,*
 27 *supra*, 109 Cal.App.4th at p. 1093.) Indeed, federal regulations expressly permit non-
 28 numeric effluent limitations - such as best management practices - when numeric effluent
 limitations are “infeasible.” (40 C.F.R. § 122 44(k)(3); *see also* State Board Order WQ
 2006-0012, p. 16.)

The State Board construes “infeasibility” to refer to “the ability or propriety of
 establishing” numeric limits. (See State Board Order WQ 2009-0015, p.7; State Board
 Order WQ 2006-0012, pp. 14-16.) Thus, according to the State Board, feasibility turns on

1 the ability and propriety of establishing numeric effluent limitations, rather than the ability
2 of a discharger to comply.

3 However, this argument is unfounded and is not supported by case law or by the Board's
4 own Water Quality Orders. It will nearly always be possible to establish numeric effluent
5 limitations, but there will be many instances in which it will not be feasible for dischargers
6 to comply with such limitations. In those instances, states have the authority to adopt non-
7 numeric effluent limitations.

8 *Communities for a Better Environment* makes clear that one factor a board may consider in
9 determining whether a numerical effluent limitation is "feasible" is the "ability of the
10 discharger to comply." (See *Communities for a Better Environment, supra*, 109 Cal.App 4th
11 at pp 1100.) The court expressly approved the regional board's consideration of this factor
12 in upholding the determination that numeric effluent limits were not "appropriate" for the
13 refinery at issue in that case. (*Id.* at p. 1105 [approving determination that numeric WQBEL
14 was not feasible "for the reasons discussed above," which included inability of discharger
15 to comply.]

16 Likewise, in Water Quality Order 2003-0012, the State Board declined to impose numeric
17 effluent limitations [for WET] in a waste discharge permit because of a concern that
18 numeric limitations would not be appropriate.^{FN} (State Board Order WQ 2003-0012.)

19 FN. The Board's Water Quality Orders indicate a "preference" for determining the "ability and
20 propriety" of establishing numeric effluent limitations in a regulatory setting, e g as part of a basin
21 plan amendment, rather than as part of a permit petition process. (See State Board Order WQ 2003-
22 0012, pp 8-9, State Board Order WQ 2009-0015, p 7 fn 28.) Thus, the Board contends, while the
23 Board may consider dischargers' ability to comply when deciding whether numeric effluent
24 limitations are "appropriate," in general, a discharger's ability to comply should not be considered
25 when setting specific numeric effluent limitations in a permit (See *ibid.*) However, Water Quality
26 Order 2003-0012 shows that the Board has considered the "ability and propriety" of numeric
27 effluent limitations as part of the permit petition process, at least to give the Board time to address
28 the issue in a regulatory setting (See State Board Order WQ 2003-0012, p 9.)

The Board's Order in this proceeding cited to WQO 2003-0012 with approval, noting
that "it IS possible to have effluent limitations other than numeric effluent limitations
[provided] the effluent limitation is enforceable and designed to implement the water
quality objective." (CSPA000398.) The Board remanded the matter to the Regional Board
to further consider whether there are feasible alternatives or methods, other than reverse
osmosis, that the City could use to achieve the numeric limits. (CSPA000401.)

Accordingly, the Court rejects the argument that in determining the "propriety" of numeric
effluent limitations, the Board may not consider the ability (or inability) of the discharger to
comply with such limitations. The ability to comply is a critical factor in determining the
"propriety" of numerical limitations.

This decision and those cases cited as underlying authority for the decision challenge the
Regional Board's justification. As these cases proclaim, numeric effluent limitations are not

1 required by any law or regulation for any constituent. Moreover, numeric limits are particularly
2 inappropriate for WET because of the inherent inaccuracies of biological testing and the likelihood
3 of false positive test results that puts the permittee in compliance jeopardy for false failures,
4 creating a violation when the effluent is not truly “toxic.”

5 The legal validity of numeric chronic toxicity limits using any method (NOEC/IC25/TST)
6 is questionable. EPA recognizes that the precision of freshwater chronic toxicity tests is generally
7 in the range of 30-60% in terms of coefficient of variation. *See* 60 Fed. Reg. 53533-4 (Oct. 16,
8 1995). This variation is similar to a range of non-detect to 2.2 TUc for any particular clean (method
9 blank) sample, or using a non-technical analogy, is similar to a radar detector registering a stopped
10 car at any speed from 0-121 miles per hour.

11 In addition, these tests have been shown to have 5-40% false failures (a “fail” under the
12 TST when there is no actual toxicity), further placing their regulatory usefulness in question and
13 raising constitutional due process issues in the context of strict liability for permit violations. *See*
14 Risk Sciences White Paper (2014) submitted to the Regional Board on May 6, 2014.¹⁶ Even EPA
15 has determined that “the accuracy of toxicity tests cannot be determined.” *See Short Term Methods*
16 *for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*;
17 EPA/600/4-91/002 at 139, 193, and 225 (July 1994). Even if there is only a 5% false failure level
18 (as is set for the TST), this guarantees at least one numeric effluent limit “violation” in the five
19 year permit term, even though there is no actual toxicity for those incidents. This would be an
20 enforceable violation, not subject to MMPs per Water Code section 13385(i)(1)(D) if there are
21 other toxic pollutant limits in the permit, but subject to discretionary and citizen suit enforcement.
22 No reason exists to put permittees in such compliance jeopardy unnecessarily.

23 Reanalysis of actual WET test data, from a wide variety of real-world samples,
24 demonstrates that the TST technique consistently “detects” the existence of toxicity more
25

26 ¹⁶ Although the Regional Board asked for additional information, the Regional Board excluded some of the submitted
27 information from the official record even though it directly related to previous comments and addressed numeric limits
28 and compliance schedules discussed on the May 1, 2014 teleconference between the permittees and Regional Board
staff. *See* Regional Board, Notice of Determination (May 7, 2014). This action was also an abuse of discretion.

1 frequently than the NOEC method, especially for tests with relatively small effect levels. *See State*
2 *Board, Effluent, Stormwater and Ambient Toxicity Test Drive Analysis of the Test of Significant*
3 *Toxicity (TST)* (Dec., 2011) (*see e.g.*, Chronic Freshwater results in Table E-1).

4 One should not assume that greater statistical sensitivity equates with improved accuracy in
5 WET testing. Reanalysis of data from EPA's inter-laboratory WET variability study indicates that
6 the TST technique also "detects" toxicity in blank samples at a rate up to three times higher than
7 the NOEC. (U.S. EPA. *Final Report: Interlaboratory Variability Study of EPA Short-term Chronic*
8 *and Acute Whole Effluent Toxicity Test Methods*, Vol. 1; EPA-821-B-01-004 (Sept., 2001). Blank
9 samples are comprised solely of laboratory dilution water that is known to be non-toxic before the
10 test begins. Such inaccuracies demonstrate that the TST does not provide performance "acceptably
11 equivalent" to that of the standard methods that were promulgated in 2002. *See Regional Board*
12 *Response to Comments* at pg. 13.

13 Because of the unreliability and inaccuracy of these biological test methods, strictly
14 construed numeric ("pass/fail" or "% Effect") effluent limits for toxicity are inappropriate,
15 infeasible to comply with, and should not have been imposed.

16 In conclusion, for all the reasons cited in herein, the effluent limits for chronic toxicity in
17 Table 4 of the Permit should be changed back to the narrative effluent limitation contained in the
18 last permit with a numeric trigger for additional investigations (e.g., TIE/TRE). No authority exists
19 for mandating numeric chronic toxicity effluent limitations and particularly not limits of "Pass", or
20 "% effect <50" using a non-Part 136 method. As stated above, the Basin Plan Amendment
21 incorporating the Toxicity TMDL, Resolution No. R4-2005-009 at page 7, expressly stated that the
22 numeric toxicity targets "would be implemented as a trigger," so the limit in Table 4 of Provision
23 IV. and the Compliance Determination for Chronic Toxicity in Provision VII.J. should be adjusted
24 accordingly. Furthermore, as stated above, the inclusion of numeric chronic toxicity effluent
25 limitations violates the current binding precedent from State Board Order No. WQ 2003-0012.
26 Finally, since the TST is not an approved Part 136 methodology (or a valid ATP), this method
27 should not be utilized for compliance purposes unless promulgated as a formal rule by EPA.

28

1 **C. Other Problematic Effluent and Receiving Water Limitations**

2 **1. Unnecessary Effluent limit for MBAS.**

3 Effluent limits for Methylene Blue Activated Substances (“MBAS”), set as both
4 concentration and mass as average monthly limits, are included in Table 4 that is set equal to the
5 drinking water Maximum Contaminant Level (“MCL”) of 0.5 mg/L, even though there is no
6 municipal drinking water (“MUN”) use designated for the waters to which the City discharges.
7 Neither the effluent nor ambient data exceed the MCL, with a maximum observed effluent
8 concentration of <0.5. Section IV.C.2.b.ix. of the Tentative Order’s Fact Sheet (pg. F-27), stated
9 that this effluent limitation “was developed based on the Basin Plan incorporation of Title 22
10 Drinking Water Standards to protect the surface water MUN beneficial use.” However, as the City
11 pointed out in comments, MUN is not applicable to the surface receiving waters as is recognized in
12 footnote 1 of Table F-3 (pg. F-13) of the Permit. In the final Permit, the justification is modified to
13 now state that the limit is needed because “the discharge has reasonable potential to exceed both
14 the numeric MBAS WQO and the narrative WQO for the prohibition of floating material such as
15 foams and scums.” Permit at pgs. F-28 and F-29. The Regional Board failed to conduct a
16 reasonable potential analysis for MBAS (see Table F-6 at pgs. F-34 to F-37) so there is no evidence
17 to support the finding of reasonable potential. In addition, the Permit already contains a receiving
18 water limitation to prevent discharges of foam or scum that could affect local waterways. Permit at
19 pg. 10, para. 17. Thus, there is no evidence that this effluent limitation is necessary.

20 Furthermore, MBAS is discussed in Chapter 3 of the Basin Plan in the section covering
21 Regional Objectives for Inland Surface waters, which clearly states that this objective only applies
22 to [surface] waters designated MUN, not to waters designated as GWR. Title 22 MCLs are also
23 referenced under the Groundwater objectives. However, even though groundwater recharge is not
24 considered an acceptable justification to apply these objectives to the WQCP discharge, MBAS is
25 not even specifically listed in the Tables referenced from Title 22 in Chapter 3 of the Basin Plan in
26 the section under Groundwater – Chemical Constituents and Radioactivity (Basin Plan, pg. 3-18).
27 Furthermore, the GWR use is not a recognized or mandatory Clean Water Act use, so protection of
28 this use is not required by federal law and imposition of this effluent limit for state law purposes

1 requires additional analysis under Water Code sections 13263 and 13241 specific to this limit prior
2 to imposing any effluent limitation that is more stringent than required by federal law. *City of*
3 *Burbank v. SWRCB*, 35 Cal. 4th 613, 618, 628 (2005). Further, application of MCLs at end of pipe
4 ignores dilution in receiving waters and removal through soil aquifer treatment. No evidence has
5 been presented that there is a lack of assimilative capacity in local aquifers that would justify an
6 end-of-pipe effluent limit for MBAS equal to the MCL.

7 In addition, Section IV.C.2.b.ix. of the Fact Sheet goes on to say that “given the nature of
8 the Facility which accepts domestic wastewater into the sewer system and treatment plant, and the
9 characteristics of the pollutants discharges, the discharge has reasonable potential...” This is not
10 an adequate justification for requiring an effluent limit for MBAS (or any other pollutant without
11 reasonable potential). The fact that a pollutant may be present in domestic wastewater *influent* in
12 no way correlates with its potential for being *discharged in recycled water* at a level that impacts
13 the beneficial uses of the receiving water, or causes an in-stream exceedance of an applicable water
14 quality standard. This same reasoning would apply to any constituent that is regularly detected in
15 wastewater treatment plant influent and, unless the concentration of the constituent in effluent
16 exceeds water quality criteria, those constituents are not assigned effluent limits. 40 C.F.R.
17 §122.44(d)(1)(iii).

18 Therefore, for all these reasons, the City requests that the effluent limit for MBAS be
19 removed as unnecessary.

20 **2. Unnecessary Effluent limits for Chlorinated Pesticides and PCBs.**

21 Table 4 of the Permit contains average monthly and daily maximum concentration-based
22 effluent limits for chlordane, 4,4-DDD, 4,4-DDE, 4,4-DDT, dieldrin, PCBs and toxaphene. Permit
23 at pg. 7. These effluent limits are based on the WLAs set forth in the Calleguas Creek Watershed
24 Organochlorine Pesticides, PCB and Siltation TMDL (“OP TMDL”) established in 2005 by the
25 Regional Water Board. However, many of these constituents, including but not limited to
26 chlordane, dieldrin, DDT and DDD have been not detected in the effluent or the receiving water.
27 Permit at F-37. Therefore, there is no reasonable potential for these constituents to cause or
28 contribute to a water quality exceedance and the effluent limits should be removed from Table 4.

1 See accord *City of Woodland v. California Regional Water Quality Control Board, Central Valley*
2 *Region*, Alameda County Superior Court Case No. RG04-188200 (May 16, 2005) at pgs. 4, 13. To
3 address any concern associated with the TMDL, a detected value of one of these constituents at a
4 level near the applicable WLA could be a trigger for a source investigation, and detection at or
5 above the applicable WLA could trigger reasonable potential and the related reopener clause.
6 Permit at pg. 14.

7 The allegation that a reasonable potential analysis is not required when there is a TMDL is
8 not borne out by careful review of the federal regulations. The federal regulations require effluent
9 limitations as necessary to achieve water quality standards, including narrative water quality
10 criteria. 40 C.F.R. §122.44(d)(1). In order to determine whether an effluent limitation is
11 “necessary,” the permitting authority performs what is known as a “reasonable potential analysis”
12 or “RPA.” *Id.* at §122.44(d)(1)(i)-(vi). If an effluent limit is necessary, then “when developing
13 water quality-based effluent limits under this paragraph,” the permitting authority shall ensure that
14 those effluent limits “are consistent with the assumptions and requirements of any available
15 wasteload allocations for the discharge prepared by the State and approved by EPA pursuant to 40
16 CFR 130.7,” which relates to TMDLs. *Id.* at §122.44(d)(1)(vii); §130.7. If there is no reasonable
17 potential under subdivisions (i) through (vi), then there is no need for consistency with the TMDL
18 and WLAs under the later subdivision (vii). One subdivision cannot be read to the exclusion of the
19 other preceding parts.

20 The State Implementation Policy (“SIP”) does not change this analysis. Under the SIP, the
21 permit writer must “conduct the analysis in this section for each priority pollutant with an
22 applicable criterion or objective, *excluding priority pollutants for which a Total Maximum Daily*
23 *Load (TMDL) has been developed*, to determine if a water quality-based effluent limitation is
24 required in the discharger’s permit.” SIP at Section 1.3, pgs. 5-6 (emphasis added). So for
25 priority pollutants without a TMDL, the permit writer uses the SIP RPA procedure. If there is a
26 TMDL, then the SIP analysis in Section 1.3 is not required, but the RPA is still mandated under the
27 federal regulations and the rule that there is no limit required if there is no reasonable potential still
28 applies.

1 **3. Unnecessary Radioactivity Limit**

2 An effluent limitation for general radioactivity is not warranted as there is no demonstrated
3 reasonable potential and this limit unnecessarily duplicates the discharge prohibition for
4 radiological waste in III.G. The response to comments states that there is reasonable potential
5 because radioactivity was detected in the effluent. Regional Board Response to Comments at pg.
6 33. However, no evidence related to detections is included in the Fact Sheet, and even if it were,
7 the detection of a substance is not enough to provide reasonable potential. The detection must be at
8 a level with a reasonable potential to cause or contribute to an in-stream exceedance of the
9 applicable water quality standard. No evidence was provided that a proper reasonable potential
10 analysis was done for radioactivity, or that radioactivity is an issue in receiving waters. Therefore,
11 this effluent limit must be removed.

12 **4. Unnecessary Mass Limits**

13 For conventional pollutants, no need exists for both mass limits and 85% removal
14 requirements as both are not required by either federal or state law. Under federal law, mass limits
15 are specifically not required for Technology-Based Limits, such as BOD and TSS. The federal
16 regulations only require concentration-based effluent limits and 85% removal requirements. (See
17 40 C.F.R. §133.102(a)(1)-(3) and (b)(1)-(3); see e.g., Order No. R2-2012-0051, Table 6 (monthly
18 and weekly conventional pollutant limits only with no mass limits required).) The only way that
19 mass limits for BOD and TSS are authorized by the federal regulations is where substituting the
20 percent removal requirements with a mass loading limit for less concentrated influent wastewater
21 for separate sewers. (40 C.F.R. §133.103(d).) Since the Regional Board did not substitute mass
22 limits for the percent removal requirements that are contained in Provision IV.A.3.a., the mass
23 limits in Table 4 are not justified under federal law.

24 Finally, the Fact Sheet at page F-40 states that “40 CFR §122.45 (f)(1) requires that except
25 under certain conditions, all permit limits, standards, or prohibitions be expressed in terms of mass
26 units. 40 CFR § 122.45(f)(2) allows the permit writer, at its discretion, to express limits in
27 additional units (e.g., concentration units).” This statement ignores that 40 C.F.R. section
28 122.45(f)(1) does not require and exempts mass-based effluent limitations for: i) pH, temperature,

1 radiation, or other pollutants which cannot be appropriately expressed by mass, and ii) “when
2 applicable standards and limitations are expressed in terms of other units of measurement.”
3 (Emphasis added.) Further, Table 4 includes all limits expressed initially in concentration;
4 therefore, additional mass limits are not needed or required (except in the case of TMDL-based
5 mass limits, and then concentration-based limits are not required). Because the technology-based
6 limits and most water quality-based limits and criteria are expressed in concentration (i.e., “other
7 units of measure” besides mass), the exception to the requirement for mass limits has been met and
8 mass limits are not required under federal law. (*See accord* Order No. R1-2013-001 at F-26
9 (“Because secondary treatment standards for BOD₅ and TSS are expressed in terms of
10 concentration and percent removal, mass-based effluent limitations for these parameters are not
11 required. Mass-based effluent limitations for BOD₅ and TSS were included in the previous Order,
12 but have been removed from this Order...”).¹⁷) Furthermore, where flow is limited either expressly
13 in the permit or by design constraints, mass will be limited in accordance with the concentration
14 cap and the flow limit. The Regional Boards must consistently interpret the regulatory
15 requirements or equal protection problems arise when similarly situated permittees are treated
16 differently under the same statutory and regulatory scheme. The Region 1 approach should be
17 preferred over the Region 4 approach.

18 All mass limits should be removed since not required by federal law. If being imposed
19 under state law, or the discretionary ability to include mass limits in addition to concentration
20 based limit under section 122.45(f)(2), then these requirements are more stringent than required by
21 federal law and have not been adequately justified and nor have all of the considerations under
22

23 ¹⁷ See Order No. R1-2013-001 at F-53 and F-54 (“The previous Order contained mass-based effluent limitations for
24 BOD₅ and TSS that applied when the Permittee was discharging treated effluent to any of its authorized surface water
25 discharge points. The draft Order removes mass limitations for discharges of treated wastewater because Regional
26 Water Board staff misinterpreted the exception in 40 CFR 122.45(f)(2), which states that mass limitations are not
27 required for (1) pH, temperature, radiation, or other pollutants which cannot be appropriately expressed by mass, and
28 (2) when applicable standards and limitations are expressed in terms of other units of measure.” Staff should have
granted exception No. 2, because secondary treatment standards for BOD₅ and TSS in 40 CFR 133.102, on which the
effluent limitations in previous permits were based, are expressed in concentration and percent removal (i.e., “other
units of measure”). The relaxation of effluent limitations for BOD₅ and TSS in this Order is permissible under CWA
section 402(o)(2)(B), because Regional Water Board staff has determined that mass limitations for BOD₅ and TSS
were applied in the previous permit as a result of a mistaken interpretation of law when issuing the previous permit.”)
(emphasis added).

1 Water Code section 13263 and 13241 been satisfied for these particular limits. (*See City of*
2 *Burbank v. State Water Resources Control Board*, 35 Cal. 4th 613, 629 (2005).)

3 No evidence has been cited that mass-based limits are necessary ensure to ensure proper
4 treatment of a tertiary treatment plant, or that the City has potable or other water available to dilute
5 its effluent in order to comply with the final effluent concentration limits as suggested on page F-
6 40, particularly in a drought. In fact, the City meets concentration-based limits much more
7 stringent than those proposed under federal secondary treatment requirements. 40 C.F.R. Part 133.
8 Without evidence to support the findings of necessity for these limits that are more stringent than
9 required by federal law (including the mass limits for BOD and TSS), the mass limits must be
10 removed.

11 If retained, then the mass limits (even those from TMDLs) need to be calculated based on
12 design flow to allow for growth. 40 C.F.R. §122.45(b); 44 Fed. Reg. 32864 (June 7, 1979)(when
13 previously numbered 122.16). Not all of the current mass limits have a reference to footnote 1 to
14 Table 4, but need to in order to be consistent with EPA regulations. *See also* City of Moscow,
15 Idaho, NPDES Appeal No. 00-10, 2001 WL 988721 (July 27, 2001) *citing* 40 C.F.R. 122.45(b) and
16 122.44(d)(1)(vii) (approving the use of design flow rather than the number referenced in the
17 TMDL because although the regulations require consistency with the WLAs in a TMDL, “they do
18 not require that the permit limitations that will be finally adopted in a final NPDES permit be
19 identical to any of the WLAs that may be provided in a TMDL.”).

20 **5. Unnecessary Daily Limits**

21 There is inadequate justification for daily limits for BOD, TSS, oil & grease or settleable
22 solids. These limits are inconsistent with federal law (40 C.F.R. §122.44(d)(if no reasonable
23 potential), 122.45(d)(2)(no daily limits generally for POTWs) and Part 133) and cannot be justified
24 by the aquatic life protection portions of the SIP. Thus, these limits need to be removed. (*See*
25 *accord* Order No. R1-2013-0001 at 8 (no daily limits for conventionals).) The Fact Sheet at F-25
26 states “daily maximum limits cannot be removed because none of the anti-backsliding exceptions
27 apply.” This is incorrect because several provisions would justify removal of these daily limits,
28

1 including but not limited to CWA, 33 U.S.C. §1342(o)(1)(compliance with 1314(d)(4)(B)), or
 2 (o)(2)(A)(substantial alterations to plant since last permit), or (o)(2)(B)(ii)(mistake of law).

3 **6. Unnecessary Receiving Water Limits for Temperature**

4 Provision V.A.1.'s prohibition on effluent from altering water temperature by more than 5
 5 degrees may be an unachievable. Permit at pg. 9. When upstream flow conditions are extremely
 6 low, the City's temperature can alter stream by more than 5 degrees. A statement should be added
 7 either in this section or under compliance determination that "When upstream flow is <6 cfs, the
 8 upstream temperature is not representative of natural conditions."

9 **7. Inappropriate Pest Breeding Limitation**

10 One of the Receiving Water Limitations states that the "discharge shall not result in
 11 problems due to breeding of mosquitoes, gnats, black flies, midges, or other pests." Permit at pg.
 12 10, Provision V.A.16. This Receiving Water Limitation for insect control is inappropriate and not
 13 applicable to this highly treated recycled water discharge, and must be removed.

14 **8. Unnecessary Receiving Water Limits where Effluent Limits Prescribed**

15 Both an effluent limitation and a receiving water limitation for temperature, pH, total
 16 residual chlorine, and turbidity are not required. *See* Permit at IV.A.1.a -Table 4, IV.A.3.b. and
 17 A.4.e.; V.A.1., 2., and 6. If the discharge has a reasonable potential for any constituents for which
 18 receiving water limitations are proposed, then the appropriate regulation is an effluent limit. If
 19 there was no reasonable potential, then no regulation of these substances is required. Similarly,
 20 where an effluent limit is being proposed, as in the case of temperature, pH and turbidity, a
 21 duplicative receiving water limitation is unnecessary because the effluent is being adequately
 22 controlled to not cause or contribute to an in-stream exceedance. A similar comment would apply
 23 to the receiving water limitations for toxicity, ammonia, and chlorine. Each of these duplicative
 24 receiving water limitations should be removed to not impose "double jeopardy" for the same
 25 discharge violating both types of limitations.

26 **9. Inappropriate Groundwater Limitations**

27 The Groundwater Limitations at Provision V.B. should be deemed "Not Applicable" since
 28 there are no direct discharges to groundwater and all potential incidental discharges are adequately

1 protected by the effluent and receiving water limitations. Groundwater requirements are strictly
2 State law requirements only and do not belong in a federal NPDES permit that does not directly
3 regulate groundwater.

4 **D. Unnecessary and Burdensome Monitoring and Reporting Requirements**

5 **1. Sediment Monitoring for Mercury**

6 The requirement for sediment monitoring in Section E.IV.A.4. (pg. E-13) should be deleted.
7 Sediment monitoring is not required by the Calleguas Creek Watershed Metals TMDL (“Metals
8 TMDL”) and it is not possible to monitor sediment through effluent samples. TSS and water
9 column total mercury samples are sufficient to address the TMDL requirements. It is overly
10 conservative to assume that the total water load is equal to the suspended sediment load and to
11 assume that suspended sediment is not the same makeup as bottoms sediments. In its response to
12 comments (pg.13, Comment C.5.), the Regional Board stated that this requirement is needed to
13 address the Sediment Toxicity component of the Toxicity TMDL, and comparing it to a different
14 permit and different TMDL for the Dominguez Channel and Los Angeles and Long Beach
15 Harbors. *Id.* at pg. 14. However, the City does not discharge to a reach that is impaired with
16 respect to Sediment Toxicity. Sediment Toxicity is being addressed in the two Reaches that are
17 impaired (i.e., Mugu Lagoon, and lower reach of Calleguas Creek) through sediment monitoring
18 being conducted there as part of the TMDL Watershed Monitoring Program. This monitoring is
19 adequate to ensure that any concerns regarding toxicity are being addressed. Finally, the Regional
20 Board has failed to justify the need to include sediment monitoring pursuant to Water Code section
21 13267(b) and 13225(c). Measuring TSS and total mercury in water is all that is needed to meet the
22 Metals TMDL requirements.

23 **2. Excessive Monitoring Requirements**

24 The Calleguas Creek Watershed stakeholder group has been implementing a coordinated
25 monitoring program for TMDL implementation for over 5 years with no permit requirements
26 mandating this participation. However, Section I.N. and IX.C of the Monitoring and Reporting
27 Program now ignores the voluntary efforts of the City and mandates the implementation and
28 compliance with the Watershed-Wide Monitoring Program, and the submittal of annual progress

1 reports regarding the implementation of a watershed monitoring program. The watershed TMDL
2 monitoring program is already established and there is no need to submit progress reports detailing
3 efforts to implement the monitoring program.

4 Additionally, consistent with State Board Resolution 2013-0029 regarding "Reducing Costs
5 of Compliance while Maintaining Water Quality Protection," Regional Board staff have been
6 directed to work with Permittees to identify duplicative or unnecessary monitoring during
7 reissuance of NPDES permits. Thus, the City requests the following changes to the monitoring
8 frequencies to reduce unnecessary monitoring:

- 9 • Monitoring under the approved Calleguas Creek Watershed TMDL monitoring program has
10 established quarterly as the necessary monitoring frequency for determining compliance
11 with the TMDL requirements. The monitoring frequencies for effluent and receiving water
12 in Table E-3 for all nitrogen and phosphorus compounds, copper, mercury, and nickel,
13 should be reduced from monthly to quarterly consistent with the approved TMDL
14 monitoring program.
- 15 • Because chlorinated pesticides and PCBs (as arochlors) have not been measured at
16 concentrations above detection limits, the monitoring frequencies listed in Tables E-3
17 (Effluent Monitoring) for all these constituents should be changed from quarterly to semi-
18 annually. Based on historic data, more frequent monitoring is unnecessary.
- 19 • Inadequate justification has been provided for additional PCB monitoring using an
20 unapproved method. Permit MRP, IV.A.3., Table E-3 at pg. E-9. This appears to be
21 monitoring "strictly for monitoring purposes" with no other purpose. In accordance with
22 State Water Board direction in its Resource Alignment/Cost of Compliance Initiative to
23 minimize excessive monitoring on municipalities, this should be removed from the Permit.

24 3. Constituents of Emerging Concern ("CEC") study

25 Provision VI.C.2.b. of the Permit requires the City to "conduct a special study to investigate
26 the CECs in the effluent discharge." Permit at pg. 16. The paragraph then goes on to describe that
27 the requirements of the work plan are discussed in the Monitoring and Reporting Program and Fact
28 Sheet. The Special Study for CECs has not been adequately justified and should be removed. No

1 “approved” analytical methods exist for the testing of these constituents, so the results from these
2 unapproved methods are merely estimations that provide no valid data or relevant information.

3 **4. Recycling Study “Required” in the Fact Sheet**

4 The Tentative Order at Provision VI.C.2.d contained provisions requiring a Recycling
5 Study. That provision was removed from the final Permit. However, the Fact Sheet at Section
6 III.C.11. still seems to require such a study (“the Permittee shall investigate... The Permittee shall
7 submit...”). *See also* Permit at pg. F-57, Section VIII.G. (“To encourage recycling, the Permittee
8 is required by this Order to continue to explore the feasibility of recycling to maximize the
9 beneficial reuse of tertiary treated effluent.”)(emphasis added).

10 A Fact Sheet is not supposed to contain binding provisions, and is merely included to
11 provide background and rationale for the Permit’s provisions. *See* Permit at pg. 4, Findings II.B
12 (incorporated into the Permit and “constitutes Findings for this Order.”) Therefore, these
13 seemingly mandatory provisions should be removed from the Fact Sheet or modified to not include
14 substantive requirements as Findings. If the State Board believes that these Findings should be
15 interpreted as binding provisions, then the City seeks a stay of the mandatory language, which
16 requires the City to submit an update to its feasibility study, which was submitted to the Regional
17 Board on January 30, 2014 without a permit requirement to do so, along with its Report of Waste
18 Discharge.

19 Requiring an update to a just completed Recycling Feasibility Study has not been
20 adequately justified and is unnecessary. The City is already recycling and has plans for additional
21 recycling. This activity has nothing to do with an NPDES permit discharge, except to lessen the
22 amount and perhaps eliminate the discharge. While the City is perfectly happy informally letting
23 the Regional Board know about potential new recycling opportunities, the requirement to conduct a
24 formal update to its feasibility study is unreasonable and has not been adequately justified under
25 Water Code section 13267(b) or 13225(c). Excessive reporting requirements are also contrary to
26 the intent of the State Board’s Resource Alignment/Cost of Compliance Initiative to minimize
27 excessive costs for municipalities like the City.

28

1 **E. Miscellaneous Issues**

2 **1. Sanitary Sewer Overflow Provisions**

3 Sewage spills are regulated by the State Water Board's Sanitary Sewer Overflow ("SSO")
4 Waste Discharge Requirements ("WDRs"), which discourages Regional Boards from issuing
5 different requirements in NPDES permits. Paragraph 9 of the SSO WDR states (with emphasis
6 added): "Both uniform SSO reporting and a centralized statewide electronic database are needed to
7 collect information to allow the State Water Board and Regional Water Quality Control Boards
8 (Regional Water Boards) to effectively analyze the extent of SSOs statewide and their potential
9 impacts on **beneficial uses** and **public health.**" Paragraph 11 also states that "it is the State Water
10 Board's intent that this Order be the primary regulatory mechanism for sanitary sewer systems
11 statewide." Regional Water Boards would need to include findings of necessity for more stringent
12 or differing requirements than the SSO WDR, supported by substantial evidence. The Los Angeles
13 Regional Board failed to demonstrate why its region needs more stringent requirements besides
14 stating that there historically has been a "loss of recreational use in coastal beaches and in Arroyo
15 Conejo as a result of major sewer spills." Regional Board Response to Comments at pgs. 40-41,
16 Permit at pg. F-52. This justification is no different than anywhere else in the State where large
17 spills have occurred. Therefore, the requirements from other regions should be used in lieu of the
18 proposed section 6. f., as follows:

19 "The Permittee has coverage under, and is separately subject to, the requirements of State
20 Water Board Order No. 2006-003-DWQ, Statewide General WDRs for Sanitary Sewer
21 Systems. As such, the Permittee provides notification and reporting of SSOs in accordance
22 with the requirements of Order No. 2006-003-DWQ and WQ 2008-0002-EXEC and any
23 revisions thereto for the operation of its wastewater collection system."

24 *See accord* Order No. R2-2013-0042 at 27, section VI.A.5.a.i.; R5-2012-0115 at 29, section
25 VI.C.5.d.

26 The remaining requirements in Section VI.C.6. of the Permit related to sewer spills could
27 remain, but should only do so if amended to relate solely to non-sewage spills. Specifically, the
28 last sentence in section 6.a. should state: "For certain spills, overflows and bypasses, not including

1 sewage spills, the Permittee shall make notifications as required below.” Then all other references
2 to sewage in this section should be removed, as follows:

3 a.i. “unauthorized release of ~~sewage or other waste~~ other than sewage”
4 a.ii. – This section is unnecessary and should be removed as it is implemented through the
5 SSO WDR.

6 a.iii. “The Permittee shall notify the Regional Water Board of any unauthorized release or
7 spill at of sewage from its POTW...”

8 a.iii.(3) “An estimate of the amount of non-sewage or other waste released...”

9 c.i. “As soon as possible, but not later than twenty-four hours after becoming aware of an
10 unauthorized discharge of non-sewage or other waste...”

11 c.ii. “Submission to the Regional Water Board of the California Integrated Water Quality
12 System (CIWQS) ~~Sanitary Sewer Overflow (SSO)~~ event number shall satisfy this requirement.
13 Within 30 days after submitting the preliminary report, the Permittee shall submit the final written
14 report to this Regional Water Board. ~~(A copy of the final written report, for a given incident,~~
15 ~~already submitted pursuant to a statewide General WDRs for Wastewater Collection System~~
16 ~~Ageneies (SSO WDR), may be submitted to the Regional Water Board to satisfy this~~
17 ~~requirement.)...~~”

18 d. “The Permittee shall develop and maintain a record of all spills, overflows or bypasses
19 of raw or partially treated non-sewage waste from its collection system or at its treatment plant or
20 from its operations.”

21 Remove section 6.d.viii as unrelated to non-sewage spills.

22 Allowing different regions to impose different requirements for similar types of discharges
23 is not only inconsistent, but may raise constitutional equal protection issues. The only
24 requirements under federal law are those contained in Appendix D (Standard Provisions) related to
25 proper operation and maintenance, reporting, and mitigation. 40 C.F.R. §122.41(e), (l), and (d).
26 The Regional Board’s response that it “has discretionary authority in enforcement actions” is no
27 comfort to the City when non-NPDES requirements suddenly become federally enforceable by
28 third parties. Because sewer spills that don’t reach waters of the United States are adequately

1 covered by the SSO WDR and those that do are enforceable as unpermitted discharges, these
2 additional requirements should be removed from the Permit.

3 **2. Permit Effective Date**

4 In accordance with the Memorandum Of Agreement between the U.S. EPA and State Water
5 Board, this permit's effective date should be 50 days after the adoption date. (*See* Permit at pg. 1,
6 Table 3; *see also* NPDES Memorandum of Agreement between the U.S. Environmental Protection
7 Agency and the State Board at 22, section I.F.2.a. (Sept. 22, 1989)(NPDES permits adopted by the
8 Regional Water Board "shall become effective on the 50th day after the date of adoption, if EPA
9 has made no objection to the permit; if there has been significant public comment".) To be
10 consistent with the SWRCB's 1989 MOU with EPA on NPDES permitting, the Permit should have
11 had an effective 50 days from the adoption date. The Regional Board in the response to comments
12 claimed that, in relation to USEPA's draft Program Quality Review (2014), "Regional Board staff
13 and USEPA agreed to address the issue by making the effective date fall on the first of the month
14 following the 50 day period post NPDES permit adoption." Regional Board Response to
15 Comments at pgs. 28-29 (April 30, 2014). The response further states that "USEPA issued a new
16 guideline on 'effective date' of permits. The guideline states that staff shall make all permit
17 effective date and permit date the first day of the month, no less than 30 days following Board
18 adoption....This practice has been agreed upon by USEPA and State Water Board and helps
19 prevent permits issued for five years plus one day." *Id.* at 29. Although the City requested a copy
20 of this new guideline and State Board agreement, none was provided. Thus, it appears that the
21 Regional Board once again is relying upon guidance to overrule a signed Memorandum of
22 Agreement that would need to be modified in writing. If such modifications exist, they need to be
23 provided to permittees so that everyone is aware of the currently binding requirements.
24 Alternatively, if such modifications are still being negotiated, the City would suggest that the
25 effective date be 60-90 days after adoption to allow adequate time to petition the permit and
26 receive a stay prior to the permit becoming effective.

1 **3. 100 Year Flood Protection**

2 There is no authority listed for this 100 year storm protection requirement under state or
3 federal law. Permit at Provision VI.A.2.c. Without such authority, the inclusion of this
4 unjustified "Standard Provisions" constitutes an abuse of discretion. The Regional Board's
5 response to comments states that this provision "is commonly used as a requirement for this
6 standard provision." Regional Board Response to Comments at pg. 36. However, the fact that it
7 has been used before does not provide adequate authority for use of this provision in the first place.
8 Without adequate authority and justification, this provision must be removed.

9 **8. A STATEMENT THAT THE PETITION HAS BEEN SENT TO THE
10 APPROPRIATE REGIONAL BOARD (AND TO THE DISCHARGER IF NOT THE
11 PETITIONER):**

12 A true and correct copy of this Petition was mailed by First Class mail on June 4, 2014 to
13 the Regional Board at the following address:

14 Mr. Sam Unger, Executive Officer
15 Los Angeles Regional Water Quality Control Board
16 320 West Fourth Street, Suite 200
17 Los Angeles, CA 90013

18 The Petitioner is the discharger, so no need exists to send a copy to the Discharger.

19 **9. A STATEMENT THAT THE SUBSTANTIVE ISSUES OR OBJECTIONS RAISED
20 IN THE PETITION WERE RAISED BEFORE THE REGIONAL BOARD, OR AN
21 EXPLANATION WHY NOT.**

22 The substantive and legal issues raised in this petition were presented to the Regional Board
23 before the Regional Board acted to adopt the Permit and TSO. The City submitted extensive
24 comments to the Regional Board on April 14, 2014, and supplemental comments as requested by
25 the Regional Board staff on April 29 and May 7, 2014. City representatives also appeared and
26 provided testimony at the adoption hearing on May 8, 2014.

27 **10. REQUEST FOR STAY.**

28 Because of the very real possibility of harm from the imposition of certain effluent
limitations in the Permit and provisions in the TSO, the City has contemporaneously filed a
Petition for Stay and requests that several provisions be stayed before the effective date of the

DOWNEY BRAND LLP

1 Permit on July 1, 2014. The City requests the State Board, either on its own motion or in
2 accordance with 23 C.C.R. §2053(a), issue a stay of the following contested provisions of the
3 Permit and TSO:

4 PERMIT, ORDER R4-2014-0066:

5 1. The final wet weather and dry weather effluent limitations for Total
6 Dissolved Solids ("TDS"), Sulfate, Chloride and Boron. (Permit Provision IV.A.1.a., Table
7 4 at pg.6.) The Permit prescribes both concentration and mass limits for these constituents
8 as Average Monthly Effluent Limits ("AMEL").

9 2. The final effluent limitations for Chronic Toxicity and the requirement to
10 use the Test of Significant Toxicity to implement those limits. (Permit Provision IV.A.1.a.,
11 Table 4 at pg. 7 and footnotes 6-7) The Permit prescribes a Monthly Median Effluent
12 Limitation ("MMEL") of "Pass" and a Maximum Daily Effluent Limitation ("MDEL") of
13 "Pass or %Effect < 50."

14 TSO, ORDER R4-2014-0067:

15 3. Provision in Paragraph 4 on page 7 of the TSO, which requires: "Submit a
16 Pollution Prevention Plan (PPP) work plan with the time schedule for implementation for
17 approval of the executive Officer no later than August 8, 2014 pursuant to CWC sections
18 13263.3."

19 4. Provision in Paragraph 5 on page 7 of the TSO to submit quarterly progress
20 reports, the first due October 15, 2014, of efforts taken by the Permittee to comply with the
21 final effluent limitation for chloride, and the requirements for the content of those reports.

22
23 Respectfully submitted,

24 DATED: June 4, 2014

DOWNEY BRAND LLP


25
26 By: 
27 Melissa A. Thorme
28 Attorneys for the City of Simi Valley

EXHIBIT A

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

320 West 4th Street, Suite 200, Los Angeles, California 90013
(213) 576-6600 • Fax (213) 576-6640
<http://www.waterboards.ca.gov/losangeles/>

**ORDER R4-2014-0066
NPDES NO. CA0055221**

**WASTE DISCHARGE REQUIREMENTS
FOR THE CITY OF SIMI VALLEY
SIMI VALLEY WATER QUALITY CONTROL PLANT
DISCHARGE TO THE ARROYO SIMI**

The following entity is subject to waste discharge requirements (WDRs) set forth in this Order:

Table 1. Discharger Information

Discharger	City of Simi Valley (The City or Permittee)
Name of Facility	Simi Valley Water Quality Control Plant (Simi Valley WQCP or Facility) and its associated wastewater collection system and outfalls
Facility Address	600 West Los Angeles Avenue
	Simi Valley, CA 93065
	Ventura County

Table 2. Discharge Location

Discharge Point	Effluent Description	Discharge Point Latitude (North)	Discharge Point Longitude (West)	Receiving Water
001	Tertiary treated wastewater	34.28222°	-118.81222°	Arroyo Simi 001
002	Tertiary treated wastewater	34.28222°	-118.81278°	Arroyo Simi 002

Table 3. Administrative Information

This Order was adopted on:	May 8, 2014
This Order shall become effective on:	July 1, 2014
This Order shall expire on:	June 30, 2019
The Permittee shall file a Report of Waste Discharge as an application for renewal of waste discharge requirements in accordance with Title 23, Division 3, Chapter 9 of the California Code of Regulations, and an application for reissuance of a National Pollutant Discharge Elimination System permit in accordance with Title 40, part 122.21(d) of the Code of Federal regulations no later than:	180 days prior to the Order expiration date
The United States Environmental Protection Agency and the California Regional Water Quality Control Board, Los Angeles Region have classified this discharge as follows:	Major

I, Samuel Unger, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on the date indicated above.

Samuel Unger

Samuel Unger, P.E., Executive Officer

Contents

I.	Facility Information	4
II.	Findings	4
III.	Discharge Prohibitions	4
IV.	Effluent Limitations and Discharge Specifications	5
	A. Effluent Limitations – Discharge Points 001 and 002	5
	1. Final Effluent Limitations – Discharge Points 001 and 002	5
	2. Interim Effluent Limitations	8
	B. Land Discharge Specifications – Not Applicable	9
	C. Recycling Specifications – Not Applicable	9
V.	Receiving Water Limitations	9
	A. Surface Water Limitations	9
	B. Groundwater Limitations	11
VI.	Provisions	11
	A. Standard Provisions	11
	B. Monitoring and Reporting Program (MRP) Requirements	14
	C. Special Provisions	14
	1. Reopener Provisions	14
	2. Special Studies, Technical Reports and Additional Monitoring Requirements	15
	3. Best Management Practices and Pollution Prevention	16
	4. Construction, Operation and Maintenance Specifications	18
	5. Special Provisions for Municipal Facilities (POTWs Only)	18
	6. Spill Reporting Requirements	20
	7. Compliance Schedules – Not Applicable	23
VII.	Compliance Determination	23

Tables

Table 1.	Discharger Information	1
Table 2.	Discharge Location	1
Table 3.	Administrative Information	1
Table 4.	Effluent Limitations	5

Attachments

Attachment A – Definitions	A-1
Attachment B – Map	B-1
Attachment C – Flow Schematic	C-1
Attachment D – Standard Provisions	D-1
Attachment E – Monitoring and Reporting Program	E-1
Attachment F – Fact Sheet	F-1
Attachment G – Toxicity Reduction Evaluation (TRE) Work Plan	G-1
Attachment H – Biosolids and Sludge Management	H-1
Attachment I – Pretreatment Reporting Requirements	I-1

I. FACILITY INFORMATION

Information describing the Simi Valley Water Quality Control Plant (Simi Valley WQCP or Facility) is summarized in Table 1 and in sections I and II of the Fact Sheet (Attachment F). Section I of the Fact Sheet also includes information regarding the Facility's permit application.

II. FINDINGS

The California Regional Water Quality Control Board, Los Angeles Region (Regional Water Board), finds:

- A. Legal Authorities.** This Order serves as WDRs pursuant to article 4, chapter 4, division 7 of the California Water Code (CWC; commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the United States Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the CWC (commencing with section 13370). It shall serve as an National Pollutant Discharge Elimination System (NPDES) permit for point source discharges from this facility to surface waters.
- B. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for the requirements in this Order, is hereby incorporated into and constitutes Findings for this Order. Attachments A through E and G through I are also incorporated into this Order.
- C. Notification of Interested Parties.** The Regional Water Board has notified the Permittee and interested agencies and persons of its intent to prescribe WDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of the notification are provided in the Fact Sheet.
- D. Provisions and Requirements Implementing State Law.** Some of the provisions/requirements in this Order and the MRP are included to implement state law only. These provisions/requirements are not mandated or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies available for NPDES violations.
- E. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet.

THEREFORE, IT IS HEREBY ORDERED that this Order supersedes Order R4-2003-0081 except for enforcement purposes, and, in order to meet the provisions contained in Division 7 of the CWC (commencing with section 13000) and regulations adopted thereunder, and the provisions of the CWA and regulations and guidelines adopted thereunder, the Permittee is authorized to discharge from the identified facility and outfalls into waters of the United States and shall comply with the requirements in this Order. This action in no way prevents the Regional Water Board from taking enforcement action for past violations of the previous Order.

III. DISCHARGE PROHIBITIONS

- A.** Discharge of treated wastewater at a location different from that described in this Order is prohibited.

- B. The bypass or overflow of untreated wastewater or wastes to surface waters or surface water drainage courses is prohibited, except as allowed in Standard Provision I.G. of Attachment D, Standard Provisions.
- C. The monthly average effluent dry weather discharge flow rate from the facility shall not exceed the design capacity.
- D. The Permittee shall not cause degradation of any water supply, except as consistent with State Water Board Resolution No. 68-16.
- E. The treatment or disposal of wastes from the facility shall not cause pollution or nuisance as defined in section 13050, subdivisions (l) and (m), of the California Water Code.
- F. The discharge of any substances in concentrations toxic to animal or plant is prohibited.
- G. The discharge of any radiological, chemical, or biological warfare agent or high level radiological waste is prohibited.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Points 001 and 002

1. Final Effluent Limitations – Discharge Points 001 and 002

- a. The Permittee shall maintain compliance with the following effluent limitations at Discharge Points 001 and 002, with compliance measured at Monitoring Location EFF-001 as described in the Monitoring and Reporting Program (MRP), Attachment E:

Table 4. Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand (BOD ₅ 20°C)	mg/L	20	30	45		
	lbs/day ¹	2,080	3,130	4,690		
Total Suspended Solids (TSS)	mg/L	15	40	45		
	lbs/day ¹	1,560	4,170	4,690		
pH	standard units	--	--	--	6.5	8.5
Removal Efficiency for BOD and TSS	%	85	--	--		
Oil and Grease	mg/L	10	--	15		
	lbs/day ¹	1,040	--	1,560		
Settleable Solids	ml/L	0.1	--	0.3		
Total Residual Chlorine	mg/L	--	--	0.1		
	mg/L	850	--	--		

¹ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (mgd) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Total Dissolved Solids	lbs/day ¹	88,610	--	--		
Sulfate	mg/L	250	--	--		
	lbs/day ¹	26,060	--	--		
Chloride (dry-weather) ²	lbs/day ¹	15,640 ²	--	--		
Chloride (wet-weather) ³	mg/L	150	--	--		
Boron	mg/L	1.0	--	--		
	lbs/day ¹	104	--	--		
MBAS	mg/L	0.5	--	--		
	lbs/day ¹	50	--	--		
Ammonia Nitrogen	mg/L	2.4	--	3.3		
	lbs/day	--	--	2.9 x Q ⁴		
Nitrate + Nitrite (as N)	mg/L	9	--	--		
	lbs/day	--	--	--		
Nitrate (as N)	mg/L	9	--	--		
	lbs/day	--	--	--		
Nitrite (as N)	mg/L	0.9	--	--		
	lbs/day	--	--	--		
Copper	µg/L	30.5 ⁵	--	31 ⁵		
	lbs/day	--	--	--		
Nickel	µg/L	169 ⁵	--	960 ⁵		
	lbs/day	--	--	--		
Mercury	lbs/month	0.031	--	--		
Selenium	µg/L	4.4	--	7.4		
	lbs/day ¹	0.46	--	0.77		

² Consistent with the *Calleguas Creek Watershed Salts Total Maximum Daily Load (Salts TMDL)*, this final effluent limitation shall apply only during dry weather (see section VII.O. of this Order for definition and procedures for calculating effluent limitations).

³ Any day that does not qualify as dry-weather is wet-weather. See also section VII.O. of this Order for definition of wet-weather.

⁴ Q represents the POTW effluent flow at the time the water quality measurement is collected (not to exceed 12.5 mgd) and a conversion factor to lbs/day based on the units of measure for the flow.

⁵ This limitation is derived from the final waste load allocation, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006, and became effective on March 26, 2007.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Cyanide	µg/L	4.3	--	8.5		
	lbs/day ¹	0.45	--	0.89		
Chlorpyrifos	µg/L	0.014	--	0.025		
	lbs/day	--	--	--		
Diazinon	µg/L	0.1	--	0.1		
	lbs/day	--	--	--		
Chronic Toxicity ⁶	Pass or Fail, % Effect	Pass ⁷	--	Pass or % Effect <50		
Chlordane	µg/L	0.00059	--	0.0012		
	lbs/day	--	--	--		
4,4'-DDD	µg/L	0.00084	--	0.0017		
	lbs/day	--	--	--		
4,4'-DDE	µg/L	0.00059	--	0.0012		
	lbs/day	--	--	--		
4,4'-DDT	µg/L	0.00059	--	0.0012		
	lbs/day	--	--	--		
Dieldrin	µg/L	0.00014	--	0.00028		
	lbs/day	--	--	--		
PCBs ⁸	µg/L	0.00017	--	0.00034		
	lbs/day	--	--	--		
Toxaphene	µg/L	0.00016	--	0.00033		
	lbs/day	--	--	--		

- b. **Percent Removal:** The average monthly percent removal of BOD 5-day 20°C and TSS shall not be less than 85 percent.
- c. The temperature of wastes discharged shall not exceed 86°F except as a result of external ambient temperature.

⁶ Pass" or "Fail" for Median Monthly Effluent Limitation (MMEL). "Pass" or "Fail" and "% Effect" for Maximum Daily Effluent Limitation (MDEL). The MMEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail".

⁷ This is a Median Monthly Effluent Limitation.

⁸ Applies to sum of all congener or isomer or homolog or Aroclor analyses.

- d. The radioactivity of the wastes discharged shall not exceed the limits specified in Title 22, chapter 15, article 5, sections 64442 and 64443, of the California Code of Regulations (CCR), or subsequent revisions.
- e. The wastes discharged to water courses shall at all times be adequately disinfected. For the purpose of this requirement, the wastes shall be considered adequately disinfected if the median number of total coliform bacteria at some point in the treatment process does not exceed a 7-day median of 2.2 Most Probable Number (MPN) or Colony Forming Unit (CFU) per 100 milliliters, and the number of total coliform bacteria does not exceed 23 MPN or CFU per 100 milliliters in more than one sample within any 30-day period. No sample shall exceed 240 MPN or CFU of total coliform bacteria per 100 milliliters. The median value shall be determined from the bacteriological results of the last seven (7) days for which an analysis has been completed. Samples shall be collected at a time when wastewater flow and characteristics are most demanding on treatment facilities and disinfection processes.
- f. For the protection of the water contact recreation beneficial use, the wastes discharged to water courses shall have received adequate treatment, so that the turbidity of the treated wastewater does not exceed any of the following: (a) an average of 2 Nephelometric turbidity units (NTUs) within a 24-hour period; (b) 5 NTUs more than 5 percent of the time (72 minutes) within a 24-hour period; and (c) 10 NTU at any time.

2. Interim Effluent Limitations

- a. **Metals TMDL-based Interim limits:** Interim waste load allocations (WLAs) are included in the Metals TMDL for copper, nickel, and mercury applicable to Simi Valley WQCP effluent discharge. However, existing data indicate that the facility is consistently meeting the final effluent limitation for copper, nickel, and mercury. (For mercury, however, there is one data in over 10 years that exceeded the final effluent limitation). Therefore, the final effluent limitations for metals are included in this permit.
- b. **OC Pesticides, PCBs, and Siltation TMDL-based Interim limits:** Interim WLAs are included in the OC Pesticides, PCBs, and Siltation TMDL for chlordane, 4,4'-DDD, 4,4'-DDE, 4,4'-DDT, dieldrin, PCBs, and toxaphene applicable to Simi Valley WQCP effluent discharge. However, existing data indicate that the facility is consistently meeting the final effluent limitation for the aforementioned parameters. Therefore, the final effluent limitations for these pollutants are included in this permit.
- c. **Boron, Chloride, Sulfate, and TDS (Salts) TMDL-based Interim limits:** The interim effluent limitation for Salts is derived from the interim WLAs as set forth in the *Calleguas Creek Watershed Salts TMDL*, established by the Regional Water Board on October 4, 2007, and became effective on December 8, 2008. The TMDL interim effluent limitation is set equal to the 95th percentile of available discharge data. There is no interim effluent limitation for boron because the 95th percentile concentration is below the Basin Plan objective. TDS and sulfate data indicate that the facility is complying with the Basin Plan WQOs. The facility has never exceeded the TDS and sulfate WQOs since July 2005 (except for one sulfate exceedance in April 2011). Therefore, the final effluent limitations for TDS, sulfate, and boron are included in this permit.

A compliance schedule for chloride is not included in this Order because the permittee did not submit sufficient information to demonstrate satisfaction of the Compliance Schedule Policy (Resolution No. 2008-0025) and 40 C.F.R. § 122.47, which require among other elements, a showing that the proposed implementation actions will lead to compliance with the final effluent limitation for chloride.

B. Land Discharge Specifications – Not Applicable

C. Recycling Specifications – Not Applicable

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in Arroyo Simi:

1. For waters designated with a warm freshwater habitat (WARM) beneficial use, the temperature of the receiving water at any time or place and within any given 24-hour period shall not be altered by more than 5°F above the natural temperature and shall not be raised above 86°F due to the discharge of effluent at the receiving water station located downstream of the discharge. Natural conditions shall be determined on a case-by-case basis.

If the receiving water temperature, downstream of the discharge, exceeds 86°F as a result of the following:

- i. High temperature in the ambient air; or,
- ii. High temperature in the receiving water upstream of the discharge,

then the exceedance shall not be considered a violation.

2. The pH of inland surface waters shall not be depressed below 6.5 or raised above 8.5 as a result of wastes discharged. Ambient pH levels shall not be changed more than 0.5 units from natural conditions as a result of wastes discharged. Natural conditions shall be determined on a case-by-case basis.
3. The dissolved oxygen in the receiving water shall not be depressed below 5 mg/L as a result of the wastes discharged.
4. The total residual chlorine shall not exceed 0.1 mg/L in the receiving waters and shall not persist in the receiving water at any concentration that causes impairment of beneficial uses as a result of the wastes discharged.
5. The Escherichia coli (E. coli) concentration in the receiving water shall not exceed the following, as a result of wastes discharged:
 - a. Geometric Mean Limits
 - i. E. coli density shall not exceed 126/100 mL.
 - b. Single Sample Limits
 - i. E. coli density shall not exceed 235/100 mL.
6. Waters shall be free of changes in turbidity that cause nuisance or adversely affect beneficial uses. Increases in natural turbidity attributable to controllable water quality factors shall not exceed the following limits, as a result of wastes discharged:

- a. Where natural turbidity is between 0 and 50 NTU, increases shall not exceed 20%, and
- b. Where natural turbidity is greater than 50 NTU, increases shall not exceed 10%.
7. The wastes discharged shall not produce concentrations of substances in the receiving water that are toxic to or cause detrimental physiological responses in human, animal, or aquatic life.
8. The wastes discharged shall not cause concentrations of contaminants to occur at levels that are harmful to human health in waters which are existing or potential sources of drinking water.
9. The concentrations of toxic pollutants in the water column, sediments, or biota shall not adversely affect beneficial uses as a result of the wastes discharged.
10. The wastes discharged shall not contain substances that result in increases in BOD, which adversely affect the beneficial uses of the receiving waters.
11. Waters discharged shall not contain biostimulatory substances in concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses.
12. The dissolved sulfide concentration of waters in and near sediments shall not be significantly increased above that present under natural conditions as a result of waters discharged.
13. The wastes discharged shall not cause the receiving waters to contain any substance in concentrations that adversely affect any designated beneficial use.
14. The wastes discharged shall not degrade surface water communities and populations, including vertebrate, invertebrate, and plant species.
15. The wastes discharged shall not alter the natural taste, odor, or color of fish, shellfish, or other surface water resources used for human consumption.
16. The wastes discharged shall not result in problems due to breeding of mosquitoes, gnats, black flies, midges, or other pests.
17. The wastes discharged shall not result in visible floating particulates, foams, or oil and grease in the receiving waters.
18. The wastes discharged shall not cause objectionable aquatic growths or degrade indigenous biota.
19. The wastes discharged shall not alter the color of the receiving waters; create a visual contrast with the natural appearance of the water; or cause aesthetically undesirable discoloration of the receiving waters.
20. The wastes discharged shall not contain any individual pesticide or combination of pesticides in concentrations that adversely affect beneficial uses of the receiving waters. There shall be no increase in pesticide concentrations found in bottom sediments or aquatic life as a result of the wastes discharged.
21. Ammonia shall not be present at levels that, when oxidized to nitrate, pose a threat to groundwater quality.
22. Chronic Toxicity Receiving Water Quality Objective
 - a. There shall be no chronic toxicity in ambient waters as a result of wastes discharged.

- b. Receiving water and effluent toxicity testing shall be performed on the same day as close to concurrently as possible.

B. Groundwater Limitations

1. The discharge shall not cause the underlying groundwater to be degraded, exceed WQOs, unreasonably affect beneficial uses, or cause a condition of pollution or nuisance.

VI. PROVISIONS

A. Standard Provisions

1. The Permittee shall comply with all Standard Provisions included in Attachment D.
2. **Regional Water Board Standard Provisions.** The Permittee shall comply with the following provisions. In the event that there is any conflict, duplication, or overlap between provisions specified by this Order, the more stringent provision shall apply:
 - a. Neither the treatment nor the discharge of pollutants shall create a pollution, contamination, or nuisance as defined by section 13050 of the CWC.
 - b. Odors, vectors, and other nuisances of sewage or sludge origin beyond the limits of the treatment plant site or the sewage collection system due to improper operation of facilities, as determined by the Regional Water Board, are prohibited.
 - c. All facilities used for collection, transport, treatment, or disposal of wastes shall be adequately protected against damage resulting from overflow, washout, or inundation from a storm or flood having a recurrence interval of once in 100 years.
 - d. Collection, treatment, and disposal systems shall be operated in a manner that precludes or impedes public contact with wastewater.
 - e. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer of the Regional Water Board.
 - f. The provisions of this order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
 - g. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation under authority preserved by section 510 of the CWA, related to oil and hazardous substances liability.
 - h. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities or penalties to which the Permittee is or may be subject to under section 311 of the CWA.
 - i. Discharge of wastes to any point other than specifically described in this Order is prohibited.
 - j. The Permittee shall comply with all applicable effluent limitations, national standards of performance, toxic effluent standards, and all federal regulations established pursuant to sections 301, 302, 303(d), 304, 306, 307, 316, 403, and 405 of the federal CWA and amendments thereto.
 - k. These requirements do not exempt the operator of the waste disposal facility from compliance with any other laws, regulations, or ordinances which may be applicable; they do not legalize this waste disposal facility; and they leave

unaffected any further restraints on the disposal of wastes at this site which may be contained in other statutes or required by other agencies.

- l. Oil or oily material, chemicals, refuse, or other polluting materials shall not be stored or deposited in areas where they may be picked up by rainfall and carried off of the property and/or discharged to surface waters. Any such spill of such materials shall be contained and removed immediately.
- m. A copy of these waste discharge specifications shall be maintained at the discharge Facility so as to be available at all times to operating personnel.
- n. If there is any storage of hazardous or toxic materials or hydrocarbons at this Facility and if the Facility is not manned at all times, a 24-hour emergency response telephone number shall be prominently posted where it can easily be read from the outside.
- o. The Permittee shall file with the Regional Water Board a report of waste discharge at least 120 days before making any proposed change in the character, location or volume of the discharge.
- p. In the event of any change in name, ownership, or control of these waste disposal facilities, the Permittee shall notify the Regional Water Board of such change and shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to the Regional Water Board, 30 days prior to taking effect.
- q. The discharge of any waste resulting from the combustion of toxic or hazardous wastes to any waste stream that ultimately discharges to waters of the United States is prohibited, unless specifically authorized elsewhere in this Order.
- r. The Permittee shall notify the Executive Officer in writing no later than 6 months prior to planned discharge of any chemical, other than the products previously reported to the Executive Officer, which may be toxic to aquatic life. Such notification shall include:
 - i. Name and general composition of the chemical,
 - ii. Frequency of use,
 - iii. Quantities to be used,
 - iv. Proposed discharge concentrations, and
 - v. USEPA registration number, if applicable.
- s. Violation of any of the provisions of this Order may subject the Permittee to any of the penalties described herein or in Attachment D of this Order, or any combination thereof, at the discretion of the prosecuting authority; except that only one kind of penalty may be applied for each kind of violation.
- t. Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this Facility, may subject the Permittee to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Permittee to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
- u. The CWC provides that any person who violates a waste discharge requirement or a provision of the CWC is subject to civil penalties of up to \$5,000 per day, \$10,000 per day, or \$25,000 per day of violation, or when the violation involves the discharge

- of pollutants, is subject to civil penalties of up to \$10 per gallon per day or \$25 per gallon per day of violation, or some combination thereof, depending on the violation, or upon the combination of violations.
- v. CWC section 13385(h)(i) requires the Regional Water Board to assess a mandatory minimum penalty of three-thousand dollars (\$3,000) for each serious violation. Pursuant to CWC section 13385(h)(2), a "serious violation" is defined as any waste discharge that violates the effluent limitations contained in the applicable waste discharge requirements for a Group II pollutant by 20 percent or more, or for a Group I pollutant by 40 percent or more. Appendix A of 40 CFR part 123.45 specifies the Group I and II pollutants. Pursuant to CWC section 13385.1(a)(1), a "serious violation" is also defined as "a failure to file a discharge monitoring report required pursuant to section 13383 for each complete period of 30 days following the deadline for submitting the report, if the report is designed to ensure compliance with limitations contained in waste discharge requirements that contain effluent limitations."
 - w. CWC section 13385(i) requires the Regional Water Board to assess a mandatory minimum penalty of three-thousand dollars (\$3,000) for each violation whenever a person violates a waste discharge requirement effluent limitation in any period of six consecutive months, except that the requirement to assess the mandatory minimum penalty shall not be applicable to the first three violations within that time period.
 - x. Pursuant to CWC section 13385.1(d), for the purposes of section 13385.1 and subdivisions (h), (i), and (j) of section 13385, "effluent limitation" means a numeric restriction or a numerically expressed narrative restriction, on the quantity, discharge rate, concentration, or toxicity units of a pollutant or pollutants that may be discharged from an authorized location. An effluent limitation may be final or interim, and may be expressed as a prohibition. An effluent limitation, for these purposes, does not include a receiving water limitation, a compliance schedule, or a best management practice.
 - y. CWC section 13387(e) provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this order, including monitoring reports or reports of compliance or noncompliance, or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained in this order shall be punished by a fine of not more than twenty-five thousand dollars (\$25,000), imprisonment pursuant to subdivision (h) of Section 1170 of the Penal Code for 16, 20, or 24 months, or by both that fine and imprisonment. For a subsequent conviction, such a person shall be punished by a fine of not more than twenty-five thousand dollars (\$25,000) per day of violation, by imprisonment pursuant to subdivision (h) of Section 1170 of the Penal Code for two, three, or four years, or by both that fine and imprisonment.
 - z. In the event the Permittee does not comply or will be unable to comply for any reason, with any prohibition, effluent limitation, or receiving water limitation of this Order, the Permittee shall notify the Chief of the Watershed Regulatory Section at the Regional Water Board by telephone (213) 576-6616 or by fax at (213) 576-6660 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing to the Regional Water Board within five days, unless the Regional Water Board waives confirmation. The written notification shall state the nature, time, duration, and cause of noncompliance, and shall describe the measures being taken to remedy the current noncompliance and, prevent

recurrence including, where applicable, a schedule of implementation. The written notification shall also be submitted via email with reference to CI-3021 to losangeles@waterboards.ca.gov. Other noncompliance requires written notification as above at the time of the normal monitoring report.

- aa. The Permittee shall investigate the feasibility of recycling, conservation, and/or alternative disposal methods of wastewater (such as groundwater injection), and/or use of storm water and dry-weather urban runoff. The Permittee submitted a feasibility study on January 30, 2014. The Permittee shall submit an update to this feasibility study as part of the submittal of the Report of Waste Discharge (ROWD) for the next permit renewal.

B. Monitoring and Reporting Program (MRP) Requirements

The Permittee shall comply with the MRP, and future revisions thereto, in Attachment E.

C. Special Provisions

1. Reopener Provisions

- a. This Order may be modified, revoked and reissued, or terminated for cause, including, but not limited to:

- i. Violation of any term or condition contained in this Order;
- ii. Obtaining this Order by misrepresentation, or by failure to disclose fully all relevant facts; or
- iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.

The filing of a request by the Permittee for an Order modification, revocation, and issuance or termination, or a notification of planned changes or anticipated noncompliance does not stay any condition of this Order.

- b. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity testing, monitoring of internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.
- c. This Order may be modified, in accordance with the provisions set forth in title 40 of the Code of Federal Regulations (40 CFR) parts 122 and 124 to include requirements for the implementation of a watershed protection management approach.
- d. The Board may modify, or revoke and reissue this Order if present or future investigations demonstrate that the discharge(s) governed by this Order have or will have a reasonable potential to cause, or contribute to adverse impacts on water quality or beneficial uses of the receiving waters.
- e. This Order may also be modified, revoked, and reissued or terminated in accordance with the provisions of 40 CFR parts 122.44, 122.62 to 122.64, 125.62, and 125.64. Causes for taking such actions include, but are not limited to, failure to comply with any condition of this Order, endangerment to human health or the environment resulting from the permitted activity, or acquisition of newly obtained information which would have justified the application of different conditions if known at the time of Order adoption. The filing of a request by the Permittee for an Order modification, revocation

and issuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any condition of this Order.

- f. This Order may be modified, in accordance with the provisions set forth in 40 CFR parts 122 to 124, to include new minimum levels (MLs).
- g. If an applicable toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under section 307(a) of the CWA for a toxic pollutant and that standard or prohibition is more stringent than any limitation on the pollutant in this Order, the Regional Water Board may institute proceedings under these regulations to modify or revoke and reissue the Orders to conform to the toxic effluent standard or prohibition.
- h. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments, thereto, the Regional Water Board will revise and modify this Order in accordance with such standards.
- i. This Order may be reopened and modified, to add or revise effluent limitations as a result of future Basin Plan Amendments, such as an update of a water quality objective, or the adoption/revision of any of the Calleguas Creek Watershed TMDLs.
- j. This Order may be reopened to modify the total dissolved solids, sulfate, and chloride final effluent limitations to include an adjustment factor (AF), following approval of an AF for the Facility by the Regional Water Board.
- k. This Order may be reopened and modified, to revise effluent limitations as a result of the delisting of a pollutant from the 303(d) list.
- l. This Order may be reopened and modified to revise the chronic toxicity effluent limitation and/or total residual chlorine limitations, to the extent necessary, to be consistent with State Water Board precedential decisions, new policies, a new state-wide plan, new laws, or new regulations.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

a. Calleguas Creek TMDL Monitoring Requirements

The POTWs within the Calleguas Creek Watershed (CCW) have developed a watershed monitoring program to implement the requirements for monitoring, conducting special studies, and implementing actions to reduce discharges of pollutants covered by the TMDL. This watershed monitoring program has been approved by the Regional Water Board. The responsible parties to the CCW TMDLs have signed a Memorandum of Agreement to jointly fund and complete the implementation of the TMDL Calleguas Creek Watershed Monitoring Program (CCWTMP), which began in August 2008. The CCWTMP was created to better facilitate a coordinated monitoring effort where multiple TMDL monitoring requirements could be addressed via a single program that would carry out and manage all aspects of the monitoring activities. This monitoring program has been developed to easily integrate new TMDL monitoring efforts as TMDLs are adopted and/or special study monitoring efforts are required.

The CCWTMP Annual Monitoring Report has been submitted since 2009. The annual monitoring reports summarize the monitoring reports for five of the six TMDLs currently effective in the CCW. These TMDLs include nitrogen compounds and related effects, toxicity, organochlorine pesticides and PCBs, metals and

selenium, and salts. A separate annual report is submitted for the trash TMDL. These reports were submitted to the Regional Water Board TMDL staff for review.

Since 2009, all sampling has followed the Standard Operating Procedures outlined in the Executive Officer approved *Calleguas Creek Watershed Management Plan Quality Assurance Project Plan (QAPP)*, with the following exception: the methods for the salts compliance monitoring that began on September 9, 2012, are not currently contained in the QAPP but were described in detail in the final Salts Monitoring Approach submitted to the Regional Water Board on June 29, 2012. The QAPP will be revised in 2014 to incorporate the methods, sites, and schedule for compliance salts monitoring described in the final approach document.

In addition, the majority of the TMDLs include requirements for monitoring, conducting special studies, and implementing actions to reduce discharges of pollutants covered by the TMDL. Many of these activities overlap and provide benefits for numerous TMDLs in the watershed. The CCWTMP annual reports included an appendix that summarizes workplan and study submittal dates, dates of responses to comments received by the Regional Water Board, and actions that have been taken to reduce pollutant discharges to the waterbodies. Additionally, the report provides a mechanism for providing the Regional Water Board with required progress reports for some of the TMDLs.

b. Special Study for Constituents of Emerging Concern (CECs)

i. CECs Monitoring Requirement in the Effluent

- (a) The Permittee shall conduct a special study to investigate the CECs in the effluent discharge. The Permittee shall follow the CEC monitoring requirements as discussed in the MRP and the Fact Sheet.

c. Treatment Plant Capacity

The Permittee shall submit a written report to the Executive Officer of the Regional Water Board within 90 days after the "30-day (monthly) average" daily dry-weather flow equals or exceeds 75 percent of the design capacity of waste treatment and/or disposal facilities. The Permittee's senior administrative officer shall sign a letter, which transmits that report and certifies that the Permittee's policy-making body is adequately informed of the report's contents. The report shall include the following:

- i. The average daily flow for the month, the date on which the peak flow occurred, the rate of that peak flow, and the total flow for the day;
- ii. The best estimate of when the monthly average daily dry-weather flow rate will equal or exceed the design capacity of the facilities; and,
- iii. A schedule for studies, design, and other steps needed to provide additional capacity for waste treatment and/or disposal facilities before the waste flow rate equals the capacity of present units.

This requirement is applicable to those facilities which have not reached 75 percent of capacity as of the effective date of this Order. For those facilities that have reached 75 percent of capacity by that date but for which no such report has been previously submitted, such a report shall be filed within 90 days of the issuance of this Order.

3. Best Management Practices and Pollution Prevention

a. Storm Water Pollution Prevention Plan (SWPPP) – (Not Applicable)

b. **Spill Clean-up Contingency Plan (SCCP)**

Within 90 days of the effective date of this Order, the Permittee is required to submit a SCCP, which describes the activities and protocols to address clean-up of spills, overflows, and bypasses of untreated or partially treated wastewater from the Permittee's collection system or treatment facilities that reach water bodies, including dry channels and beach sands. At a minimum, the plan shall include sections on spill clean-up and containment measures, public notification, and monitoring. The Permittee shall review and amend the plan as appropriate after each spill from the Facility or in the service area of the Facility. The Permittee shall include a discussion in the annual summary report of any modifications to the Plan and the application of the Plan to all spills during the year.

c. **Pollutant Minimization Program (PMP)**

Reporting protocols in MRP section X.C.4 describe sample results that are to be reported as Detected but Not Quantified (DNQ) or Not Detected (ND). Definitions for a reported Minimum Level (ML) and Method Detection Limit (MDL) are provided in Attachment A. These reporting protocols and definitions are used in determining the need to conduct a PMP as follows:

The Permittee shall develop and conduct a PMP as further described below when there is evidence (e.g., sample results reported as DNQ when the effluent limitation is less than the MDL; sample results from analytical methods more sensitive than those methods required by this Order; presence of whole effluent toxicity; health advisories for fish consumption; or, results of benthic or aquatic organism tissue sampling) that a pollutant is present in the effluent above an effluent limitation and either of the following is true:

- i. The concentration of the pollutant is reported as DNQ and the effluent limitation is less than the reported ML; or,
- ii. The concentration of the pollutant is reported as ND and the effluent limitation is less than the MDL, using definitions described in Attachment A and reporting protocols described in the MRP.

The goal of the PMP shall be to reduce all potential sources of a pollutant through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost-effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan (PPP), if required pursuant to CWC section 13263.3(d), shall be considered to fulfill the PMP requirements.

The PMP shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:

- i. An annual review and semi-annual monitoring of potential sources of the reportable pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling;
- ii. Quarterly monitoring for the reportable pollutant(s) in the influent to the wastewater treatment system;

- iii. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable pollutant(s) in the effluent at or below the effluent limitation;
- iv. Implementation of appropriate cost-effective control measures for the reportable pollutant(s), consistent with the control strategy; and
- v. An annual status report that shall be sent to the Regional Water Board including:
 - (a) All PMP monitoring results for the previous year;
 - (b) A list of potential sources of the reportable pollutant(s);
 - (c) A summary of all actions undertaken pursuant to the control strategy; and
 - (d) A description of actions to be taken in the following year.

4. Construction, Operation and Maintenance Specifications

- a. Wastewater treatment facilities subject to this Order shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to California Code of Regulations (CCR), title 23, division 3, chapter 26 (CWC sections 13625 – 13633).
- b. The Permittee shall maintain in good working order a sufficient alternate power source for operating the wastewater treatment and disposal facilities. All equipment shall be located to minimize failure due to moisture, liquid spray, flooding, and other physical phenomena. The alternate power source shall be designed to permit inspection and maintenance and shall provide for periodic testing. If such alternate power source is not in existence, the Permittee shall halt, reduce, or otherwise control all discharges upon the reduction, loss, or failure of the primary source of power.
- c. The Permittee shall provide standby or emergency power facilities and/or storage capacity or other means so that in the event of plant upset or outage due to power failure or other cause, discharge of raw or inadequately treated sewage does not occur

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Sludge Disposal Requirements

- i. All sludge generated at the wastewater treatment plant must be disposed of, treated, or applied to land in accordance with federal regulations contained in 40 CFR part 503. These requirements are enforceable by USEPA.
- ii. The Permittee is separately required to comply with the requirements in State Water Board Order No. 2004-10-DWQ, *General WDRs for the Discharge of Biosolids to Land for Use as a Soil Amendment in Agricultural, Silvicultural, Horticultural and Land Reclamation Activities* for those sites receiving the Permittee's biosolids which a Regional Water Board has placed under this general order, and with the requirements in individual WDRs issued by a Regional Water Board for sites receiving the Permittee's biosolids.
- iii. The Permittee shall separately comply, if applicable, with WDRs issued by other Regional Water Boards to which jurisdiction the biosolids are transported and applied.

- iv. The Permittee shall assure that haulers transporting sludge off site for treatment, storage, use, or disposal take all necessary measures to keep the sludge contained. The Permittee shall maintain and have haulers adhere to a spill clean-up plan. Any spills shall be reported to USEPA and the Regional Water Board or state agency in which the spill occurred. All trucks hauling sludge shall be thoroughly washed after unloading at the field or at the receiving facility.
 - v. The Permittee shall furnish this Regional Water Board with a copy of any report submitted to USEPA, the State Water Board or other Regional Water Board, with respect to municipal sludge or biosolids.
- b. Pretreatment Requirements**
- i. The Permittee has developed and implemented an approved Pretreatment Program that was submitted to the Regional Water Board. This Order requires implementation of the approved Pretreatment Program. Any violation of the Pretreatment Program will be considered a violation of this Order.
 - ii. On March 21, 2011, the City Council of the City of Simi Valley added Chapter 13 to Title 6 of the Simi Valley Municipal Code regulating sewer use by adopting Ordinance No. 1170, providing the Simi Valley WQCP the legal authority to continue to implement and enforce its Pretreatment Program. On March 21, 2011, based on the conditions of Chapter 13 of Title 6 of the Simi Valley Municipal Code, the City Council of the City of Simi Valley approved the local limits through Ordinance No. 1170 and incorporated them into its Pretreatment Program. Based on the legal authority provided by the Simi Valley Municipal Code, the Simi Valley WQCP prepared an Enforcement Response Plan on February 14, 2011, that is part of the City's Pretreatment Program.
 - iii. Any change to the program shall be reported to the Regional Water Board in writing and shall not become effective until approved by the Executive Officer in accordance with procedures established in 40 CFR part 403.18.
 - iv. Applications for renewal or modification of this Order must contain information about industrial discharges to the POTW pursuant to 40 CFR part 122.21(j)(6). Pursuant to 40 CFR part 122.42(b) and provision VII.A of Attachment D, Standard Provisions, of this Order, the Permittee shall provide adequate notice of any new introduction of pollutants or substantial change in the volume or character of pollutants from industrial discharges which were not included in the permit application. Pursuant to 40 CFR part 122.44(j)(1), the Permittee shall annually identify and report, in terms of character and volume of pollutants, any Significant Industrial Users discharging to the POTW subject to Pretreatment Standards under section 307(b) of the CWA and 40 CFR part 403.
 - v. The Permittee shall comply with Attachment I – Pretreatment Reporting Requirements.
- c. Collection System Requirements**
- i. The Permittee's collection system is part of the system that is subject to this Order. As such, the Permittee must properly operate and maintain its collection system (40 CFR part 122.41(e)). The Permittee must report any non-compliance (40 CFR part 122.41(l)(6) and (7)) and mitigate any discharge

from the collection system in violation of this Order (40 CFR part 122.41(d)). See the Order at Attachment D, subsections I.D, V.E, V.H, and I.C., and the following section of this Order.

6. Spill Reporting Requirements

a. Initial Notification

Although State and Regional Water Board staff do not have duties as first responders, this requirement is an appropriate mechanism to ensure that the agencies that do have first responder duties are notified in a timely manner in order to protect public health and beneficial uses. For certain spills, overflows and bypasses, the Permittee shall make notifications as required below:

- i. In accordance with the requirements of Health and Safety Code section 5411.5, the Permittee shall provide notification to the local health officer or the director of environmental health with jurisdiction over the affected water body of any unauthorized release of sewage or other waste that causes, or probably will cause, a discharge to any waters of the state as soon as possible, but no later than two hours after becoming aware of the release.
- ii. In accordance with the requirements of CWC section 13271, the Permittee shall provide notification to the California Emergency Management Agency (Cal EMA) of the release of reportable amounts of hazardous substances or sewage that causes, or probably will cause, a discharge to any waters of the state as soon as possible, but not later than two hours after becoming aware of the release. The CCR, Title 23, section 2250, defines a reportable amount of sewage as being 1,000 gallons. The phone number for reporting these releases to the Cal EMA is (800) 852-7550.
- iii. The Permittee shall notify the Regional Water Board of any unauthorized release of sewage from its POTW that causes, or probably will cause, a discharge to a water of the state as soon as possible, but not later than two hours after becoming aware of the release. This initial notification does not need to be made if the Permittee has notified Cal EMA and the local health officer or the director of environmental health with jurisdiction over the affected waterbody. The phone number for reporting these releases of sewage to the Regional Water Board is (213) 576-6657. The phone numbers for after hours and weekend reporting of releases of sewage to the Regional Water Board are (213) 305-2284 and (213) 305-2253.

At a minimum, the following information shall be provided to the Regional Water Board:

- (a) The location, date, and time of the release;
- (b) The water body that received or will receive the discharge;
- (c) An estimate of the amount of sewage or other waste released and the amount that reached a surface water at the time of notification;
- (d) If ongoing, the estimated flow rate of the release at the time of the notification;
- (e) The name, organization, phone number and email address of the reporting representative; and,

- (f) A certification that the State Office of Emergency Services and the local health officer or directors of environmental health with jurisdiction over the affected water bodies have been notified of the discharge.

b. Monitoring

For spills, overflows and bypasses reported under section VI.C.6.a, the Permittee shall monitor as required below:

- i. To define the geographical extent of the spill's impact, the Permittee shall obtain grab samples (if feasible, accessible, and safe) for all spills, overflows or bypasses of any volume that reach any waters of the state (including surface and ground waters). The Permittee shall analyze the samples for total coliform, fecal coliform, E. coli (if fecal coliform test shows positive), enterococcus, and relevant pollutants of concern, upstream and downstream of the point of entry of the spill (if feasible, accessible, and safe). This monitoring shall be done on a daily basis from the time the spill is known until the results of two consecutive sets of bacteriological monitoring indicate the return to the background level or the County Department of Public Health authorizes cessation of monitoring.

c. Reporting

The initial notification required under section VI.C.6.a shall be followed by:

- i. As soon as possible, but not later than twenty-four hours after becoming aware of an unauthorized discharge of sewage or other waste from its wastewater treatment plant to a water of the state, the Permittee shall submit a statement to the Regional Water Board by email at augustine.anijelo@waterboards.ca.gov. If the discharge is 1,000 gallons or more, this statement shall certify that Cal EMA has been notified of the discharge in accordance with CWC section 13271. The statement shall also certify that the local health officer or director of environmental health with jurisdiction over the affected water bodies has been notified of the discharge in accordance with Health and Safety Code section 5411.5. The statement shall also include at a minimum the following information:
 - (a) Agency, NPDES No., Order No., and MRP CI No., if applicable;
 - (b) The location, date, and time of the discharge;
 - (c) The water body that received the discharge;
 - (d) A description of the level of treatment of the sewage or other waste discharged;
 - (e) An initial estimate of the amount of sewage or other waste released and the amount that reached a surface water;
 - (f) The Cal EMA control number and the date and time that notification of the incident was provided to Cal EMA; and,
 - (g) The name of the local health officer or director of environmental health representative notified (if contacted directly); the date and time of notification; and the method of notification (e.g., phone, fax, email).
- ii. A written preliminary report five working days after disclosure of the incident is required. Submission to the Regional Water Board of the California Integrated Water Quality System (CIWQS) Sanitary Sewer Overflow (SSO) event number

shall satisfy this requirement. Within 30 days after submitting the preliminary report, the Permittee shall submit the final written report to this Regional Water Board. (A copy of the final written report, for a given incident, already submitted pursuant to a statewide General WDRs for Wastewater Collection System Agencies (SSO WDR), may be submitted to the Regional Water Board to satisfy this requirement.) The written report shall document the information required in paragraph d below, monitoring results and any other information required in provisions of the Standard Provisions document including corrective measures implemented or proposed to be implemented to prevent/minimize future occurrences. The Executive Officer for just cause can grant an extension for submittal of the final written report.

- iii. The Permittee shall include a certification in the annual summary report (due according to the schedule in the MRP) that states that the sewer system emergency equipment, including alarm systems, backup pumps, standby power generators, and other critical emergency pump station components were maintained and tested in accordance with the Permittee's preventive maintenance plan. Any deviations from or modifications to the plan shall be discussed.

d. Records

The Permittee shall develop and maintain a record of all spills, overflows or bypasses of raw or partially treated sewage from its collection system or treatment plant. This record shall be made available to the Regional Water Board upon request and a spill summary shall be included in the annual summary report. The records shall contain:

- i. The date and time of each spill, overflow, or bypass;
- ii. The location of each spill, overflow, or bypass;
- iii. The estimated volume of each spill, overflow, and bypass including gross volume, amount recovered and amount not recovered, monitoring results as required by section VI.C.6.b;
- iv. The cause of each spill, overflow, or bypass;
- v. Whether each spill, overflow, or bypass entered a receiving water and, if so, the name of the water body and whether it entered via storm drains or other man-made conveyances;
- vi. Any mitigation measures implemented;
- vii. Any corrective measures implemented or proposed to be implemented to prevent/minimize future occurrences; and,
- viii. The mandatory information included in SSO online reporting for finalizing and certifying the SSO report for each spill, overflow, or bypass under the SSO WDR.

e. Activities Coordination

Although not required by this Order, Regional Water Board also expects the watershed group to continue to work together regarding activities related to desalters, water uses, and the use of the brine line in order to comply with the requirements of this Order, in addition to meeting the deadlines in the Salts TMDL Implementation Plan.

f. **Consistency with SSO WDRs**

The CWA prohibits the discharge of pollutants from point sources to surface waters of the United States unless authorized under an NPDES permit. (33 United States Code sections 1311, 1342). The State Water Board adopted *General Waste Discharge Requirements for Sanitary Sewer Systems*, (WQ Order No. 2006-0003-DWQ; SSO WDR) on May 2, 2006, to provide a consistent, statewide regulatory approach to address sanitary sewer overflows. The SSO WDR requires public agencies that own or operate sanitary sewer systems to apply for coverage under the SSO WDR, develop and implement sewer system management plans, and report all SSO to the State Water Board's online SSOs database. Regardless of the coverage obtained under the SSO WDR, the Permittee's collection system is part of the POTW that is subject to this NPDES permit. As such, pursuant to federal regulations, the Permittee must properly operate and maintain its collection system (40 CFR part 122.41 (e)), report any non-compliance (40 CFR part 122.41(1)(6) and (7)), and mitigate any discharge from the collection system in violation of this NPDES permit (40 CFR part 122.41(d)).

The requirements contained in this Order in sections VI.C.3.b (SCCP Plan section), VI.C.4 (Construction, Operation and Maintenance Specifications section), and VI.C.6 (Spill Reporting Requirements section) are intended to be consistent with the requirements of the SSO WDR. The Regional Water Board recognizes that there may be some overlap between these NPDES permit provisions and SSO WDR requirements, related to the collection systems. The requirements of the SSO WDR are considered the minimum thresholds (see finding 11 of State Water Board Order No. 2006-0003-DWQ). To encourage efficiency, the Regional Water Board will accept the documentation prepared by the Permittees under the SSO WDR for compliance purposes as satisfying the requirements in sections VI.C.3.b, VI.C.4, and VI.C.6 provided the more stringent provisions contained in this NPDES permit are also addressed. Pursuant to SSO WDR, section D, provision 2(iii) and (iv), the provisions of this NPDES permit supercede the SSO WDR, for all purposes, including enforcement, to the extent the requirements may be deemed duplicative

7. Compliance Schedules – Not Applicable

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

A. General

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the MRP and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Permittee shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

B. Multiple Sample Data

When determining compliance with a measure of central tendency (arithmetic mean, geometric mean, median, etc.) of multiple sample analyses and the data set contains one or

more reported determinations of DNQ or ND. In those cases, the Permittee shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

C. Average Monthly Effluent Limitation (AMEL)

If the average (or when applicable, the median determined by subsection B above for multiple sample data) of daily discharges over a calendar month exceeds the AMEL for a given parameter, this will represent a single violation, though the Permittee may be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AMEL, the Permittee may be considered out of compliance for that calendar month. The Permittee will only be considered out of compliance for days when the discharge occurs. For any one calendar month during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar month with respect to the AMEL.

If the analytical result of a single sample, monitored monthly, quarterly, semiannually, or annually, does not exceed the AMEL for a given parameter, the Permittee will have demonstrated compliance with the AMEL for each day of that month for that parameter.

If the analytical result of any single sample, monitored monthly, quarterly, semiannually, or annually, exceeds the AMEL for any parameter, the Permittee may collect up to four additional samples within the same calendar month. All analytical results shall be reported in the monitoring report for that month. The concentration of pollutant (an arithmetic mean or a median) in these samples estimated from the "Multiple Sample Data Reduction" section above, will be used for compliance determination.

In the event of noncompliance with an AMEL, the sampling frequency for that parameter shall be increased to weekly and shall continue at this level until compliance with the AMEL has been demonstrated.

D. Average Weekly Effluent Limitation (AWEL)

If the average of daily discharges over a calendar week exceeds the AWEL for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for each day of that week for that parameter, resulting in 7 days of non-compliance. The average of daily discharges over the calendar week that exceeds the AWEL for a parameter will be considered out of compliance for that week only. If only a single sample is taken during the calendar week and the analytical result for that sample exceeds the AWEL, the Permittee will be considered out of compliance for that calendar week. For any one calendar week during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar week with respect to the AWEL.

A calendar week will begin on Sunday and end on Saturday. Partial calendar weeks at the end of calendar month will be carried forward to the next month in order to calculate and report a consecutive seven-day average value on Saturday.

E. Maximum Daily Effluent Limitation (MDEL)

If a daily discharge on a calendar day exceeds the MDEL for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for that day for that parameter. If no sample (daily discharge) is taken over a calendar day, no compliance determination can be made for that day with respect to effluent violation determination, but compliance determination can be made for that day with respect to reporting violation determination.

F. Instantaneous Minimum Effluent Limitation

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, a violation will be flagged and the Permittee will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

G. Instantaneous Maximum Effluent Limitation

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, a violation will be flagged and the Permittee will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

H. Six-month Median Effluent Limitation

If the median of daily discharges over any 180-day period exceeds the six-month median effluent limitation for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for each day of that 180-day period for that parameter. The next assessment of compliance will occur after the next sample is taken. If only a single sample is taken during a given 180-day period and the analytical result for that sample exceeds the six-month median, the Permittee will be considered out of compliance for the 180-day period. For any 180-period during which no sample is taken, no compliance determination can be made for the six-month median effluent limitation.

I. Median Monthly Effluent Limitation (MMEL)

If the median of daily discharges over a calendar month exceeds the MMEL for a given parameter, an alleged violation will be flagged and the Permittee will be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). However, an alleged violation of the MMEL will be considered one violation for the purpose of assessing State mandatory minimum penalties. If no sample (daily discharge) is taken over a calendar month, no compliance determination can be made for that month with respect to effluent violation determination, but compliance determination can be made for that month with respect to reporting violation determination.

J. Chronic Toxicity

The discharge is subject to determination of "Pass" or "Fail" and "Percent Effect" from a single-effluent concentration chronic toxicity test at the discharge IWC using the Test of Significant Toxicity (TST) approach described in National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, 2010), Appendix A, Figure A-1, and Table A-1. The null hypothesis (H_0) for the TST approach is: Mean discharge IWC response $\leq 0.75 \times$ Mean control response. A test result that rejects this

null hypothesis is reported as "Pass". A test result that does not reject this null hypothesis is reported as "Fail". The relative "Percent Effect" at the discharge IWC is defined and reported as: $((\text{Mean control response} - \text{Mean discharge IWC response}) \div \text{Mean control response}) \times 100$.

The Maximum Daily Effluent Limitation (MDEL) for chronic toxicity is exceeded and a violation will be flagged when a chronic toxicity test, analyzed using the TST approach, results in "Fail" and the "Percent Effect" is ≥ 0.50 .

The Median Monthly Effluent Limitation (MMEL) for chronic toxicity is exceeded and a violation will be flagged when the median of no more than three independent chronic toxicity tests, conducted within the same calendar month and analyzed using the TST approach, results in "Fail". The MMEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail".

K. Percent Removal

The average monthly percent removal is the removal efficiency expressed in percentage across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of pollutant concentrations (C in mg/L) of influent and effluent samples collected at about the same time using the following equation:

$$\text{Percent Removal (\%)} = [1 - (C_{\text{Effluent}}/C_{\text{Influent}})] \times 100\%$$

When preferred, the Permittee may substitute mass loadings and mass emissions for the concentrations.

L. Mass and Concentration Limitations

Compliance with mass and concentration effluent limitations for the same parameter shall be determined separately with their respective limitations. When the concentration of a constituent in an effluent sample is determined to be ND or DNQ, the corresponding mass emission rate determined from that sample concentration shall also be reported as ND or DNQ.

M. Compliance with single constituent effluent limitations

Permittees may be considered out of compliance with the effluent limitation if the concentration of the pollutant (see section B "Multiple Sample Data Reduction" above) in the monitoring sample is greater than the effluent limitation and greater than or equal to the RL.

N. Compliance with effluent limitations expressed as a sum of several constituents

Permittees are out of compliance with an effluent limitation which applies to the sum of a group of chemicals (e.g., PCB's) if the sum of the individual pollutant concentrations is greater than the effluent limitation. Individual pollutants of the group will be considered to have a concentration of zero if the constituent is reported as ND or DNQ.

O. Compliance with Calleguas Creek Salts TMDL effluent limitations

Simi Valley WQCP discharges to Arroyo Simi, Reach 7 of the Calleguas Creek. The Calleguas Creek and its tributaries are on the CWA section 303(d) list as impaired for TDS, Sulfate, Chloride, and Boron. For this discharge, the Calleguas Creek Salts TMDL has established seasonal WLAs for TDS, Sulfate, Chloride, and Boron. Federal regulations require that NPDES permits incorporate WQBELs consistent with the requirements and assumptions of any available WLAs.

Chloride Compliance

Compliance with the effluent limitations for chloride will be determined through monitoring of final effluent discharge as defined in the NPDES permit. The effluent limitations will be applied as end-of pipe mass-based and concentration-based monthly average effluent limits. Compliance with the minimum salt export requirements for Simi Valley WQCP will be based on the salt export from the subwatershed to which they discharge. The mechanisms for meeting the minimum salt export requirements and for monitoring progress towards meeting those requirements will be included in the monitoring program work plan and approved by the Executive Officer.

Simi Valley WQCP's mass-based WLAs are calculated as the POTW effluent flow rate multiplied by the water quality objective and include a mass-based adjustment factor (AF) that is subtracted from the product of the flow-rate and the water quality objective. AF is set equal to the difference between the minimum salts export requirement to attain a salt balance in the subject reaches and the actual salts export.

The dry-weather final effluent limitation for Chloride will be calculated as follows:

Given: Minimum Salt Export Requirements for AF

Chloride = 460 lbs/day

The formula for determining final effluent limitation (dry weather) applied as monthly average is as follows:

86th Percentile flow = 9.7 cfs

Chloride, lbs/day = 150 x Q-AF

The use of AFs are subject to approval by the Regional Water Board. A Permittee seeking to utilize AFs must apply to the Regional Water Board for approval, and submit the following documentation with the request: (1) water supply chloride concentrations, (2) receiving water chloride concentrations, (3) the effluent mass, and (4) evidence of increased salt exports to offset the increased discharges from the POTW. The AF term is equal to zero since the Regional Water Board has not approved an AF for the Facility. As a result, the AF term drops out of the equation, and the final effluent limitations are expressed as:

Chloride (dry-weather), lbs/day = 150 x Q

where; Q is equal to the plant's design flow

therefore; Chloride = 150 x 12.5 x 8.34/1000

Chloride (dry-weather), lbs/day = 15,640 lbs/day.

Dry-weather definition. The WLAs apply to Simi Valley WQCP during dry weather when the average flows in the receiving water are below the 86th percentile flow and there is no measurable precipitation. For flow monitoring purposes of the receiving water, the Permittee shall use the existing flow gauging station at Calleguas Creek at California State University Channel Islands (USGS 11106550). Based on the most recent data collected from USGS 11106550, the 86th percentile flow equal to 31 cubic feet per second (cfs). The rainfall precipitation shall be obtained from an existing rainfall gauging station located at the Simi Valley WQCP, Station ID: 246A. The stream flow and rainfall gauging stations are operated and maintained by the Ventura County Watershed Protection District. The required stream flow and rainfall data are available online at <http://www.vcwatershed.net/fws/>.

The wet-weather final effluent limitation for Chloride.

The final wet-weather effluent limitation for Chloride is set equal to concentration-based limit in the Basin Plan.

Chloride (wet-weather), mg/L = 150 mg/L.

Wet-weather definition. Wet-weather is any day when the average flow in the receiving water is equal to or flows greater than the 86th percentile flow of the receiving water measured at Calleguas Creek at California State University Channel Islands (USGS 11106550). The 86th percentile flow is equal to 31 cfs. During wet weather, the loading capacity of the stream is significantly increased by storm water flows with very low salt concentrations. Any discharges from the Facility during wet weather would be assimilated by these large storm flows and would not cause exceedances of water quality objectives.

Summary of Chloride Final Effluent Limitations

Parameter	Units	Effluent Limitations (Average Monthly)
Chloride (wet-weather)	mg/L	150
Chloride (dry-weather)	lbs/day	15,640

TDS, Sulfate, and Boron Compliance

The Permittee is able to meet the final effluent limitations for TDS, sulfate and boron in this permit. The final effluent limitations for TDS, sulfate, and boron will be set equal to the Basin Plan water quality objectives. These effluent limitations will apply all-year round.

Summary of TDS, Sulfate, and Boron Final Effluent Limitations

Parameter	Units	Effluent Limitations (Average Monthly)
TDS	mg/L	850
	lbs/day	88,610
Sulfate	mg/L	250
	lbs/day	26,060
Boron	mg/L	1.0
	lbs/day	104

P. Compliance with Calleguas Creek Metals TMDL for Mercury in Suspended Solids

A mass-based limit is developed for mercury expressed in lbs/month. The final waste load allocation for Simi Valley WQCP for mercury is based on median monthly mercury effluent concentrations which are currently more stringent than the number targets multiplied by the design flow. The *Metals TMDL* assumes that the total load in water is equal to suspended sediment load.

Q. Mass Emission Rate

The mass emission rate shall be obtained from the following calculation for any calendar day:

$$\text{Mass emission rate (lb/day)} = \frac{8.34}{N} \sum_{i=1}^N Q_i C_i$$

$$\text{Mass emission rate (kg/day)} = \frac{3.79}{N} \sum_{i=1}^N Q_i C_i$$

in which 'N' is the number of samples analyzed in any calendar day. 'Q_i' and 'C_i' are the flow rate (mgd) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' grab samples, which may be taken in any calendar day. If a composite sample is taken, 'C_i' is the concentration measured in the composite sample and 'Q_i' is the average flow rate occurring during the period over which samples are composited.

The daily concentration of all constituents shall be determined from the flow-weighted average of the same constituents in the combined waste streams as follows:

$$\text{Daily concentration} = \frac{1}{Q_t} \sum_{i=1}^N Q_i C_i$$

in which 'N' is the number of component waste streams. 'Q_i' and 'C_i' are the flow rate (MGD) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' waste streams. 'Q_t' is the total flow rate of the combined waste streams.

R. Bacterial Standards and Analysis

1. The geometric mean used for determining compliance with bacterial standards is calculated with the following equation:

$$\text{Geometric Mean} = (C_1 \times C_2 \times \dots \times C_n)^{1/n}$$

where n is the number of days samples were collected during the period and C is the concentration of bacteria (MPN/100 mL or CFU/100 mL) found on each day of sampling.

2. For bacterial analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliform, at a minimum, and 1 to 1000 per 100 ml for enterococcus). The detection methods used for each analysis shall be reported with the results of the analyses.
3. Detection methods used for coliforms (total and fecal) shall be those presented in Table 1A of 40 CFR part 136, unless alternate methods have been approved by USEPA pursuant to 40 CFR part 136, or improved methods have been determined by the Executive Officer and/or USEPA.
4. Detection methods used for enterococcus shall be those presented in Table 1A of 40 CFR part 136 or in the USEPA publication EPA 600/4-85/076, Test Methods for Escherichia coli and Enterococci in Water By Membrane Filter Procedure or any improved method determined by the Executive Officer and/or USEPA to be appropriate.

S. Single Operational Upset (SOU)

A SOU that leads to simultaneous violations of more than one pollutant parameter shall be treated as a single violation and limits the Permittee's liability in accordance with the following conditions:

1. A SOU is broadly defined as a single unusual event that temporarily disrupts the usually satisfactory operation of a system in such a way that it results in violation of multiple pollutant parameters.
2. A Permittee may assert SOU to limit liability only for those violations which the Permittee submitted notice of the upset as required in Provision V.E.2(b) of Attachment D – Standard Provisions.
3. For purpose outside of CWC section 13385 subdivisions (h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Permittees to assert the SOU limitation of liability, and the manner of counting violations) shall be in accordance with USEPA Memorandum "Issuance of Guidance Interpreting Single Operational Upset" (September 27, 1989).
4. For purpose of CWC section 13385 (h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Permittees to assert the SOU limitation of liability, and the manner of counting violations) shall be in accordance with CWC section 13385 (f)(2).

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ)

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

Arithmetic mean = $\mu = \Sigma x / n$ where: Σx is the sum of the measured ambient water concentrations, and n is the number of samples.

Average Monthly Effluent Limitation (AMEL)

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL)

The highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Biosolids

Biosolids refer to sewage sludge that has been treated and tested and shown to be capable of being beneficially and legally used pursuant to federal and state regulations as a soil amendment for agricultural, silvicultural, horticultural, and land reclamation activities as specified under 40 CFR part 503.

Carcinogenic

Pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV)

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge

Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ)

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL. Sample results reported as DNQ are estimated concentrations.

Dilution Credit

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA)

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in U.S. EPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters

All surface waters of the state that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation

The highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

The lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL)

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the n/2 and n/2+1).

Method Detection Limit (MDL)

MDL is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in 40 CFR part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML)

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND)

Sample results which are less than the laboratory's MDL.

Persistent Pollutants

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP)

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as

defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State Water Resources Control Board (State Water Board) or Regional Water Board.

Reporting Level (RL)

The RL is the ML (and its associated analytical method) chosen by the Permittee for reporting and compliance determination from the MLs included in this Order, including an additional factor if applicable as discussed herein. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Source of Drinking Water

Any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ)

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

x is the observed value;


μ is the arithmetic mean of the observed values; and

n is the number of samples.

Toxicity Reduction Evaluation (TRE)

TRE is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)


ATTACHMENT B – MAP



REVISED TENTATIVE

ATTACHMENT C – FLOW SCHEMATIC

PROCESS FLOW DIAGRAM
(ADF September 2007)



ATTACHMENT D – STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Permittee must comply with all of the terms, requirements, and conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA), its regulations, and the California Water Code (CWC) and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof. (40 CFR part 122.41(a); California Water Code (CWC) sections 13261, 13263, 13264, 13265, 13268, 13000, 13001, 13304, 13350, 13385.)
2. The Permittee shall comply with effluent standards or prohibitions established under Part 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (Title 40 of the Code of Federal Regulations (40 CFR) part 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR part 122.41(c).)

C. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR part 122.41(d).)

D. Proper Operation and Maintenance

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Permittee only when necessary to achieve compliance with the conditions of this Order. (40 CFR part 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR part 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 CFR part 122.5(c).)

F. Inspection and Entry

The Permittee shall allow the Regional Water Board, State Water Board, USEPA, and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (33 U.S.C. section 1318(a)(4)(B); 40 CFR part 122.41(i); CWC sections 13267 and 13383):

1. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (33 U.S.C. section 1318(a)(4)(B)(i); 40 CFR part 122.41(i)(1); CWC sections 13267 and 13383);
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (33 U.S.C. section 1318(a)(4)(B)(ii); 40 CFR part 122.41(i)(2); CWC sections 13267 and 13383);
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (33 U.S.C. section 1318(a)(4)(B)(ii); 40 CFR part 122.41(i)(3); CWC sections 13267 and 13383); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the CWC, any substances or parameters at any location. (33 U.S.C. section 1318(a)(4)(B); 40 CFR part 122.41(i)(4); CWC sections 13267 and 13383)

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR part 122.41(m)(1)(i).)
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR part 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Permittee may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 CFR part 122.41(m)(2).)
3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Permittee for bypass, unless (40 CFR part 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR part 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR part 122.41(m)(4)(i)(B)); and
 - c. The Permittee submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR part 122.41(m)(4)(i)(C).)
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 CFR part 122.41(m)(4)(ii).)

5. Notice

- a. Anticipated bypass. If the Permittee knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR part 122.41(m)(3)(i).)
- b. Unanticipated bypass. The Permittee shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR part 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR part 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR part 122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR part 122.41(n)(3)):
 - a. An upset occurred and that the Permittee can identify the cause(s) of the upset (40 CFR part 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 CFR part 122.41(n)(3)(ii));
 - c. The Permittee submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR part 122.41(n)(3)(iii)); and
 - d. The Permittee complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR part 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Permittee seeking to establish the occurrence of an upset has the burden of proof. (40 CFR part 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR part 122.41(f).)

B. Duty to Reapply

If the Permittee wishes to continue an activity regulated by this Order after the expiration date of this Order, the Permittee must apply for and obtain a new permit. (40 CFR part 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Permittee and incorporate such other requirements as may be necessary under the CWA and the CWC. (40 CFR part 122.41(l)(3); and 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR part 122.41(j)(1).)
- B. Monitoring results must be conducted according to test procedures approved under 40 CFR part 136 for the analyses of pollutants unless another method is required under 40 CFR subchapters N or O. In the case of pollutants for which there are no approved methods under 40 CFR part 136 or otherwise required under 40 CFR subchapters N or O, monitoring must be conducted according to a test procedure specified in this Order for such pollutants. (40 CFR part 122.41(j)(4); part 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR part 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 CFR part 122.41(j)(2).)
- B. Records of monitoring information shall include:
 - 1. The date, exact place, and time of sampling or measurements (40 CFR part 122.41(j)(3)(i));
 - 2. The individual(s) who performed the sampling or measurements (40 CFR part 122.41(j)(3)(ii));
 - 3. The date(s) analyses were performed (40 CFR part 122.41(j)(3)(iii));
 - 4. The individual(s) who performed the analyses (40 CFR part 122.41(j)(3)(iv));
 - 5. The analytical techniques or methods used (40 CFR part 122.41(j)(3)(v)); and
 - 6. The results of such analyses. (40 CFR part 122.41(j)(3)(vi).)
- C. Claims of confidentiality for the following information will be denied (40 CFR part 122.7(b)):
 - 1. The name and address of any permit applicant or Permittee (40 CFR part 122.7(b)(1)); and
 - 2. Permit applications and attachments, permits and effluent data. (40 CFR part 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Permittee shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the

Permittee shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR part 122.41(h); CWC sections 13267 and 13383.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR part 122.41(k).)
2. *Signatory requirements for a municipality, State, Federal, or other public agency.* All applications submitted to the Regional Water Board shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR part 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR part 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR part 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 CFR part 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR part 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR part 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR part 122.41(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 CFR part 122.41(l)(4)(i).)
3. If the Permittee monitors any pollutant more frequently than required by this Order using test procedures approved under 40 CFR part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 CFR part 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR part 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR part 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Permittee shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR part 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR part 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR part 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR part 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR part 122.41(l)(6)(iii).)

F. Planned Changes

The Permittee shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR part 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 CFR part 122.41(l)(1)(i)); or

2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 CFR part 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR part 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Permittee shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with this Order's requirements. (40 CFR part 122.41(l)(2).)

H. Other Noncompliance

The Permittee shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR part 122.41(l)(7).)

I. Other Information

When the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Permittee shall promptly submit such facts or information. (40 CFR part 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13268, 13385, 13386, and 13387.
- B. The CWA provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the CWA, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the CWA, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The CWA provides that any person who *negligently* violates sections 301, 302, 306, 307, 308, 318, or 405 of the CWA, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the CWA, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the CWA, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two years, or both. Any person who *knowingly* violates such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both. Any person who *knowingly* violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the CWA, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the CWA, and who knows at that time that he thereby places another person in imminent danger

of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions (40 CFR part 122.41(a)(2); CWC section 13385 and 13387).

- C. Any person may be assessed an administrative penalty by the Administrator of USEPA, the Regional Water Board, or State Water Board for violating section 301, 302, 306, 307, 308, 318 or 405 of this CWA, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the CWA. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000. (40 CFR part 122.41(a)(3))
- D. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. (40 CFR part 122.41(j)(5)).
- E. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both. (40 CFR part 122.41(k)(2)).

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 CFR part 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect Permittee that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR part 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 CFR part 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR part 122.42(b)(3).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Contents

I.	General Monitoring Provisions	E-2
II.	Monitoring Locations	E-4
III.	Influent Monitoring Requirements	E-7
	A. Monitoring Location INF-001	E-7
IV.	Effluent Monitoring Requirements	E-8
	A. Monitoring Location EFF-001	E-8
V.	Whole Effluent Toxicity Testing Requirements	E-13
VI.	Land Discharge Monitoring Requirements (Not Applicable)	E-17
VII.	Recycling Monitoring Requirements	E-17
VIII.	Receiving Water Monitoring Requirements	E-17
	A. Monitoring Location RSW-001 and RSW-002	E-17
	B. TMDL Stream Flow and Rainfall Monitoring	E-20
IX.	Other Monitoring Requirements	E-21
X.	Reporting Requirements	E-25
	A. General Monitoring and Reporting Requirements	E-25
	B. Calleguas Creek TMDL Monitoring and Reporting Requirements	E-25
	C. Self-Monitoring Reports (SMRs)	E-26
	D. Discharge Monitoring Reports (DMRs)	E-28
	E. Other Reports	E-28

Tables

Table E-1.	Monitoring Station Locations	E-5
Table E-2.	Influent Monitoring	E-7
Table E-3.	Effluent Monitoring	E-8
Table E-4.	Salts Monitoring and Reporting Requirements	E-12
Table E-5.	Sediment Monitoring	E-13
Table E-6.	Receiving Water Monitoring Requirements	E-17
Table E-7.	TMDL Stream Flow and Rainfall Monitoring Requirements	E-21
Table E-8.	CEC Monitoring Requirements	E-21
Table E-9.	Monitoring Periods and Reporting Schedule	E-26

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP), (CI-3021)

Section 308(a) of the federal Clean Water Act and sections 122.41(h), (j)-(l), 122.44(i), and 122.48 of Title 40 of the Code of Federal Regulations (40 CFR) requires that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) sections 13267 and 13383 also authorizes the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. This MRP establishes monitoring, reporting, and recordkeeping requirements that implement federal and California laws and/or regulations.

I. GENERAL MONITORING PROVISIONS

- A. All samples shall be representative of the waste discharge under conditions of peak load. Quarterly effluent analyses shall be performed during the months of February, May, August, and November. Semiannual analyses shall be performed during the months of February and August. Annual analyses shall be performed during the month of August. Should there be instances when monitoring could not be done during these specified months, the Permittee must notify the Regional Water Board, state the reason why monitoring could not be conducted, and obtain approval from the Executive Officer for an alternate schedule. Results of monthly, quarterly, semiannual, and annual analyses shall be reported as due date specified in Table E-6 of MRP.
- B. Pollutants shall be analyzed using the analytical methods described in 40 CFR parts 136.3, 136.4, and 136.5; or where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. Laboratories analyzing effluent samples and receiving water samples shall be certified by the California Department of Public Health (CDPH) Environmental Laboratory Accreditation Program (ELAP) or approved by the Executive Officer and must include quality assurance/quality control (QA/QC) data in their reports. A copy of the laboratory certification shall be provided in the Annual Report due to the Regional Water Board each time a new certification and/or renewal of the certification is obtained from ELAP.
- C. Water/wastewater samples must be analyzed within allowable holding time limits as specified in 40 CFR part 136.3. All QA/QC analyses must be run on the same dates that samples are actually analyzed. The Permittee shall retain the QA/QC documentation in its files and make available for inspection and/or submit them when requested by the Regional Water Board. Proper chain of custody procedures must be followed and a copy of that documentation shall be submitted with the monthly report.
- D. The Permittee shall calibrate and perform maintenance procedures on all monitoring instruments and to ensure accuracy of measurements, or shall ensure that both equipment activities will be conducted.
- E. For any analyses performed for which no procedure is specified in the United States Environmental Protection Agency (USEPA) guidelines, or in the MRP, the constituent or parameter analyzed and the method or procedure used must be specified in the monitoring report.
- F. Each monitoring report must affirm in writing that "all analyses were conducted at a laboratory certified for such analyses by the CDPH or approved by the Executive Officer and in accordance with current USEPA guideline procedures or as specified in this Monitoring and Reporting Program."
- G. The monitoring report shall specify the USEPA analytical method used, the Method Detection Limit (MDL), and the Reporting Level (RL) [the applicable minimum level (ML) or reported Minimum Level (RML)] for each pollutant. The MLs are those published by the State Water

Resources Control Board (State Water Board) in the *Policy for the Implementation of Toxic Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California, (State Implementation Policy or SIP)*, February 9, 2005, Appendix 4. The ML represents the lowest quantifiable concentration in a sample based on the proper application of all method-based analytical procedures and the absence of any matrix interference. When all specific analytical steps are followed and after appropriate application of method specific factors, the ML also represents the lowest standard in the calibration curve for that specific analytical technique. When there is deviation from the method analytical procedures, such as dilution or concentration of samples, other factors may be applied to the ML depending on the sample preparation. The resulting value is the reported ML.

- H. The Permittee shall select the analytical method that provides a ML lower than the permit limit established for a given parameter, unless the Permittee can demonstrate that a particular ML is not attainable, in accordance with procedures set forth in 40 CFR part 136, and obtains approval for a higher ML from the Executive Officer, as provided for in section J, below. If the effluent limitation is lower than all the MLs in Appendix 4, SIP, the Discharge must select the method with the lowest ML for compliance purposes. The Permittee shall include in the Annual Summary Report a list of the analytical methods employed for each test.
- I. The Permittee shall instruct its laboratories to establish calibration standards so that the ML (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Permittee to use analytical data derived from extrapolation beyond the lowest point of the calibration curve. In accordance with section J, below, the Permittee's laboratory may employ a calibration standard lower than the ML in Appendix 4 of the SIP.
- J. In accordance with section 2.4.3 of the SIP, the Regional Water Board Executive Officer, in consultation with the State Water Board's Quality Assurance Program Manager, may establish an ML that is not contained in Appendix 4 of the SIP to be included in the Permittee's permit in any of the following situations:
1. When the pollutant under consideration is not included in Appendix 4, SIP;
 2. When the Permittee and the Regional Water Board agree to include in the permit a test method that is more sensitive than those specified in 40 CFR part 136;
 3. When the Permittee agrees to use an ML that is lower than those listed in Appendix 4;
 4. When the Permittee demonstrates that the calibration standard matrix is sufficiently different from that used to establish the ML in Appendix 4 and proposes an appropriate ML for the matrix; or,
 5. When the Permittee uses a method, which quantification practices are not consistent with the definition of the ML. Examples of such methods are USEPA-approved method 1613 for dioxins, and furans, method 1624 for volatile organic substances, and method 1625 for semi-volatile organic substances. In such cases, the Permittee, the Regional Water Board, and the State Water Board shall agree on a lowest quantifiable limit and that limit will substitute for the ML for reporting and compliance determination purposes.
- If there is any conflict between foregoing provisions and the SIP, the provisions stated in the SIP (section 2.4) shall prevail.
- K. If the Permittee samples and performs analyses (other than for process/operational control, startup, research, or equipment testing) on any influent, effluent, or receiving water constituent more frequently than required by this MRP using approved analytical methods, the results of those analyses shall be included in the report. These results shall be reflected in the

calculation of the average used in demonstrating compliance with limitations set forth in this Order.

- L. The Permittee shall develop and maintain a record of all spills or bypasses of raw or partially treated sewage from its collection system or treatment plant according to the requirements in the WDR section of this Order. This record shall be made available to the Regional Water Board upon request and a spill summary shall be included in the annual summary report.
- M. For all bacteriological analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliform, at a minimum, and 1 to 1000 per 100 ml for *enterococcus*). The detection methods used for each analysis shall be reported with the results of the analyses.
 - 1. Detection methods used for coliforms (total and fecal) shall be those presented in Table 1A of 40 CFR part 136, unless alternate methods have been approved in advance by the USEPA pursuant to 40 CFR part 136.
 - 2. Detection methods used for E.coli shall be those presented in Table 1A of 40 CFR part 136 or in the USEPA publication EPA 600/4-85/076, *Test Methods for Escherichia coli and Enterococci in Water By Membrane Filter Procedure*, or any improved method determined by the Regional Water Board to be appropriate.
- N. Since compliance monitoring focuses on the effects of a point source discharge, it is not designed to assess impacts from other sources of pollution (e.g., non-point source run-off, aerial fallout) or to evaluate the current status of important ecological resources on a regional basis.

The Permittee shall participate in the implementation of and comply with the Watershed-wide Monitoring Program developed by stakeholders and initiated in 2008. The City's responsibilities under the Watershed-wide Monitoring Program are described in the Receiving Water Monitoring Requirements section. To achieve the goals of the Watershed-wide Monitoring Program, revisions to the Receiving Water Monitoring Requirements may be made under the direction of USEPA and the Regional Water Board. The Permittee shall submit annual reports providing the monitoring data collected during the calendar year, as well as an interpretation of the significance of the results with respect to the health of the watershed. Annual reports shall be submitted by July 1st of each year. The first annual report covering the period from January 1 to December 31, 2014 should be received in the Regional Water Board office by July 1, 2015.

Changes to the compliance monitoring program may be required to fulfill the goals of the watershed-wide monitoring program, while retaining the compliance monitoring component required to evaluate compliance with the NPDES permit. Revisions to the Permittee's program will be made under the direction of the Regional Water Board, as necessary, to accomplish the goal, and may include a reduction or increase in the number of parameters to be monitored, the frequency of monitoring, and/or the number of samples collected.

Until such time when a watershed-wide monitoring program is developed, Simi Valley WQCP shall implement the monitoring program in section IX.C of this MRP.


II. MONITORING LOCATIONS

The Permittee shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
Influent Monitoring Station		
--	INF-001	Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained.
Effluent Monitoring Stations		
001, 002	EFF-001	The effluent sampling station shall be located downstream of any in-plant return flows and after the final disinfection process, where representative samples of the effluent can be obtained.
Receiving Water Monitoring Stations		
--	RSW-001	(Upstream of Discharge Points 001 and 002). Arroyo Simi, approximately 400 feet east of Discharge Points 001 and 002, approximate coordinates: Latitude 34.28250°, Longitude -118.81167° (previously W-12)
--	RSW-002	(Downstream of Discharge Points 001 and 002). Arroyo Simi, upstream of its confluence with Alamos Canyon, approximate coordinates: Latitude 34.28222°, Longitude -118.81778° (previously W-11)
TMDL Dry- and Wet-Weather Flow Monitoring Station		
--	RSW-003D	<i>Salts TMDL</i> stream flow monitoring station at Calleguas Creek near California State University Channel Islands (CSUCI). For the purposes of this permit, this station is also known as RSW-003D (USGS 11106550).

The North latitude and West longitude information in Table 1 are approximate for administrative purposes.



Simi Valley WQCP Receiving Water Stations

III. INFLUENT MONITORING REQUIREMENTS

Influent monitoring is required to:

- Determine compliance with NPDES permit conditions.
- Assess treatment plant performance.
- Assess effectiveness of the Pretreatment Program.

A. Monitoring Location INF-001

1. The Permittee shall monitor influent to the facility at INF-001 as follows:

Table E-2. Influent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	mgd	recorder	continuous ¹	1
pH	pH unit	grab	weekly	2
Total suspended solids	mg/L	24-hour composite	weekly	2
BOD ₅ 20°C	mg/L	24-hour composite	weekly	2
Remaining USEPA priority pollutants ³ excluding asbestos	µg/L	24-hour composite/grab for VOCs, Cyanide, and Chromium VI	semiannually	2

¹ Total daily flow and instantaneous peak daily flow (24-hr basis). Actual monitored flow shall be reported (not the maximum flow, i.e., design capacity).

² Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Board. For any pollutant whose effluent limitation is lower than all the minimum levels (MLs) specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

³ Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423. PCB as arochlors shall be analyzed using method EPA 608 and PCB as congeners shall be analyzed using method EPA 1668c.

IV. EFFLUENT MONITORING REQUIREMENTS

Effluent monitoring is required to:

- Determine compliance with National Pollutant Discharge Elimination System (NPDES) permit conditions and water quality standards.
- Assess plant performance, identify operational problems and improve plant performance.
- Provide information on wastewater characteristics and flows for use in interpreting water quality and biological data.
- Determine reasonable potential analysis for toxic pollutants.
- Determine TMDL effectiveness in waste load allocation compliance.

A. Monitoring Location EFF-001

1. The Permittee shall monitor the discharge of tertiary-treated effluent at EFF-001 as follows. If more than one analytical test method is listed for a given parameter, the Permittee must select from the listed methods and corresponding Minimum Level:

Table E-3. Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Total waste flow	Mgd	recorder	continuous ⁴	5
Turbidity	NTU	recorder	continuous ⁴	5
Total residual chlorine	mg/L	recorder	continuous ⁶	-
Total residual chlorine	mg/L	grab	daily ⁷	5
Total coliform	MPN/100mL	grab	daily ⁸	5

⁴ Where continuous monitoring of a constituent is required, the following shall be reported:

Total waste flow – Total daily and peak daily flow (24-hr basis);

Turbidity – Maximum daily value, total amount of time each day the turbidity exceeded 5 NTU, flow proportioned average daily value.

⁵ Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Resources Control Board. For any pollutant whose effluent limitation is lower than all the minimum levels (MLs) specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

⁶ Total residual chlorine shall be recorded continuously. The recorded data shall be maintained by the Permittee for at least five years. The Permittee shall extract the maximum daily peak, minimum daily peak, and average daily from the recorded media and shall be made available upon request of the Regional Water Board. The continuous monitoring data are not intended to be used for compliance determination purposes.

⁷ Daily grab samples shall be collected at monitoring location EFF-001, Monday through Friday only, except for holidays. Analytical results of daily grab samples will be used to determine compliance with total residual chlorine effluent limitation. Furthermore, additional monitoring requirements specified in section IV.A.2. shall be followed.

⁸ Daily samples shall be collected Monday to Friday, except for holidays.

E. coli testing shall be conducted only if fecal coliform testing is positive. If the fecal coliform analysis results in no detection, a result of less than (<) the reporting limit for fecal coliform will be reported for E. coli.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
	or CFU/100ml			
Fecal coliform	MPN/100mL or CFU/100ml	grab	daily ⁸	5
E. coli	MPN/100mL or CFU/100ml	grab	daily ⁸	5
Temperature	°F	grab	weekly	5
pH	pH units	grab	weekly	5
Settleable Solids	mL/L	grab	weekly	5
Total Suspended Solids (TSS) ⁹	mg/L	24-hour composite	weekly	5
BOD ₅ 20°C	mg/L	24-hour composite	weekly ¹⁰	5
Oil and grease	mg/L	grab	quarterly	5
Dissolved oxygen	mg/L	grab	quarterly	5
Total Dissolved Solids	mg/L	24-hour composite	monthly	5
Sulfate	mg/L	24-hour composite	monthly	5
Chloride	mg/L	24-hour composite	monthly	5
Boron	mg/L	24-hour composite	monthly	5
Ammonia Nitrogen	mg/L	24-hour composite	monthly	5
Nitrite nitrogen	mg/L	24-hour composite	monthly	5
Nitrate nitrogen	mg/L	24-hour composite	monthly	5
Organic nitrogen	mg/L	24-hour composite	monthly	5
Total nitrogen	mg/L	24-hour composite	monthly	5
Total phosphorus	mg/L	24-hour composite	monthly	5
Surfactants (MBAS)	mg/L	24-hour composite	monthly	5
Surfactants (CTAS)	mg/L	24-hour composite	quarterly	5
Total hardness (CaCO ₃)	mg/L	24-hour composite	monthly	5
Chronic toxicity	Pass or Fail,	24-hour composite	monthly	5, 11

⁹ During each reporting period, if effluent monitoring results show that both the TSS and the Mercury water column final effluent limitations were exceeded, then implementation of the Sediment Monitoring Program is required. Sediment monitoring of the effluent shall begin during the first discharge event following the effluent exceedances.

The mercury effluent samples shall be analyzed using EPA method 1631E, per 40 CFR part 136.

¹⁰ If the result of the weekly BOD analysis yields a value greater than the 30-day average limit, the frequency of analysis shall be increased to daily within one week of knowledge of the test result for at least 30 days and until compliance with the 7-day and 30-day average BOD limits is demonstrated; after which the frequency shall revert to weekly.

¹¹ The Permittee shall conduct whole effluent toxicity monitoring as outlined in section V. The median monthly summary result shall be reported as "Pass" or "Fail". The Maximum Daily Single Result shall be reported as "Pass or Fail" with a "% Effect". During calendar months when there is a discharge more than one day, exactly three independent toxicity tests are required when one toxicity test results in "Fail". The median of three testing results (Fail or Pass) will be used for the determination of compliance with the Median Monthly Effluent Limitation. Please refer to section V.A.7. for the accelerated monitoring schedule.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
	% Effect			
Radioactivity (Including gross alpha, gross beta, combined radium-226 and radium-228, tritium, strontium-90 and uranium)	pCi/L	24-hour composite	semiannually	12
Copper	µg/L	24-hour composite	monthly	5
Mercury ⁹	µg/L	24-hour composite	monthly	5
Nickel	µg/L	24-hour composite	monthly	5
Selenium	µg/L	24-hour composite	monthly	5
Cyanide	µg/L	grab	monthly	5
Zinc	µg/L	24-hour composite	quarterly	5
Bromoform	µg/L	grab	quarterly	5
Dibromochloromethane	µg/L	grab	quarterly	5
Chloroform	µg/L	grab	quarterly	5
Bromodichloromethane	µg/L	grab	quarterly	5
Bis(2-ethylhexyl) Phthalate	µg/L	24-hour composite	quarterly	5
Chlorpyrifos	µg/L	24-hour composite	quarterly	5
Diazinon	µg/L	24-hour composite	quarterly	5
Chlordane	µg/L	24-hour composite	quarterly	5
4,4'-DDD	µg/L	24-hour composite	quarterly	5
4,4'-DDE	µg/L	24-hour composite	quarterly	5
4,4'-DDT	µg/L	24-hour composite	quarterly	5
Dieldrin	µg/L	24-hour composite	quarterly	5
PCBs as arochlors ¹³	µg/L	24-hour composite	quarterly	5, 14
PCBs as congeners ¹⁵	µg/L	24-hour composite	semiannually	5, 14

¹² Analyze these radiochemicals by the following USEPA methods: method 900.0 for gross alpha and gross beta, method 903.0 or 903.1 for radium-226, method 904.0 for radium-228, method 906.0 for tritium, method 905.0 for strontium-90, and method 908.0 for uranium. Analysis for combined Radium-226 & 228 shall be conducted only if gross alpha results for the same sample exceed 15 pCi/L or beta greater than 50 pCi/L. If Radium-226 & 228 exceeds the stipulated criteria, analyze for Tritium, Strontium-90 and uranium.

¹³ PCBs mean the sum of Aroclor 1016, Aroclor 1221, Aroclor 1232, Aroclor 1242, Aroclor 1248, Aroclor 1254, and Aroclor 1260 when monitoring using USEPA method 608.

¹⁴ USEPA recommends that until USEPA proposed method 1668c for PCBs is incorporated into 40 CFR 136, Permittees should use for discharge monitoring reports/State monitoring reports: (1) USEPA method 608 for monitoring data, reported as aroclor results, that will be used for assessing compliance with WQBELs established using the WLAs, and (2) USEPA proposed method 1668c for monitoring data, reported as 41 congener results, that will be used for informational purposes for the established TMDL.

¹⁵ PCBs mean the sum of 41 congeners when monitoring using USEPA proposed method 1668c. PCB-18, 28, 37, 44, 49, 52, 66, 70, 74, 77, 81, 87, 99, 101, 105, 110, 114, 118, 119, 123, 126, 128, 138, 149, 151,

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Toxaphene	µg/L	24-hour composite	quarterly	5
Halomethanes ¹⁶	µg/L	grab	quarterly	5
Antimony	µg/L	24-hour composite	semiannually	5
Arsenic	µg/L	24-hour composite	semiannually	5
Beryllium	µg/L	24-hour composite	semiannually	5
Cadmium	µg/L	24-hour composite	semiannually	5
Chromium III	µg/L	calculation	semiannually	5
Chromium VI	µg/L	grab	semiannually	5
Lead	µg/L	24-hour composite	semiannually	5
Silver	µg/L	24-hour composite	semiannually	5
Thallium	µg/L	24-hour composite	semiannually	5
2,3,7,8-TCDD ¹⁷	µg/L	24-hour composite	semiannually	5
Iron	mg/L	24-hour composite	semiannually	5
Fluoride	mg/L	24-hour composite	semiannually	5
Barium	mg/L	24-hour composite	semiannually	5
Methoxychlor	mg/L	24-hour composite	semiannually	5
2,4-D	mg/L	24-hour composite	semiannually	5
2,4,5-TP (Silvex)	mg/L	24-hour composite	semiannually	5
Perchlorate	µg/L	grab	semiannually	18
1,4-Dioxane	µg/L	grab	semiannually	18
1,2,3-Trichloropropane	µg/L	grab	semiannually	18
Methyl tert-butyl-ether (MTBE)	µg/L	grab	semiannually	18
Remaining USEPA	µg/L	24-hour composite;	semiannually	5

153, 156, 157, 158, 167, 168, 169, 170, 177, 180, 183, 187, 189, 194, 201, and 206 shall be individually quantified.

¹⁶ Halomethanes shall mean the sum of bromoform, bromodichloromethane, chloroform, and dibromochloromethane.

¹⁷ In accordance with the SIP, the Permittee shall conduct effluent monitoring for the seventeen 2,3,7,8-tetrachlorodibenzo-p-dioxin (2,3,7,8-TCDD or dioxin) congeners in the effluent and in the receiving water Station RSW-002, located downstream of the discharge point. The Permittee shall use the appropriate Toxicity Equivalence Factor (TEF) to determine Toxic Equivalence (TEQ). Where TEQ equals the product between each of the 17 individual congeners' (i) concentration analytical result (C_i) and their corresponding Toxicity Equivalence Factor (TEF_i), (i.e., TEQ_i = C_i x TEF_i). Compliance with the Dioxin limitation shall be determined by the summation of the seventeen individual TEQs, or the following equation:

$$\text{Dioxin concentration in effluent} = \sum_{i=1}^{17} (\text{TEQ}_i) = \sum_{i=1}^{17} (C_i) (\text{TEF}_i)$$

¹⁸ Emerging chemicals include 1,4-dioxane (USEPA 8270M test method), perchlorate (USEPA 314 test method, or USEPA method 331 if a detection limit of less than 6 µg/L is achieved), 1,2,3-trichloropropane (USEPA 504.1, 8260B test method, or USEPA 524.2 in SIM mode), and methyl tert-butyl ether (USEPA 8260B test method or USEPA method 624 if a detection level of less than 5 µg/L is achieved, and if the Permittee received ELAP certification to run USEPA method 624).

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
priority pollutants ¹⁹ excluding asbestos		grab for VOCs		

2. Total Residual Chlorine Additional Monitoring

Continuous monitoring of total residual chlorine at EFF-001 shall serve as an internal trigger for the increased grab sampling at EFF-001 if either of the following occurs, except as noted in item c:

- a. Total residual chlorine concentration excursions of up to 0.3 mg/L lasting greater than 15 minutes; or
- b. Total residual chlorine concentration peaks in excess of 0.3 mg/L lasting greater than 1 minute.
- c. Additional grab samples need not be taken if it can be demonstrated that a stoichiometrically appropriate amount of dechlorination chemical has been added to effectively dechlorinate the effluent to 0.1 mg/L or less for peaks in excess of 0.3 mg/L lasting more than 1 minute, but not for more than five minutes.

3. Salts Dry- and Wet-Weather Monitoring and Reporting Requirements

The Discharger shall determine the applicable wet- or dry-weather flow condition at RSW-003D and the amount of rainfall at the time of effluent sampling. The Discharger shall tabulate the date of sampling, average flow at RSW-003D, amount of rainfall, wet- or dry weather, applicable effluent limitation (wet- or dry-weather), and actual effluent concentration/mass.

Table E-4. Salts Monitoring and Reporting Requirements

Parameter	Date of Sampling	Flow (cfs)	Rainfall Amount (inches)	Wet or Dry Weather?	Applicable Effluent Limitation	Actual Effluent Concentration/ Mass
TDS (wet-weather)						
TDS (dry-weather)						
Sulfate (wet-weather)						
Sulfate (dry-weather)						
Chloride (wet-weather)						
Chloride (dry-weather)						
Boron (wet-weather)						
Boron (dry-weather)						

¹⁹ Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423.

4. Sediment Monitoring of Effluent at Monitoring Location EFF-001

The Permittee must sample the discharge at the point following final treatment, prior to entering the receiving water. The exact location of the sampling point must be stipulated in the initial self-monitoring report. All samples shall be tested in accordance with USEPA or ASTM methodologies where such methods exist. Where no USEPA or ASTM methods exist, the State Water Board or Regional Water Board (collectively Water Boards) shall approve the use of other methods. Analytical tests shall be conducted by laboratories certified by the California Department of Public Health in accordance with Water Code Section 13176.

Table E-5. Sediment Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Mercury	mg/kg	grab	1/Year *

* Sediment Monitoring is only required during a reporting period if effluent water column monitoring results for both TSS and Mercury are exceeded. If monitoring is not triggered because both TSS and Mercury limits were not exceeded, then at a minimum, sediment monitoring must occur at least once during the five-year permit term.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Chronic Toxicity Testing

1. Discharge In-stream Waste Concentration (IWC) for Chronic Toxicity

The chronic toxicity IWC for this discharge is 100 percent effluent.

2. Sample Volume and Holding Time

The total sample volume shall be determined by the specific toxicity test method used. Sufficient sample volume shall be collected to perform the required toxicity test. For the receiving water, sufficient sample volume shall also be collected for subsequent TIE studies, if necessary, at each sampling event. All toxicity tests shall be conducted as soon as possible following sample collection. No more than 36 hours shall elapse before the conclusion of sample collection and test initiation.

3. Chronic Freshwater Species and Test Methods

If effluent samples are collected from outfalls discharging to receiving waters with salinity <1 ppt, the Permittee shall conduct the following chronic toxicity tests on effluent samples at the in-stream waste concentration for the discharge in accordance with species and test methods in *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA/821/R-02/013, 2002; Table IA, 40 CFR part 136). In no case shall these species be substituted with another test species unless written authorization from the Executive Officer is received.

- a. A static renewal toxicity test with the fathead minnow, *Pimephales promelas* (Larval Survival and Growth Test Method 1000.0).
- b. A static renewal toxicity test with the daphnid, *Ceriodaphnia dubia* (Survival and Reproduction Test Method 1002.01).
- c. A static renewal toxicity test with the green alga, *Selenastrum capricornutum* (also named *Raphidocelis subcapitata*) (Growth Test Method 1003.0).

4. Species Sensitivity Screening

Species sensitivity screening shall be conducted during this permit's first required sample collection. The Permittee shall collect a single effluent sample and concurrently conduct three toxicity tests using the fish, an invertebrate, and the alga species previously referenced. This sample shall also be analyzed for the parameters required for the discharge. The species that exhibits the highest "Percent Effect" at the discharge IWC during species sensitivity screening shall be used for routine monitoring during the permit cycle.

Species sensitivity rescreening is required every 24 months. The Permittee shall rescreen with the fish, an invertebrate, and the alga species previously referenced and continue to monitor with the most sensitive species. If the first suite of rescreening tests demonstrates that the same species is the most sensitive then the rescreening does not need to include more than one suite of tests. If a different species is the most sensitive or if there is ambiguity, then the Permittee shall proceed with suites of screening tests for a minimum of three, but not to exceed five suites.

5. Quality Assurance and Additional Requirements

Quality assurance measures, instructions, and other recommendations and requirements are found in the test methods manual previously referenced. Additional requirements are specified below.

- a. The discharge is subject to determination of "Pass" or "Fail" and "Percent Effect" from a single-effluent concentration chronic toxicity test at the discharge IWC using the Test of Significant Toxicity (TST) approach described in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010), Appendix A, Figure A-1, and Table A-1. The null hypothesis (H_0) for the TST approach is: Mean discharge IWC response $\leq 0.75 \times$ Mean control response. A test result that rejects this null hypothesis is reported as "Pass". A test result that does not reject this null hypothesis is reported as "Fail". The relative "Percent Effect" at the discharge IWC is defined and reported as: $((\text{Mean control response} - \text{Mean discharge IWC response}) \div \text{Mean control response}) \times 100$.
- b. The Median Monthly Effluent Limit (MMEL) for chronic toxicity only applies when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail".
- c. If the effluent toxicity test does not meet all test acceptability criteria (TAC) specified in the referenced test method, then the Permittee must re-sample and re-test within 14 days.
- d. Dilution water and control water, including brine controls, shall be laboratory water prepared and used as specified in the test methods manual. If dilution water and control water is different from test organism culture water, then a second control using culture water shall also be used.
- e. Monthly reference toxicant testing is sufficient. All reference toxicant test results should be reviewed and reported.
- f. The Permittee shall perform toxicity tests on final effluent samples. Chlorine and ammonia shall not be removed from the effluent sample prior to toxicity testing, unless explicitly authorized under this section of the Monitoring and Reporting Program and the rationale is explained in the Fact Sheet (Attachment F).

6. Preparation of an Initial Investigation TRE Work Plan

The Permittee shall prepare and submit a copy of the Permittee's initial investigation TRE work plan to the Executive Officer of the Regional Water Board for approval within 90 days of the effective date of this permit. If the Executive Officer does not disapprove the work plan within 60 days, the work plan shall become effective. The Permittee shall use USEPA manual EPA/833B-99/002 (municipal) as guidance, or most current version. At a minimum, the TRE Work Plan must contain the provisions in Attachment G. This work plan shall describe the steps that the Permittee intends to follow if toxicity is detected. At minimum, the work plan shall include:

- a. A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
- b. A description of the Facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in the operation of the Facility; and,
- c. If a TIE is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor).

7. Accelerated Monitoring Schedule for Median Monthly Summary Result: "Fail" (or Maximum Daily Single Result: "Fail and % Effect ≥ 50 ").

The summary result shall be used when there is discharge more than one day in a calendar month. The single result shall be used when there is discharge of only one day in a calendar month.

Within 24 hours of the time the Permittee becomes aware of this result, the Permittee shall implement an accelerated monitoring schedule consisting of four, five-concentration toxicity tests (including the discharge IWC), conducted at approximately two week intervals, over an eight week period. If each of the accelerated toxicity tests results in "Pass", the Permittee shall return to routine monitoring for the next monitoring period. If one of the accelerated toxicity tests results in "Fail", the Permittee shall immediately implement the Toxicity Reduction Evaluation (TRE) Process conditions set forth below.

8. Toxicity Reduction Evaluation (TRE) Process

- a. **Preparation and Implementation of Detailed TRE Work Plan.** The Permittee shall immediately initiate a TRE using, according to the type of treatment facility, USEPA manual *Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants* (EPA/833/B-99/002, 1999) and, within 30 days, submit to the Executive Officer a Detailed TRE Work Plan, which shall follow the generic Initial Investigation TRE Work Plan revised as appropriate for this toxicity event. It shall include the following information, and comply with additional conditions set by the Executive Officer:
 - i. Further actions by the Permittee to investigate, identify, and correct the causes of toxicity.
 - ii. Actions the Permittee will take to mitigate the effects of the discharge and prevent the recurrence of toxicity.
 - iii. A schedule for these actions, progress reports, and the final report.
- b. **TIE Implementation.** The Permittee may initiate a TIE as part of a TRE to identify the causes of toxicity using the same species and test method and, as guidance, USEPA manuals: *Methods for Aquatic Toxicity Identification Evaluations: Phase I*

Toxicity Characterization Procedures (EPA/600/6-91/003, 1991); Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity (EPA/600/R-92/080, 1993); Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity (EPA/600/R-92/081, 1993); and Marine Toxicity Identification Evaluation (TIE): Phase I Guidance Document (EPA/600/R-96-054, 1996). The TIE should be conducted on the species demonstrating the most sensitive toxicity response.

- c. Many recommended TRE elements parallel required or recommended efforts for source control, pollution prevention, and storm water control programs. TRE efforts should be coordinated with such efforts. As toxic substances are identified or characterized, the Permittee shall continue the TRE by determining the sources and evaluating alternative strategies for reducing or eliminating the substances from the discharge. All reasonable steps shall be taken to reduce toxicity to levels consistent with toxicity evaluation parameters.
- d. The Permittee shall conduct routine effluent monitoring for the duration of the TRE process. Additional accelerated monitoring and TRE work plans are not required once a TRE is begun.
- e. The Regional Water Board recognizes that toxicity may be episodic and identification of causes and reduction of sources of toxicity may not be successful in all cases. The TRE may be ended at any stage if monitoring finds there is no longer toxicity.

9. Reporting

The Self-Monitoring Report (SMR) shall include a full laboratory report for each toxicity test. This report shall be prepared using the format and content of the test methods manual chapter called Report Preparation, including:

- a. The toxicity test results for the TST approach, reported as "Pass" or "Fail" and "Percent Effect" at the chronic toxicity IWC for the discharge.
- b. Water quality measurements for each toxicity test (e.g., pH, dissolved oxygen, temperature, conductivity, hardness, salinity, chlorine, ammonia).
- c. TRE/TIE results. The Executive Officer shall be notified no later than 30 days from completion of each aspect of TRE/TIE analyses.
- d. Statistical program (e.g., TST calculator, CETIS, etc.) output results for each toxicity test.

B. Ammonia Removal

1. Except with prior approval from the Executive Officer of the Regional Water Board, ammonia shall not be removed from bioassay samples. The Permittee must demonstrate the effluent toxicity is caused by ammonia because of increasing test pH when conducting the toxicity test. It is important to distinguish the potential toxic effects of ammonia from other pH sensitive chemicals, such as certain heavy metals, sulfide, and cyanide. The following may be steps to demonstrate that the toxicity is caused by ammonia and not other toxicants before the Executive Officer would allow for control of pH in the test.
 - a. There is consistent toxicity in the effluent and the maximum pH in the toxicity test is in the range to cause toxicity due to increased pH.

- b. Chronic ammonia concentrations in the effluent are greater than 4 mg/L total ammonia.
 - c. Conduct graduated pH tests as specified in the toxicity identification evaluation methods. For example, mortality should be higher at pH 8 and lower at pH 6.
 - d. Treat the effluent with a zeolite column to remove ammonia. Mortality in the zeolite treated effluent should be lower than the non-zeolite treated effluent. Then add ammonia back to the zeolite-treated samples to confirm toxicity due to ammonia.
2. When it has been demonstrated that toxicity is due to ammonia because of increasing test pH, pH may be controlled using appropriate procedures which do not significantly alter the nature of the effluent, after submitting a written request to the Regional Water Board, and receiving written permission expressing approval from the Executive Officer of the Regional Water Board.

C. Chlorine Removal

- 1. Except with prior approval from the Executive Office of the Regional Water Board, chlorine shall not be removed from bioassay samples.

VI. LAND DISCHARGE MONITORING REQUIREMENTS (NOT APPLICABLE)

VII. RECYCLING MONITORING REQUIREMENTS

The Permittee currently recycles approximately 0.6% (18.25 million gallons per year) of the total treated effluent and plans to continue doing so. Recycled water is used for landscape irrigation at the Simi Valley WQCP and for dust control at a landfill. The production, distribution, and reuse of recycled water are presently regulated under Water Reclamation Requirements (WRR) Order No. 87-46, adopted by this Board on May 5, 1987.

VIII. RECEIVING WATER MONITORING REQUIREMENTS

A. Monitoring Location RSW-001 and RSW-002

- 1. The Permittee shall monitor Arroyo Simi at RSW-001 and RSW-002 as follows:

Table E-6. Receiving Water Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Total flow	Cfs	calculation	monthly	—
Turbidity	NTU	grab	monthly	20
Total residual chlorine	mg/L	grab	monthly	20
E. coli	MPN/100ml or CFU/100ml	grab	monthly	20
Temperature	°F	grab	monthly	20
pH	pH units	grab	monthly	20
Settleable Solids	mL/L	grab	monthly	20
Total Suspended Solids	mg/L	grab	monthly	20

²⁰ Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or State Water Board. For any pollutant whose effluent limitation is lower than all the minimum levels (MLs) specified in Attachment 4 of the SIP, the analytical method with the lowest ML must be selected.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
BOD ₅ 20°C	mg/L	grab	monthly	20
Oil and grease	mg/L	grab	quarterly	20
Dissolved oxygen	mg/L	grab	monthly	20
Conductivity	µmho/cm	grab	monthly	20
Total Dissolved Solids	mg/L	grab	monthly	20
Sulfate	mg/L	grab	monthly	20
Chloride	mg/L	grab	monthly	20
Boron	mg/L	grab	monthly	20
Nitrate nitrogen	mg/L	grab	monthly	20
Nitrite nitrogen	mg/L	grab	monthly	20
Ammonia nitrogen	mg/L	grab	monthly	20
Organic nitrogen	mg/L	grab	monthly	20
Total kjeldahl nitrogen (TKN)	mg/L	grab	monthly	20
Total nitrogen	mg/L	grab	monthly	20
Total phosphorus	mg/L	grab	monthly	20
Orthophosphate-P	mg/L	grab	monthly	20
Algal biomass ²¹	mg/cm ²	grab	annually	20
Surfactants (MBAS)	mg/L	grab	monthly	20
Surfactants (CTAS)	mg/L	grab	quarterly	20
Total hardness (CaCO ₃)	mg/L	grab	monthly	20
Chronic toxicity ²²	Pass or Fail, % Effect	grab	quarterly	20
Copper	µg/L	grab	monthly	20
Mercury	µg/L	grab	monthly	20
Nickel	µg/L	grab	monthly	20
Selenium	µg/L	grab	monthly	20
Cyanide	µg/L	grab	monthly	20
Bromoform	µg/L	grab	quarterly	20
Dibromochloromethane	µg/L	grab	quarterly	20
Chloroform	µg/L	grab	quarterly	20
Bromodichloromethane	µg/L	grab	quarterly	20

²¹ Algal biomass or Chlorophyll A samples shall be collected by obtaining scrapings from the substrate. This will be a measure of benthic algae, rather than algae in the water column. Percent cover shall also be reported. Algal biomass monitoring shall be conducted concurrently with bioassessment monitoring.

²² Refer to section V, Whole Effluent Toxicity Testing Requirements. A toxicity test sample is immediately subject to TIE procedures to identify the toxic chemical(s), if a chronic toxicity test shows "Fail and % Effect value ≥50". The Permittee shall initiate a TIE using, as guidance, EPA manuals: *Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures* (EPA/600/6-91/003, 1991); *Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA/600/R-92/080, 1993); *Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA/600/R-92/081, 1993); and *Marine Toxicity Identification Evaluation (TIE): Phase I Guidance Document* (EPA/600/R-96-054, 1996). The TIE should be conducted on the species demonstrating the most sensitive toxicity response.

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Bis(2-ethyhexyl)Phthalate	µg/L	grab	quarterly	20
Chlorpyrifos	µg/L	grab	quarterly	20
Diazinon	µg/L	grab	quarterly	20
Chlordane	µg/L	grab	quarterly	20
4,4'-DDD	µg/L	grab	quarterly	20
4,4'-DDE	µg/L	grab	quarterly	20
4,4'-DDT	µg/L	grab	quarterly	20
Dieldrin	µg/L	grab	quarterly	20
PCBs as arochlors ²³	µg/L	grab	quarterly	20, 24
PCBs as congeners ²⁵	µg/L	grab	semiannually	20, 24
Toxaphene	µg/L	grab	quarterly	20
Antimony	µg/L	grab	semiannually	20
Arsenic	µg/L	grab	semiannually	20
Beryllium	µg/L	grab	semiannually	20
Cadmium	µg/L	grab	semiannually	20
Chromium III	µg/L	calculation	semiannually	20
Chromium VI	µg/L	grab	semiannually	20
Lead	µg/L	grab	semiannually	20
Silver	µg/L	grab	semiannually	20
Thallium	µg/L	grab	semiannually	20
Zinc	µg/L	grab	semiannually	20
1,4-Dioxane	µg/L	grab	semiannually	26
Perchlorate	µg/L	grab	semiannually	26
1,2,3-Trichloropropane	µg/L	grab	semiannually	26
Methyl tert-butyl-ether (MTBE)	µg/L	grab	semiannually	26
2,3,7,8-TCDD ²⁷	µg/L	grab	semiannually	20

²³ PCBs mean the sum of Aroclor 1016, Aroclor 1221, Aroclor 1232, Aroclor 1242, Aroclor 1248, Aroclor 1254, and Aroclor 1260 when monitoring using USEPA method 608.

²⁴ USEPA recommends that until USEPA proposed method 1668c for PCBs is incorporated into 40 CFR 136, Permittees should use for discharge monitoring reports/State monitoring reports: (1) USEPA method 608 for monitoring data, reported as arochlors results, that will be used for assessing compliance with WQBELs established using the WLAs, and (2) USEPA proposed method 1668c for monitoring data, reported as 41 congener results, that will be used for informational purposes for the established TMDL.

²⁵ PCBs mean the sum of 41 congeners when monitoring using USEPA proposed method 1668c. PCB-18, 28, 37, 44, 49, 52, 66, 70, 74, 77, 81, 87, 99, 101, 105, 110, 114, 118, 119, 123, 126, 128, 138, 149, 151, 153, 156, 157, 158, 167, 168, 169, 170, 177, 180, 183, 187, 189, 194, 201, and 206 shall be individually quantified.

²⁶ Emerging chemicals include 1,4-dioxane (USEPA 8270M test method), perchlorate (USEPA 314 test method, or USEPA method 331 if a detection limit of less than 6 µg/L is achieved), 1,2,3-trichloropropane (USEPA 504.1, 8260B test method, or USEPA 524.2 in SIM mode), and methyl tert-butyl ether (USEPA 8260B test method or USEPA method 624 if a detection level of less than 5 µg/L is achieved, and if the Permittee received ELAP certification to run USEPA method 624).

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Iron	µg/L	grab	semiannually	20
Fluoride	mg/L	grab	semiannually	20
Barium	µg/L	grab	semiannually	20
Methoxychlor	µg/L	grab	semiannually	20
2,4-D	µg/L	grab	semiannually	20
2,4,5-TP (Silvex)	µg/L	grab	semiannually	20
Remaining USEPA priority pollutants ²⁸ excluding asbestos	µg/L	grab	semiannually	20

- Receiving water samples shall not be taken during or within 48-hours following the flow of rainwater runoff into the Arroyo Simi. Sampling may be rescheduled at receiving water stations if weather and/or flow conditions would endanger personnel collecting receiving water samples. The monthly monitoring report shall note such occasions.

B. TMDL Stream Flow and Rainfall Monitoring

- In order to determine the dry- and wet-weather flow conditions in the receiving water, the Permittee shall report the average daily flow at Arroyo Simi collected from an existing stream flow gauging station located at Calleguas Creek near the California State University Channel Islands (USGS 11106550). For the purposes of this permit, this station is also known as RSW-003D. The Permittee shall also report the total daily rainfall from an existing rainfall gauging station located at the Simi Valley WQCP, Station ID: 246A. The stream flow and rainfall gauging stations are operated and maintained by the Ventura County Watershed Protection District. The required stream flow and rainfall data are available online at <http://www.vcwatershed.net/fws/>.

Calleguas Creek Salts TMDL has defined dry-weather as the condition in the receiving water when the flows are below the 86th percentile of the flow and there is no measurable precipitation. The 86th percentile of the flow is equal to 31 cfs, which was calculated using the most recent 10-year stream flow data collected from Calleguas Creek near the California State University Channel Islands (USGS 11106550) stream gauging station. The rainfall precipitation shall be obtained from an existing rainfall gauging station located at the Simi Valley WQCP, Station ID: 246A. If the gauging stations are not operational, an estimated average daily flow and rainfall may be submitted.

²⁷ In accordance with the SIP, the Permittee shall conduct effluent monitoring for the seventeen 2,3,7,8-tetrachlorodibenzo-p-dioxin (2,3,7,8-TCDD or dioxin) congeners in the effluent and in the receiving water Station RSW-002, located downstream of discharge point 001. The Permittee shall use the appropriate Toxicity Equivalence Factor (TEF) to determine Toxic Equivalence (TEQ). Where TEQ equals the product between each of the 17 individual congeners' (i) concentration analytical result (C_i) and their corresponding Toxicity Equivalence Factor (TEF_i), (i.e., TEQ_i = C_i x TEF_i). Compliance with the Dioxin limitation shall be determined by the summation of the seventeen individual TEQs, or the following equation:

$$\text{Dioxin concentration in effluent} = \sum_1^{17} (\text{TEQ}_i) = \sum_1^{17} (C_i)(\text{TEF}_i)$$

²⁸ Priority pollutants are those constituents referred to in 40 CFR part 401.15; a list of these pollutants is provided as Appendix A to 40 CFR part 423.

Table E-7. TMDL Stream Flow and Rainfall Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Average Daily Flow	cubic feet per second (cfs)	On-line data	daily	N/A
Total Daily Rainfall	inches	On-line data	daily	N/A

IX. OTHER MONITORING REQUIREMENTS

A. Calleguas Creek TMDLs Monitoring Requirements

1. The TMDL monitoring program is discussed in section VI.C.2.a. of the Order.

B. Special Study

1. CEC Monitoring in the Effluent

In recent years, the Los Angeles Regional Water Board has incorporated monitoring of a select group of man-made chemicals, particularly pesticides, pharmaceuticals and personal care products, known collectively as CECs, into permits issued to publicly-owned treatment works (POTWs) to better understand the propensity, persistence and effects of CECs in our environment. Recently adopted permits in this region contain requirements for CEC effluent monitoring and submittal of a work plan identifying the CECs to be monitored in the effluent, sample type, sampling frequency and sampling methodology. Based on feedback we have received from permittees and our review of the results of a recent CEC-related study by the Southern California Coastal Water Research Project (SCCWRP) and the State Water Board, we have modified our CEC monitoring program to respond to feedback while proceeding to fill identified data gaps without overly burdening any one permittee.

The Permittee shall conduct a special study to investigate the CECs in the effluent discharge as listed in the Table below. These constituents shall be monitored annually for at least two years. The Regional Water Board has determined that two years is an appropriate time period to determine those CECs that are present in POTW effluent. Monitoring results shall be reported as part of the annual report. Analysis under this section is for monitoring purposes only. Analytical results obtained for this study will not be used for compliance determination purposes, since the methods have not been incorporated in 40 CFR part 136.

Table E-8. CEC Monitoring Requirements

Parameter	Unit	Reporting Limit	Sample Type	Analytical Method ²⁹	Minimum Sampling Frequency
17 α -Ethinyl Estradiol	ng/L	0.5	24-hr composite	EDC Steroid	annually for 2 years
17 β -Estradiol	ng/L	0.5	24-hr composite	EDC Steroid	annually for 2 years
Estrone	ng/L	0.5	24-hr composite	EDC Steroid	annually for 2 years

²⁹ Analytical method may be modified as long as the minimum reporting limit is attained.

Parameter	Unit	Reporting Limit	Sample Type	Analytical Method ²⁹	Minimum Sampling Frequency
Bisphenol A	ng/L	10	24-hr composite	EDC Steroid	annually for 2 years
Nonylphenol & Nonylphenol polyethoxylates	ng/L	100	24-hr composite	EDC Steroid	annually for 2 years
Octylphenol & octylphenol polyethoxylates	ng/L	100	24-hr composite	EDC Steroid	annually for 2 years
Polybrominated diphenyl ethers (PBDE 28, 47, 99, 100, 153, 154, 183, 209)	ng/L	100 for PBDE 209 and 5 for all others	24-hr composite	PBDEs	annually for 2 years
Amoxicillin	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Azithromycin	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Carbamazepine	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Caffeine	ng/L	10	24-hr composite	PPCPs	annually for 2 years
N,N-Diethyl-m-toluamide (DEET)	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Dilantin	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Gemfibrozil	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Ibuprofen	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Iodinated contrast media (iopromide)	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Sulfamethoxazole	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Trimethoprim	ng/L	10	24-hr composite	PPCPs	annually for 2 years
TCEP, TCPP and TDCPP	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Triclosan	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Bifenthrin	ng/L	5	24-hr composite	Pyrethroids	annually for 2 years
Permethrin	ng/L	10	24-hr composite	Pyrethroids	annually for 2 years
Chlorpyrifos	ng/L	10	24-hr composite	Chlorpyrifos	annually for 2

Parameter	Unit	Reporting Limit	Sample Type	Analytical Method ²⁹	Minimum Sampling Frequency
					years
Galaxolide	ng/L	10	24-hr composite	Galaxolide	annually for 2 years
Diclofenac	ng/L	10	24-hr composite	PPCPs	annually for 2 years
Perfluorooctane Sulfonate (PFOS)	ng/L	40	24-hr composite	PFOS	annually for 2 years
Fipronil	ng/L	2	24-hr composite	Fipronil	annually for 2 years
Meprobamate	ng/L	10	24-hr composite	PPCPs	annually for 2 years

C. Watershed Monitoring

1. The goals of the Watershed-wide Monitoring Program for the Calleguas Creek Watershed are to:
 - Determine compliance with receiving water limits.
 - Monitor trends in surface water quality.
 - Ensure protection of beneficial uses.
 - Provide data for modeling contaminants of concern.
 - Characterize water quality including seasonal variation of surface waters within the watershed.
 - Assess the health of the biological community.
 - Determine mixing dynamics of effluent and receiving waters in the estuary.
2. The Permittee shall participate in the implementation of the Watershed-wide Monitoring Program developed by stakeholders and initiated in 2008. The City's responsibilities under the Watershed-wide Monitoring Program are described in the Receiving Water Monitoring Requirements section. To achieve the goals of the Watershed-wide Monitoring Program, revisions to the Receiving Water Monitoring Requirements may be made under the direction of USEPA and the Regional Water Board. The Permittee shall submit annual reports providing the monitoring data collected during the calendar year, as well as an interpretation of the significance of the results with respect to the health of the watershed. Annual reports shall be submitted by July 1st of each year. The first annual report covering the period from January 1 to December 31, 2014 should be received in the Regional Water Board office by July 1, 2015.
3. In coordination with interested stakeholders in the Calleguas Creek Watershed, the Permittee shall conduct bioassessment program annually in the spring/summer period and include an analysis of the community structure of the instream macroinvertebrate assemblages, the community structure of the instream algal assemblages (benthic diatoms and soft-bodied algae), chlorophyll a and biomass for instream algae, and physical habitat assessment at the random monitoring stations designated by the Calleguas Creek Watershed Monitoring Program.

- a. The bioassessment program shall include an analysis of the community structure of the instream macroinvertebrate assemblages and physical habitat assessment at monitoring stations RSW-001 and RSW-002.

This program shall be implemented by appropriately trained staff. Alternatively, a professional subcontractor qualified to conduct bioassessments may be selected to perform the bioassessment work for the Permittee. Analyses of the results of the bioassessment monitoring program, along with photographs of the monitoring site locations taken during sample collection, shall be submitted in the corresponding annual report. If another stakeholder, or interested party in the watershed subcontracts a qualified professional to conduct bioassessment monitoring during the same season and at the same location as specified in the MRP, then the Permittee may, in lieu of duplicative sampling, submit the data, a report interpreting the data, photographs of the site, and related QA/QC documentation in the corresponding annual report.

- b. The Permittee must provide a copy of their Standard Operation Procedures (SOPs) for the Bioassessment Monitoring Program to the Regional Water Board upon request. The document must contain step-by-step field, laboratory and data entry procedures, as well as, related QA/QC procedures. The SOP must also include specific information about each bioassessment program including: assessment program description, its organization and the responsibilities of all its personnel; assessment project description and objectives; qualifications of all personnel; and the type of training each member has received.
- c. Field sampling must conform to the SOP established for the California Stream Bioassessment Procedure (CSBP) or more recently established sampling protocols, such as used by the Surface Water Ambient Monitoring Program (SWAMP). Field crews shall be trained on aspects of the protocol and appropriate safety issues. All field data and sample Chain of Custody (COC) forms must be examined for completion and gross errors. Field inspections shall be planned with random visits and shall be performed by the Permittee or an independent auditor. These visits shall report on all aspects of the field procedure with corrective action occurring immediately.
- d. A taxonomic identification laboratory shall process the biological samples that usually consist of subsampling organisms, enumerating and identifying taxonomic groups and entering the information into an electronic format. The Regional Water Board may require QA/QC documents from the taxonomic laboratories and examine their records regularly. Intra-laboratory QA/QC for subsampling, taxonomic validation and corrective actions shall be conducted and documented. Biological laboratories shall also maintain reference collections, vouchered specimens (the Permittee may request the return of their sample voucher collections) and remnant collections. The laboratory should participate in an (external) laboratory taxonomic validation program at a recommended level of 10% or 20%. External QA/QC may be arranged through the California Department of Fish and Wildlife's Aquatic Bioassessment Laboratory located in Rancho Cordova, California.

4. The Executive Officer of the Regional Water Board may modify Monitoring and Reporting Program to accommodate the watershed-wide monitoring.

D. Tertiary Filter Treatment Bypasses

1. During any day that filters are bypassed, the Permittee shall monitor the effluent for BOD, suspended solids, and settleable solids, on daily basis, until it is demonstrated that the filter "bypass" has not caused an adverse impact on the receiving water.
2. The Permittee shall maintain chronological log of tertiary filter treatment process bypasses, to include the following:
 - a. Date and time of bypass start and end;
 - b. Total duration time; and,
 - c. Estimated total volume bypassed
3. The Permittee shall submit a written report to the Regional Water Board, according to the corresponding monthly self-monitoring report schedule. The report shall include, at a minimum, the information from the chronological log. Results from the daily effluent monitoring, required by D.1. above, shall be verbally reported to the Regional Water Board as the results become available and submitted as part of the monthly SMR.

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Permittee shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. If there is no discharge during any reporting period, the report shall so state.
3. Each monitoring report shall contain a separate section titled "Summary of Non-Compliance" which discusses the compliance record and the corrective actions taken or planned that may be needed to bring the discharge into full compliance with waste discharge requirements. This section shall clearly list all non-compliance with discharge requirements, as well as all excursions of effluent limitations.
4. The Permittee shall inform the Regional Water Board well in advance of any proposed construction activity that could potentially affect compliance with applicable requirements

B. Calleguas Creek TMDL Monitoring and Reporting Requirements

The Calleguas Creek Watershed TMDL Monitoring Plan (CCWTMP) is designed to monitor and evaluate the implementation of this TMDL and refine the understanding of metal and selenium loads. CCWTMP is intended to parallel efforts of the Calleguas Creek Watershed Nutrients TMDL, Toxicity TMDL, and OC Pesticide, PCBs, and Sediment TMDL monitoring programs.

The goals of the CCWTMP include: (1) to determined compliance with copper, mercury, nickel, and selenium numeric targets at receiving water monitoring stations and at POTWs discharges; (2) to determine compliance with waste load allocations for copper, mercury, nickel, and selenium at receiving water monitoring stations and at POTWs Permittee; (3) to monitor the effect of implementation action by urban, POTW, and agricultural Permittees on in-stream water quality; and (4) to implement the CCWTMP in a manner consistent with other TMDL implementation plans and regulatory actions within the Calleguas Creek watershed.

The Permittee shall submit reports to the Regional Water Board as required by the approved CCWTMP.

(See also section VI.C.2.a. of the Order for Monitoring and Reporting Requirements).

C. Self-Monitoring Reports (SMRs)

1. The Permittee shall electronically submit SMRs using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS Web site will provide additional information for SMR submittal in the event there will be a planned service interruption for electronic submittal.
2. The Permittee shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Permittee shall submit monthly, quarterly, semiannual, and annual SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. SMRs are to include all new monitoring results obtained since the last SMR was submitted. If the Permittee monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-9. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	Submit with monthly SMR
Daily	Permit effective date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	Submit with monthly SMR
Weekly	Sunday following permit effective date or on permit effective date if on a Sunday	Sunday through Saturday	Submit with monthly SMR
Monthly	First day of calendar month following permit effective date or on permit effective date if that date is first day of the month	1 st day of calendar month through last day of calendar month	By the 15 th day of the third month after the month of sampling
Quarterly	Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31	June 15 September 15 December 15 March 15
Semiannually	Closest of January 1 or July 1 following (or on) permit effective date	January 1 through June 30 July 1 through December 31	September 15 March 15
Annually	January 1 following (or on) permit effective date	January 1 through December 31	April 15

4. Reporting Protocols. The Permittee shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR part 136.

The Permittee shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ. The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or "ND".
 - d. Permittees are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Permittee to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.
5. Compliance Determination. Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined above and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional Water Board and State Water Board, the Permittee shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the RL).
6. Multiple Sample Data. When determining compliance with an average monthly effluent limitation (AMEL), average weekly effluent limitation (AWEL), or maximum daily effluent limitation (MDEL) for priority pollutants and more than one sample result is available, the Permittee shall compute the arithmetic mean unless the data set contains one or more reported determinations of DNQ or ND. In those cases, the Permittee shall compute the median in place of the arithmetic mean in accordance with the following procedure:
- a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.
7. The Permittee shall submit SMRs in accordance with the following requirements:
- a. The Permittee shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Permittee is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular

format within the system, the Permittee shall electronically submit the data in a tabular format as an attachment.

- b. The Permittee shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify instances of non-compliance or exceedances of effluent limitations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.

D. Discharge Monitoring Reports (DMRs)

- 1. At any time during the term of this permit, the State Water Board or Regional Water Board may notify the Permittee to electronically submit DMRs. Until such notification is given specifically for the submittal of DMRs, the Permittee shall submit DMRs in accordance with the requirements described below.
- 2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Permittee shall submit the original DMR and one copy of the DMR to the address listed below:

STANDARD MAIL	FEDEX/UPS/ OTHER PRIVATE CARRIERS
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814

- 3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1) or on self-generated forms that follow the exact same format of EPA Form 3320-1.

E. Other Reports

- 1. The Permittee shall report the results of any special studies, acute and chronic toxicity testing, TRE/TIE, Pollutant Minimization Program (PMP), and Pollution Prevention Plan required by Special Provisions – section VI.C. The Permittee shall submit reports in compliance with SMR reporting requirements described in subsection X.C. above.

2. Annual Summary Report

By April 15 of each year, the Permittee shall submit an annual report containing a discussion of the previous year's influent/effluent analytical results and receiving water monitoring data. The annual report shall contain an overview of any plans for upgrades to the treatment plant's collection system, the treatment processes, or the outfall system. The Permittee shall submit annual report to the Regional Water Board in accordance with the requirements described in subsection X.C.7 above.

Each annual monitoring report shall contain a separate section titled "Reasonable Potential Analysis" which discusses whether or not reasonable potential was triggered for pollutants which do not have a final effluent limitation in the NPDES permit. This section shall contain the following statement: "The analytical results for this sampling period did/did not trigger reasonable potential." If reasonable potential was triggered, then the following information should also be provided:

- a. A list of the pollutant(s) that triggered reasonable potential.
- b. The Basin Plan or CTR criteria that was exceeded for each given pollutant.

- c. The concentration of the pollutant(s).
 - d. The test method used to analyze the sample.
 - e. The date and time of sample collection.
3. The Permittee shall submit to the Regional Water Board, together with the first monitoring report required by this permit, a list of all chemicals and proprietary additives which could affect this waste discharge, including quantities of each. Any subsequent changes in types and/or quantities shall be reported promptly.
 4. The Regional Water Board requires the Permittee to file with the Regional Water Board, within 90 days after the effective date of this Order, a technical report on his preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. The technical report should:
 - a. Identify the possible sources of accidental loss, untreated waste bypass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks, and pipes should be considered.
 - b. Evaluate the effectiveness of present facilities and procedures and state when they become operational.
 - c. Describe facilities and procedures needed for effective preventive and contingency plans.
 - d. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule contingent interim and final dates when they will be constructed, implemented, or operational.

ATTACHMENT F – FACT SHEET

Contents

I.	Permit Information	F-3
II.	Facility Description	F-4
	A. Description of Wastewater and Biosolids Treatment and Controls	F-4
	B. Discharge Points and Receiving Waters	F-5
	C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data	F-5
	D. Compliance Summary	F-10
	E. Planned Changes	F-11
III.	Applicable Plans, Policies, and Regulations	F-11
	A. Legal Authorities	F-11
	B. California Environmental Quality Act (CEQA)	F-11
	C. State and Federal Laws, Regulations, Policies, and Plans	F-11
	D. Impaired Water Bodies on CWA 303(d) List	F-18
	E. Other Plans, Policies and Regulations	F-18
IV.	Rationale For Effluent Limitations and Discharge Specifications	F-23
	A. Discharge Prohibitions	F-23
	B. Technology-Based Effluent Limitations (TBELs)	F-23
	1. Scope and Authority	F-23
	2. Applicable TBELs	F-23
	C. Water Quality-Based Effluent Limitations (WQBELs)	F-24
	1. Scope and Authority	F-24
	2. Applicable Beneficial Uses and Water Quality Criteria and Objectives	F-25
	3. Determining the Need for WQBELs	F-33
	4. WQBEL Calculations	F-38
	5. Whole Effluent Toxicity (WET)	F-43
	D. Final Effluent Limitation Considerations	F-44
	1. Anti-Backsliding Requirements	F-44
	2. Antidegradation Policies	F-45
	3. Stringency of Requirements for Individual Pollutants	F-46
	E. Interim Effluent Limitations	F-49
	F. Land Discharge Specifications – Not Applicable	F-49
	G. Recycling Specifications	F-49
V.	Rationale for Receiving Water Limitations	F-49
	A. Surface Water	F-49
	B. Groundwater	F-49
VI.	Rationale for Provisions	F-50
	A. Standard Provisions	F-50
	B. Special Provisions	F-50
	1. Reopener Provisions	F-50
	2. Special Studies and Additional Monitoring Requirements	F-50
	3. Best Management Practices and Pollution Prevention	F-51
	4. Construction, Operation, and Maintenance Specifications	F-51
	5. Special Provisions for Municipal Facilities (POTWs Only)	F-51
	6. Other Special Provisions (Not Applicable)	F-52
	7. Compliance Schedules (Not Applicable)	F-52
VII.	Rationale for Monitoring and Reporting Requirements	F-52
	A. Influent Monitoring	F-52

B.	Effluent Monitoring	F-52
C.	WET Requirements.....	F-55
D.	Receiving Water Monitoring.....	F-55
	1. Surface Water	F-55
	2. Groundwater – (Not Applicable).....	F-55
E.	Other Monitoring Requirements	F-55
	1. Watershed Monitoring and Bioassessment Monitoring	F-55
VIII.	Consideration of Need to Prevent Nuisance and CWC Section 13241 Factors	F-55
IX.	Public Participation.....	F-57
	A. Notification of Interested Parties	F-57
	B. Written Comments	F-57
	C. Public Hearing	F-58
	D. Reconsideration of Waste Discharge Requirements	F-58
	E. Information and Copying	F-58
	F. Register of Interested Persons.....	F-58
	G. Additional Information	F-58

Tables

Table F-1.	Facility Information.....	F-3
Table F-2.	Historic Effluent Limitations and Monitoring Data.....	F-5
Table F-3.	Basin Plan Beneficial Uses – Receiving Waters	F-13
Table F-4.	Basin Plan Beneficial Uses – Ground Waters	F-14
Table F-5.	Summary of TBELs.....	F-23
Table F-6.	Summary of Reasonable Potential Analysis.....	F-34
Table F-7.	Summary of WQBELs for Discharge Points 001 and 002	F-40
Table F-8.	Summary of Final Effluent Limitations for Discharge Points 001 and 002	F-46
Table F-9.	Monitoring Frequency Comparison.....	F-53

ATTACHMENT F – FACT SHEET

As described in section IIB of this Order, the Regional Water Board incorporates this Fact Sheet as findings of the Regional Water Board supporting the issuance of this Order. This Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Permittees in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Permittee. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Permittee.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

WDID	4A560110001
Discharger	City of Simi Valley
Name of Facility	Simi Valley Water Quality Control Plant
Facility Address	600 West Los Angeles Avenue
	Simi Valley, CA 93065
	Ventura County
Facility Contact, Title and Phone	James F. Langley, Deputy Director/Sanitations Services, (805) 583-6443
Authorized Person to Sign and Submit Reports	James F. Langley, Deputy Director/Sanitations Services, (805) 583-6443
Mailing Address	2929 Tapo Canyon Road, Simi Valley, CA 93063
Billing Address	Same as Mailing Address
Type of Facility	POTW
Major or Minor Facility	Major
Threat to Water Quality	1
Complexity	A
Pretreatment Program	Y
Recycling Requirements	Producer/User
Facility Permitted Flow	12.5 million gallons per day (mgd)
Facility Design Flow	12.5 mgd
Watershed	Calleguas Creek
Receiving Water	Arroyo Simi
Receiving Water Type	Inland surface water

- A. The City of Simi Valley (The City or Permittee) owns and operates a publicly-owned treatment works (POTW) comprised of Simi Valley Water Quality Control Plant (Simi Valley WQCP or Facility) and its associated wastewater collection system and outfalls.

For the purposes of this Order, references to the “Permittee” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Permittee herein.

- B. The Facility discharges wastewater to Arroyo Simi, a water of the United States, within Calleguas Creek Watershed. The Permittee was previously regulated by Order R4-2003-0081 and NPDES Permit No. CA0055221 adopted on June 5, 2003, and expired on June 5, 2008. Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.
- C. The Permittee filed a report of waste discharge and submitted an application for reissuance of its WDRs and NPDES permit on November 22, 2013. Supplemental information was requested via email on December 27, 2013, and received on January 13, 2014. The application was deemed complete on March 12, 2014. A site visit was conducted on April 1, 2014, to observe operations and collect additional data to develop permit limitations and requirements for waste discharge.

II. FACILITY DESCRIPTION

A. Description of Wastewater and Biosolids Treatment and Controls

1. The Simi Valley WQCP is a tertiary wastewater treatment plant with a dry weather design capacity of 12.5 mgd and serves an estimated population of 126,300 people. The Simi Valley WQCP receives wastewater from the City of Simi Valley and unincorporated sections of Ventura County.

Pretreatment Program: The wastewater is a mixture of domestic wastewater and industrial wastewater that is pre-treated pursuant to 40 CFR part 403. The City of Simi Valley modified the City's Pretreatment Program and was adopted by the Regional Water Board on June 2, 2011. The updated Pretreatment Program includes revised Sewer Use Ordinance with local limits and Enforcement Response Plan.

The City of Simi Valley currently consists of 510 permitted nondomestic dischargers. There are eight significant industrial users (SIUs). Three of them are categorical industrial users (CIUs). The City also has fats, oils, and grease (FOG) control program and conducts periodic inspections of its restaurants. In 2013, the City conducted 1,072 inspections, collected and analyzed 389 samples. The City also issued 29 Initial Notices of Violation and 13 Notices of Violation.

2. Treatment at the Simi Valley WQCP consists of primary sedimentation, activated sludge biological treatment with nitrification and denitrification, secondary sedimentation, dual media filtration, chlorination, and dechlorination. Treated wastewater discharged to Arroyo Simi is dechlorinated but the effluent delivered for reuse is not dechlorinated.
3. Sodium hypochlorite is used as a disinfectant in the Simi Valley WQCP. The disinfectant is dosed prior to the serpentine chlorine contact chamber and occasionally added prior to the filters to minimize algae growth. Additional disinfectant may be dosed prior to the serpentine chlorine contact chamber. Prior to discharge, sodium bisulfite is added to the treated effluent to remove residual chlorine.
4. Primary sludge is anaerobically digested. Sewage solids (sludge) separated from the wastewater are dewatered with a press and transported to Simi Valley Landfill, Simi Valley, California.
5. Simi Valley WQCP has constructed a biological nutrient removal system with nitrification de-nitrification process (NDN) in order to achieve compliance with the ammonia Basin Plan objectives. The system was completed and has been in operation since September 2004. However, the NDN did not achieve the design objectives for nitrate + nitrite as nitrogen. The Permittee modified the NDN process and completed the modification on April 30, 2009.

B. Discharge Points and Receiving Waters

The Simi Valley WQCP discharges tertiary-treated municipal and industrial wastewater to Arroyo Simi. Treated effluents are discharged from the plant to surface waters at the following discharge points:

Discharge Point 001: Discharge to Arroyo Simi (approximate coordinates: Latitude 34.28222°, Longitude -118.81222°).

Discharge Point 002: Discharge to Arroyo Simi (approximate coordinates: Latitude 34.28222°, Longitude -118.81278°). This is an alternate downstream outfall that has never been used. It was provided as a backup discharge point in the event that discharge through Discharge Point 001 is restricted because of flooding in the Arroyo Simi. Discharge Point 002 is 225 feet downstream of Discharge Point 001.

During dry weather (May 1 – October 31), the primary sources of water flow in the receiving waters, downstream of the discharge point, is the Simi Valley WQCP effluent and other NPDES-permitted discharges, including urban runoff conveyed through the municipal separate storm sewer systems (MS4). Storm water and dry weather urban runoff from MS4 are regulated under an NPDES permit, Waste Discharge Requirements for Municipal Storm Water and Urban Runoff Discharges within the Ventura County Watershed Protection District (formerly known as Ventura County Flood Control District), County of Ventura, and the Cities of Ventura County (Ventura Municipal Permit), NPDES Permit No. CAS004002. During dry weather, surface water flow usually percolates to groundwater before the surface flow reaches Hitch Boulevard in the City of Moorpark, past the Moorpark Wastewater Treatment Plant. Some effluent may reach Seminary Road during parts of the year. The Moorpark WWTP is another POTW in Calleguas Creek Watershed, located downstream of the Simi Valley WQCP, that intermittently discharges to Arroyo Las Posas (tributary to Arroyo Simi).

The Ventura County Watershed Protection District channelized portions of Calleguas Creek to convey and control floodwater, and to prevent damage to homes located adjacent to the Creek. Calleguas Creek is a water of the United States that conveys floodwater and urban runoff, along with treated waste water. Arroyo Simi is unlined near the point of discharge. Groundwater recharge may occur incidentally in these unlined areas of Arroyo Simi, Arroyo Las Posas, and Calleguas Creek, where the underlying sediments maybe transmissive to water as well as pollutants.

Notwithstanding that segments located further downstream of the discharge are concrete-lined, the watershed supports a diversity of wildlife. Threatened and endangered species such as the peregrine falcon, least tern, light-footed clapper rail, and the brown pelican are found in Calleguas Creek and Mugu Lagoon.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in the existing Order for discharges from Discharge Point 001 (Monitoring Location EFF-001) and representative monitoring data from the term of the previous Order as reported in the ROWD, are as follows:

Table F-2. Historic Effluent Limitations and Monitoring Data

Parameter	Units	Effluent Limitation (Order No. R4-2003-0081)			Monitoring Data (From 01/01/2008 To 10/31/2013)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
BOD ₅ 20°C	mg/L	20	30	45	9.7	2.5	18.9

Parameter	Units	Effluent Limitation (Order No. R4-2003-0081)			Monitoring Data (From 01/01/2008 To 10/31/2013)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Total Suspended Solids (TSS)	mg/L	15	40	45	3.1	2.8	10.6
Oil and Grease	mg/L	10	--	15	<5	--	<5
Settleable Solids	ml/L	0.1	--	0.3	<0.1	--	< 0.1
Residual Chlorine	mg/L	--	--	0.1	<0.1	--	<0.1
Total Dissolved Solids	mg/L	850	--	--	1055	--	1055
MBAS	mg/L	0.5	--	--	<0.5	--	<0.5
Chloride	mg/L	150	--	--	256	--	256
Sulfate	mg/L	250	--	--	342	--	342
Boron	mg/L	1	--	--	0.9	--	0.9
Fluoride	mg/L	1.6	--	--	0.8	--	0.8
Nitrite-N (as N)	mg/L	0.9	--	--	0.32	--	0.32
Nitrate + Nitrite as N	mg/L	9	--	--	8.8	--	8.8
Total Ammonia	mg/L	2.35	--	--	<1	--	<1
Antimony	µg/L	6	--	--	1.1	--	1.1
Arsenic	µg/L	50	--	--	9	--	9
Beryllium	µg/L	--	--	--	ND	--	ND
Cadmium	µg/L	5	--	--	3.1	--	3.1
Chromium III	µg/L	--	--	--	1.2	--	1.2
Chromium VI	µg/L	50	--	--	9.9	--	9.9
Copper	µg/L	1000	--	--	30	--	30
Lead	µg/L	50	--	--	6	--	6
Mercury	µg/L	2	--	--	1.7	--	1.7
Nickel	µg/L	100	--	--	10	--	10
Selenium	µg/L	4.1	--	--	4.5	--	4.5
Silver	µg/L	50	--	--	10	--	10
Thallium	µg/L	2	--	--	ND<2	--	ND<2
Zinc	µg/L	5000	--	--	120	--	120
Cyanide	µg/L	3.9	--	--	9.8	--	9.8
Asbestos	µg/L	--	--	--	--	--	--
2,3,7,8-TCDD (Dioxin)	µg/L	--	--	--	< 0.000006	--	< 0.000006
Acrolein	µg/L	--	--	--	ND< 10	--	ND< 10
Acrylonitrile	µg/L	--	--	--	ND< 20	--	ND< 20
Benzene	µg/L	--	--	--	ND< 0.5	--	<ND 0.5
Bromoform	µg/L	--	--	--	2.8	--	2.8
Carbon Tetrachloride	µg/L	--	--	--	ND< 0.5	--	ND< 0.5
Chlorobenzene	µg/L	--	--	--	ND	--	ND

Parameter	Units	Effluent Limitation (Order No. R4-2003-0081)			Monitoring Data (From 01/01/2008 To 10/31/2013)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Dibromochloromethane	µg/L	--	--	--	22	--	22
Chloroethane	µg/L	--	--	--	ND< 1	--	ND< 1
2-chloroethyl vinyl ether	µg/L	--	--	--	ND< 10	--	ND< 10
Chloroform	µg/L	--	--	--	46	--	46
Dichlorobromomethane	µg/L	--	--	--	35.1	--	35.1
1,1-dichloroethane	µg/L	--	--	--	ND< 1	--	ND< 1
1,2-dichloroethane	µg/L	--	--	--	ND< 0.5	--	ND< 0.5
1,1-dichloroethylene	µg/L	--	--	--	ND< 1	--	ND< 1
1,2-dichloropropane	µg/L	--	--	--	ND< 1	--	ND< 1
1,3-dichloropropylene	µg/L	--	--	--	ND< 1	--	ND< 1
Ethylbenzene	µg/L	--	--	--	ND< 1	--	ND< 1
Methyl bromide	µg/L	--	--	--	0.5	--	0.5
Methyl chloride	µg/L	--	--	--	29	--	29
Methylene chloride	µg/L	--	--	--	ND< 0.4	--	ND< 0.4
1,1,2,2-tetrachloroethane	µg/L	--	--	--	ND< 1	--	ND< 1
Tetrachloroethylene	µg/L	5	--	--	0.9	--	0.9
Toluene	µg/L	--	--	--	ND< 0.3	--	ND< 0.3
Trans 1,2-Dichloroethylene	µg/L	--	--	--	< 1	--	< 1
1,1,1-Trichloroethane	µg/L	--	--	--	< 1	--	< 1
1,1,2-Trichloroethane	µg/L	--	--	--	< 1	--	< 1
Trichloroethylene	µg/L	--	--	--	< 1	--	< 1
Vinyl Chloride	µg/L	--	--	--	< 0.5	--	< 0.5
2-chlorophenol	µg/L	--	--	--	< 5	--	< 5
2,4-dichlorophenol	µg/L	--	--	--	< 5	--	< 5
2,4-dimethylphenol	µg/L	--	--	--	< 2	--	< 2
4,6-dinitro-o-resol(aka 2-methyl-4,6-Dinitrophenol)	µg/L	--	--	--	< 5	--	< 5
2,4-dinitrophenol	µg/L	--	--	--	< 5	--	< 5
2-nitrophenol	µg/L	--	--	--	< 10	--	< 10
4-nitrophenol	µg/L	--	--	--	< 10	--	< 10

Parameter	Units	Effluent Limitation (Order No. R4-2003-0081)			Monitoring Data (From 01/01/2008 To 10/31/2013)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
3-Methyl-4-Chlorophenol (aka 4-chloro-m-cresol)	µg/L	--	--	--	< 1	--	< 1
Pentachlorophenol	µg/L	--	--	--	< 3	--	< 5
Phenol	µg/L	--	--	--	10	--	10
2,4,6-trichlorophenol	µg/L	--	--	--	0.21	--	0.21
Acenaphthene	µg/L	--	--	--	< 1	--	< 1
Acenaphthylene	µg/L	--	--	--	< 10	--	< 10
Anthracene	µg/L	--	--	--	< 10	--	< 10
Benzidine	µg/L	--	--	--	< 5	--	< 5
Benzo(a)Anthracene	µg/L	--	--	--	< 5	--	< 5
Benzo(a)Pyrene	µg/L	--	--	--	< 0.02	--	< 0.02
Benzo(b)Fluoranthene	µg/L	--	--	--	< 0.02	--	< 0.02
Benzo(ghi)Perylene	µg/L	--	--	--	< 5	--	< 5
Benzo(k)Fluoranthene	µg/L	--	--	--	< 0.02	--	< 0.02
Bis(2-Chloroethoxy)methane	µg/L	--	--	--	< 5	--	< 5
Bis(2-Chloroethyl)Ether	µg/L	--	--	--	< 1	--	< 1
Bis(2-Chloroisopropyl)Ether	µg/L	--	--	--	< 2	--	< 2
Bis(2-Ethylhexyl)Phthalate	µg/L	--	--	--	< 1	--	< 1
4-Bromophenyl Phenyl Ether	µg/L	--	--	--	< 5	--	< 5
Butylbenzyl Phthalate	µg/L	--	--	--	< 10	--	< 10
2-Chloronaphthalene	µg/L	--	--	--	< 10	--	< 10
4-Chlorophenyl Phenyl Ether	µg/L	--	--	--	< 5	--	< 5
Chrysene	µg/L	--	--	--	< 0.02	--	< 0.02
Dibenzo(a,h)Anthracene	µg/L	--	--	--	< 0.02	--	< 0.02
1,2-Dichlorobenzene	µg/L	--	--	--	< 2	--	< 2
1,3-Dichlorobenzene	µg/L	--	--	--	< 1	--	< 1

Parameter	Units	Effluent Limitation (Order No. R4-2003-0081)			Monitoring Data (From 01/01/2008 To 10/31/2013)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
1,4-Dichlorobenzene	µg/L	5	--	--	< 0.5	--	< 0.5
3,3'-Dichlorobenzidine	µg/L	--	--	--	< 5	--	< 5
Diethyl Phthalate	µg/L	--	--	--	0.27	--	0.27
Dimethyl Phthalate	µg/L	--	--	--	< 2	--	< 2
Di-n-Butyl Phthalate	µg/L	--	--	--	0.32	--	0.32
2,4-Dinitrotoluene	µg/L	--	--	--	< 5	--	< 5
2,6-Dinitrotoluene	µg/L	--	--	--	0.68	--	0.68
Di-n-Octyl Phthalate	µg/L	--	--	--	< 10	--	< 10
1,2-Diphenylhydrazine	µg/L	--	--	--	< 1	--	< 1
Fluoranthene	µg/L	--	--	--	< 1	--	< 1
Fluorene	µg/L	--	--	--	< 10	--	< 10
Hexachlorobenzene	µg/L	--	--	--	< 1	--	< 1
Hexachlorobutadiene	µg/L	--	--	--	< 1	--	< 1
Hexachlorocyclopentadiene	µg/L	--	--	--	< 5	--	< 5
Hexachloroethane	µg/L	--	--	--	< 1	--	< 1
Indeno(1,2,3-cd)Pyrene	µg/L	--	--	--	< 0.02	--	< 0.02
Isophorone	µg/L	--	--	--	1	--	1
Naphthalene	µg/L	--	--	--	< 1	--	< 1
Nitrobenzene	µg/L	--	--	--	< 1	--	< 1
N-Nitrosodimethylamine	µg/L	--	--	--	< 5	--	< 5
N-Nitrosodi-n-Propylamine	µg/L	--	--	--	< 20	--	< 20
N-Nitrosodiphenylamine	µg/L	--	--	--	< 1	--	< 1
Phenanthrene	µg/L	--	--	--	< 5	--	< 5
Pyrene	µg/L	--	--	--	< 10	--	< 10
1,2,4-Trichlorobenzene	µg/L	--	--	--	< 5	--	< 5
Aldrin	µg/L	--	--	--	< 0.01	--	< 0.01
Alpha-BHC	µg/L	--	--	--	< 0.01	--	< 0.01
Beta-BHC	µg/L	--	--	--	< 0.01	--	< 0.01

Parameter	Units	Effluent Limitation (Order No. R4-2003-0081)			Monitoring Data (From 01/01/2008 To 10/31/2013)		
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Gamma-BHC (aka Lindane)	µg/L	0.2	--	--	0.00392	--	0.00392
delta-BHC	µg/L	--	--	--	< 0.01	--	< 0.01
Chlordane	µg/L	--	--	--	< 0.05	--	< 0.05
4,4'-DDT	µg/L	--	--	--	< 0.01	--	< 0.01
4,4'-DDE	µg/L	0.00059	--	--	0.0051	--	0.0051
4,4'-DDD	µg/L	--	--	--	< 0.01	--	< 0.01
Dieldrin	µg/L	--	--	--	< 0.01	--	< 0.01
Alpha-Endosulfan	µg/L	--	--	--	< 0.01	--	< 0.01
Beta-Endosulfan	µg/L	--	--	--	< 0.01	--	< 0.01
Endosulfan Sulfate	µg/L	--	--	--	< 0.1	--	< 0.1
Endrin	µg/L	2	--	--	0.04	--	0.04
Endrin Aldehyde	µg/L	--	--	--	< 0.04	--	< 0.04
Heptachlor	µg/L	--	--	--	< 0.01	--	< 0.01
Heptachlor Epoxide	µg/L	--	--	--	< 0.05	--	< 0.05
PCB 1016	µg/L	--	--	--	< 0.1	--	< 0.1
PCB 1221	µg/L	--	--	--	< 0.5	--	< 0.5
PCB 1232	µg/L	--	--	--	< 0.3	--	< 0.3
PCB 1242	µg/L	--	--	--	< 0.1	--	< 0.1
PCB 1248	µg/L	--	--	--	< 0.1	--	< 0.1
PCB 1254	µg/L	--	--	--	< 0.05	--	< 0.05
PCB 1260	µg/L	--	--	--	< 0.1	--	< 0.1
Toxaphene	µg/L	3	--	--	1.9	--	1.9
Barium	µg/L	1000	--	--	129	--	129
Iron	µg/L	300	--	--	143	--	143
Methoxychlor	µg/L	40	--	--	10	--	10
2,4-D	µg/L	70	--	--	2	--	2
2,4,5-TP (Sylvex)	µg/L	10	--	--	3	--	3
Halomethanes	µg/L	80	--	--	25.5	--	25.5

D. Compliance Summary

On February 11, 2010, the Regional Water Board issued the City of Simi Valley Settlement Offer No. R4-2010-0014-M for \$9,000 for violation of effluent limitations for selenium and cyanide contained in Regional Water Board Order No. R4-2003-0081. On April 13, 2010, City of Simi Valley accepted the Regional Water Board's offer to participate in the Expedited Payment Program and waived their right to a hearing. On June 3, 2010, the Regional Water Board received the Permittee's full payment as required by the Expedited Payment Program.

On April 25, 2011, the Regional Water Board issued the City of Simi Valley Settlement Offer No. R4-2011-0084-M for \$60,000 for violation of effluent limitations for selenium, total residual chlorine, and oil and grease contained in Regional Water Board Order No. R4-2003-0081. On

May 24, 2011, the Regional Water Board received the signed Acceptance of Conditional Resolution and Waiver of Right to a Hearing. On July 22, 2011, the Regional Water Board received the Permittee's full payment as required by the Expedited Payment Program.

The prior permit for this facility, Order No. R4-2003-0081, included an effluent limitation for selenium of 1.6 µg/L as monthly average. This limit appears to have been calculated in error. The City of Simi Valley did not identify the error at the time of permit adoption or at the time the Regional Water Board issued the settlement offers for violations of the limit in 2010 and 2011. The City of Simi Valley accepted responsibility for the violations and waived its right to a hearing. The effluent limitation for selenium has been corrected in this Order.

E. Planned Changes

Simi Valley WQCP has constructed a biological nutrient removal system with nitrification denitrification process (NDN) in order to achieve compliance with the ammonia Basin Plan objectives. The system was completed and has been in operation since September 2004. However, the NDN did not achieve the design objectives for nitrate + nitrite as nitrogen. The Permittee modified the NDN process and completed the modification on April 30, 2009. Since completion, the facility has been in compliance with the effluent limitation for nitrate + nitrite as nitrogen.

There are no planned upgrades proposed by the Permittee.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order serves as WDRs pursuant to article 4, chapter 4, division 7 of the California Water Code (CWC; commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the United States Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the CWC (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters.

B. California Environmental Quality Act (CEQA)

Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of Chapter 3 of CEQA, (commencing with section 21100) of Division 13 of the Public Resources Code.

C. State and Federal Laws, Regulations, Policies, and Plans

- 1. Water Quality Control Plan.** The Regional Water Board adopted a Water Quality Control Plan for the Los Angeles Region (Basin Plan) on June 4, 1994 that designates beneficial uses, establishes water quality objectives (WQOs), and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Requirements in this Order implement the Basin Plan. In addition, the Basin Plan implements State Water Board Resolution 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. On May 26, 2000, the USEPA approved the revised Basin Plan except for the implementation plan for potential MUN-designated water bodies. On August 22, 2000, the City of Los Angeles, City of Burbank, City of Simi Valley, and the County Sanitation Districts of Los Angeles County challenged USEPA's water quality standards action in the U.S. District Court. On December 18, 2011, the court issued an order remanding the matter to USEPA to take

further action on the 1994 Basin Plan consistent with the court's decision. On February 15, 2002, USEPA revised its decision and approved the 1994 Basin Plan in whole. In its February 15, 2002 letter, USEPA stated:

EPA bases its approval on the court's finding that the Regional Board's identification of waters with an asterisk ("*") in conjunction with the implementation language at page 2-4 of the 1994 Basin Plan, was intended "to only conditionally designate and not finally designate as MUN those water bodies identified by an (*) for the MUN use in Table 2-1 of the Basin Plan, without further action." Court Order at p. 4. Thus, the waters identified with an (*) in Table 2-1 do not have MUN as a designated use until such time as the State undertakes additional study and modifies its Basin Plan. Because this conditional use designation has no legal effect, it does not constitute a new water quality standard subject to EPA review under section 303(c)(3) of the Clean Water Act ("CWA"). 33 U.S.C. § 1313(c)(3).

USEPA's decision has no effect on the MUN designations of groundwater. Beneficial uses applicable to Arroyo Simi and Calleguas Creek are as follows:

Table F-3. Basin Plan Beneficial Uses – Receiving Waters

Discharge Point	Receiving Water Name	Beneficial Use(s)
001, 002	Arroyo Simi (Hydro. Unit No. 403.62)	<p>Existing: Wildlife habitat (WILD); and rare, threatened, or endangered species (RARE).</p> <p>Intermittent: Industrial service supply (IND); ground water recharge (GWR); freshwater replenishment (FRSH); water contact recreation (REC-1); non-contact water recreation (REC-2); and warm freshwater habitat (WARM).</p> <p>Potential: Municipal and domestic water supply (MUN¹).</p>
001, 002	Arroyo Las Posas (Hydro. Unit No. 403.62)	<p>Existing: (GWR), (FRSH), (REC-1), (REC-2), (WARM), and (WILD).</p> <p>Intermittent: none</p> <p>Potential: (MUN¹), (IND), industrial process supply (PROC), agricultural supply (AGR), and cold freshwater habitat (COLD).</p>
001, 002	Arroyo Las Posas (Hydro. Unit No. 403.12)	<p>Existing: (GWR), (REC-1), (REC-2), (WARM), and (WILD).</p> <p>Intermittent: none</p> <p>Potential: (MUN¹), (IND), (PROC), (AGR), and (COLD).</p>
001, 002	Calleguas Creek (Hydro. Unit No. 403.12)	<p>Existing: (IND), (PROC), (AGR), (GWR), (REC-1²), (REC-2), (WARM), and (WILD).</p> <p>Intermittent: none</p> <p>Potential: (MUN¹)</p>

¹ The potential municipal and domestic supply (p*MUN) beneficial use for the water body is consistent with the State Water Board Resolution 88-63 and Regional Water Board Resolution No. 89-003; however, the Regional Water Board has only conditionally designated the potential MUN beneficial use of the surface water and it is not an applicable water quality standard for purposes of the Clean Water Act.

² Whenever flow conditions are suitable.

Discharge Point	Receiving Water Name	Beneficial Use(s)
001, 002	Calleguas Creek (Hydro. Unit No. 403.11)	Existing: (AGR), (GWR), (FRSH), (REC-1), (REC-2), (WARM), (COLD), (WILD), (RARE ³), and wetland habitat (WET). Intermittent: none Potential: (MUN ¹)
001, 002	Calleguas Creek Estuary (Hydro. Unit No. 403.11)	Existing: (REC-2), commercial and sport fishing (COMM), estuarine habitat (EST), (WILD), (RARE ^{3,4}), migration of aquatic organisms (MIGR ⁵), spawning, reproduction, and/or early development (SPWN ⁵), and (WET). Intermittent: none Potential: Navigation (NAV), and (REC-1 ⁶).
001, 002	Mugu Lagoon (Hydro. Unit No. 403.11)	Existing: (NAV), (REC-2), (COMM ⁷), estuarine habitat (EST), marine habitat (MAR), wildlife habitat (WILD ⁸), preservation of biological habitats (BIOL), (RARE ^{3,4}), (MIGR ⁵), (SPWN ⁵), shellfish harvesting (SHELL ⁷), (WET). Intermittent: None Potential: (REC-1 ⁶)

Beneficial uses of the receiving ground waters are as follows:

Table F-4. Basin Plan Beneficial Uses – Ground Waters

Discharge Point	Basin Name	Beneficial Use(s)
	Simi Valley Basin DWR Basin No. 4-9 <u>Confined Aquifers</u>	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR)

³ Habitat of the Clapper Rail

⁴ One or more rare species utilize all ocean, bays, estuaries, and coastal wetlands for foraging and/or nesting.

⁵ Aquatic organisms utilize all bays, estuaries, lagoons and coastal wetlands, to a certain extent, for spawning and early development. This may include migration into areas which are heavily influenced by freshwater inputs.

⁶ Area is currently under the control of the Navy; swimming is prohibited.

⁷ Limited public access precludes full utilization.

⁸ Marine habitats of the Channel Islands and Mugu Lagoon serve as pinniped haul-out areas for one or more species (i.e., sea lions).

Discharge Point	Basin Name	Beneficial Use(s)
001, 002	Simi Valley Basin DWR Basin No. 4-9 <u>Unconfined Aquifers</u>	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR)
001, 002	Las Posas Valley DWR Basin No. 4-8 <u>South Basin</u>	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR)
	Las Posas Valley DWR Basin No. 4-8 <u>North Basin</u>	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR)
001, 002	Pleasant Valley (Ventura Central Basin) DWR Basin No. 4-6 <u>Confined Aquifers</u>	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR)
	Pleasant Valley (Ventura Central Basin) DWR Basin No. 4-6 <u>Unconfined Aquifers</u>	<u>Existing:</u> Industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR) <u>Potential:</u> Municipal and domestic water supply (MUN)
001, 002	Oxnard Plain (Ventura Central Basin) DWR Basin No. 4-4 <u>Oxnard Forebay</u>	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial service supply (IND), industrial process supply (PROC), and agricultural supply (AGR)
	Oxnard Plain (Ventura Central Basin) DWR Basin No. 4-4 <u>Confined Aquifers</u>	<u>Existing:</u> Municipal and domestic water supply (MUN), industrial process supply (PROC), and agricultural supply (AGR)
	Oxnard Plain (Ventura Central Basin) DWR Basin No. 4-4 <u>Unconfined Aquifers</u>	<u>Existing:</u> Municipal and domestic water supply (MUN) and agricultural supply (AGR) <u>Potential:</u> Industrial service supply (IND)

2. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the

state. The CTR was amended on February 13, 2001. These rules contain federal water quality criteria for priority pollutants.

3. **State Implementation Policy.** On March 2, 2000, the State Water Board adopted the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
4. **Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards become effective for CWA purposes (40 CFR part 131.21, 65 Federal Register 24641 (April 27, 2000)). Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
5. **Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based effluent limitations (TBELs) and water quality-based effluent limitations (WQBELs) for individual pollutants. The TBELs consist of restrictions on BOD, TSS, oil and grease, settleable solids, turbidity, pH, and percent removal of BOD and TSS. Restrictions on BOD, TSS, oil and grease, settleable solids, turbidity, and pH are discussed in section IV.B.2 of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements that are carried over from the previous permit. WQBELs have been scientifically derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal water quality standards. All beneficial uses and WQOs contained in the Basin Plan and the Ocean Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 CFR part 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.
6. **Antidegradation Policy.** Federal regulation 40 CFR part 131.12 requires that state water quality standards include an antidegradation policy consistent with the federal antidegradation policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16 ("Statement of Policy with Respect to Maintaining the Quality of the Waters of the State"). Resolution 68-16 is deemed to incorporate the federal antidegradation policy where the federal policy applies under federal law. Resolution 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal

antidegradation policies. The permitted discharges must be consistent with the antidegradation provisions of 40 CFR part 131.12 and State Water Board Resolution 68-16.

7. **Anti-Backsliding Requirements.** Sections 402(o) and 303(d)(4) of the CWA and federal regulations at 40 CFR part 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.
8. **Endangered Species Act Requirements.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California ESA (Fish and Game Code, sections 2050 to 2097) or the Federal ESA (16 USC sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The Permittee is responsible for meeting all requirements of the applicable ESA.
9. **Water Rights.** Prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a surface or subterranean stream, the Permittee must file a petition with the State Water Board (State Water Board), Division of Water Rights, and receive approval for such a change. The State Water Board retains the jurisdictional authority to enforce such requirements under CWC section 1211.
10. **Domestic Water Quality.** In compliance with CWC section 106.3, it is the policy of the State of California that every human being has the right to safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes. This Order promotes that policy by requiring discharges to meet maximum contaminant levels developed to protect human health and ensure that water is safe for domestic use.
11. **Water Recycling** - In accordance with statewide policies concerning water reclamation⁹, this Regional Water Board strongly encourages, wherever practical, water recycling, water conservation, and use of storm water and dry-weather urban runoff. The Permittee shall investigate the feasibility of recycling, conservation, and/or alternative disposal methods of wastewater (such as groundwater injection), and/or use of storm water and dry-weather urban runoff. The Permittee submitted a feasibility study on January 30, 2014. The Permittee shall submit an update to this feasibility study as part of the submittal of the Report of Waste Discharge (ROWD) for the next permit renewal.
12. **Monitoring and Reporting.** 40 CFR part 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP) establishes monitoring and reporting requirements to implement federal and state requirements. This MRP is provided in Attachment E.
13. **Sewage Sludge/Biosolids Requirements.** Section 405 of the CWA and implementing regulations at 40 CFR part 503 require that producers of sewage sludge/biosolids meet certain reporting, handling, and use or disposal requirements. The state has not been

⁹ See, e.g., CWC sections 13000 and 13550-13557, State Water Board Resolution No. 77-1 (Policy with Respect to Water Reclamation in California), and State Water Board Resolution No. 2009-0011 (Recycled Water Policy).

delegated the authority to implement this program; therefore, USEPA is the implementing agency. This Order contains sewage sludge/biosolids requirements pursuant to 40 CFR part 503 that are applicable to the Permittee.

D. Impaired Water Bodies on CWA 303(d) List

The State Water Board proposed the California 2008-2010 Integrated Report from a compilation of the adopted Regional Water Boards' Integrated Reports containing 303(d) List of Impaired Waters and 305(b) Reports following recommendations from the Regional Water Boards and information solicited from the public and other interested parties. The Regional Water Boards' Integrated Reports were used to revise their 2006 303(d) List. On August 4, 2010, the State Water Board adopted the California 2008-2010 Integrated Report. On November 12, 2010, the USEPA approved California 2008-2010 Integrated Report Section 303(d) List of Impaired Waters requiring Total Maximum Daily Loads (TMDL) for the Los Angeles Region. The 303(d) List can be viewed at the following link:

http://www.waterboards.ca.gov/water_issues/programs/tmdl/integrated2010.shtml

Calleguas Creek and its tributaries are in the California 2008-2010 Integrated Report. The following are the identified pollutants impacting the receiving water:

Calleguas Creek Reach 7 (was Arroyo Simi Reaches 1 and 2 on 1998 303(d) List) –
Calwater Watershed 40367000

Pollutants: Ammonia, boron, chloride, chlorpyrifos, diazinon, indicator bacteria, organophosphorus pesticides, sedimentation/siltation, sulfates, total dissolved solids, toxicity, and trash.

Calleguas Creek Reach 6 (was Arroyo Las Posas Reaches 1 and 2 on 1998 303(d) List) - Calwater Watershed 40362000

Pollutants: Ammonia, chlordane, chloride, chlorpyrifos, dichlorodiphenyltrichloroethane (DDT) (sediment), diazinon, dieldrin, fecal coliform, nitrate and nitrite, nitrate as nitrate (NO₃), sedimentation/siltation, sulfates, total dissolved solids, and toxicity.

Calleguas Creek Reach 3 (Potrero Road upstream to confluence with Conejo Creek on 1998 303(d) List) - Calwater Watershed 40312000

Pollutants: Ammonia, chlordane, chloride, DDT, dieldrin, nitrate and nitrite, polychlorinated biphenyls (PCBs), sedimentation/siltation, total dissolved solids, toxaphene, and trash.

Calleguas Creek Reach 2 (Estuary to Potrero Road - was Calleguas Creek Reaches 1 and 2 on 1998 303(d) List) - Calwater Watershed 40312000

Pollutants: Ammonia, chemA (tissue), chlordane (tissue), dissolved copper, DDT, dieldrin, endosulfan (tissue), fecal coliform, nitrogen, PCBs (tissue), sediment toxicity, sedimentation/siltation, toxaphene (tissue and sediment), and trash.

E. Other Plans, Policies and Regulations

1. **Sources of Drinking Water Policy.** On May 19, 1988, the State Water Board adopted Resolution No. 88-63, *Sources of Drinking Water (SODW) Policy*, which established a policy that all surface and ground waters, with limited exemptions, are suitable or potentially suitable for municipal and domestic supply. To be consistent with State Water Board's SODW Policy, on March 27, 1989, the Regional Water Board adopted Resolution

No. 89-03, *Incorporation of Sources of Drinking Water Policy into the Water Quality Control Plans (Basin Plans) – Santa Clara River Basin (4A)/ Los Angeles River Basin (4B)*.

Consistent with Regional Water Board Resolution No. 89-03 and State Water Board Resolution No. 88-63, in 1994 the Regional Water Board conditionally designated all inland surface waters in Table 2-1 of the 1994 Basin Plan as existing, intermittent, or potential for Municipal and Domestic Supply (MUN). However, the conditional designation in the 1994 Basin Plan included the following implementation provision: "no new effluent limitations will be placed in Waste Discharge Requirements as a result of these [potential MUN designations made pursuant to the SODW policy and the Regional Water Board's enabling resolution] until the Regional Water Board adopts [a special Basin Plan Amendment that incorporates a detailed review of the waters in the Region that should be exempted from the potential MUN designations arising from SODW policy and the Regional Water Board's enabling resolution]." On February 15, 2002, the USEPA clarified its partial approval (May 26, 2000) of the 1994 Basin Plan amendments and acknowledged that the conditional designations do not currently have a legal effect, do not reflect new water quality standards subject to USEPA review, and do not support new effluent limitations based on the conditional designations stemming from the SODW Policy until a subsequent review by the Regional Water Board finalizes the designations for these waters. This permit is designed to be consistent with the existing Basin Plan.

2. **Title 22 of the California Code of Regulations (CCR Title 22).** The California Department of Public Health (CDPH) established primary and secondary maximum contaminant levels (MCLs) for inorganic, organic, and radioactive contaminants in drinking water. These MCLs are codified in Title 22. The Basin Plan (Chapter 3) incorporates Title 22 primary MCLs by reference. This incorporation by reference is prospective, including future changes to the incorporated provisions as the changes take effect. Title 22 primary MCLs have been used as bases for effluent limitations in WDRs and NPDES permits to protect groundwater recharge beneficial use when that receiving groundwater is designated as MUN. Also, the Basin Plan specifies that "Ground waters shall not contain taste or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses."
3. **Secondary Treatment Regulations.** 40 CFR part 133 of establishes the minimum levels of effluent quality to be achieved by secondary treatment. These limitations, established by USEPA, are incorporated into this Order, except where more stringent limitations are required by other applicable plans, policies, or regulations or to prevent backsliding.
4. **Storm Water.** CWA section 402(p), as amended by the Water Quality Act of 1987, requires NPDES permits for storm water discharges. Pursuant to this requirement, in 1990, USEPA promulgated 40 CFR part 122.26 that established requirements for storm water discharges under an NPDES program. To facilitate compliance with federal regulations, on November 1991, the State Water Board issued a statewide general permit, *General NPDES Permit No. CAS000001 and Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities*. This permit was amended in September 1992 and reissued on April 17, 1997 in State Water Board Order No. 97-03-DWQ to regulate storm water discharges associated with industrial activity.

General NPDES permit No. CAS000001 is not applicable to the Simi Valley WQCP because the facility captures and treats storm water collected on the premises.
5. **Sanitary Sewer Overflows (SSOs).** The CWA prohibits the discharge of pollutants from point sources to surface waters of the United States unless authorized under an NPDES permit. (33 United States Code (USC) sections 1311 and 1342). The State Water Board

adopted General WDRs for Sanitary Sewer Systems, (Water Quality Order No. 2006-0003-DWQ; SSO WDR) on May 2, 2006, to provide a consistent, statewide regulatory approach to address SSOs. The SSO WDR requires public agencies that own or operate sanitary sewer systems to apply for coverage under the SSO WDR, develop and implement sewer system management plans, and report all SSOs to the State Water Board's online SSO database. Regardless of the coverage obtained under the SSO WDR, the Permittee's collection system is part of the POTW that is subject to this NPDES permit. As such, pursuant to federal regulations, the Permittee must properly operate and maintain its collection system (40 CFR part 122.41 (e)), report any non-compliance (40 CFR part 122.41(1)(6) and (7)), and mitigate any discharge from the collection system in violation of this NPDES permit (40 CFR part 122.41(d)).

The requirements contained in this Order sections VI.C.3.b (Spill Cleanup Contingency Plan section), VI.C.4 (Construction, Operation and Maintenance Specifications section), and VI.C.6 (Spill Reporting Requirements section) are intended to be consistent with the requirements of the SSO WDR. The Regional Water Board recognizes that there may be some overlap between these NPDES permit provisions and SSO WDR requirements, related to the collection systems. The requirements of the SSO WDR are considered the minimum thresholds (see Finding 11 of State Water Board Order No. 2006-0003-DWQ). To encourage efficiency, the Regional Water Board will accept the documentation prepared by the Permittees under the SSO WDR for compliance purposes as satisfying the requirements in sections VI.C.3.b, VI.C.4, and VI.C.6, provided the more stringent provisions contained in this NPDES permit are also addressed. Pursuant to SSO WDR, section D, provision 2(iii) and (iv), the provisions of this NPDES permit supercede the SSO WDR, for all purposes, including enforcement, to the extent the requirements may be deemed duplicative.

6. **Watershed Management** - This Regional Water Board has been implementing a Watershed Management Approach (WMA) to address water quality protection in the Los Angeles Region following the USEPA guidance in *Watershed Protection: A Project Focus* (EPA841-R-95-003, August 1995). The objective of the WMA is to provide a more comprehensive and integrated strategy resulting in water resource protection, enhancement, and restoration while balancing economic and environmental impacts within a hydrologically-defined drainage basin or watershed. The WMA emphasizes cooperative relationships between regulatory agencies, the regulated community, environmental groups, and other stakeholders in the watershed to achieve the greatest environmental improvements with the resources available. The WMA integrates activities across the Regional Water Board's diverse programs, particularly permitting, planning, and other surface water-oriented programs that have tended to operate somewhat independently of each other.

The Regional Water Board has prepared and periodically updates its Watershed Management Initiative Chapter, the latest is updated December 2007. This document contains a summary of the region's approach to watershed management. It addresses each watershed and the associated water quality problems and issues. It describes the background and history of each watershed, current and future activities, and addresses TMDL development. The information can be accessed on our website: <http://www.waterboards.ca.gov/losangeles>.

7. **Relevant TMDLs** – Section 303(d) of the CWA requires states to identify water bodies that do not meet water quality standards and then to establish TMDLs for each waterbody for each pollutant of concern. TMDLs identify the maximum amount of

pollutants that can be discharged to waterbodies without causing violations of water quality standards.

- a. **Calleguas Creek Watershed Salts TMDL** - On October 4, 2007, the Regional Water Board adopted Resolution No. R4-2007-016, *Amendment to the Water Quality Control Plan – Los Angeles Region to Incorporate the Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on May 20, 2008, November 6, 2008, and December 2, 2008, respectively. This TMDL became effective on December 2, 2008.
- b. **Calleguas Creek Watershed Nitrogen Compounds and Related Effects TMDL** - On October 24, 2002, the Regional Water Board adopted Resolution No. 02-017, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in Calleguas Creek (Nitrogen Compounds TMDL)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on March 19, 2003, June 5, 2003, and June 20, 2003, respectively.

On September 11, 2008, the Regional Water Board adopted Resolution No. R4-2008-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region through revision of the Waste Load Allocation for the Calleguas Creek Watershed Nitrogen Compounds and Related Effects Total Maximum Daily Load (revised Nitrogen Compounds TMDL)*. This Basin Plan amendment corrects the mass based daily WLAs for ammonia to be used based upon MDEL, and updates the WLAs to be consistent with the current practice of recognizing that the flow is variable. The mass based WLAs for ammonia are corrected to be based on the maximum daily effluent limit, MDEL and the actual POTW effluent flow rate at the time the monitoring is conducted. This Order includes effluent limitations for nitrogen compounds established by the revised Nitrogen Compounds TMDL which became effective on October 15, 2009.

- c. **Calleguas Creek Toxicity, Chlorpyrifos, and Diazinon TMDL** - On July 7, 2005, the Regional Water Board adopted Resolution No. R4-2005-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Toxicity, Chlorpyrifos, and Diazinon in Calleguas Creek, its Tributaries, and Mugu Lagoon (Toxicity TMDL)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on September 22, 2005, November 27, 2005, and March 14, 2006, respectively. This Order includes effluent limitations for chlorpyrifos and diazinon established by the Toxicity TMDL which became effective on March 24, 2006.

The *Toxicity TMDL* includes a WLA of 1.0 TUc for toxicity, which is required to be implemented in accordance with USEPA, State Water Board, and Regional Water Board resolutions, guidance and policy at the time of permit issuance or renewal. Consistent with the Toxicity TMDL Implementation Plan, this toxicity WLA will be implemented using the recent USEPA guidance, National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, June 2010).

- d. **Calleguas Creek OC Pesticides and PCBs TMDL** - On July 7, 2005, the Regional Water Board adopted Resolution No. R4-2005-010, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Organochlorine Pesticides, Polychlorinated Biphenyls, and Siltation in*

Calleguas Creek, its Tributaries, and Mugu Lagoon (OC Pesticides and PCBs TMDL). This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on September 22, 2005, January 20, 2006, and March 14, 2006, respectively. This Order includes effluent limitations for OC pesticides and PCBs established by the OC Pesticides and PCBs TMDL which became effective on March 24, 2006.

- e. **Calleguas Creek Watershed Metals TMDL** – On June 8, 2006, the Regional Water Board adopted Resolution No. R4-2006-012, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate a Total Maximum Daily Load for Metals for the Calleguas Creek, its Tributaries, and Mugu Lagoon (Metals TMDL)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on October 25, 2006, February 6, 2007, and March 26, 2007, respectively. This Order includes effluent limitations for metals established by the Metals TMDL which became effective on March 26, 2007.
- i. **Calleguas Creek Copper WER** – On November 9, 2006, the Regional Water Board adopted Resolution No. R4-2006-022, *Amendment to the Water Quality Control Plan for the Los Angeles Region Water Effects Ratios (WERs) for Copper in Lower Calleguas Creek and Mugu Lagoon Located in the Calleguas Creek Watershed, Ventura County (Copper WER)*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on June 19, 2007, August 16, 2007, and August 23, 2007, respectively. However, a copper WER is not relevant to the discharge of Simi Valley WQCP because the discharged effluent does not reach lower Calleguas Creek and Mugu Lagoon. Therefore, a copper WER will not be applied in this permit.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source Permittees to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in 40 CFR part 122.44(a) requires that permits include applicable TBELs and standards; and 40 CFR part 122.44(d) requires that permits include WQBELs to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

The variety of potential pollutants found in the Facility discharges presents a potential for aggregate toxic effects to occur. Whole effluent toxicity (WET) is an indicator of the combined effect of pollutants contained in the discharge. Chronic toxicity is a more stringent requirement than acute toxicity. Therefore, chronic toxicity is considered pollutant of concern for protection and evaluation of narrative Basin Plan Objectives.

A. Discharge Prohibitions

Effluent and receiving water limitations in this Board Order are based on the CWA, Basin Plan, State Water Board's plans and policies, USEPA guidance and regulations, and best practicable waste treatment technology. This order authorizes the discharge of tertiary-treated wastewater from Discharge Points 001 and 002 only. It does not authorize any other types of discharges.

B. Technology-Based Effluent Limitations (TBELs)

1. Scope and Authority

Technology-based effluent limits require a minimum level of treatment for industrial/municipal point sources based on currently available treatment technologies while allowing the Permittee to use any available control techniques to meet the effluent limits. The 1972 CWA required POTWs to meet performance requirements based on available wastewater treatment technology. Section 301 of the CWA established a required performance level--referred to as "secondary treatment" --that all POTWs were required to meet by July 1, 1977. More specifically, section 301(b)(1)(B) of the CWA required that USEPA develop secondary treatment standards for POTWs as defined in section 304(d)(1). Based on this statutory requirement, USEPA developed national secondary treatment regulations which are specified in 40 CFR part 133. These technology-based regulations apply to all POTWs and identify the minimum level of effluent quality to be attained by secondary treatment in terms of BOD₅20°C, TSS, and pH.

2. Applicable TBELs

This Facility is subject to the technology-based regulations for the minimum level of effluent quality attainable by secondary treatment in terms of BOD₅20°C, TSS, and pH. However, all TBELs from the previous Order No. R4-2003-0081 are based on tertiary-treated wastewater treatment standards. These effluent limitations have been carried over from the previous Order to avoid backsliding. Further, mass-based effluent limitations are based on a design flow rate of 12.5 mgd. The removal efficiency for BOD and TSS is set at the minimum level attainable by secondary treatment technology. The following Table summarizes the TBELs applicable to the Facility:

Table F-5. Summary of TBELs

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
BOD ₅ 20°C	mg/L	20	30	45		
	lbs/day ¹⁰	2,080	3,130	4,690		
TSS	mg/L	15	40	45		
	lbs/day ¹⁰	1,560	4,170	4,690		
pH	standard units	--	--	--	6.5	8.5
Removal Efficiency for BOD and TSS	%	85	--	--		

This Facility is also subject to TBELs contained in similar NPDES permits, for similar facilities, based on the treatment level achievable by tertiary-treated wastewater treatment systems. These effluent limitations are consistent with the State Water Board precedential decision, State Water Board Order No. WQ 2004-0010 for the City of Woodland.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

CWA section 301(b) and 40 CFR part 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements, expressed as a technology equivalence requirement that are necessary to achieve water quality standards. The Regional Water Board has considered the factors listed in CWC section 13241 in establishing these requirements. The rationale for these requirements, which consist of tertiary treatment or equivalent requirements or other provisions, is discussed starting from section IV.C.2.

40 CFR part 122.44(d)(1)(i) requires that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established using (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable WQOs and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

¹⁰ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (mgd) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

- a. The Basin Plan establishes the beneficial uses for surface water bodies in the Los Angeles region. The beneficial uses of the Arroyo Simi affected by the discharge have been described previously in this Fact Sheet.
- b. The Basin Plan also specifies narrative and numeric WQOs applicable to surface water as shown in the following discussions.

i. BOD₅20°C and TSS

BOD₅20°C is a measure of the quantity of the organic matter in the water and, therefore, the water's potential for becoming depleted in dissolved oxygen. As organic degradation takes place, bacteria and other decomposers use the oxygen in the water for respiration. Unless there is a steady resupply of oxygen to the system, the water will quickly become depleted of oxygen. Adequate dissolved oxygen levels are required to support aquatic life. Depressions of dissolved oxygen can lead to anaerobic conditions resulting in odors, or, in extreme cases, fish kills.

40 CFR part 133 describes the minimum level of effluent quality attainable by secondary treatment, for BOD and TSS, as:

- The 30-day average shall not exceed 30 mg/L, and
- The 7-day average shall not exceed 45 mg/L.

Simi Valley WQCP provides tertiary treatment. The Facility achieves solids removals that are better than secondary-treated wastewater by filtering the effluent.

The monthly average, the 7-day average, and the daily maximum limits cannot be removed because none of the anti-backsliding exceptions apply. Those limits were all included in the previous permit (Order R4-2003-0081) and the Simi Valley WQCP has been able to meet both limits (monthly average and the daily maximum), for both BOD and TSS.

In addition to having mass-based and concentration-based effluent limitations for BOD and TSS, the Simi Valley WQCP also has a percent removal requirement for these two constituents. In accordance with 40 CFR parts 133.102(a)(3) and 133.102(b)(3), the 30-day average percent removal shall not be less than 85 percent. Percent removal is defined as a percentage expression of the removal efficiency across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of the raw wastewater influent pollutant concentrations to the Facility and the 30-day average values of the effluent pollutant concentrations for a given time period.

ii. pH

The hydrogen ion activity of water (pH) is measured on a logarithmic scale, ranging from 0 to 14. While the pH of "pure" water at 25°C is 7.0, the pH of natural waters is usually slightly basic due to the solubility of carbon dioxide from the atmosphere. Minor changes from natural conditions can harm aquatic life. In accordance with 40 CFR part 133.102(c), the effluent values for pH shall be maintained within the limits of 6.0 to 9.0 unless the POTW demonstrates that (1) inorganic chemicals are not added to the waste stream as part of the treatment process; and (2) contributions from industrial sources do not cause the pH of the effluent to be less than 6.0 or greater than 9.0. The effluent limitation for pH in

this permit requiring that the wastes discharged shall at all times be within the range of 6.5 to 8.5 is taken from the Basin Plan (page 3-15) which reads "the pH of inland surface waters shall not be depressed below 6.5 or raised above 8.5 as a result of waste discharge."

iii. **Settleable Solids**

Excessive deposition of sediments can destroy spawning habitat, blanket benthic (bottom dwelling) organisms, and abrade the gills of larval fish. The limits for settleable solids are based on the Basin Plan (page 3-16) narrative, "Waters shall not contain suspended or settleable material in concentrations that cause nuisance or adversely affect beneficial uses." The numeric limits are empirically based on results obtained from the settleable solids 1-hour test, using an Imhoff cone.

It is impracticable to use a 7-day average limitation, because short-term spikes of settleable solid levels that would be permissible under a 7-day average scheme would not be adequately protective of all beneficial uses. The monthly average and the daily maximum limits cannot be removed because none of the anti-backsliding exceptions apply. The monthly average and daily maximum limits were both included in the previous permit (Order R4-2003-0081) and the Simi Valley WQCP has been able to meet both limits.

iv. **Oil and grease**

Oil and grease are not readily soluble in water and form a film on the water surface. Oily films can coat birds and aquatic organisms, impacting respiration and thermal regulation, and causing death. Oil and grease can also cause nuisance conditions (odors and taste), are aesthetically unpleasant, and can restrict a wide variety of beneficial uses. The limits for oil and grease are based on the Basin Plan (page 3-11) narrative, "Waters shall not contain oils, greases, waxes, or other materials in concentrations that result in a visible film or coating on the surface of the water or on objects in the water, that cause nuisance, or that otherwise adversely affect beneficial uses."

The numeric limits are empirically based on concentrations at which an oily sheen becomes visible in water. It is impracticable to use a 7-day average limitation, because spikes that occur under a 7-day average scheme could cause a visible oil sheen. A 7-day average scheme would not be sufficiently protective of beneficial uses. The monthly average and the daily maximum limits cannot be removed because none of the anti-backsliding exceptions apply. Both limits were included in the previous permit (Order R4-2003-0081) and the Simi Valley WQCP has been able to meet both limits.

v. **Residual Chlorine**

Disinfection of wastewaters with chlorine produces a chlorine residual. Chlorine and its reaction products are toxic to aquatic life. The limit for residual chlorine is based on the Basin Plan (page 3-9) narrative, "Chlorine residual shall not be present in surface water discharges at concentrations that exceed 0.1 mg/L and shall not persist in receiving waters at any concentration that causes impairment of beneficial uses."

It is impracticable to use a 7-day average or a 30-day average limitation, because it is not as protective as of beneficial uses as a daily maximum limitation is.

Chlorine is very toxic to aquatic life and short term exposures of chlorine may cause fish kills.

vi. **Fluoride**

The existing permit effluent limitation of 1.6 mg/L for fluoride was developed based on the Basin Plan chemical constituent incorporation of Title 22, Drinking Water Standards. Fluoride is not a priority pollutant. The discharge from the Simi Valley WQCP does not exhibit reasonable potential to exceed the USEPA Quality Criteria for Water 1976 (EPA 440/9-76-023) limit of 2,000 µg/L. Therefore, the accompanying Order will not contain a limit for fluoride.

vii. **TDS, Sulfate, and Boron**

The WQO for TDS, Sulfate, and Boron in the Basin Plan Table 3-8 (page 3-12), for the Calleguas Creek watershed (above Potrero Road) is TDS = 850 mg/L, Sulfate = 250 mg/L, and Boron = 1.0 mg/L.

On October 4, 2007, the Regional Water Board adopted Resolution No. R4-2007-016, *Amendment to the Water Quality Control Plant – Los Angeles Region to Incorporate the Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed*. On May 20, 2008, the State Water Board approved the *Calleguas Creek Salts TMDL*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on May 20, 2008, November 6, 2008, and December 2, 2008, respectively. This TMDL became effective on December 2, 2008.

Calleguas Creek Salts TMDL contains WLAs for TDS, sulfate, chloride and boron. However, the Facility is consistently complying with the Basin Plan WQO for TDS, sulfate, and boron. Therefore, this permit includes final effluent limitations for TDS, sulfate, and boron based on Basin Plan WQOs.

viii. **Chloride**

The WQO for chloride in the Basin Plan Table 3-8 (page 3-12), for Calleguas Creek Watershed (above Potrero Road) is 150 mg/L.

On January 27, 1997, the Regional Water Board adopted Resolution No. 97-02, Amendment to the Basin Plan to incorporate a Policy for Addressing Levels of Chloride in Discharges of Wastewaters. It was approved by the State Water Board (SWRCB Resolution 97-94); approved by the Office of Administrative Law (OAL) on January 8, 1998. Resolution 97-02 served to revise the chloride water quality objective in Calleguas Creek and other surface waters.

On April 13, 1998, the Regional Water Board adopted Order No. 98-027, which temporarily amended NPDES Order No. 96-043 for Simi Valley WQCP to include an interim chloride daily maximum effluent limit to 190 mg/L based on Resolution 97-02. This interim limit expired on January 9, 2001.

On December 7, 2000, the Regional Water Board adopted Resolution No. 2000-22, to extend the Interim Chloride Limits for Discharges to Calleguas Creek until March 31, 2001.

On March 22, 2002, USEPA Region 9 established the Calleguas Creek Total Maximum Daily Load for chloride which used the 150 mg/L objective in the Basin Plan to establish a waste load allocation of 10,100 lbs/day for the Simi Valley WQCP during normal conditions, and a waste load allocation of 9,200 lbs/day for the Simi Valley WQCP during drought conditions.

On August 14, 2002 the City of Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), Camrosa Sanitation District (Camrosa WRP), Ventura County Water Works District No. 1 (Moorpark facility) and the Regional Water Board entered into a "Stipulation for Order Issuing Stay, with Conditions," which stayed the chloride final effluent limitation in NPDES Order No. 96-043. The State Water Board adopted WQO 2002-0017, which approved the August 14, 2002 stipulation.

On June 5, 2003, the NPDES permits for the City of Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP) were renewed, thereby rescinding the 1996 NPDES Orders, except for enforcement purposes. The Permittees petitioned the revised NPDES Orders to the State Water Board, requested an extension of the chloride stay, and asked that the petitions be held in abeyance.

On October 10, 2003, the City of Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), and the Regional Water Board entered into a "Stipulation for Further Order Issuing Stay, with Conditions," which stayed the chloride final effluent limitation in NPDES Order No. R4-2003-0081. The State Water Board adopted WQO 2003-0019, which approved the October 10, 2003, stipulation and held the petitions in abeyance for three years (until November 19, 2006).

On September 28, 2006, the State Water Board granted an extension of the abeyance until July 15, 2008. The State Water Board has continued granting extensions to the abeyance.

On October 4, 2007, the Regional Water Board adopted the *Calleguas Creek Salts TMDL*, Resolution No. R4-2007-016, *Amendment to the Water Quality Control Plan – Los Angeles Region to Incorporate the Total Maximum Daily Load for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed*. This Resolution was approved by the State Water Board, Office of Administrative Law, and USEPA on May 20, 2008, November 6, 2008, and December 2, 2008, respectively. This TMDL became effective on December 2, 2008. The Salts TMDL established WLAs for chloride. During wet weather, the chloride effluent limit is based on the water quality objective found in Basin Plan Table 3-8 (page 3-12) for the Calleguas Creek watershed (above Potrero Road) which is 150 mg/L. During dry weather, the final effluent limitation for chloride is based on the WLAs contained in the Salts TMDL.

ix. **Iron**

The previous Order had an effluent limitation of 300 mg/L for iron, which was based on the USEPA document, Quality Criteria for Water 1986 [EPA 440/5-86-001, May 1, 1986], also referred to as the Gold Book, for the protection of GWR beneficial use. 300 µg/L was also the secondary MCL for iron. However, the limit was removed because there was no reasonable potential for the discharge to cause or contribute to an exceedance.

x. **Methylene Blue Activated Substances (MBAS)**

The existing permit effluent limitation of 0.5 mg/L for MBAS was developed based on the Basin Plan incorporation of Title 22, Drinking Water Standards. Given the nature of the Facility which accepts domestic wastewater into the sewer system and treatment plant, and the characteristics of the pollutant discharged, the discharge has reasonable potential to exceed both the numeric MBAS WQO and

the narrative WQO for the prohibition of floating material such as foams and scums. Therefore an effluent limitation is required.

xi. **Total Inorganic Nitrogen (NO₂ + NO₃ as N)**

Total inorganic nitrogen is the sum of Nitrate-nitrogen and Nitrite-nitrogen. High nitrate levels in drinking water can cause health problems in humans. Infants are particularly sensitive and can develop methemoglobinemia (blue-baby syndrome). Nitrogen is also considered a nutrient. Excessive amounts of nutrients can lead to other water quality impairments.

(a). **Algae**

Excessive growth of algae and/or other aquatic plants can degrade water quality. Algal blooms sometimes occur naturally, but they are often the result of excess nutrients (i.e., nitrogen, phosphorus) from waste discharges or nonpoint sources. These algal blooms can lead to problems with tastes, odors, color, and increased turbidity and can depress the dissolved oxygen content of the water, leading to fish kills. Floating algal scum and algal mats are also an aesthetically unpleasant nuisance.

The WQO for biostimulatory substances are based on Basin Plan (page 3-8) narrative, "Waters shall not contain biostimulatory substances in concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses," and other relevant information to arrive at a mass based-limit intended to be protective of the beneficial uses, pursuant to 40 CFR part 122.44(d). Total inorganic nitrogen will be the indicator parameter intended to control algae, pursuant to 40 CFR part 122.44(d)(1)(vi)(C).

(b). **Concentration-based limit**

Total inorganic nitrogen (NO₂-N + NO₃-N) effluent limitation of 10 mg/L is based on Basin Plan Table 3-8 (page 3-12), for Calleguas Creek Watershed above Potrero Road. However, the Nitrogen Compound TMDL for this Watershed has been in effect since July 16, 2003. Therefore, total inorganic nitrogen effluent limitation of 9 mg/L, which is based on the Nitrogen Compound TMDL, will apply in this permit.

(c). **Mass-based limit**

Since the Nitrogen Compound TMDL does not specify any mass-based WLA for nitrate plus nitrite as nitrogen, mass based limits are not included for NO₂-N + NO₃-N.

xii. **Nitrite as Nitrogen and Nitrate as Nitrogen**

The effluent limit for nitrite as nitrogen (NO₂-N) of 0.9 mg/L is based on the Calleguas Creek Watershed Nutrient TMDL Waste Load Allocation which was assigned to the Simi Valley WQCP. The effluent limit for nitrate as nitrogen (NO₃-N) of 9 mg/L is based on the Calleguas Creek Watershed Nutrient TMDL Waste Load Allocation which was assigned to the Simi Valley WQCP. Since the TMDL does not specify any mass-based WLA for nitrate as nitrogen or nitrite as nitrogen, mass based limits are not included for either of the two constituents.

xiii. **Total ammonia**

Ammonia is a pollutant routinely found in the wastewater effluent of POTWs, in landfill-leachate, as well as in run-off from agricultural fields where commercial fertilizers and animal manure are applied. Ammonia exists in two forms – un-ionized ammonia (NH_3) and the ammonium ion (NH_4^+). They are both toxic, but the neutral, un-ionized ammonia species (NH_3) is much more toxic, because it is able to diffuse across the epithelial membranes of aquatic organisms much more readily than the charged ammonium ion. The form of ammonia is primarily a function of pH, but it is also affected by temperature and other factors. Additional impacts can also occur as the oxidation of ammonia lowers the dissolved oxygen content of the water, further stressing aquatic organisms. Oxidation of ammonia to nitrate may lead to groundwater impacts in areas of recharge. There is groundwater recharge in these reaches. Ammonia also combines with chlorine (often both are present in POTW treated effluent discharges) to form chloramines – persistent toxic compounds that extend the effects of ammonia and chlorine downstream.

On October 24, 2002, the Regional Water Board adopted Resolution No. 02-017, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Include a TMDL for Nitrogen Compounds and Related Effects in Calleguas Creek*. This Resolution was approved by the State Water Resources Control Board, Office of Administrative Law, and USEPA on March 19, 2003, June 5, 2003, and June 20, 2003, respectively.

On September 11, 2008, the Regional Water Board adopted Resolution No. R4-2008-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region through revision of the Waste Load Allocation for the Calleguas Creek Watershed Nitrogen Compounds and Related Effects Total Maximum Daily Load (revised Nitrogen Compounds TMDL)*. This Basin Plan amendment corrects the mass based daily WLAs for ammonia to be used based upon MDEL, and updates the WLAs to be consistent with the current practice of recognizing that the flow is variable. The mass based WLAs for ammonia are corrected to be based on the maximum daily effluent limit, MDEL and the actual POTW effluent flow rate at the time the monitoring is conducted. This Order includes effluent limitations for nitrogen compounds established by the revised Nitrogen Compounds TMDL which became effective on October 15, 2009. The Calleguas Creek Nitrogen Compounds TMDL has ammonia nitrogen waste load allocations of 3.3 mg/L and 2.4 mg/L as maximum daily and average monthly effluent limitation, respectively. These waste load allocations will apply as end-of-pipe effluent limitations for Simi Valley WQCP.

xiv. **Coliform**

Total and fecal coliform bacteria are used to indicate the likelihood of pathogenic bacteria in surface waters. Given the nature of the facility, a wastewater treatment plant, pathogens are likely to be present in the effluent in cases where the disinfection process is not operating adequately. As such, the permit contains the following:

ii. **Effluent Limitations:**

- The 7 day median number of coliform organisms at some point in the treatment process must not exceed a Most Probable Number (MPN) or Colony Forming Unit (CFU) of 2.2 per 100 milliliters,

- The number of coliform organisms must not exceed an MPN or CFU of 23 per 100 milliliters in more than one sample within any 30-day period, and
- No sample shall exceed an MPN of CFU of 240 total coliform bacteria per 100 milliliters.

These disinfection-based effluent limitations for coliform are for human health protection and are consistent with requirements established by the California Department of Public Health. These limits for coliform must be met at the point of the treatment train immediately following disinfection, as a measure of the effectiveness of the disinfection process.

iii. Receiving Water Limitation

- Geometric Mean Limits
 - * E.coli density shall not exceed 126/100 mL.
- Single Sample Limits
 - * E.coli density shall not exceed 235/100 mL.

These receiving water limitations are based on Resolution No. R10-005, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Update the Bacteria Objectives for Freshwaters Designated for Water Contact Recreation by Removing the Fecal Coliform Objective*, adopted by the Regional Water Board on July 8, 2010, and became effective on December 5, 2011.

xv. Temperature

USEPA document, *Quality Criteria for Water 1986* [EPA 440/5-86-001, May 1, 1986], also referred to as the *Gold Book*, discusses temperature and its effects on beneficial uses, such as recreation and aquatic life.

- The Federal Water Pollution Control Administration in 1967 called temperature "a catalyst, a depressant, an activator, a restrictor, a stimulator, a controller, a killer, and one of the most important water quality characteristics to life in water." The suitability of water for total body immersion is greatly affected by temperature. Depending on the amount of activity by the swimmer, comfortable temperatures range from 20°C to 30°C (68 °F to 86 °F).
- Temperature also affects the self-purification phenomenon in water bodies and therefore the aesthetic and sanitary qualities that exist. Increased temperatures accelerate the biodegradation of organic material both in the overlying water and in bottom deposits which makes increased demands on the dissolved oxygen resources of a given system. The typical situation is exacerbated by the fact that oxygen becomes less soluble as water temperature increases. Thus, greater demands are exerted on an increasingly scarce resource which may lead to total oxygen depletion and obnoxious septic conditions. Increased temperature may increase the odor of water because of the increased volatility of odor-causing compounds. Odor problems associated with plankton may also be aggravated.
- Temperature changes in water bodies can alter the existing aquatic community. Coutant (1972) has reviewed the effects of temperature on

aquatic life reproduction and development. Reproductive elements are noted as perhaps the most thermally restricted of all life phases assuming other factors are at or near optimum levels. Natural short-term temperature fluctuations appear to cause reduced reproduction of fish and invertebrates.

The Basin Plan lists temperature requirements for the receiving waters. Based on the requirements of the Basin Plan and a white paper developed by Regional Water Board staff entitled *Temperature and Dissolved Oxygen Impacts on Biota in Tidal Estuaries and Enclosed Bays in the Los Angeles Region*, a maximum effluent temperature limitation of 86°F is included in the Order. The white paper evaluated the optimum temperatures for steelhead, topsmelt, ghost shrimp, brown rock crab, jackknife clam, and blue mussel. The new temperature effluent limitation is reflective of new information available that indicates that the 100°F temperature which was formerly used in permits was not protective of aquatic organisms. A survey was completed for several kinds of fish and the 86°F temperature was found to be protective. It is impracticable to use a 7-day average or a 30-day average limitation for temperature, because it is not as protective as of beneficial uses as a daily maximum limitation is. A daily maximum limit is necessary to protect aquatic life and is consistent with the fishable/swimmable goals of the CWA.

Section IV.A.1.c. of the Order contains the following effluent limitation for temperature:

"The temperature of wastes discharged shall not exceed 86°F except as a result of external ambient temperature."

The above effluent limitation for temperature has been quoted in all recent NPDES permits adopted by this Regional Water Board. Section V.A.1. of the Order explains how compliance with the receiving water temperature limitation will be determined.

xvi. Turbidity

Turbidity is an expression of the optical property that causes light to be scattered in water due to particulate matter such as clay, silt, organic matter, and microscopic organisms. Turbidity can result in a variety of water quality impairments. The effluent limitation for turbidity which reads, "For the protection of the water contact recreation beneficial use, the discharge to water courses shall have received adequate treatment, so that the turbidity of the wastewater does not exceed: (a) a daily average of 2 Nephelometric turbidity units (NTU); (b) 5 NTU more than 5 percent of the time (72 minutes) during any 24 hour period; and (c) 10 NTU at any time" is based on the Basin Plan (page 3-17) and section 60301.320 of Title 22, Chapter 3, "Filtered Wastewater" of the CCR.

xvii. Radioactivity

Radioactive substances are generally present in natural waters in extremely low concentrations. Mining or industrial activities increase the amount of radioactive substances in waters to levels that are harmful to aquatic life, wildlife, or humans. Section 301(f) of the CWA contains the following statement with respect to effluent limitations for radioactive substances: "Notwithstanding any of other provisions of this Act it shall be unlawful to discharge any radiological, chemical, or biological warfare agent, any high-level

radioactive waste, or any medical waste, into the navigable waters." Chapter 4.4 of the CWC contains a similar prohibition under section 13375, which reads as follows: "The discharge of any radiological, chemical, or biological warfare agent into the waters of the state is hereby prohibited." However, rather than an absolute prohibition on radioactive substances, Regional Water Board staff have set the following effluent limit for radioactivity: "Radioactivity of the wastes discharged shall not exceed the limits specified in Title 22, Chapter 15, Article 5, sections 64442 and 64443, of the CCR, or subsequent revisions." The limit is based on the Basin Plan incorporation of Title 22, CCR, *Drinking Water Standards*, by reference, to protect beneficial use. Therefore, the accompanying Order will retain the limit for radioactivity.

c. CTR and SIP

The CTR and the SIP specify numeric objectives for toxic substances and the procedures whereby these objectives are to be implemented. The procedures include those used to conduct reasonable potential analysis (RPA) to determine the need for effluent limitations for priority pollutants. The TSD specifies the procedures to conduct reasonable potential analyses for non-priority pollutants.

3. Determining the Need for WQBELs

The Regional Water Board developed WQBELs for ammonia-nitrogen, nitrite-nitrogen, nitrate-nitrogen, nitrite plus nitrite as nitrogen, TDS, sulfate, chloride, boron, copper, nickel, mercury, chlordane, 4,4'-DDD, 4,4'-DDE, 4,4'-DDT, dieldrin, PCBs, toxaphene, chlorpyrifos, diazinon, and chronic toxicity based upon Total Maximum Daily Loads (TMDLs). The effluent limitations for these pollutants were established regardless of whether or not there is reasonable potential for the pollutants to be present in the discharge at levels that would cause or contribute to a violation of water quality standards. The Regional Water Board developed water quality-based effluent limitations for these pollutants pursuant to Part 122.44(d)(1)(vii), which does not require or contemplate a reasonable potential analysis. Similarly, the SIP at Section 1.3 recognizes that reasonable potential analysis is not appropriate if a TMDL has been developed.

In accordance with Section 1.3 of the SIP, the Regional Water Board conducted a reasonable potential analysis for each priority pollutant with an applicable criterion or objective to determine if a WQBEL is required in the permit. The Regional Water Board analyzed effluent data to determine if a pollutant in a discharge has a reasonable potential to cause or contribute to an excursion above a state water quality standard. For all parameters that demonstrate reasonable potential, numeric WQBELs are required. The RPA considers water quality criteria from the CTR and NTR, and when applicable, water quality objectives specified in the Basin Plan. To conduct the RPA, the Regional Water Board staff identified the maximum effluent concentration (MEC) and maximum background concentration in the receiving water for each constituent, based on data provided by the Permittee. The monitoring data cover the period from January 2008 to October 2013.

Section 1.3 of the SIP provides the procedures for determining reasonable potential to exceed applicable water quality criteria and objectives. The SIP specifies three triggers to complete a RPA:

Trigger 1 – If the MEC is greater than or equal to the CTR water quality criteria or applicable objective (C), a limitation is needed.

Trigger 2 – If background water quality (B) > C and the pollutant is detected in the effluent, a limitation is needed.

Trigger 3 – If other related information such as CWA 303(d) listing for a pollutant, discharge type, compliance history, then best professional judgment is used to determine that a limit is needed.

Sufficient effluent and ambient data are needed to conduct a complete RPA. If data are not sufficient, the Permittee will be required to gather the appropriate data for the Regional Water Board to conduct the RPA. Upon review of the data, and if the Regional Water Board determines that WQBELs are needed to protect the beneficial uses, the permit will be reopened for appropriate modification.

The RPA was performed for the priority pollutants regulated in the CTR for which data are available. Based on the RPA, pollutants that demonstrate reasonable potential are copper, mercury, nickel, chlordane, 4,4'-DDD, 4,4'-DDE, 4,4'-DDT, dieldrin, PCBs, and toxaphene because TMDLs are adopted for these constituents. Selenium also shows reasonable potential because receiving water concentration B is greater than the criteria and detected at the effluent. Cyanide shows reasonable potential because MEC is greater than C. The following Table summarizes results from RPA.

Table F-6. Summary of Reasonable Potential Analysis

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc. (B) µg/L	RPA Result - Need Limitation ?	Reason
1	Antimony	4300	1.1	19	No	C>B, C>MEC
2	Arsenic	150	9	13	No	C>B, C>MEC
3	Beryllium	Narrative	ND	ND	No	C>B, C>MEC
4	Cadmium	6.2	3.1	5	No	C>B, C>MEC
5a	Chromium III	549.5	2.8	0	No	C>B, C>MEC
5b	Chromium VI	11	9.9	ND	No	C>B, C>MEC
6	Copper	29	30	6.6	Yes	TMDL
7	Lead	10.8	6	6.7	No	C>B, C>MEC
8	Mercury	0.051	1.7	0.06	Yes	TMDL, Tier 1, and Tier 2
9	Nickel	166.6	10	10	Yes	TMDL
10	Selenium	5	4.5	23	Yes	Tier 2
11	Silver	36.8	10	4	No	C>B, C>MEC
12	Thallium	6.3	ND	30	No	C>MEC
13	Zinc	376.1	120	60	No	TMDL; but no assigned WLA
14	Cyanide	5.2	9.8	7.7	Yes	Tier 1 & Tier 2
15	Asbestos	7x10 ⁶ fibers/L	No sample	No sample	No	N/A
16	2,3,7,8-TCDD (Dioxin)	1.4x10 ⁻⁰⁸	ND	ND	No	C>B, C>MEC
17	Acrolein	780	ND	ND	No	C>B, C>MEC
18	Acrylonitrile	0.66	ND	ND	No	C>B, C>MEC
19	Benzene	71	ND	ND	No	C>B, C>MEC
20	Bromoform	360	2.8	2.8	No	C>B, C>MEC
21	Carbon Tetrachloride	4.4	ND	ND	No	C>B, C>MEC
22	Chlorobenzene	21,000	ND	ND	No	C>B, C>MEC
23	Dibromochloromethan	34	22	6.3	No	C>B, C>MEC

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc. (B) µg/L	RPA Result - Need Limitation ?	Reason
	e					
24	Chloroethane	No criteria	ND	ND	No	No criteria
25	2-chloroethyl vinyl ether	No criteria	ND	ND	No	No criteria
26	Chloroform	No criteria	46	0.9	No	No criteria
27	Dichlorobromomethane	46	35.1	13	No	C>B, C>MEC
28	1,1-dichloroethane	No criteria	ND	ND	No	No criteria
29	1,2-dichloroethane	99	ND	ND	No	C>B, C>MEC
30	1,1-dichloroethylene	3.2	ND	ND	No	C>B, C>MEC
31	1,2-dichloropropane	39	ND	ND	No	C>B, C>MEC
32	1,3-dichloropropylene	1,700	ND	ND	No	C>B, C>MEC
33	Ethylbenzene	29,000	ND	ND	No	C>B, C>MEC
34	Methyl bromide	4,000	0.5	ND	No	C>B, C>MEC
35	Methyl chloride	No criteria	29	ND	No	No criteria
36	Methylene chloride	1,600	ND	ND	No	C>B, C>MEC
37	1,1,2,2-tetrachloroethane	11	ND	ND	No	C>B, C>MEC
38	Tetrachloroethylene	8.85	0.9	0.9	No	C>B, C>MEC
39	Toluene	200,000	ND	ND	No	C>B, C>MEC
40	Trans 1,2-Dichloroethylene	140,000	ND	ND	No	C>B, C>MEC
41	1,1,1-Trichloroethane	No criteria	ND	ND	No	C>B, C>MEC
42	1,1,2-Trichloroethane	42	ND	ND	No	C>B, C>MEC
43	Trichloroethylene	81	ND	ND	No	C>B, C>MEC
44	Vinyl Chloride	525	ND	ND	No	C>B, C>MEC
45	2-chlorophenol	400	<5	<5/<5	No	C>B, C>MEC
46	2,4-dichlorophenol	790	<5	<5<5	No	C>B, C>MEC
47	2,4-dimethylphenol	2,300	<2	<2/<2	No	C>B, C>MEC
48	4,6-dinitro-o-cresol(aka 2-methyl-4,6-Dinitrophenol)	765	<5	<5/<5	No	C>B, C>MEC
49	2,4-dinitrophenol	14,000	<5	<5/<5	No	C>B, C>MEC
50	2-nitrophenol	No criteria	ND	ND	No	No criteria
51	4-nitrophenol	No criteria	ND	ND	No	No criteria
52	3-Methyl-4-Chlorophenol (aka P-chloro-m-cresol)	No criteria	ND	ND	No	No criteria
53	Pentachlorophenol	8.2	ND	ND	No	C>B, C>MEC
54	Phenol	4,600,000	10	ND	No	C>B, C>MEC
55	2,4,6-trichlorophenol	6.5	0.21	ND	No	C>B, C>MEC
56	Acenaphthene	2,700	ND	ND	No	C>B, C>MEC
57	Acenaphthylene	No criteria	ND	ND	No	No criteria

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc. (B) µg/L	RPA Result - Need Limitation ?	Reason
58	Anthracene	110,000	ND	ND	No	C>B, C>MEC
59	Benzidine	0.00054	ND	ND	No	C>B, C>MEC
60	Benzo(a)Anthracene	0.049	ND	ND	No	C>B, C>MEC
61	Benzo(a)Pyrene	0.049	ND	ND	No	C>B, C>MEC
62	Benzo(b)Fluoranthene	0.049	ND	ND	No	C>B, C>MEC
63	Benzo(ghi)Perylene	No criteria	ND	ND	No	No criteria
64	Benzo(k)Fluoranthene	0.049	ND	ND	No	C>B, C>MEC
65	Bis(2-Chloroethoxy) methane	No criteria	ND	ND	No	No criteria
66	Bis(2-Chloroethyl)Ether	1.4	ND	ND	No	C>B, C>MEC
67	Bis(2-Chloroisopropyl) Ether	170,000	ND	ND	No	C>B, C>MEC
68	Bis(2-Ethylhexyl)Phthalate	4	ND	ND	No	C>B, C>MEC
69	4-Bromophenyl Phenyl Ether	No criteria	ND	ND	No	No criteria
70	Butylbenzyl Phthalate	5,200	ND	ND	No	C>B, C>MEC
71	2-Chloronaphthalene	4,300	ND	ND	No	C>B, C>MEC
72	4-Chlorophenyl Phenyl Ether	No criteria	ND	ND	No	No criteria
73	Chrysene	0.049	ND	ND	No	C>B, C>MEC
74	Dibenzo(a,h) Anthracene	0.049	ND	ND	No	C>B, C>MEC
75	1,2-Dichlorobenzene	17,000	ND	ND	No	C>B, C>MEC
76	1,3-Dichlorobenzene	2,600	ND	ND	No	C>B, C>MEC
77	1,4-Dichlorobenzene	2,600	ND	ND	No	C>B, C>MEC
78	3-3'-Dichlorobenzidine	0.077	ND	ND	No	C>B, C>MEC
79	Diethyl Phthalate	120,000	0.27	ND	No	C>B, C>MEC
80	Dimethyl Phthalate	2,900,000	ND	ND	No	C>B, C>MEC
81	Di-n-Butyl Phthalate	12,000	0.32	ND	No	C>B, C>MEC
82	2-4-Dinitrotoluene	9.1	ND	ND	No	C>B, C>MEC
83	2-6-Dinitrotoluene	No criteria	0.68	ND	No	No criteria
84	Di-n-Octyl Phthalate	No criteria	ND	ND	No	No criteria
85	1,2-Diphenylhydrazine	0.54	ND	ND	No	C>B, C>MEC
86	Fluoranthene	370	ND	ND	No	C>B, C>MEC
87	Fluorene	14,000	ND	ND	No	C>B, C>MEC
88	Hexachlorobenzene	50	ND	ND	No	C>B, C>MEC
89	Hexachlorobutadiene	50	ND	ND	No	C>B, C>MEC
90	Hexachlorocyclopenta diene	17,000	ND	ND	No	C>B, C>MEC
91	Hexachloroethane	8.9	ND	ND	No	C>B, C>MEC

CTR No.	Constituent	Applicable Water Quality Criteria (C) µg/L	Max Effluent Conc. (MEC) µg/L	Maximum Detected Receiving Water Conc. (B) µg/L	RPA Result - Need Limitation ?	Reason
92	Indeno(1,2,3-cd)Pyrene	0.049	ND	ND	No	C>B, C>MEC
93	Isophorone	600	ND	ND	No	C>B, C>MEC
94	Naphthalene	No criteria	ND	ND	No	No criteria
95	Nitrobenzene	1,900	ND	ND	No	C>B, C>MEC
96	N-Nitrosodimethylamine	8.1	ND	ND	No	C>B, C>MEC
97	N-Nitrosodi-n-Propylamine	1.4	ND	ND	No	C>B, C>MEC
98	N-Nitrosodiphenylamine	16	ND	ND	No	C>B, C>MEC
99	Phenanthrene	No criteria	ND	ND	No	No criteria
100	Pyrene	11,000	ND	ND	No	C>B, C>MEC
101	1,2,4-Trichlorobenzene	No criteria	ND	ND	No	No criteria
102	Aldrin	0.00014	ND	ND	No	C>B, C>MEC
103	Alpha-BHC	0.013	ND	0.016	No	C>MEC
104	Beta-BHC	0.046	ND	ND	No	C>B, C>MEC
105	Gamma-BHC (aka Lindane)	0.063	0.004	0.03	No	C>B, C>MEC
106	delta-BHC	No criteria	ND	ND	No	No criteria
107	Chlordane	0.00059	ND	ND	Yes	TMDL
108	4,4'-DDT	0.00059	ND	ND	Yes	TMDL
109	4,4'-DDE	0.00059	0.0051	0.03	Yes	TMDL
110	4,4'-DDD	0.00084	ND	<0.01	Yes	TMDL
111	Dieldrin	0.00014	ND	<0.01	Yes	TMDL
112	Alpha-Endosulfan	0.056	ND	<0.01	No	C>B, C>MEC
113	Beta-Endosulfan	0.056	ND	<0.01	No	C>B, C>MEC
114	Endosulfan Sulfate	240	ND	<0.01	No	C>B, C>MEC
115	Endrin	0.036	ND	ND	No	C>B, C>MEC
116	Endrin Aldehyde	0.81	ND	ND	No	C>B, C>MEC
117	Heptachlor	0.00021	ND	ND	No	C>B, C>MEC
118	Heptachlor Epoxide	0.00011	<0.05	ND	No	C>B, C>MEC
119	PCB 1016	0.00017	<1	<0.1	Yes	TMDL
120	PCB 1221	0.00017	<1	<0.1	Yes	TMDL
121	PCB 1232	0.00017	<1	<0.1	Yes	TMDL
122	PCB 1242	0.00017	<1	<0.1	Yes	TMDL
123	PCB 1248	0.00017	<1	<0.1	Yes	TMDL
124	PCB 1254	0.00017	<1	<0.05	Yes	TMDL
125	PCB 1260	0.00017	<1	<0.1	Yes	TMDL
126	Toxaphene	0.0002	<1	<0.5	Yes	TMDL

4. WQBEL Calculations

- a. **Calculation Options.** Once RPA has been conducted using either the TSD or the SIP methodologies, WQBELs are calculated. Alternative procedures for calculating WQBELs include:
 - i. Use WLA from applicable TMDL
 - ii. Use a steady-state model to derive MDELs and AMELs.
 - iii. Where sufficient data exist, use a dynamic model which has been approved by the State Water Board.
- b. **Calleguas Creek Watershed Metals TMDL.** Concentration-based and mass-based WLAs are established for copper, nickel, and selenium in total recoverable forms, and are applied to POTWs during both wet and dry weather. Mass-based WLAs are developed for mercury for POTWs. Zinc allocations are not set because current information indicate that numeric targets for zinc are attained. The TMDL implementation plan includes a task to provide State Water Board data to support delisting of zinc. Waste load allocations for selenium are not set for POTWs because POTWs do not discharge to reaches listed for selenium. However, for Simi Valley WQCP's case, selenium effluent limitations are prescribed because the data show reasonable potential (Tier 2, B>C and was detected at the effluent).
- c. **SIP Calculation Procedure.** Section 1.4 of the SIP requires the step-by-step procedure to "adjust" or convert CTR numeric criteria into AMELs and MDELs, for toxics.

Step 3 of Section 1.4 of the SIP (page 8) lists the statistical equations that adjust CTR criteria for effluent variability.

Step 5 of Section 1.4 of the SIP (page 10) lists the statistical equations that adjust CTR criteria for averaging periods and exceedance frequencies of the criteria/objectives. This section also reads, "For this method only, maximum daily effluent limitations shall be used for POTWs in place of average weekly limitations.

Sample calculation for Cyanide:

Step 1: Identify applicable water quality criteria.

From California Toxics Rule (CTR), we can obtain the Criterion Maximum Concentration (CMC) and the Criterion Continuous Concentration (CCC).

Freshwater Aquatic Life Criteria:

CMC = 22 µg/L (CTR page 31712, column B1) and

CCC = 5.2 µg/L (CTR page 31712, column B2); and

Human Health Criteria for Organisms only = 220,000 µg/L (CTR page 31712, column D2).

Step 2: Calculate effluent concentration allowance (ECA)

ECA = Criteria in CTR, since no dilution is allowed.

Step 3: Determine long-term average (LTA) discharge condition

i. Calculate CV:

CV = Standard Deviation/Mean

= 0.6

Find the ECA Multipliers from SIP Table 1 (page 7), or by calculating them using equations on SIP page 6. When $CV = 0.6$, then:

ECA Multiplier acute = 0.321 and

ECA Multiplier chronic = 0.527

LTA acute = ECA acute x ECA Multiplier acute
= $22 \mu\text{g/L} \times 0.321 = 7.062 \mu\text{g/L}$

LTA chronic = ECA chronic x ECA Multiplier chronic
= $5.2 \mu\text{g/L} \times 0.527 = 2.740 \mu\text{g/L}$

Step 4: Select the lowest LTA

In this case, LTA chronic < LTA acute, therefore lowest LTA = $2.740 \mu\text{g/L}$

Step 5: Calculate the Average Monthly Effluent Limitation (AMEL) & Maximum Daily Effluent Limitation (MDEL) for AQUATIC LIFE

- i. Find the multipliers. You need to know CV and n (frequency of sample collection per month). If effluent samples are collected 4 times a month or less, then $n = 4$. CV was determined to be 0.6 in a previous step.

AMEL Multiplier = 1.55

MDEL Multiplier = 3.11

- ii. AMEL aquatic life = lowest LTA (from Step 4) x AMEL Multiplier
= $2.74 \mu\text{g/L} \times 1.55 = 4.247 \mu\text{g/L}$
- iii. MDEL aquatic life = lowest LTA (from Step 4) x MDEL Multiplier
= $2.74 \mu\text{g/L} \times 3.11 = 8.521 \mu\text{g/L}$

Step 6: Find the Average Monthly Effluent Limitation (AMEL) & Maximum Daily Effluent Limitation (MDEL) for HUMAN HEALTH

- i. Find factors. Given $CV = 0.6$ and $n = 4$.

For AMEL human health limit, there is no factor.

The MDEL/AMEL human health factor = 2.01

- ii. AMEL human health = ECA = $220,000 \mu\text{g/L}$
- iii. MDEL human health = ECA x MDEL/AMEL factor
= $220,000 \mu\text{g/L} \times 2.01 = 442,200 \mu\text{g/L}$

Step 7: Compare the AMELs for Aquatic life and Human health and select the lowest. Compare the MDELs for Aquatic life and Human health and select the lowest

- i. Lowest AMEL = $4.2 \mu\text{g/L}$ (Based on Aquatic life protection)
- ii. Lowest MDEL = $8.5 \mu\text{g/L}$ (Based on Aquatic life protection)

d. **Impracticability Analysis**

Federal NPDES regulations contained in 40 CFR part 122.45 continuous Permittees, states that all permit limitations, standards, and prohibitions, including those to achieve water quality standards, shall unless impracticable be stated as

maximum daily and average monthly discharge limitations for all Permittees other than POTWs.

As stated by USEPA in its long standing guidance for developing WQBELs average alone limitations are not practical for limiting acute, chronic, and human health toxic effects.

For example, a POTW sampling for a toxicant to evaluate compliance with a 7-day average limitation could fully comply with this average limit, but still be discharging toxic effluent on one, two, three, or up to four of these seven days and not be meeting 1-hour average acute criteria or 4-day average chronic criteria. For these reason, USEPA recommends daily maximum and 30-day average limits for regulating toxics in all NPDES discharges. For the purposes of protecting the acute effects of discharges containing toxicants (CTR human health for the ingestion of fish), daily maximum limitations have been established in this NPDES permit for mercury because it is considered to be a carcinogen, endocrine disruptor, and is bioaccumulative.

A 7-day average alone would not protect one, two, three, or four days of discharging pollutants in excess of the acute and chronic criteria. Fish exposed to these endocrine disrupting chemicals will be passed on to the human consumer. Endocrine disrupters alter hormonal functions by several means. These substances can:

- i. mimic or partly mimic the sex steroid hormones estrogens and androgens (the male sex hormone) by binding to hormone receptors or influencing cell signaling pathways.
 - ii. block, prevent and alter hormonal binding to hormone receptors or influencing cell signaling pathways.
 - iii. alter production and breakdown of natural hormones.
 - iv. modify the making and function of hormone receptors.
- e. **Mass-based limits.** 40 CFR part 122.45(f)(1) requires that except under certain conditions, all permit limits, standards, or prohibitions be expressed in terms of mass units. 40 CFR part 122.45(f)(2) allows the permit writer, at its discretion, to express limits in additional units (e.g., concentration units). The regulations mandate that, where limits are expressed in more than one unit, the permittee must comply with both.

Generally, mass-based limits ensure that proper treatment, and not dilution, is employed to comply with the final effluent concentration limits. Concentration-based effluent limits, on the other hand, discourage the reduction in treatment efficiency during low-flow periods and require proper operation of the treatment units at all times. In the absence of concentration-based effluent limits, a permittee would be able to increase its effluent concentration (i.e., reduce its level of treatment) during low-flow periods and still meet its mass-based limits. To account for this, this permit includes mass and concentration limits for some constituents.

Table F-7. Summary of WQBELs for Discharge Points 001 and 002

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Copper	µg/L	30.5 ¹¹	--	31 ¹¹		
	lbs/day	--	--	--		
Nickel	µg/L	169 ¹¹	--	960 ¹¹		
	lbs/day	--	--	--		
Mercury	µg/L	--	--	--		
	lbs/month	0.031 ¹²	--	--		
Selenium	µg/L	4.4	--	7.4		
	lbs/day ¹³	0.46	--	0.77		
Cyanide	µg/L	4.3	--	8.5		
	lbs/day ¹³	0.45	--	0.89		
Chlorpyrifos	µg/L	0.014 ¹⁴	--	0.025 ¹⁴		
	lbs/day	--	--	--		
Diazinon	µg/L	0.1 ¹⁴	--	0.1 ¹⁴		
	lbs/day	--	--	--		

¹¹ This limitation is derived from the final waste load allocation, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007.

¹² According to Metals TMDL, the mercury (in suspended sediment) effluent limitation, in lbs/month, is assumed that the total load in effluent water is equal to the suspended sediment load.

¹³ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day. During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

¹⁴ This limitation is derived from the final waste load allocation as set forth in the *Calleguas Creek Watershed Toxicity TMDL*, established by the Regional Water Board on July 7, 2005. The TMDL became effective on March 24, 2006. Consistent with the TMDL, the final WLA-based limit became operative on March 23, 2008. The interim limits specified in this TMDL lapsed prior to the date this permit was renewed. Therefore, only final WLA-based limits are incorporated into this permit.

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Chronic Toxicity ^{15,16}	Pass or Fail, % Effect	Pass ¹⁷	--	Pass or % Effect < 50		
Chlordane	µg/L	0.00059	--	0.0012		
	lbs/day	--	--	--		
4,4'-DDD	µg/L	0.00084	--	0.0017		
	lbs/day	--	--	--		
4,4'-DDE	µg/L	0.00059	--	0.0012		
	lbs/day	--	--	--		
4,4'-DDT	µg/L	0.00059	--	0.0012		
	lbs/day	--	--	--		
Dieldrin	µg/L	0.00014	--	0.00028		
	lbs/day	--	--	--		
PCBs ¹⁸	µg/L	0.00017	--	0.00034		
	lbs/day	--	--	--		
Toxaphene	µg/L	0.00016	--	0.00033		
	lbs/day	--	--	--		
Ammonia Nitrogen	mg/L	2.4 ¹⁹	--	3.3 ¹⁹		
	lbs/day	--	--	2.9 x Q ²⁰		

¹⁵ The *Calleguas Creek Watershed Toxicity TMDL* includes a WLA of 1.0 TUc for toxicity, which is required to be implemented in accordance with USEPA, State Water Board, and Regional Water Board resolutions, guidance and policy at the time of permit issuance or renewal. The numeric WLA is protecting the narrative Basin Plan objective. Consistent with the *Toxicity TMDL Implementation Plan*, this toxicity WLA will be implemented using current USEPA guidance in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R-10-003, June /2010)* and *EPA Regions 8, 9 and 10 Toxicity Training Tool (January 2010)*, <http://www2.epa.gov/region8/epa-regions-8-9-and-10-toxicity-training-tool-january-2010>.

¹⁶ "Pass" or "Fail" for Median Monthly Effluent Limitation (MDEL). "Pass" or "Fail" and "% Effect" for Maximum Daily Effluent Limitation (MDEL). The MDEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail".

¹⁷ This is a Median Monthly Effluent Limitation.

¹⁸ Applies to sum of all congener or isomer or homolog or Aroclor analyses.

¹⁹ This limitation is derived from the final waste load allocation for ammonia nitrogen, as set forth in the Resolution R4-2008-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region through revision of the Waste Load Allocations for the Calleguas Creek Watershed Nitrogen Compounds and Related Effects Total Maximum Daily Load*, established by the Regional Water Board on September 11, 2008 and became effective on October 15, 2009.

²⁰ Q represents the POTW effluent flow at the time the water quality measurement is collected (not to exceed 12.5 mgd) and a conversion factor to lbs/day based on the units of measure for the flow.

5. Whole Effluent Toxicity (WET)

Whole effluent toxicity (WET) testing protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth. Chronic toxicity is a more stringent requirement than acute toxicity. A chemical at a low concentration can have chronic effects but no acute effects until it gets to the higher level.

The 2003 permit contained final effluent limitations for both acute toxicity and chronic toxicity. The 2014 permit only contains final effluent limitations for chronic toxicity. Since chronic toxicity is a more stringent requirement than acute toxicity, the removal of the numeric acute toxicity effluent limitation from the 2003 permit does not constitute backsliding. The numeric chronic toxicity effluent limitation protects the Basin Plan acute toxicity objective and chronic toxicity is the more stringent and sensitive requirement.

For this permit, chronic toxicity in the discharge is evaluated using USEPA's 2010 Test of Significant Toxicity (TST) hypothesis testing approach. Chronic toxicity limitations are expressed as "Pass" or "Fail" for the median monthly summary result and "Pass" or "Fail" and "% Effect" for the maximum daily single result. The chronic toxicity effluent limitations are as stringent as necessary to protect the narrative Basin Plan Water Quality Objective for chronic toxicity. Those limitations are also consistent with the chronic toxicity WLA of 1.0 TUc and the assumptions of the *Calleguas Creek Toxicity TMDL* which went into effect on March 24, 2006, and the implementation language which reads as follows: "The toxicity WLAs will be implemented in accordance with USEPA, State Board and Regional Board resolutions, guidance (**emphasis added**) and policy at the time of permit issuance or renewal."

In January 2010, USEPA published a guidance document titled, "EPA Regions 8, 9 and 10 Toxicity Training Tool," which among other things discusses permit limit expression for chronic toxicity. The document acknowledges that NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both a Maximum Daily Limitation (MDL) and an Average Monthly Limitation (AML) for all Permittees other than POTWs, and as an average weekly limit (AWL) and AML for POTWs. Following Section 5.2.3 of the Technical Support Document (TSD), the use of an AWL is not appropriate for WET. In lieu of an AWL for POTWs, EPA recommends establishing an MDL for toxic pollutants and pollutants in water quality permitting, including WET. This is appropriate for two reasons. The basis for the average weekly requirement for POTWs derives from secondary treatment regulations and is not related to the requirement to assure achievement of WQS. Moreover, an average weekly requirement comprising up to seven daily samples could average out daily peak toxic concentrations for WET and therefore, the discharge's potential for causing acute and chronic effects would be missed. It is impracticable to use an AWL, because short-term spikes of toxicity levels that would be permissible under the 7-day average scheme would not be adequately protective of all beneficial uses. The MDL is the highest allowable value for the discharge measured during a calendar day or 24-hour period representing a calendar day. The permit should contain a condition indicating that the MDL is interpreted as the maximum acute or chronic WET result for that calendar month. The AML is the highest allowable value for the average of daily discharges obtained over a calendar month. For WET, this is the average of individual WET test results for that calendar month. However, in cases where a chronic mixing zone is not authorized, EPA Regions 9 and 10 continue to recommend that the AML for chronic WET should be expressed as a median monthly limit (MML).

Later in June 2010, USEPA published another guidance document titled, *Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, June 2010), in which they recommend the following: "Permitting authorities should consider adding the TST approach to their implementation procedures for analyzing valid WET data for their current NPDES WET Program." The TST approach is another statistical option for analyzing valid WET test data. Use of the TST approach does not result in any changes to EPA's WET test methods. Section 9.4.1.2 of the USEPA's *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA/821/R-02/013, 2002), recognizes that, "the statistical methods in this manual are not the only possible methods of statistical analysis." The TST approach can be applied to acute (survival) and chronic (sublethal) endpoints and is appropriate to use for both freshwater and marine EPA WET test methods

The effluent limitation for chronic toxicity was established regardless of whether or not there is reasonable potential for the pollutants to be present in the discharge at levels that would cause or contribute to a violation of water quality standards, since the *Toxicity TMDL* establishes a chronic toxicity WLA for the Simi Valley WQCP. The Regional Water Board developed water quality-based effluent limitations for these pollutants pursuant to Part 122.44(d)(1)(vii), which does not require or contemplate a reasonable potential analysis.

In the past, the State Water Board reviewed the circumstances warranting a numeric chronic toxicity effluent limitation for POTWs when there is reasonable potential with respect to SWRCB/OCC Files A-1496 & A-1496(a) [Los Coyotes/Long Beach Petitions]. On September 16, 2003, at a public hearing, the State Water Board adopted Order No. 2003-0012 deferring the issue of numeric chronic toxicity effluent limitation for POTWs until a subsequent Phase of the SIP is adopted. In the meantime, the State Water Board replaced the numeric chronic toxicity limit with a narrative effluent limitation and a 1 TUc trigger, in the Long Beach and Los Coyotes WRP NPDES permits. Simi Valley WQCP's NPDES permit contained a similar narrative chronic toxicity effluent limitation, with a numeric trigger for accelerated monitoring, consistent with the State Water Board's precedential Order.

However, many things have changed since the State Water Board adopted its precedential Order in 2003. Namely, the Regional Water Board adopted the *Calleguas Creek Toxicity TMDL* containing a numeric WLA for chronic toxicity for the five POTWs located in the watershed; USEPA published two new guidance documents with respect to chronic toxicity; the Los Angeles Regional Water Board adopted NPDES permits for industrial facilities incorporating TST-based limits for chronic toxicity and has adopted numeric chronic toxicity effluent limitations for industrial facilities with TMDL WLAs of 1.0 TUc; the Santa Ana Regional Water Board adopted an NPDES permit for a POTW incorporating TST-based limits for chronic toxicity; and the State Water Board is in the process of adopting a statewide plan incorporating the TST approach. Based on differences between the facts before the Regional Water Board in 2014 and the facts that were the basis for the State Water Board precedent in 2003, Regional Water Board staff conclude that the State Water Board precedent does not apply.

Never the less, this Order contains a reopener to allow the Regional Water Board to modify the permit in the future, if necessary, to make it consistent with any new policy, plan, law, or regulation.

D. Final Effluent Limitation Considerations

1. Anti-Backsliding Requirements

Sections 402(o) and 303(d)(4) of the CWA and federal regulations at 40 CFR part 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed.

The effluent limitations in this Order for the following pollutants have been relaxed as compared to the prior order: total ammonia nitrogen, nickel, selenium, and cyanide. The effluent limitations for the following pollutants that were included in the prior order are not included in this Order because the pollutant did not show reasonable potential to exceed the applicable water quality criteria: antimony, arsenic, cadmium, chromium VI, lead, silver, thallium, zinc, tetrachloroethylene, 1,4-dichlorobenzene, lindane (gamma-BHC), barium, iron, methoxychlor, 2,4-D, 2,4,5-TP (Silvex), and halomethanes.

This relaxation of effluent limitations for the above listed pollutants is consistent with the anti-backsliding requirements of the CWA and federal regulations. Section 303(d)(4)(B) of the Clean Water Act allows relaxation of effluent limitations where the quality of the receiving water equals or exceeds the levels necessary to protect the designated uses of the water or otherwise required by applicable water quality standards, if the revision is subject to and consistent with the state's antidegradation policy. Arroyo Simi is not impaired for antimony, arsenic, cadmium, chromium VI, lead, silver, thallium, zinc, tetrachloroethylene, 1,4-dichlorobenzene, lindane (gamma-BHC), barium, iron, fluoride, methoxychlor, 2,4-D, 2,4,5-TP (Silvex), and halomethanes. As described below, relaxation or removal of effluent limitations for these pollutants is consistent with the state's antidegradation policy. Therefore, the exception to the prohibition on relaxation of effluent limitations found in section 303(d)(4)(B) allows the removal of these effluent limitations.

Section 303(d)(4)(A) of the Clean Water Act allows revision of any effluent limitation based on a total maximum daily load or other waste load allocation established under this section if the cumulative effect of all such revised effluent limitations based on such total maximum daily load or waste load allocation will assure the attainment of such water quality standard. The revised effluent limitations for total ammonia nitrogen, nickel, selenium, and cyanide are based on a total maximum daily load or waste load allocation that will assure the attainment of water quality standards in Arroyo Simi for those pollutants.

2. Antidegradation Policies

40 CFR part 131.12 requires that state water quality standards include an antidegradation policy consistent with the federal antidegradation policy. On October 28, 1968, the State Water Board established California's antidegradation policy when it adopted Resolution No. 68-16, *Statement of Policy with Respect to Maintaining the Quality of the Waters of the State*. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The State Water Board has, in State Water Board Order No. 86-17 and an October 7, 1987 guidance memorandum, interpreted Resolution No. 68-16 to be fully consistent with the federal antidegradation policy contained in 40 CFR part 131.12. Similarly, CWA section 303(d)(4)(B) and 40 CFR part 131.12 require that all permitting actions be consistent with the federal antidegradation policy. Together, the state and federal antidegradation policies are designed to ensure that a water body will not be degraded resulting from the permitted discharge. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies.

Discharges permitted in this Order are consistent with the antidegradation provisions of 40 CFR part 131.12 and State Water Board Resolution No. 68-16 because the discharge

will not degrade any existing high quality water. Effluent limitations for antimony, arsenic, cadmium, chromium VI, lead, silver, thallium, zinc, tetrachloroethylene, 1,4-dichlorobenzene, lindane (gamma-BHC), barium, iron, fluoride, methoxychlor, 2,4-D, 2,4,5-TP (Silvex), and halomethanes are not included in this Order. The effluent limitations for total ammonia and nickel are relaxed in this Order as compared to the prior Order. The maximum concentrations of these pollutants detected in the receiving water were greater than that detected in the effluent, suggesting that no degradation of the receiving water is occurring. Furthermore, no changes to the plant's treatment facilities or processes are planned that would impact the concentrations of these constituents in the discharged effluent. Monitoring for these constituents in the effluent and receiving waters continue to be required under this Order. The Regional Water Board may modify the terms of this Order to prevent degradation of high quality waters based on any change in the concentration of these constituents in the effluent or receiving water that indicates that a degradation of receiving water quality may occur. The treatment required by this Order is the best practicable treatment or control of the discharge necessary to assure that a pollution or nuisance will not occur and the highest water quality consistent with maximum benefit to the people of the State will be maintained.

3. Stringency of Requirements for Individual Pollutants

This Order contains both TBELs and WQBELs for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD, TSS, pH, and percent removal of BOD and TSS. Restrictions on BOD, TSS and pH are discussed in section IV.B. of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements that are necessary to meet water quality standards.

Water quality-based effluent limitations have been scientifically derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR part 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and WQOs contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 CFR part 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA and the applicable water quality standards for purposes of the CWA.

Table F-8. Summary of Final Effluent Limitations for Discharge Points 001 and 002

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
BOD ₅ 20°C	mg/L	20	30	45			Existing
	lbs/day ²¹	2,080	3,130	4,690			

²¹ The mass emission rates are based on the plant design flow rate of 12.5 mgd, and are calculated as follows: Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day. During wet-weather

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
TSS	mg/L	15	40	45			Existing
	lbs/day ²¹	1,560	4,170	4,690			
pH	standard units	--	--	--	6.5	8.5	Existing
Removal Efficiency for BOD and TSS	%	85	--	--			Existing
Oil and Grease	mg/L	10	--	15			Existing
	lbs/day ²¹	1,040	--	1,560			
Settleable Solids	ml/L	0.1	--	0.3			Existing
Total Residual Chlorine	mg/L	--	--	0.1			Existing
	--	--	--	--			
Total Dissolved Solids	mg/L	850	--	--			Basin Plan
	lbs/day ²¹	88,610	--	--			
Sulfate	mg/L	250	--	--			Basin Plan
	lbs/day ²¹	26,060	--	--			
Chloride (dry-weather) ²²	lbs/day ²¹	15,640 ²²	--	--			TMDL
Chloride (wet-weather) ²³	mg/L	150		--			
Boron	mg/L	1.0	--	--			Basin Plan
	lbs/day ²¹	104	--	--			
MBAS	mg/L	0.5	--	--			Existing
	lbs/day	50	--	--			
Ammonia Nitrogen	mg/L	2.4 ²⁴	--	3.3 ²⁴			TMDL
	lbs/day	--	--	2.9 x Q ²⁵			
Nitrate + Nitrite (as N)	mg/L	9 ²⁴	--	--			TMDL
	lbs/day	--	--	--			

storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

²² Consistent with *Salts TMDL*, this final effluent limitation shall apply only during dry weather (see section VII.O. of this Order for definition and procedures for calculating effluent limitations).

²³ Any day that does not qualify as dry-weather is wet-weather. See also section VII.O. of this Order for definition of wet-weather.

²⁴ This final effluent limitation is derived from the final waste load allocation for ammonia nitrogen, as set forth in Resolution No. R4-2008-009, *Amendment to the Water Quality Control Plan for the Los Angeles Region through revision of the Waste Load Allocations for the Calleguas Creek Watershed Nitrogen Compounds and Related Effects Total Maximum Daily Load*, adopted by the Regional Water Board on September 11, 2008, and became effective on October 15, 2009.

²⁵ Q represents the POTW effluent flow at the time the water quality measurement is collected (not to exceed 12.5 mgd) and a conversion factor to lbs/day based on the units of measure for the flow.

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
Nitrate (as N)	mg/L	9 ²⁴	--	--			TMDL
	lbs/day	--	--	--			
Nitrite (as N)	mg/L	0.9 ²⁴	--	--			TMDL
	lbs/day	--	--	--			
Copper	µg/L	30.5 ²⁶	--	31 ²⁶			TMDL
	lbs/day	--	--	--			
Nickel	µg/L	169 ²⁶	--	960 ²⁶			TMDL
	lbs/day	--	--	--			
Mercury	lbs/month	0.031 ²⁷	--	--			TMDL
Selenium	µg/L	4.4	--	7.4			SIP/CTR
	lbs/day ²¹	0.46	--	0.77			
Cyanide	µg/L	4.3	--	8.5			SIP/CTR
	lbs/day ²¹	0.45	--	0.89			
Chlorpyrifos	µg/L	0.014 ²⁸	--	0.025 ²⁸			TMDL
	lbs/day	--	--	--			
Diazinon	µg/L	0.1 ²⁸	--	0.1 ²⁸			TMDL
	lbs/day	--	--	--			
Chronic Toxicity ²⁹	Pass or Fail, % Effect	Pass ³⁰	--	Pass or % Effect < 50			TMDL, TST
Chlordane	µg/L	0.00059	--	0.0012			TMDL
	lbs/day	--	--	--			
4,4'-DDD	µg/L	0.00084	--	0.0017			TMDL
	lbs/day	--	--	--			
	µg/L	0.00059	--	0.0012			

²⁶ This limitation is derived from the final waste load allocation, as set forth in the *Calleguas Creek Watershed Metals TMDL*, established by the Regional Water Board on June 8, 2006. The TMDL became effective on March 26, 2007.

²⁷ According to the Metals TMDL, the mercury (in suspended sediment) effluent limitation, in lbs/month, is assumed that the total load in effluent water is equal to the suspended sediment load.

²⁸ This limitation is derived from the final waste load allocation as set forth in the *Calleguas Creek Watershed Toxicity TMDL*, established by the Regional Water Board on July 7, 2005. The TMDL became effective on March 24, 2006. Consistent with the TMDL, the implementation of final WLA-based limit became operative on March 25, 2008. The interim limits specified in this TMDL lapsed prior to the date this permit was renewed. Therefore, only final WLA-based limits are incorporated into this permit.

²⁹ "Pass" or "Fail" for Median Monthly Effluent Limitation (MMEL). "Pass" or "Fail" and "% Effect" for Maximum Daily Effluent Limitation (MDEL). The MMEL for chronic toxicity shall only apply when there is a discharge more than one day in a calendar month period. During such calendar months, exactly three independent toxicity tests are required when one toxicity test results in "Fail".

³⁰ This is a Median Monthly Effluent Limitation.

Parameter	Units	Effluent Limitations					Basis
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
4,4'-DDE	lbs/day	--	--	--			TMDL
4,4'-DDT	µg/L	0.00059	--	0.0012			TMDL
	lbs/day	--	--	--			
Dieldrin	µg/L	0.00014	--	0.00028			TMDL
	lbs/day	--	--	--			
PCBs ³¹	µg/L	0.00017	--	0.00034			TMDL
	lbs/day	--	--	--			
Toxaphene	µg/L	0.00016	--	0.00033			TMDL
	lbs/day	--	--	--			

E. Interim Effluent Limitations

No interim limits are included in this Order.

F. Land Discharge Specifications – Not Applicable

G. Recycling Specifications

The Permittee currently recycles approximately 0.6% (18.25 million gallons per year) of the total treated effluent and plans to continue doing so. Recycled water is used for landscape irrigation at the Simi Valley WQCP and for dust control at a landfill. The production, distribution, and reuse of recycled water are presently regulated under Water Reclamation Requirements (WRR) Order No. 87-46, adopted by this Board on May 5, 1987.

The City of Simi Valley proposes to extend the existing recycled water distribution system for border-use landscape irrigation and industrial use sites in western areas of Simi Valley and Thousand Oaks. The proposed expansion will consist of an upgraded pump station at the Simi Valley WQCP, a 1.25 million gallon capacity recycled water distribution storage reservoir, and approximately 12.2 miles of transmission mains to deliver recycled water supply for various user sites for irrigation and other non-potable use. The average recycled water served to users is approximately 25 acre-feet per year (AFY). The proposed recycled water use will increase to 743 AFY. Any change in recycled water use will require amendment to the WRRs, Order No. 87-46.

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

Receiving water limitations are based on WQOs contained in the Basin Plan and are a required part of this Order.

B. Groundwater

Limitations in this Order must protect not only surface receiving water beneficial uses, but also, the beneficial uses of underlying groundwater where there is a recharge beneficial use of the surface water. In addition to a discharge to surface water, there is discharge that can impact groundwater. Sections of the Arroyo Simi and Calleguas Creek, near Simi Valley WQCP discharge points, are designated as GWR beneficial use. Surface water from the

³¹ Applies to sum of all congener or isomer or homolog or Aroclor analyses.

Arroyo Simi percolates into the Simi Valley and Ventura Central Groundwater Basins with MUN beneficial use specified in the Basin Plan. Since groundwater from the Basin is used to provide drinking water to the community, the groundwater aquifers should be protected.

VI. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR part 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR part 122.42, are provided in Attachment D. The Permittee must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Parts 122.41(a)(1) and (b) through (n) of 40 CFR establish conditions that apply to all state-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Part 123.25(a)(12) of 40 CFR allows the state to omit or modify conditions to impose more stringent requirements. In accordance with 40 CFR part 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR part 122.41(j)(5) and (k)(2) because the enforcement authority under the CWC is more stringent. In lieu of these conditions, this Order incorporates by reference CWC section 13387(e).

B. Special Provisions

1. Reopener Provisions

- a. This provision is based on 40 CFR part 123. The Regional Water Board may reopen the permit to modify permit conditions and requirements. Causes for modifications include the promulgation of new regulations, modification in sludge use or disposal practices, or adoption of new regulations by the State Water Board or Regional Water Board, including revisions to the Basin Plan.

2. Special Studies and Additional Monitoring Requirements

- a. **Constituent of Emerging Concern (CEC).** In recent years, the Los Angeles Regional Water Board has incorporated monitoring of a select group of man-made chemicals, particularly pesticides, pharmaceuticals and personal care products, known collectively as CECs, into permits issued to POTWs to better understand the propensity, persistence and effects of CECs in our environment. Recently adopted permits in this region contain requirements for CEC effluent monitoring and submittal of a work plan identifying the CECs to be monitored in the effluent, sample type, sampling frequency and sampling methodology. Based on feedback we have received from permittees and our review of the results of a recent CEC-related study by the Southern California Coastal Water Research Project (SCCWRP) and the State Water Board, we have modified our CEC monitoring program to respond to feedback while proceeding to fill identified data gaps without overly burdening any one permittee.

The Permittee shall conduct a special study to investigate the CECs in the effluent discharge as listed in Table E-5 of the MRP. These constituents shall be monitored annually for at least two years. The Regional Water Board has determined that two years is an appropriate time period to determine those CECs that are present in POTW effluent. Monitoring results shall be reported as part of the annual report.

from its collection system or treatment plant covered by this Order shall be reported to regulatory agencies.

The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order 2006-0003-DWQ (SSO WDR) on May 2, 2006. The Monitoring and Reporting Requirements for the SSO WDR were amended by Water Quality Order WQ 2008-0002-EXEC on February 20, 2008. The SSO WDR requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the SSO WDR. The SSO WDR requires agencies to develop sanitary sewer management plans (SSMPs) and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions.

Furthermore, the SSO WDR contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. Inasmuch that the Permittee's collection system is part of the system that is subject to this Order, certain standard provisions are applicable as specified in Provisions, section VI.C.5. For instance, the 24-hour reporting requirements in this Order are not included in the SSO WDR. The Permittee must comply with both the SSO WDR and this Order. The Permittee and public agencies that are discharging wastewater into the Facility were required to obtain enrollment for regulation under the SSO WDR by December 1, 2006.

In the past, the Los Angeles Regional Water Board has experienced loss of recreational use in coastal beaches and in Arroyo Conejo as a result of major sewage spills. The SSO requirements are intended to prevent or minimize impacts to receiving waters as a result of spills.

6. Other Special Provisions (Not Applicable)

7. Compliance Schedules (Not Applicable)

VII. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

Section 308(a) of the federal Clean Water Act and sections 122.41(h), (j)-(l), 122.44(i), and 122.48 of Title 40 of the Code of Federal Regulations (40 CFR) require that all NPDES permits specify monitoring and reporting requirements. CWC sections 13267 and 13383 also authorizes the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The MRP of this Order establishes monitoring, reporting, and recordkeeping requirements that implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this Facility.

A. Influent Monitoring

Influent monitoring is required:

- To determine compliance with the permit conditions for BOD₅ 20°C and suspended solids removal rates;
- To assess treatment plant performance;
- To assess the effectiveness of the Pretreatment Program; and,
- As a requirement of the PMP

B. Effluent Monitoring

The Permittee is required to conduct monitoring of the permitted discharges in order to evaluate compliance with permit conditions. Monitoring requirements are given in the MRP Attachment E. This provision requires compliance with the MRP, and is based on 40 CFR

parts 122.44(i), 122.62, 122.63, and 124.5. The MRP is a standard requirement in almost all NPDES permits (including this Order) issued by the Regional Water Board. In addition to containing definition of terms, it specifies general sampling/analytical protocols and the requirements of reporting spills, violation, and routine monitoring data in accordance with NPDES regulations, the CWC, and Regional Water Board policies. The MRP also contains sampling program specific for the Permittee's wastewater treatment plant. It defines the sampling stations and frequency, pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all pollutants for which effluent limitations are specified. Further, in accordance with section 1.3 of the SIP, a periodic monitoring is required for all priority pollutants defined by the CTR, for which criteria apply and for which no effluent limitations have been established, to evaluate reasonable potential to cause or contribute to an excursion above a water quality standard.

Monitoring for those pollutants expected to be present in the discharge from the Facility, will be required as shown on the MRP and as required in the SIP. Semi-annual monitoring for priority pollutants in the effluent is required in accordance with the Pretreatment requirements.

Table F-9. Monitoring Frequency Comparison

Parameter	Monitoring Frequency (2003 Permit)	Monitoring Frequency (2014 Permit)
Total waste flow	Continuous	continuous
Total residual chlorine	--	daily
Turbidity	Continuous	continuous
Temperature	Weekly	weekly
pH	Weekly	weekly
Settleable solids	Weekly	weekly
Total suspended solids	Weekly	weekly
Oil and grease	Monthly	quarterly
BOD	Weekly	weekly
Total coliform	Daily	daily
Fecal Coliform	Daily	daily
E.coli	not monitored	daily (as necessary)
Total Dissolved Solids	Monthly	monthly
Sulfate	Monthly	monthly
Chloride	Monthly	monthly
Boron	Monthly	monthly
MBAS	Monthly	monthly
Ammonia nitrogen	Monthly	monthly
Nitrate + nitrite (as nitrogen)	Monthly	monthly
Nitrite nitrogen	Monthly	monthly
Chronic toxicity	Monthly	no change
Bis(2-ethylhexyl)phthalate	semiannually	quarterly
Total Nitrogen	Monthly	monthly
Total Phosphorus	Monthly	monthly
Algal biomass (Chlorophyll a)	Monthly	deleted
Iron	Quarterly	semiannually
Fluoride	Monthly	semiannually
Antimony	Quarterly	semiannually
Arsenic	Quarterly	semiannually

Parameter	Monitoring Frequency (2003 Permit)	Monitoring Frequency (2014 Permit)
Beryllium	semiannually	no change
Cadmium	Quarterly	semiannually
Chromium III	semiannually	no change
Chromium VI	Quarterly	semiannually
Copper	Quarterly	monthly
Lead	Quarterly	semiannually
Mercury	Quarterly	monthly
Nickel	Quarterly	monthly
Selenium	Monthly	no change
Silver	Quarterly	semiannually
Thallium	Quarterly	semiannually
Zinc	Quarterly	no change
Cyanide	Monthly	no change
2,3,7,8-TCDD (Dioxin)	Quarterly	semiannually
Bromoform	Quarterly	quarterly
Dibromochloromethane	Quarterly	quarterly
Chloroform	Quarterly	quarterly
Bromodichloromethane	Quarterly	quarterly
Tetrachloroethylene	Quarterly	semiannually
N-Nitrosodi-n-propylamine	semiannually	no change
Gamma-BHC (Lindane)	Monthly	semiannually
Chlordane	semiannually	quarterly
4,4'-DDT	semiannually	quarterly
4,4'- DDE	Monthly	quarterly
4,4'-DDD	semiannually	quarterly
Dieldrin	semiannually	quarterly
Endrin	Quarterly	semiannually
Heptachlor epoxide	semiannually	no change
PCBs	semiannually	quarterly
Aroclor 1016	semiannually	quarterly
Aroclor 1221	semiannually	quarterly
Aroclor 1232	semiannually	quarterly
Aroclor 1242	semiannually	quarterly
Aroclor 1248	semiannually	quarterly
Aroclor 1254	semiannually	quarterly
Aroclor 1260	semiannually	quarterly
Toxaphene	Quarterly	no change
Chlorpyrifos	not monitored	quarterly
Diazinon	not monitored	quarterly
Methoxychlor	Quarterly	semiannually
Barium	Quarterly	semiannually
2,4-D	Quarterly	semiannually
2,4,5-TP (Silvex)	Quarterly	semiannually
Halomethanes ³²	Quarterly	no change
Ammonium perchlorate	semiannually	no change
1,4-Dioxane	semiannually	no change
1,2,3-Trichloropropane	semiannually	no change
Methyl-tert-butyl-ether (MTBE)	--	semiannually

³² Halomethanes shall mean the sum of bromoform, bromodichloromethane, chloroform, and dibromochloromethane.

Parameter	Monitoring Frequency (2003 Permit)	Monitoring Frequency (2014 Permit)
Remaining USEPA priority pollutant not listed on this Table	--	semiannually

C. WET Requirements

WET testing protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a short or longer period of time and may measure mortality, reproduction, and growth. Chronic toxicity is a more stringent requirement than acute toxicity. A chemical at a low concentration can have chronic effects but no acute effects until it gets to the higher level. For this permit, chronic toxicity in the discharge is evaluated using USEPA's 2010 TST hypothesis testing approach. The chronic toxicity effluent limitations are as stringent as necessary to protect the Basin Plan Water Quality Objective for chronic toxicity. Those limitations are also consistent with the assumptions of the *Calleguas Creek Toxicity TMDL* which went into effect on March 24, 2006, and the implementation language which reads as follows: "The toxicity WLAs will be implemented in accordance with USEPA, State Board and Regional Board resolutions, **guidance** (emphasis added) and policy at the time of permit issuance or renewal." The rationale for WET has been discussed extensively in section IV.C.5 of this Fact Sheet.

D. Receiving Water Monitoring

1. Surface Water

Receiving water monitoring is required to determine compliance with receiving water limitations and to characterize the water quality of the receiving water.

2. Groundwater – (Not Applicable)

E. Other Monitoring Requirements

1. Watershed Monitoring and Bioassessment Monitoring

The goals of the Watershed-wide Monitoring Program including the bioassessment monitoring for the Ventura River Watershed are to:

- Determine compliance with receiving water limits;
- Monitor trends in surface water quality;
- Ensure protection of beneficial uses;
- Provide data for modeling contaminants of concern;
- Characterize water quality including seasonal variation of surface waters within the watershed;
- Assess the health of the biological community; and,
- Determine mixing dynamics of effluent and receiving waters in the estuary.

VIII. CONSIDERATION OF NEED TO PREVENT NUISANCE AND CWC SECTION 13241 FACTORS.

Some of the provisions/requirements in this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations. As required by CWC section 13263, the Regional Water Board has considered the need to prevent nuisance and the factors listed in CWC section 13241 in

establishing the state law provisions/requirements. The Regional Water Board finds, on balance, that the state law requirements in this Order are reasonably necessary to prevent nuisance and to protect beneficial uses identified in the Basin Plan, and the section 13241 factors are not sufficient to justify failing to protect those beneficial uses.

- A. Need to prevent nuisance: The state law requirements in this Order are required to prevent pollution or nuisance as defined in section 13050, subdivisions (l) and (m), of the CWC. Many are also required in accordance with narrative water quality objectives in the Basin Plan. These state requirements include, but are not limited to, groundwater limitations, spill prevention plans, operator certification, sanitary sewer overflow reporting, and requirements for standby or emergency power.
- B. Past, present, and probable future beneficial uses of water: Chapter 2 of the Basin Plan identifies designated beneficial uses for water bodies in the Los Angeles Region. Beneficial uses of water relevant to this Order are also identified above in Section III.C.1.
- C. Environmental characteristics of the hydrographic unit under consideration, including the quality of water available thereto: The environmental characteristics are discussed in the Region's Watershed Management Initiative Chapter, as well as available in State of the Watershed reports and the State's CWA Section 303(d) List of impaired waters. The environmental characteristics of the hydrographic unit, including the quality of available water, will be improved by compliance with the requirements of this Order. Additional information on the CCW is available at http://www.waterboards.ca.gov/losangeles/water_issues/programs/regional_program/Water_Quality_and_Watersheds/ws_calleguas.shtml.
- D. Water quality conditions that could reasonably be achieved through the coordinated control of all factors which affect water quality in the area: The beneficial uses of the waterbodies in the CCW can reasonably be achieved through the coordinate control of all factors that affect water quality in the area. TMDLs have been developed (as required by the Clean Water Act) for many of the impairments in the watershed. A number of Regional Water Board programs and actions are in place to address the water quality impairments in the watershed, including regulation of point source municipal and industrial discharges with appropriate NPDES permits and non-point source discharges such as irrigated agriculture. All of these regulatory programs control the discharge of pollutants to surface and ground waters to prevent nuisance and protect beneficial uses. These regulatory programs have resulted in watershed solutions and have improved water quality. Generally, improvements in the quality of the receiving waters impacted by the permittee's discharges can be achieved by reducing the volume of discharges to receiving waters (e.g., through increased recycling), reducing pollutant loads through source control/pollution prevention, including operational source control such as public education (e.g., disposal of pesticides, pharmaceuticals, and personal care products into the sewer) and product or materials elimination or substitution, and removing pollutants through treatment.
- E. Economic considerations: The Permittee did not present any evidence regarding economic considerations related to this Order. However, the Regional Water Board has considered the economic impact of requiring certain provisions pursuant to state law. The additional costs associated with complying with state law requirements are reasonably necessary to prevent nuisance and protect beneficial uses identified in the Basin Plan. Further, the loss of, or impacts to, beneficial uses would have a detrimental economic impact. Economic considerations related to costs of compliance are therefore not sufficient, in the Regional Water Board's determination, to justify failing to prevent nuisance and protect beneficial uses.
- F. Need for developing housing within the region: The Regional Water Board has no evidence regarding the need for developing housing within the region or how the Permittee's discharge

will affect that need. The Regional Water Board, however, does not anticipate that these state law requirements will adversely impact the need for housing in the area. The region generally relies on imported water to meet many of its water resource needs. Imported water makes up a vast majority of the region's water supply, with local groundwater, local surface water, and reclaimed water making up the remaining amount. This Order helps address the need for housing by controlling pollutants in discharges, which will improve the quality of local surface and ground water, as well as water available for recycling and re-use. This in turn may reduce the demand for imported water thereby increasing the region's capacity to support continued housing development. A reliable water supply for future housing development is required by law, and with less imported water available to guarantee this reliability, an increase in local supply is necessary. Therefore, the potential for developing housing in the area will be facilitated by improved water quality.

- G. Need to develop and use recycled water:** The State Water Board's Recycled Water Policy requires the Regional Water Boards to encourage the use of recycled water. In addition, as discussed immediately above, a need to develop and use recycled water exists within the region, especially during times of drought. To encourage recycling, the Permittee is required by this Order to continue to explore the feasibility of recycling to maximize the beneficial reuse of tertiary treated effluent.

The Permittee currently recycles approximately 0.6% (18.25 million gallons per year) of the total treated effluent and plans to continue doing so. The City of Simi Valley proposes to extend the existing recycled water distribution system for border-use landscape irrigation and industrial use sites in western areas of Simi Valley and Thousand Oaks. The proposed expansion will consist of an upgraded pump station at the Simi Valley WQCP, a 1.25 million gallon capacity recycled water distribution storage reservoir, and approximately 12.2 miles of transmission mains to deliver recycled water supply for various user sites for irrigation and other non-potable use. The average recycled water served to users is approximately 25 acre-feet per year (AFY). The proposed recycled water use will increase to 743 AFY

IX. PUBLIC PARTICIPATION

The Regional Water Board has considered the issuance of WDRs that will serve as an NPDES permit for Simi Valley WQCP. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs and has encouraged public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board notified the Permittee and interested agencies and persons of its intent to prescribe WDRs for the discharge and provided an opportunity to submit written comments and recommendations. Notification was provided through the following: (1) one copy at the entrance of 600 West Los Angeles Avenue, Simi Valley and (2) posted at the City of Simi Valley website www.simivalley.org/claendar, the City's event calendar for May 8, 2014.

The public had access to the agenda and any changes in dates and locations through the Regional Water Board's website at: <http://www.waterboards.ca.gov/losangeles/>.

B. Written Comments

Interested persons were invited to submit written comments concerning tentative WDRs as provided through the notification process. Comments were due either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order, or by email submitted to losangeles@waterboards.ca.gov.

To be fully responded to by staff and considered by the Regional Water Board, the written comments were due at the Regional Water Board office by **5:00 p.m. on April 14, 2014.**

C. Public Hearing

The Regional Water Board held a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: May 8, 2014
Time: 9:00 a.m.
Location: City of Simi Valley, Council Chambers
2929 Tapo Canyon Road
Simi Valley, California

Interested persons were invited to attend. At the public hearing, the Regional Water Board heard testimony pertinent to the discharge, WDRs, and permit. For accuracy of the record, important testimony was requested in writing.

D. Reconsideration of Waste Discharge Requirements

Any aggrieved person may petition the State Water Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be received by the State Water Board at the following address within 30 calendar days of the Regional Water Board's action:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

For instructions on how to file a petition for review, see
http://www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instr.shtml

E. Information and Copying

The ROWD, other supporting documents, and comments received are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (213) 576-6600.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to Raul Medina at (213) 620-2160.

ATTACHMENT G – TOXICITY REDUCTION EVALUATION (TRE) WORK PLAN

INFORMATION AND DATA ACQUISITION

A. Operations and performance review

1. NPDES permit requirements
 - a. Effluent limitations
 - b. Special conditions
 - c. Monitoring data and compliance history
2. POTW design criteria
 - a. Hydraulic loading capacities
 - b. Pollutant loading capacities
 - c. Biodegradation kinetics calculations/assumptions
3. Influent and effluent conventional pollutant data
 - a. Biochemical oxygen demand (BOD5)
 - b. Chemical oxygen demand (COD)
 - c. Suspended solids (SS)
 - d. Ammonia
 - e. Residual chlorine
 - f. pH
4. Process control data
 - a. Primary sedimentation - hydraulic loading capacity and BOD and SS removal
 - b. Activated sludge - Food-to-microorganism (F/M) ratio, mean cell residence time (MCRT), mixed liquor suspended solids (MLSS), sludge yield, and BOD and COD removal
 - c. Secondary clarification - hydraulic and solids loading capacity, sludge volume index and sludge blanket depth
5. Operations information
 - a. Operating logs
 - b. Standard operating procedures
 - c. Operations and maintenance practices
6. Process sidestream characterization data
 - a. Sludge processing sidestreams
 - b. Tertiary filter backwash
 - c. Cooling water
7. Combined sewer overflow (CSO) bypass data
 - a. Frequency

- b. Volume
- 8. Chemical coagulant usage for wastewater treatment and sludge processing
 - a. Polymer
 - b. Ferric chloride
 - c. Alum

B. POTW influent and effluent characterization data

- 1. Toxicity
- 2. Priority pollutants
- 3. Hazardous pollutants
- 4. SARA 313 pollutants,
- 5. Other chemical-specific monitoring results

C. Sewage residuals (raw, digested, thickened and dewatered sludge and incinerator ash) characterization data

- 1. EP toxicity
- 2. Toxicity Characteristic Leaching Procedure (TCLP)
- 3. Chemical analysis

D. Industrial waste survey (IWS)

- 1. Information on IUs with categorical standards or local limits and other significant non-categorical IUs
- 2. Number of IUs
- 3. Discharge flow
- 4. Standard Industrial Classification (SIC) code
- 5. Wastewater flow
 - a. Types and concentrations of pollutants in the discharge
 - b. Products manufactured
- 6. Description of pretreatment facilities and operating practices
- 7. Annual pretreatment report
- 8. Schematic of sewer collection system

9. POTW monitoring data
 - a. Discharge characterization data
 - b. Spill prevention and control procedures
 - c. Hazardous waste generation
10. IU self-monitoring data
 - a. Description of operations
 - b. Flow measurements
 - c. Discharge characterization data
 - d. Notice of sludge loading
 - e. Compliance schedule (if out of compliance)
11. Technically based local limits compliance reports
12. Waste hauler monitoring data manifests
13. Evidence of POTW treatment interferences (i.e., biological process inhibition)

ATTACHMENT H – BIOSOLIDS AND SLUDGE MANAGEMENT

BIOSOLIDS USE AND DISPOSAL REQUIREMENTS

- A. All biosolids generated by the Permittee shall be reused or disposed of in compliance with the applicable portions of:
1. 40 CFR part 503: for biosolids that are land applied, placed in surface disposal sites (dedicated land disposal sites or monofills), or incinerated; 40 CFR part 503 Subpart B (land application) applies to biosolids placed on the land for the purpose of providing nutrients or conditioning the soil for crops or vegetation. 40 CFR part 503 Subpart C (surface disposal) applies to biosolids placed on the land for the purpose of disposal.
 2. 40 CFR part 258: for biosolids disposed of in Municipal Solid Waste landfills.
 3. 40 CFR part 257: for all biosolids disposal practices not covered under 40 CFR part 258 or 503.
- B. The Permittee is responsible for assuring that all biosolids from its facility are used or disposed of in accordance with 40 CFR part 503, whether the Permittee reuses or disposes of the biosolids itself or transfers them to another party for further treatment, reuse, or disposal. The Permittee is responsible for informing subsequent preparers, appliers, or disposers of the requirements they must meet under 40 CFR part 503.
- C. Duty to mitigate: The Permittee shall take all reasonable steps to prevent or minimize any biosolids use or disposal which may adversely impact human health or the environment.
- D. No biosolids shall be allowed to enter wetland or other waters of the United States.
- E. Biosolids treatment, storage, and use or disposal shall not contaminate groundwater.
- F. Biosolids treatment, storage, and use or disposal shall not create a nuisance such as objectionable odors or flies.
- G. The Permittee shall assure that haulers who transport biosolids off site for further treatment, storage, reuse, or disposal take all necessary measures to keep the biosolids contained.
- H. If biosolids are stored for over two years from the time they are generated, the Permittee must ensure compliance with all the requirements for surface disposal under 40 CFR part 503 Subpart C, or must submit a written request to USEPA with the information in part 503.20 (b), requesting permission for longer temporary storage.
- I. Sewage sludge containing more than 50 mg/kg PCB's shall be disposed of in accordance with 40 CFR part 761.
- J. Any off-site biosolids treatment, storage, use or disposal site operated by the Permittee within Region 4 (Los Angeles Region of RWQCB) that is not subject to its own Waste Discharge Requirements shall have facilities adequate to divert surface runoff from the adjacent area, to protect the site boundaries from erosion, and to prevent any conditions that would cause

drainage from the materials in the disposal site to escape from the site. Adequate protection is defined as protected from at least a 100-year storm and from the highest tidal stage that may occur.

- K. Inspection and Entry: The Regional Water Board, USEPA or an authorized representative thereof, upon the presentation of credentials, shall be allowed by the Permittee, directly or through contractual arrangements with their biosolids management contractors, to:
1. enter upon all premises where biosolids are produced by the Permittee and all premises where Permittee biosolids are further treated, stored, used, or disposed, either by the Permittee or by another party to whom the Permittee transfers the biosolids for further treatment, storage, use, or disposal;
 2. have access to and copy any records that must be kept under the conditions of this permit or of 40 CFR part 503, by the Permittee or by another party to whom the Permittee transfers the biosolids for further treatment, storage, use, or disposal; and
 3. inspect any facilities, equipment (including monitoring and control equipment), practices, or operations used in the production of biosolids and further treatment, storage, use, or disposal by the Permittee or by another party to whom the Permittee transfers the biosolids for further treatment, storage, use, or disposal.
- L. Monitoring shall be conducted as follows:

1. Biosolids shall be tested for the metals required in part 503.16 (for land application) or part 503.26 (for surface disposal), using the methods in "Test Methods for Evaluating Solids Waste, Physical/Chemical Methods" (SW-846), as required in 503.8(b)(4), at the following minimum frequencies:

<u>Volume (dry metric tons/year)</u>	<u>Frequency</u>
0 – 290	once per year
290 – 1500	once per quarter
1500 – 15000	once per 60 days
> 15000	once per month

For accumulated, previously untested biosolids, the Discharge shall develop a representative sampling plan, which addresses the number and location of sampling points, and collect representative samples.

Test results shall be expressed in mg pollutant per kg biosolids on a 100% dry weight basis.

Biosolids to be land applied shall be tested for Organic-N, ammonium-N, and nitrate-N at the frequencies required above.

2. Prior to land application, the Permittee shall demonstrate that the biosolids meet Class A or Class B pathogen reduction levels by one of the methods listed in 40 CFR part 503.32. Prior to disposal in a surface disposal site, the Permittee shall demonstrate that the biosolids meet Class B levels or shall ensure that the site is covered at the end of each operating day.

3. For biosolids that are land applied or placed in a surface disposal site, the Permittee shall track and keep records of the operational parameters used to achieve Vector Attraction Reduction requirements in 40 CFR part 503.33 (b).
 4. Class 1 facilities (facilities with pretreatment programs or others designated as Class 1 by the Regional Administrator) and Federal facilities with > 5 mgd influent flow shall sample biosolids for pollutants listed under section 307 (a) of the Act (as required in the pretreatment section of the permit for POTWs with pretreatment programs.) Class 1 facilities and Federal Facilities with > 5 mgd influent flow shall test dioxins/dibenzofurans using a detection limit of < 1 pg/g during their next sampling period if they have not done so within the past 5 years and once per 5 years thereafter.
 5. The biosolids shall be tested annually or more frequently if necessary to determine hazardousness in accordance with California Law.
 6. If biosolids are placed in a surface disposal site (dedicated land disposal site or monofill), a qualified groundwater scientist shall develop a groundwater monitoring program for the site, or shall certify that the placement of biosolids on the site will not contaminate an aquifer.
 7. Biosolids placed in a municipal landfill shall be tested semi-annually by the Paint Filter Test (SW-846, Method 9095) to demonstrate that there are no free liquids.
- M.** The Permittee either directly or through contractual arrangements with their biosolids management contractors shall comply with the following 40 CFR part 503 notification requirements:
8. A reuse/disposal plan shall be submitted to USEPA Region IX Coordinator and, in the absence of other state or regional reporting requirements, to the state permitting agency, prior to the use or disposal of any biosolids from this facility to a new or previously unreported site. The plan shall be submitted by the land applier of the biosolids and shall include, a description and a topographic map of the proposed site(s) for reuse or disposal, names and addresses of the applier(s) and site owner(s), and a list of any state or local permits which must be obtained. For land application sites, the plan shall include a description of the crops or vegetation to be grown, proposed nitrogen loadings to be used for the crops, and a groundwater monitoring plan if one exists.
 9. If the Permittee biosolids do not meet 40 CFR part 503.13 Table 3 metals concentration limits, the Permittee must require their land applier to contact the state permitting authority to determine whether bulk biosolids subject to the cumulative pollutant loading rates in 40 CFR part 503.12(b)(2) have been applied to the site since July 20, 1993, and, if so, the cumulative amount of pollutants applied to date, and background concentration, if known. The Permittee shall then notify USEPA Region IX Coordinator of this information.

10. For biosolids that are land applied, the Permittee shall notify the applier in writing of the nitrogen content of the biosolids, and the applier's requirements under 40 CFR part 503, including the requirements that the applier certify that the requirement to obtain information in Subpart A, and that the management practices, site restrictions, and any applicable vector attraction reduction requirements Subpart D have been met. The Permittee shall require the applier to certify at the end of 38 months following application of Class B biosolids that those harvesting restrictions in effect for up to 38 months have been met.
 11. If bulk biosolids are shipped to another State or to Indian Lands, the Permittee must send written notice prior to the initial application of bulk biosolids to the permitting authorities in the receiving State or Indian Land (the USEPA Regional Office for the area and the State/Indian authorities).
 12. Notification of 40 CFR part 503 non-compliance: The Permittee shall require appliers of their biosolids to notify USEPA Region 9 and their state permitting agency of any noncompliance within 24 hours if the non-compliance may seriously endanger health or the environment. For other instances of non-compliance, the Permittee shall require appliers of their biosolids to notify USEPA Region 9 and their state permitting agency of the non-compliance in writing within 10 working days of becoming aware of the non-compliance.
- N. The Permittee shall submit an annual biosolids report to USEPA Region IX Biosolids Coordinator and the Los Angeles Regional Water Quality Control Board by February 19 of each year for the period covering the previous calendar year. The report shall include:
1. The amount of biosolids generated that year, in dry metric tons, and the amount accumulated from previous years.
 2. Results of all pollutant monitoring required in the Monitoring Section above.
 3. Descriptions of pathogen reduction methods, and vector attraction reduction methods, as required in 40 CFR parts 503.17 and 503.27.
 4. Results of any groundwater monitoring or certification by groundwater scientist that the placement of biosolids in a surface disposal site will not contaminate an aquifer.
 5. Names and addresses of land appliers and surface disposal site operators, and volumes applied (dry metric tons).
 6. Names and addresses of persons who received biosolids for storage, further treatment, disposal in a municipal waste landfill, or for other reuse/disposal methods not covered in N.3, above, and volumes delivered to each.
- O. The Permittee shall require all parties contracted to manage their biosolids to submit an annual biosolids report to USEPA Region IX Biosolids Coordinator by February 19 of each year for the period covering the previous calendar year. The report shall include:
1. Names and addresses of land appliers and surface disposal site operators, name, location (latitude/longitude), and size (hectares) of site(s), volumes applied/disposed (dry metric tons) and for land application, biosolids loading rates (metric tons per hectare), nitrogen loading rates (kg/ha), dates of applications, crops grown, dates of seeding and

harvesting and certifications that the requirement to obtain information in 40 CFR part 503.12(e)(2), management practices in part 503.14 and site restrictions in part 503.32(b)(5) have been met.

ATTACHMENT I – PRETREATMENT REPORTING REQUIREMENTS

The City of Simi Valley (Permittee) is required to submit annual Pretreatment Program Compliance Report (Report) to the Regional Water Board and United States Environmental Protection Agency, Region 9 (USEPA). This Attachment outlines the minimum reporting requirements of the Report. If there is any conflict between requirements stated in this attachment and provisions stated in the Waste Discharge Requirements (WDR), those contained in the WDR will prevail.

A. Pretreatment Requirements

1. The Permittee shall be responsible and liable for the performance of all Control Authority pretreatment requirements contained in 40 CFR part 403, including any subsequent regulatory revisions to part 403. Where part 403 or subsequent revision places mandatory actions upon the Permittee as Control Authority but does not specify a timetable for completion of the actions, the Permittee shall complete the required actions within six months from the issuance date of this permit or the effective date of the part 403 revisions, whichever comes later. For violations of pretreatment requirements, the Permittee shall be subject to enforcement actions, penalties, fines and other remedies by the USEPA or other appropriate parties, as provided in the Act. USEPA may initiate enforcement action against a nondomestic user for noncompliance with applicable standards and requirements as provided in the act.
2. The Permittee shall enforce the requirements promulgated under sections 307(b), 307(c), 307(d) and 402(b) of the Act with timely, appropriate and effective enforcement actions. The Permittee shall cause all nondomestic users subject to federal categorical standards to achieve compliance no later than the date specified in those requirements or, in the case of a new nondomestic user, upon commencement of the discharge.
3. The Permittee shall perform the pretreatment functions as required in 40 CFR part 403 including, but not limited to:
 - a. Implement the necessary legal authorities as provided in 40 CFR part 403.8(f)(1);
 - b. Enforce the pretreatment requirements under 40 CFR parts 403.5 and 403.6;
 - c. Implement the programmatic functions as provided in 40 CFR part 403.8(f)(2); and
 - d. Provide the requisite funding and personnel to implement the pretreatment program as provided in 40 CFR part 403.8(f)(3).
4. The Permittee shall submit annually a report to USEPA Pacific Southwest Region, and the State describing its pretreatment activities over the previous year. In the event the District is not in compliance with any conditions or requirements of this permit, then the District shall also include the reasons for noncompliance and state how and when the District shall comply with such conditions and requirements. This annual report shall cover operations from January 1 through December 31 and is due on April 15 of each year. The report shall contain, but not be limited to, the following information:
 - a. A summary of analytical results from representative, flow proportioned, 24-hour composite sampling of the publicly-owned treatment works (POTW) influent and

effluent for those pollutants USEPA has identified under section 307(a) of the Act which are known or suspected to be discharged by nondomestic users. This will consist of an annual full priority pollutant scan, with quarterly samples analyzed only for those pollutants detected in the full scan. The District is not required to sample and analyze for asbestos. Sludge sampling and analysis are covered in the sludge section of this permit. The District shall also provide any influent or effluent monitoring data for nonpriority pollutants which the District believes may be causing or contributing to interference or pass through. Sampling and analysis shall be performed with the techniques prescribed in 40 CFR part 136;

- b. A discussion of Upset, Interference or Pass Through incidents, if any, at the treatment plant which the District knows or suspects were caused by nondomestic users of the POTW system. The discussion shall include the reasons why the incidents occurred, the corrective actions taken and, if known, the name and address of the nondomestic user(s) responsible. The discussion shall also include a review of the applicable pollutant limitations to determine whether any additional limitations, or changes to existing requirements, may be necessary to prevent pass through or interference;
- c. An updated list of the District's significant industrial users (SIUs) including their names and addresses, and a list of deletions, additions and SIU name changes keyed to the previously submitted list. The District shall provide a brief explanation for each change. The list shall identify the SIUs subject to federal categorical standards by specifying which set(s) of standards are applicable to each SIU. The list shall also indicate which SIUs are subject to local limitations;
- d. The District shall characterize the compliance status of each SIU by providing a list or table which includes the following information:
 - i. Name of the SIU;
 - ii. Category, if subject to federal categorical standards;
 - iii. The type of wastewater treatment or control processes in place;
 - iv. The number of samples taken by the POTW during the year;
 - v. The number of samples taken by the SIU during the year;
 - vi. For an SIU subject to discharge requirements for total toxic organics, whether all required certifications were provided;
 - vii. A list of the standards violated during the year. Identify whether the violations were for categorical standards or local limits;
 - viii. Whether the facility is in significant noncompliance (SNC) as defined at 40 CFR part 403.8(f)(2)(viii) at any time during the year; and
 - ix. A summary of enforcement or other actions taken during the year to return the SIU to compliance. Describe the type of action, final compliance date, and the amount of fines and penalties collected, if any. Describe any proposed actions for bringing the SIU into compliance.
- e. A brief description of any programs the POTW implements to reduce pollutants from nondomestic users that are not classified as SIUs;
- f. A brief description of any significant changes in operating the pretreatment program which differ from the previous year including, but not limited to, changes concerning the program's administrative structure, local limits, monitoring program or monitoring frequencies, legal authority, enforcement policy, funding levels, or staffing levels;

- g. A summary of the annual pretreatment budget, including the cost of pretreatment program functions and equipment purchases; and
- h. A summary of activities to involve and inform the public of the program including a copy of the newspaper notice, if any, required under 40 CFR part 403.8(f)(2)(viii).

B. LOCAL LIMITS EVALUATION

1. In accordance with 40 CFR part 122.44(j)(2)(ii), the POTW shall provide a written technical evaluation of the need to revise local limits under 40 CFR part 403.5(c)(1) within 180 days of issuance or reissuance of the NPDES permit.

C. SIGNATORY REQUIREMENTS AND REPORT SUBMITTAL

1. Signatory Requirements.

The annual report must be signed by a principal executive officer, ranking elected official or other duly authorized employee if such employee is responsible for the overall operation of the POTW. Any person signing these reports must make the following certification [40 CFR part 403.6(a)(2)(ii)]:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

2. Report Submittal.

An original copy of the Annual Report must be sent to the Pretreatment Program Coordinator of the Regional Water Board and the duplicate copies of the Report must be sent to USEPA through the following addresses:

Information and Technology Unit
Attn: Pretreatment Program Coordinator
California Regional Water Quality Control Board, Los Angeles Region
320 West 4th Street, Suite 200
Los Angeles, CA 90013

Pretreatment Program
CWA Compliance Office (WTR-7)
Water Division
U.S. Environmental Protection Agency, Region IX
75 Hawthorne Street
San Francisco, CA 94105-3901

EXHIBIT B

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION

TIME SCHEDULE ORDER NO. R4-2014-0067

REQUIRING THE CITY OF SIMI VALLEY
(SIMI VALLEY WATER QUALITY CONTROL PLANT)
TO COMPLY WITH REQUIREMENTS PRESCRIBED IN
ORDER NUMBER R4-2014-0066
(NPDES PERMIT NO. CA0055221)

The California Regional Water Quality Control Board, Los Angeles Region (hereafter Regional Water Board), finds:

1. The City of Simi Valley (hereafter The City, Permittee or Discharger) owns and operates the Simi Valley Water Quality Control Plant (hereafter Simi Valley WQCP), a publicly owned treatment works (POTW) located at 600 West Los Angeles Avenue, Simi Valley, California, within the Calleguas Watershed.
2. The Simi Valley WQCP discharges tertiary-treated wastewater under waste discharge requirements contained in Order No. R4-2003-0081, adopted by this Regional Water Board on June 5, 2003. Order No. R4-2003-0081 serves as a permit under the National Pollutant Discharge Elimination System (NPDES No. CA0055221) and regulates the discharge of treated wastewater to Arroyo Simi, a water of the United States and the State of California, within the Calleguas Creek Watershed. Order No. R4-2003-0081 expired on June 5, 2008, but was administratively extended.
3. On May 8, 2014, the Regional Water Board adopted Order No. R4-2014-0066 which renewed the waste discharge requirements and NPDES permit for the Simi Valley WQCP. Order No. R4-2014-0066 is effective on July 1, 2014.
4. The treatment system at the Simi Valley WQCP consists of primary sedimentation, activated sludge biological treatment with nitrification and denitrification, secondary sedimentation, dual media filtration, chlorination, and dechlorination. Primary sludge is anaerobically digested and waste activated sludge is thickened and aerobically digested. Sewage solids separated from the wastewater are dried in sludge drying beds and transported off site to a landfill facility. The Simi Valley WQCP was recently upgraded to remove nutrient from the wastewater. However, the treatment facility is not designed to remove chloride or other salts from the influent.
5. Several reaches of Calleguas Creek that include Arroyo Simi have been identified on the 2010 303(d) List as not meeting water quality standards for chloride, because the surface waters above Potrero Road do not meet the Basin Plan chloride water quality objective of 150 mg/L.
6. The drought in the late 1980s increased chloride concentrations in supply waters imported into the Los Angeles Region. This increase, plus salt loading that occurs during beneficial use of supply waters, has made it difficult for many dischargers in the Region to comply with water quality limits for chloride. In 1990, the Regional Water Board adopted Resolution No.

- 90-04, *Effects of Drought-Induced Water Supply Changes and Water Conservation Measures on Compliance with Waste Discharge Requirements within the Los Angeles Region*. This resolution, commonly referred to as the *Drought Policy*, was intended to provide short-term and temporary relief to POTWs who were unable to comply with limits for chloride due to the effects of drought on chloride levels in supply waters imported into the Region.
7. Chloride levels in supply waters imported into the Region continue to be generally higher than they were before drought conditions in the late 1980s. The high levels of chloride in imported waters appear to be the result of intensifying demands for and utilization of water resources in watersheds that are the sources of supply waters. On January 27, 1997, the Regional Water Board adopted an amendment to the *Basin Plan*, Resolution 97-02, *Amendment to the Water Quality Control Plan to Incorporate a Policy for Addressing Levels of Chloride in Discharges of Wastewaters*. This amendment was subsequently approved by the State Water Resources Control Board (Resolution 97-94) and by the Office of Administrative Law on January 9, 1998. The Resolution granted a three-year variance for interim relief to existing dischargers in the Santa Clara River and Calleguas Creek watersheds. On April 13, 1998, the Regional Water Board adopted Order No. 98-027, which amended Order No. 96-043 for Simi Valley WQCP to include an interim chloride daily maximum effluent limit of 190 mg/L based on Resolution 97-02. This interim limit was set to expire on January 9, 2001.
 8. On December 7, 2000, the Regional Water Board adopted Resolution No. 2000-22, to extend the Interim Chloride Limits for Discharges to Calleguas Creek until March 31, 2001.
 9. On March 22, 2002, USEPA Region 9 established the Calleguas Creek Total Maximum Daily Load for chloride which used the 150 mg/L objective in the Basin Plan to establish a waste load allocation of 10,100 lbs/day for the Simi Valley WQCP during normal conditions, and a waste load allocation of 9,200 lbs/day for the Simi Valley WQCP during drought conditions.
 10. On August 14, 2002 the City of Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), Camrosa Sanitation District (Camrosa WRP), Ventura County Water Works District No. 1 (Moorpark facility) and the Regional Water Board entered into a "Stipulation for Order Issuing Stay, with Conditions," which stayed the chloride final effluent limitation in NPDES Order No. 96-043. The State Water Board adopted WQO 2002-0017, which approved the August 14, 2002 stipulation.
 11. On June 5, 2003, the NPDES permits for the City of Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP) were renewed, thereby rescinding the 1996 NPDES Orders, except for enforcement purposes. The Dischargers petitioned the revised NPDES Orders to the State Water Board, requested an extension of the chloride stay, and asked that the petitions be held in abeyance.
 12. On October 10, 2003, the City of Simi Valley (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo WRP), and the Regional Water Board entered into a "Stipulation for Further Order Issuing Stay, with Conditions," which stayed the chloride final effluent limitation in NPDES Order No. R4-2003-0081. The State Water Board adopted WQO 2003-0019, which approved the October 10, 2003, stipulation and held the petitions in abeyance for three years (until November 19, 2006).

13. On September 28, 2006, the State Water Board granted an extension of the abeyance until July 15, 2008. The State Water Board, however, has continued granting extensions to the abeyance.
14. On October 4, 2007, the Regional Water Board adopted Resolution No. 2007-016, *Amendment to the Water Quality Control Plan for the Los Angeles Region to Incorporate the TMDL for Boron, Chloride, Sulfate, and TDS (Salts) in the Calleguas Creek Watershed (Salts TMDL)*, which established final WLAs for chloride, sulfate, boron, and total dissolved solids (TDS). The *Salts TMDL* became effective on December 8, 2008. The *Salts TMDL* includes an implementation plan that provides a compliance schedule for application of the final WLAs. The compliance schedule requires final WLAs to be included in permits for POTWs 15 years after the effective date of the TMDL (December 8, 2023). Prior to that time, interim WLAs are to be included in permits for POTWs. USEPA approved the *Salts TMDL* pursuant to Clean Water Act section 303(d)(2). USEPA did not take action on the implementation plan provided with the TMDL, and did not approve the compliance schedule for implementation of the final WLAs pursuant to 303(c). Therefore, the final WLAs for chloride were required to be included in Order No. 2014-0066.
15. NPDES Order No. R4-2014-0066 prescribes effluent limitations for chloride consistent with the *Salts TMDL*, as presented in the Table below. This TSO applies to both the dry-weather and wet-weather, and concentration based and mass based limits, for chloride provided by the TMDL.

Table 1. Final Effluent Limitation

Parameter	Units	Effluent Limitations		
		Average Monthly	Average Weekly	Maximum Daily
Chloride (wet-weather) ¹	mg/L	150	--	--
Chloride (dry-weather) ¹	lbs/day	15,640		

16. The Discharger cannot consistently meet the above-mentioned chloride effluent limits.
17. The dischargers, including Simi Valley WQCP, have participated with other stakeholders in the Calleguas Creek Watershed Management Plan Committee to develop a watershed-wide solution to the salts water quality problem. The proposed Calleguas brine line will remove salts (chloride, TDS, sulfate, and boron) from inland waters in the Calleguas Creek Watershed and discharge them to the ocean through a permitted outfall. The brine line is expected to be completed and in operation by December 31, 2018.
18. On February 13, 2014, the Discharger submitted an email requesting a TSO under CWC section 13385(j)(3)(B)(iii) based on the following facts:
 - a. The final effluent limitation for chloride is based on the Calleguas Creek Watershed Salts TMDL that specifies the final WLA = 150 x Q-AF. Based on data collected, the

¹ See section VII.O. of the NPDES Order for definition of dry- and wet-weather.

Discharger will not be able to consistently comply with the final effluent limitation for chloride in Order No. 2014-0066.

- b. The final WLAs include an adjustment factor to allow higher loads in effluent if those loads are offset by watershed salt removal. The watershed salt removal mechanisms are not yet in place and as a result, Simi Valley WQCP will not have the ability to consistently comply with the final WLAs in the *Salts TMDL* should source water quality cause an increase in effluent concentrations.
 - c. Milestones and completion dates for capital improvement projects will require more than thirty days to install and put into operation. These capital improvements include constructing a connection from Simi Valley WQCP to Calleguas Municipal Water District's brine line by December 2018, and discharging to the brine line to achieve compliance with the salts final effluent limitations.
19. The Regional Water Board acknowledges that the Discharger has made substantial efforts to upgrade its wastewater treatment plant and to participate with stakeholders in the watershed to develop and implement a regional salt management plan. The Regional Water Board issues this Order in recognition that the Discharger needs time to complete construction and startup operations of capital improvement projects associated with the brine line.
 20. California Water Code (CWC) section 13300 states that "[w]henver a regional board finds that a discharge of waste is taking place or threatening to take place that violates or will violate requirements prescribed by the regional board ... the board may require the discharger to submit for approval of the board, with such modifications as [the board] may deem necessary, a detailed time schedule of specific actions the discharger shall take in order to correct or prevent a violation of requirements." The Discharger has proposed a strategy for complying with the chloride limits in Order No. 2014-0066.
 21. Based on monitoring data, the Permittee cannot consistently achieve compliance with the final effluent limitations for chloride in Order No. R4-2014-0066. Accordingly, pursuant to CWC section 13300, a discharge of waste is threatening to take place that violates requirements prescribed by the Regional Water Board.
 22. Water Code section 13385, subdivisions (h) and (i), require the Regional Water Board to impose mandatory minimum penalties upon dischargers that violate certain effluent limitations. Section 13385(j)(3) exempts violations of an effluent limitation from mandatory minimum penalties "where the waste discharge is in compliance with either a cease and desist order issued pursuant to Section 13301 or a time schedule order issued pursuant to Section 13300, if all of the [specified] requirements are met."
 23. In accordance with CWC section 13385(j)(3)(B)(i), the Regional Water Board finds that "[t]he effluent limitation is a new, more stringent, or modified regulatory requirement that has become applicable to the waste discharge after the effective date of the waste discharge requirements and after July 1, 2000, new or modified control measures are necessary in order to comply with the effluent limitation, and the new or modified control measures cannot be designed, installed, and put into operation within 30 calendar days. The effluent limitation for chloride in Order No. 2014-0066 is a more stringent and modified regulatory

requirement that became applicable to the waste discharge after the effective date of the prior permit and after July 1, 2000. New control measures at the Facility are necessary to comply with the chloride effluent limitation and the control measures cannot be designed, installed, and put into operation within 30 calendar days.

24. This time schedule to bring the waste discharge into compliance with the effluent limitation for chloride is as short as possible, taking into account the technological, operational, and economic factors that affect the design, development, and implementation of the control measures that are necessary to comply. This time schedule does not exceed five years in length.
25. Since the time schedule for completion of the actions necessary to bring the waste discharge into compliance with the chloride effluent limitation exceeds one year from the effective date of this TSO, this TSO includes interim requirements and the dates for their achievement. The interim requirements include both interim effluent limitations for chloride and actions and milestones leading to compliance with the final effluent limitation for chloride.
26. The monthly average interim effluent limitation for chloride is derived from the interim waste load allocation as set forth in the *Calleguas Creek Watershed Salts TMDL*, established by the Regional Water Board on October 4, 2007, effective on December 8, 2008. The TMDL interim effluent limitation is set equal to the 95th percentile of available discharge data.
27. CWC section 13385(j)(3)(D) requires the Permittee to prepare and implement a Pollution Prevention Plan (PPP) pursuant to CWC section 13263.3.
28. Pursuant to CWC section 13385(j)(3), full compliance with the requirements of this TSO exempts the Permittee from mandatory minimum penalties only for violations of the effluent limitations for chloride in Order No. R4-2014-0066 that occur after the effective date of this TSO.
29. This TSO concerns an existing facility and does not significantly alter the status with respect to the facility. This TSO is also being taken for the protection of the environment. Therefore, issuance of this TSO is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21100, et seq.) in accordance with sections 15301 and 15321(a)(2) of Title 14 of the California Code of Regulations (CCR).
30. The Regional Water Board has notified the Permittee and interested agencies and persons of its intent to issue this TSO concerning compliance with waste discharge requirements. The Regional Water Board, in a public hearing, heard and considered all testimony pertinent to this matter.
31. Any person aggrieved by this action of the Regional Water Board may petition the State Water Board to review the action in accordance with CWC section 13320 and CCR, title 23, sections 2050 and following. The State Water Board must receive the petition by 5:00 p.m., 30 days after the Regional Water Board action, except that if the thirtieth day following the action falls on a Saturday, Sunday, or state holiday, the petition must be received by the State Water Board by 5:00 p.m. on the next business day. Copies of the law and regulations applicable to filing petitions may be found on the Internet at

http://www.waterboards.ca.gov/public_notices/petitions/water_quality or will be provided upon request.

IT IS HEREBY ORDERED that, pursuant to the CWC section 13300, the City of Simi Valley, as owner and operator of the Simi Valley WQCP, shall:

1. Immediately comply with the chloride interim effluent limitation, applicable to both dry-weather and wet-weather:

Table 2. Interim Effluent Limitation

Parameter	Units	Effluent Limitations		
		Average Monthly	Average Weekly	Maximum Daily
Chloride	mg/L	183	--	--

If the analytical result of a single sample, monitored monthly, exceeds the monthly average interim effluent limitation, Simi Valley WQCP may collect up to four additional samples, at approximately equal intervals during that calendar month, to determine compliance with the monthly average interim effluent limitation.

2. Complete the capital improvement projects according to the schedule proposed by Simi Valley WQCP in their email dated February 13, 2014, as follows:

Table 3. Compliance Schedule for Chloride

Task No.	Description	Start Date	End Date
1	Conduct Source evaluation study and identify feasible source control strategies.	7/1/2014	8/31/2015
2	Implement Phase 2 of the Northern Reach Renewal Water Management Plan (NRRMP) implementation plan (i.e., construction of Moorpark Desalter).	1/1/2015	12/31/2015
3	Implement identified feasible source control strategies.	9/1/2015	12/31/2016
4	Implement Phase 3 of the NRRMP implementation plan (dewatering wells).	3/1/2016	12/31/2018
5	Determine if Optional Special Studies are needed as described in TMDL Basin Plan Amendment and submit workplans. 1. Develop Averaging Periods, Compliance Points 2. Develop Natural Background Exclusion 3. Develop Site Specific Objectives 4. Develop Site Specific Objectives for	1/1/2018	12/31/2018

Task No.	Description	Start Date	End Date
	Drought Conditions		
The tasks below will be completed after the term of this TSO.			
6	Submit results of special studies	2 years after EO approval: Dec 3, 2018	12/3/2020
7	Implement Phase 4 of the NRRMP implementation plan	3/1/2020	12/1/2023
8	Achieve WLAs, & WQOs		12/02/2023

3. Achieve full compliance with the final effluent limitation for chloride as soon as possible, but no later than June 30, 2019. If the Discharger is unable to comply with the effluent limitation for chloride by the expiration date of this TSO, the Discharger may request additional time pursuant to Water Code section 13385(j)(3)(C)(ii)(II), if warranted, to complete the additional described tasks.
4. Submit a Pollution Prevention Plan (PPP) work plan with the time schedule for implementation for approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3.
5. Submit quarterly progress reports of actions taken towards achieving compliance with the final effluent limitation for chloride. The reports shall summarize the progress to date, activities conducted during that quarter, and the activities planned for the upcoming quarters. The reports shall also state whether or not the Facility was in compliance with the interim effluent limitation for chloride during the reporting period. Each quarterly report shall be received by the Regional Water Board by the 15th day of the first month following the reporting period (January 15, April 15, July 15, and October 15). The first progress report shall be received by the Regional Water Board by October 15, 2014, and will cover the months of July 2014 through September 2014.
6. All technical and monitoring reports required under this TSO are required pursuant to CWC sections 13267 and 13383. The Regional Water Board needs the required information in order to determine compliance with this TSO and Order No. R4-2014-0066. The burdens, including costs, of these reports bear a reasonable relationship to the needs for the reports and the benefits to be obtained from the reports.
7. Any person signing a document submitted under this TSO shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my

knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."


8. If the Permittee fails to comply with any provision of this TSO, the Regional Water Board may take any further action authorized by law. The Executive Officer, or his/her delegee, is authorized to take appropriate enforcement action pursuant, but not limited to, CWC sections 13350 and 13385. The Regional Water Board may also refer any violations to the Attorney General for judicial enforcement, including injunction and civil monetary remedies.
9. Except as described herein, this Order does not affect any provision of NPDES Order No. R4-2014-0066.
10. The Regional Water Board may reopen this TSO at its discretion or at the request of the Permittee, if warranted. Lack of progress towards compliance with this TSO may be cause for the Regional Water Board to modify the conditions of this TSO.
11. This TSO becomes effective on July 1, 2014. This TSO expires on June 30, 2019.

I, Samuel Unger, Executive Officer, do hereby certify that the foregoing is a full, true and correct copy of an order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on May 8, 2014.



Samuel Unger, P.E., Executive Officer

Personally Served
6/4/14
3:45 PM



1 DOWNEY, BRAND LLP
2 MELISSA A. THORME
3 621 Capitol Mall, 18th Floor
4 Sacramento, CA 95814-4686
5 Tel.: (916) 520-5376
6 Fax: (916) 520-5776
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

DOWNEY BRAND LLP

BEFORE THE
CALIFORNIA STATE WATER RESOURCES CONTROL BOARD

)
) **PETITION FOR STAY AND**
) **COMPLIANCE SCHEDULE**
) **MODIFICATION FOR SPECIFIC**
) **PROVISIONS IN ORDER NOS. R4-2014-**
) **0066 AND R4-2014-0067 ISSUED BY THE**
) **CALIFORNIA REGIONAL WATER**
) **QUALITY CONTROL BOARD, LOS**
) **ANGELES REGION**
)
) **[WATER CODE §13320 and §13321; 23**
) **C.C.R. §2053]**

INTRODUCTION

In accordance with Water Code sections 13320 and 13321, Petitioner Simi Valley ("City") hereby requests a stay of specific provisions of Order Nos. R4-2014-0066 (the "Permit") and Order No. R4-2014-0067 (the Time Schedule Order or "TSO") adopted by the California Regional Water Quality Control Board for the Los Angeles Region ("Regional Board") on May 8, 2014. Copies of Order Nos. R4-2014-0066 and R4-2014-0067 are attached as Exhibits A and B, respectively, to the City's Petition for Review filed with the State Water Resources Control Board ("State Board").

These orders contain unreasonable, inappropriate, and illegal requirements, which are the subject of a Petition for Review, submitted to the State Board. Because of the substantial harm to the City and the public interest while the City awaits final resolution of its administrative appeal,

1 the lack of substantial harm to other interested persons and to the public interest if a stay is granted,
2 and the substantial questions of fact and law that exist, the State Board should immediately act to
3 stay the requested provisions of these orders pending full administrative review of the City's
4 Petition for Review.

5 The City specifically requests that the State Board immediately provide notice in
6 accordance with 23 Cal. Code Reg. §2053(b) on an expedited basis so that a stay may be granted
7 before the effective date of the permit on July 1, 2014 and so that the City can avoid the immediate
8 unnecessary expenditure of public funds and corresponding increases in sewer service fees, the
9 imposition of discretionary administrative civil or criminal penalties, and third party lawsuits
10 pending administrative review of the City's Petition for Review.

11 LEGAL AUTHORIZATION

12 Water Code sections 13320(e) and 13321(a) authorize the State Board to issue stays of
13 provisions in Waste Discharge Requirements ("WDRs"). Section 13320(e) states that: "If a
14 petition for state board review of a regional board action on waste discharge requirements includes
15 a request for a state of the waste discharge requirements, the state board shall act on the requested
16 stay portion of the petition within 60 days of accepting the petition. The board may order any stay
17 to be in effect from the effective date of the waste discharge requirements." Section 13321(a)
18 further states: "In the case of a review by the state board under section 13320, the state board, upon
19 notice and hearing, if a hearing is requested, may stay in whole or in part the effect of the decision
20 and order of a regional board or of the state board."

21 Under Water Code section 13320(c), the State Board "may direct the appropriate action be
22 taken by the regional board... take the appropriate action itself, or take any combination of those
23 actions. In taking any action, the state board is vested with all the powers of the regional boards
24 under this division." This section provides the authority for the State Board to modify (or direct the
25 Regional Board to modify) the Permit and TSO provisions and provide additional time for
26 compliance to take into account the pending related Petition for Review. For example, where a
27 compliance deadline is due 180 days after the effective date of the Permit, that deadline should be
28 modified to be 180 days after the provision on appeal is upheld (if ultimately upheld). This

1 modification merely preserves the status quo (since the requirement is not currently effective) and
2 tolls the timing of the deadline.

3 Pursuant to State Board regulations implementing the Water Code, the State Board has the
4 duty to issue a stay of provisions contained in the Permit if the City can allege facts and provide
5 evidence of: (1) substantial harm to the City or to the public interest if a stay is not granted; (2) a
6 lack of substantial harm to other interested persons and to the public interest if a stay is granted;
7 and (3) substantial questions of fact or law regarding the disputed action. *See* 23 C.C.R.
8 §2053(a)(1)-(3); *see accord* Water Code §13321. Importantly, had the U.S. Environmental
9 Protection Agency issued this NPDES Permit instead of the Regional Board, issuance of a stay
10 would be mandatory. *See* 40 C.F.R. §124.16(a) (“the effect of the contested permit conditions shall
11 be stayed”)(emphasis added). California law must be construed to assure consistency with the
12 requirements of the Clean Water Act related to NPDES Permits, under which the above regulation
13 was promulgated. *See* Water Code §13372; 23 C.C.R. §2235.2.

14 **FACTUAL AND PROCEDURAL BACKGROUND¹**

15 The City owns and operates a Water Quality Control Plant (“WQCP”), a tertiary treatment
16 wastewater facility located at 600 West Los Angeles in Simi Valley, California serving a
17 population of 126,300 people. Permit at pg. F-4. The Simi Valley WQCP receives industrial,
18 commercial and residential wastewater from the local collection system, with 510 permitted
19 nondomestic users and eight (8) significant industrial users (“SIUs”). *Id.* The Simi Valley WQCP
20 discharges tertiary treated wastewater to Arroyo Simi. Permit at F-4.

21 The Permit, along with TSO, was adopted by the Regional Board on May 8, 2014 with an
22 effective date of July 1, 2014. Permit at pg. 1. In the City’s Petition for Review, the City
23 requested the State Board to, either on its own motion or in accordance with 23 C.C.R. §2053(a),
24 issue a stay of the contested provisions of the Permit and TSO. The purpose of this Petition for
25 Stay is to satisfy the requirements of the Water Code and implementing regulations at 23 C.C.R.
26 §2053(a).

27 _____
28 ¹ To avoid unnecessary duplication, the City incorporates by reference the Factual Background section set forth in the City’s Petition for Review submitted to the State Board.

1 **PROVISIONS THE CITY IS REQUESTING BE STAYED/MODIFIED**
2 **PENDING DECISION ON THE PETITION FOR REVIEW**

3 For reasons set forth herein, the City is requesting the following provisions be stayed
4 pending administrative review of the City's Petition for Review:

5 **EFFLUENT LIMITATIONS AND IMPLEMENTATION PROVISIONS:**

6 PERMIT; ORDER R4-2014-0066:

7 1. The final numeric effluent limitations for Total Dissolved Solids ("TDS"), sulfate,
8 and chloride (for both dry weather and wet weather), and boron. (Permit Provision IV.A.1.a.,
9 Table 4 at pgs. 5-6.) The Permit prescribes both concentration and mass limits for these
10 constituents as Average Monthly Effluent Limits ("AMEL").

11 2. The final numeric effluent limitations for Chronic Toxicity and the requirement to
12 use the two concentration Test of Significant Toxicity to implement those limits. (Permit Provision
13 IV.A.1.a., Table 4 at pg. 7 and footnotes 6-7.) The Permit prescribes a Monthly Median Effluent
14 Limitation ("MMEL") of "Pass" and a Maximum Daily Effluent Limitation ("MDEL") of "Pass or
15 %Effect < 50." *Id.*

16 TSO, ORDER R4-2014-0067:

17 3. Provision in Paragraph 4 on page 7 of the TSO, which requires the City to "Submit
18 a Pollution Prevention Plan (PPP) work plan with the time schedule for implementation for
19 approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3."

20 4. Provision in Paragraph 5 on page 7 of the TSO to submit quarterly progress reports,
21 the first due October 15, 2014, of efforts taken by the Permittee to comply with the final effluent
22 limitation for chloride, and the requirements for the content of those reports.

23
24 Although there are many other effluent limitations and provisions being petitioned by the
25 City, these provisions are the ones most likely to cause significant compliance problems for the
26 City during the pendency of review of its Petition for Review. Thus, the City was selective in the
27 issues for which a stay is requested.

28

DOWNEY BRAND LLP

DOWNEY BRAND LLP

ARGUMENT

A. THE STATE BOARD HAS THE DUTY TO GRANT A STAY OF PROVISIONS IN THE PERMIT UPON THE SHOWING OF HARM TO THE CITY, A LACK OF HARM TO THE PUBLIC, AND SUBSTANTIAL QUESTIONS OF LAW OR FACT.

As discussed herein, the City’s stay request meets the regulatory criteria set forth in 23 C.C.R. §2053(a), which mandates that the requested stay be granted by the State Board upon the City making the required showings. The City therefore requests that the State Board issue the requisite public notice so that it may grant the City’s stay request on an expedited basis before the effective date of the permit on July 1, 2014, so that the City can avoid needlessly expending limited public resources duplicative of those being spent implementing the applicable Total Maximum Daily Loads (“TMDLs”), increasing sewer service fees to fund unnecessary facility upgrades at the water reclamation plant instead of implementing a watershed solution, and avert detrimental discretionary civil and criminal enforcement of the above-named provisions of the Permit pending administrative review. *See* 23 C.C.R. §2053.

B. THE CITY SATISFIES THE REGULATORY REQUIREMENTS APPLICABLE TO STAY REQUESTS.

1. SUBSTANTIAL HARM TO THE CITY OR TO THE PUBLIC INTEREST WILL OCCUR IF A STAY IS NOT GRANTED.

The City and the public interest will incur substantial harm if the requested stay is not granted by the State Board pending administrative review of the City’s Petition for Review. In accordance with 23 C.C.R. §2053(a), the following discussion alleges facts and provides evidence in support of the City’s stay request.

A) SUBSTANTIAL HARM TO THE CITY WILL OCCUR IF A STAY IS NOT GRANTED.

1) FINAL EFFLUENT LIMITS FOR SALINITY

The City currently operates an advanced tertiary treatment wastewater facility with nitrification, de-nitrification and biological nutrient removal (“BNR”) and a dry weather design capacity of 12.5 mgd. Permit at F-4. This level of treatment greatly exceeds the secondary treatment requirements of the Clean Water Act. *See* 33 U.S.C. §1311(b)(1)(B); *See* Declaration

1 of Eric Levitt (“Levitt Decl.”), filed herewith, at ¶ 4. However, even the City’s advanced facilities
2 are not specifically designed for the removal of many pollutants, including salinity, which were
3 included as effluent limitations in the Permit. *Id.*

4 Although a compliance schedule was included in the Calleguas Watershed Salinity Total
5 Maximum Daily Load (“Salinity TMDL”) through 2023,² the Permit still contains final numeric
6 effluent limitations for salinity constituents (chloride, sulfate, TDS, and boron) described above
7 without the benefit of the corresponding TMDL compliance schedule. Without an adequate
8 compliance schedule, it is infeasible and impractical to achieve immediate and full compliance
9 with the new final effluent limitations contained in the Permit. *See* Permit at pg. F-6, Table F-2;
10 TSO No. R4-2014-0067 at pg. 3, para. 16 (“The discharger cannot consistently meet the above-
11 mentioned chloride effluent limits”). A compliance schedule is needed, as recognized in the
12 TMDL, to provide for sufficient time to properly develop and implement the tasks required for
13 compliance with the applicable objectives on a watershed basis in an orderly, logical, and well
14 planned sequence “linked to the construction schedule for the Regional Salinity Management
15 Conveyance” (RSMC or brine line). *See* Attachment A to Regional Board Res. No. R4-2007-016,
16 at pg.17.

17 In extensive comments submitted to the Regional Board, the City asserted that a
18 compliance period is necessary in order to accommodate the magnitude of work necessary to
19 comply with the water quality standards in the watershed, and the TMDL recognized that this
20 would be done, not with final numeric effluent limitations on the treatment plants, but through a
21 watershed wide approach using de-salters on groundwater, constructing the RSMC to remove salts
22 from the basin, and implementing agricultural BMPs. *See, e.g.,* City’s Comment Letters on the
23 Permit and TSO; *see also* TSO, Order No. R4-2014-0067 at pg. 4, para. 18. The TSO recognizes
24 this and states:

25
26
27 ² *See* Attachment A to Regional Board Res. No. R4-2007-016, at pg. 22, Table 7-22.2, Implementation Schedule (“The
28 POTWs and non-stormwater NPDES Permits shall achieve WLAs, which shall be expressed as NPDES mass-based
effluent limitations specified in accordance with federal regulations and state policy on water quality control... 15
years after effective date of the TMDL.”)

1 “These capital improvements include constructing a connection from Simi Valley WQCP to
2 Calleguas Municipal Water District’s brine line by December 2018, and discharging to the
3 brine line to achieve compliance with the salts final effluent limitations.

4 The Regional Water Board acknowledges that the Discharger has made substantial efforts
5 to upgrade its wastewater treatment plant and to participate with stakeholders in the
6 watershed to develop and implement a regional salt management plan. The Regional Water
7 Board issues this Order in recognition that the Discharger needs time to complete
8 construction and startup operations of capital improvement projects associated with the
9 brine line.” TSO, Order No. R4-2014-0067 at pg. 4, paras. 18.c. and 19.

10 Without a compliance schedule in the Permit, the City will be forced to work on different
11 tasks in parallel, including tasks to add treatment to the WQCP, which were not anticipated by the
12 adopted and approved TMDL. *See* Levitt Decl. at ¶ 5. For example, the City would have to
13 commit to design and construct additional treatment at the WQCP before other activities, such as
14 the RSMC, are complete and may obviate the need for such POTW treatment (*e.g.*, influent source
15 control). *Id.* at ¶ 5. It is impractical to begin construction of costly end-of-pipe treatment options
16 when a plan is already in place and being implemented to address the actual source of the
17 pollutants, which, if successful, will render additional end-of-pipe treatment unnecessary. *Id.* The
18 City and the other stakeholders in the Calleguas Creek Watershed developed a watershed solution
19 to address the salt accumulation problem that was found to be impairing surface waters. The TSO
20 recognizes that the TMDL compliance schedule doesn’t require final WLAs to be included in
21 permits for POTWs until “15 years after the effective date of the TMDL (December 8, 2023).”
22 TSO, Order No. R4-2014-0067 at pg. 3, para. 14 (emphasis added). The Regional Board ignores
23 this provision citing an inaccurate legal conclusion, thereby placing the City in greater compliance
24 jeopardy.

25 All of this was ignored by the Regional Board in the Permit even during a declared drought
26 emergency when there is widespread recognition that source water salinity levels are increasing.
27 Levitt Decl. at ¶ 7. On April 14, 2014, the City requested in writing higher interim limits for salts
28 based on anticipated changes to its potable water supply and supplemental information was sent to
the Regional Board on April 25th. *Id.* The City is concerned that the effluent concentrations may
exceed the proposed interim and will exceed the final effluent limitations due to the changes in
water supply. *Id.*

1 In addition, the City repeatedly requested that the final effluent limitations be included in a
2 finding in the Permit and that the TMDL compliance schedule be included in the Permit. Levitt
3 Decl. at ¶ 4. As discussed in the TMDL schedule, proper identification and control of a
4 constituent's source provides the most economical and flexible method of compliance.

5 Harm can be presumed in this case since similar stays have been in place for the previous
6 chloride limits in the City's last NPDES permits. On August 14, 2002, a "Stipulation for Order
7 Issuing Stay, with Conditions" was entered into in the matter denominated as SWRCB/OCC File
8 A-1474, a petition regarding the various treatment plants owned and operated by the City (Simi
9 Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary District (Camarillo
10 WRP), Camrosa Water District, Ventura County Water Works District No. 1, respectively, and the
11 Los Angeles Regional Water Quality Control Board (Regional Board), regarding certain chloride
12 effluent limitations then applicable to the discharges from the aforesaid facilities, and the water
13 quality objectives from which those limitations were derived. The State Board issued WQO 2002-
14 0017, which approved the August 14, 2002 stipulation. TSO at pg. 2, para. 10.

15 On October 10, 2003, another "Stipulation for Further Order Issuing Stay" was entered into
16 by the City (Simi Valley WQCP), Thousand Oaks (Hill Canyon WWTP), Camarillo Sanitary
17 District (Camarillo WRP), and the Regional Board in the matters denominated as SWRCB/OCC
18 Files A-1577, A-1578, and A-1579. The State Board issued WQO 2003-0019, which approved the
19 October 10, 2003 stay stipulation and held the petitions in abeyance until November 19, 2006.
20 The State Board granted several extensions of the abeyance periods in the aforementioned matters
21 and the stay of the chloride limits remains in place until the new limits under this Permit become
22 effective. See TSO at pg.2, para. 12.

23 If water supply concentrations continue to rise and salinity concentrations increase, Simi
24 Valley could be in violation of their final numeric salinity effluent limitations even though the
25 TMDL did not require compliance with the final effluent limitations until 2023. See Levitt Decl. at
26 ¶ 7. If the City is required to install advanced salinity removal facilities, without the benefit of the
27 TMDL compliance schedule described above, sewer services fees will have to be substantially
28 increased to fund a new construction project and the funds used for participation in the TMDL

1 development process will represent a completely wasted effort. *See* Levitt Decl. at ¶ 9. The costs
2 to add reverse osmosis (“RO”) for salinity treatment at the WQCP is substantial. Based upon a
3 cost study performed by Montgomery Watson Harza for the County Sanitation Districts of Los
4 Angeles County and submitted to the Regional Board in June 2002, the capital cost for the addition
5 of advanced treatment technologies necessary to meet final effluent limitations in their permits
6 were estimated to range to the hundreds of millions of dollars depending on the size of the plant
7 and the treatment train needed (with the highest costs if micro-filtration, reverse osmosis, and brine
8 disposal were required). *Id.* The additional annual operation and maintenance costs necessary to
9 meet the final effluent limitations were estimated to be in the millions annually, not including brine
10 disposal costs if membrane technologies are required to comply. *Id.*

11 The City’s facilities and flows are smaller, but the City still anticipates the costs for
12 planning, pre-design, and CEQA-compliance costs to eventually come into compliance with the
13 final effluent limitations to be approximately \$12 million to build a 2.5 mgd RO facility in order to
14 blend the effluent and the RO flows to meet standards and approximately \$1 million annually to
15 operate. Levitt Decl. at ¶ 13. These costs are considerable, and should not be incurred without the
16 benefit of careful analysis. *Id.* at ¶ 9. Once expended, these costs are irretrievable and will result in
17 significant rate increases for area residents even if the RO system is ultimately mothballed as
18 unnecessary. *Id.* at ¶ 10. Given the fact that a separate watershed approach is currently being
19 implemented, the costs of compliance with these end-of-pipe final effluent limits are wildly
20 disproportionate to any minor water quality benefits in the short term, particularly when the
21 agricultural users of this water have not voiced any complaints about the current salinity levels. In
22 this drought, the farmers may be thankful to have wet water available for use. *Id.*

23 In addition, all during construction and up until the time that the RO system is operation,
24 the City will potentially be accruing civil penalties. Levitt Decl. at ¶ 15. The fact that a TSO
25 contains interim limits for chloride does nothing more than protect against Mandatory Minimum
26 Penalties (“MMPs”) for those limits. The Regional Board failed to include interim limits for TDS
27 or sulfate. A TSO may protect Simi Valley from MMPs, but not from citizen suits or discretionary
28

1 enforcement. Orders issued by the Regional Board that contain compliance schedules and interim
2 limits, such as TSOs, do not suspend the final effluent limits and deadlines contained in the
3 underlying NPDES permit, and do not shield NPDES permit holders from third party citizen suits
4 pursuant to CWA section 505 for noncompliance with the underlying permit. *See* 33 U.S.C.
5 §1365; *Citizens for a Better Environment-California v. Union Oil*, 83 F.3d 1111, 1119-1120 (9th
6 Cir. 1996). Under this rationale, an entity attempting to comply with final effluent limitations by
7 complying with the mandates of a TSO would still be vulnerable to discretionary administrative
8 enforcement by the State or USEPA, and by suits by third parties to enforce the final effluent
9 limitations. Significantly, the Clean Water Act and the Porter-Cologne Water Quality Control Act
10 prescribe harsh civil *and criminal* penalties for violations of any NPDES Permit condition or
11 limitation. *See* 33 U.S.C. §§1319(d) and 1365; Water Code §§13385 and 13387. Such compliance
12 jeopardy constitutes harm.

13 The Regional Board's failure to conduct a reasonable potential analysis, and if limits are
14 required include all compliance schedules and interim limits within the Permit also places the City
15 in an untenable position, in that the Permit requires immediate compliance where immediate
16 compliance is unachievable. This is especially arbitrary and unjust in the case of salinity, where
17 the applicable TMDL included a schedule of compliance until 2023. *See* Attachment A to
18 Regional Board Res. No. R4-2007-016, at pg. 22. The City has been diligently working to
19 implement the requirements of the Salinity TMDL, even without such provisions being included in
20 an enforceable order or permit, and properly relied upon the compliance schedule contained
21 therein. TSO at pg. 4, para. 19; Levitt Decl. at ¶ 13.

22 For the foregoing reasons, the City requests the State Board issue a stay of the final numeric
23 salinity effluent limitations in the Permit. During the period in which the requested stay is in
24 effect, the City will comply with the interim limits for salinity set forth in the TSO, unless
25 additional changes are needed and requested to address worsening drought and source water
26 conditions. Levitt Decl. at ¶17.

27 //

28 //

DOWNEY BRAND LLP

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

2) FINAL EFFLUENT LIMITATIONS FOR CHRONIC TOXICITY.

When the Regional Board adopted the Permit, the Regional Board failed to comply with precedential orders regarding the appropriate limitations for chronic toxicity, even though the Regional Board was aware of these orders. See Permit Fact Sheet at pg. F- 44. The Regional Board’s failure to include a narrative effluent limit for chronic toxicity within the Permit not only ignored State Board precedent, but also ignored the implementation provisions of the Calleguas Watershed TMDL that states that the chronic toxicity Wasteload Allocations (WLAs) will be based on chronic toxicity units (TUc) and implemented as a trigger instead of as numeric effluent limitations. This failure by the Regional Board to follow applicable precedent and TMDL implementation provisions places the City in immediate jeopardy of being in violation of the final effluent limitations for chronic toxicity set forth in the Permit on July 1, 2014, the effective date of the Permit. Levitt Decl. at ¶ 6. There is no TSO interim limit to provide MMP protection, and MMPs are not applicable to toxicity limits if any other toxic pollutants are limited, which is the case for this Permit. See Permit at pg. 7, Table 4; Wat. Code §13385(i)(1)(D).

Notwithstanding the City’s objection in its comments and the Petition for Review regarding the imposition of the final numeric effluent limitations for chronic toxicity, the Regional Board imposed the limits anyway. It is unclear why the City is burdened with these newly imposed, final effluent limitations since has a very high level of treatment, and no demonstrated reasonable potential to exceed the current toxicity trigger of 1 TUc. See Permit Hearing Presentation of the Regional Board (May 8, 2014) at slide 7 (During the 2003-2014 Permit cycle, the City did not exceed the 1 TUc trigger). With the new “Pass” limits, implemented using a two concentration Test of Significant Toxicity (TST) method, which is not approved under 40 C.F.R. Part 136 as a standard method, the City is statistically guaranteed to be in violation of its permit at least 5% of the time. Levitt Decl. at ¶16. This is an unacceptable situation. The Regional Board’s action will unnecessarily result in the City being out of compliance with the final effluent limitations for chronic toxicity set forth in the Permit and subject to MMPs and other discretionary penalties

1 because the City is statistically guaranteed to fail at least one test in the Permit term even if the
2 recycled water is not truly "toxic."

3 For the foregoing reasons, the City requests the State Board to stay the final numeric
4 effluent limitations for chronic toxicity set forth in the Permit. During the period in which the
5 requested stay is in effect, the City will comply with the narrative toxicity limit in the current
6 permit provisions, using 1 TUc as a chronic toxicity trigger for accelerated monitoring and
7 potentially a Toxicity Identification Evaluation. Levitt Decl. at ¶ 17.

8 **3) TSO REQUIREMENT FOR A POLLUTION PREVENTION PLAN WORKPLAN**

9 The TSO, Order R4-2014-0067, at Provision 4 on page 7 requires the City to "Submit a
10 Pollution Prevention Plan (PPP) work plan, with the time schedule for implementation, for
11 approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3."
12 The City has challenged the final chloride effluent limitations and asked for the full compliance
13 schedule allowed by the TMDL to be included in the Permit. Had that been done, then the
14 requirements of Water Code section 13263.3 would not have been triggered by the MMP law at
15 Water Code section 13385(j)(3)(D). Since the deadline of August 8, 2014 contained in this
16 provision will arrive before a substantive ruling on the City's Petition, the City seeks a stay and an
17 extension of the time schedule provision in addition to the requested stay on the limits in the
18 Permit. *See accord In the Matter of the Review on Own Motion of Waste Discharge Requirements*
19 *for Vacaville*, State Board Order WQO 2002-0015 at 75 ("By staying these schedules, the Board
20 intends that the schedules not run during the stay period. This means that the effective date of the
21 relevant final limits will be delayed beyond their existing effective date by a period of time equal to
22 the stay period."); Wat. Code §13321(a)(allowing stay of the effect of a decision), §13320(c)(State
23 Board to take appropriate action). If a stay and modification to toll this language are not granted,
24 the City will be harmed by having to spend time and resources to prepare a workplan that might
25 otherwise be unnecessary. Levitt Decl. at ¶¶14, 16.

26 **4) UNNECESSARY AND BURDENSOME QUARTERLY COMPLIANCE REPORTS**

27 Provision in Paragraph 5 on page 7 of the TSO requires the City to submit quarterly
28 progress reports, the first due October 15, 2014, of efforts taken by the City to comply with the

1 final effluent limitation for chloride, and the requirements for the content of those reports. This
2 reporting is wholly unnecessary given that the efforts needed for compliance are spelled out in the
3 Salts TMDL. Levitt Decl. at ¶ 14.

4 **B) SUBSTANTIAL HARM WILL BE INCURRED BY THE PUBLIC IF A STAY IS NOT**
5 **GRANTED.**

6 The general public will also be substantially harmed if the State Board does not grant the
7 City's stay request. If the requirements contained in the Permit are not immediately stayed,
8 residents and businesses in the City's service area, already under substantial strain from the recent
9 recession and other rising utility costs, will be asked to pay for unnecessary costs, and to factor an
10 anticipated sewer rate increase into their critical decisions of whether to remain in the area, and
11 whether to increase or reduce their workforces. *See* Levitt Decl. at ¶ 11. These decisions will
12 begin occurring immediately if a stay is not granted and may have irreversible impacts on housing,
13 investment, and employment in the City's service area. *Id.*

14 To assure compliance with the salinity and toxicity³ final effluent limits, would likely
15 require construction and operation of reverse osmosis (or other similar separation technology) for
16 at least a portion of the City's effluent at a very large cost. A 2001 analysis of the economic
17 impacts of the installation of advanced treatment facilities conducted by the Santa Clarita Valley
18 Joint Sewerage System ("SCVJSS") consultant, M.Cubed, which concluded that, as a result of the
19 cost increases associated with constructing advanced reverse osmosis treatment facilities,
20 employment would be reduced in the that District's service area by approximately 423 jobs, local
21 tax revenue would fall by over \$2.6 million annually, total industry output would drop by nearly
22 \$55.5 million per year, and total value added would decline by more than \$26 million annually. *Id.*
23 at ¶12 *citing* M.Cubed, "Economic Implications of Proposed NPDES Permits for the Sanitation
24 Districts of Los Angeles County" (May 2001). The compliance costs, and therefore the economic
25 impacts, from the new Simi Valley WQCP Permit are expected to be smaller than those associated
26 with the February 2001 tentative permit for the SCVJSS facilities, but may include substantial

27 _____
28 ³ It is not clear that toxicity limits can be met consistently even with the operation of reverse osmosis because of the
inherent false failure rate that guarantees failure at least 5% of the time.

1 reductions in employment, decreases in total industry output, and declines in local tax revenue. *Id.*
 2 at ¶¶ 11-12.

3 The City’s service area is smaller, but proportionately the impacts are still large. In
 4 addition to the monies spent by the City to participate in the Calleguas Creek Watershed Program
 5 with the intent of creating and implementing a watershed solution to avoid having to build reverse
 6 osmosis at the WQCP, the City’s ratepayers will be asked to fund this new project that may
 7 become wholly unnecessary once the watershed projects are completed. *Id.*

8 The local residents have already been asked to pay an inordinate amount for local water quality-
 9 related projects. The City has thus far spent upwards of \$20 million in capital expenditures for
 10 upgrading to address the nutrient TMDL (for nitrogen), \$1.5 on TMDL development, and \$1
 11 million thus far on TMDL implementation. The City of Simi Valley on the water side is planning
 12 future capital expenditures of as much as \$40 million on a groundwater desalter. The City of Simi
 13 Valley on the stormwater side has spent about a half million on TMDL implementation this far.
 14 Levitt Decl. at ¶ 13. The overall watershed group has spent over \$6.6 million on TMDL
 15 development, and \$16 million on TMDL implementation. In addition, Calleguas Municipal Water
 16 District customers have had to bear the cost to build the brine line of over \$230 million. *Id.*
 17 Tacking on additional costs to this very proactive watershed is not only unnecessary, it is unduly
 18 burdensome.

19 The forced implementation of costly requirements that may ultimately prove unnecessary,
 20 or the commencement of enforcement actions based on such requirements, is a misdirection of
 21 scarce public resources, and should be avoided in order to prevent substantial harm to the public.
 22 *Id.* The adoption of effluent limitations in violation of federal and state law also causes substantial
 23 harm to the public who have a vested interest in the government complying with its own laws and
 24 regulations. *Id.*

25 **2. OTHER INTERESTED PARTIES AND THE PUBLIC WILL NOT INCUR SUBSTANTIAL**
 26 **HARM IF A STAY IS GRANTED.**

27 Other interested persons and the public will not suffer substantial harm if a stay of the
 28 requested requirements is granted by the State Board. Granting a stay of the requested provisions

1 will not operate to alter or eliminate those provisions. *See* Levitt Decl. at ¶15. In addition, the
2 issuance of the stay will not eliminate or alter any other requirements set forth in the Permit besides
3 those specifically stayed or temporarily extended. *Id.* Instead, the requested stay will simply
4 temporarily suspend the necessity to pursue tasks in an illogical manner, and to prematurely
5 construct costly facility upgrades, resulting in immediate and substantial increases in sewer service
6 fees and concomitant economic impacts, and to comply with improper requirements that are being
7 administratively reviewed. *Id.* The requested stay will also temporarily suspend administrative and
8 civil and potential criminal liability for non-compliance with requirements that the City 1) cannot
9 currently meet, or 2) cannot feasibly meet within the timeframes specified, and which may
10 ultimately be removed from the Permit or modified. *Id.* Thus, issuance of a stay by the State Board
11 simply suspends the unnecessary imposition of increased sewer service fees, onerous fines, and
12 penalties that will be passed on to the public via increased sewer rates or special assessments, and
13 susceptibility to third-party lawsuits pending review of the requested provisions, which may
14 ultimately be removed from the Permit. *Id.* Given that there have been stipulated stays in place for
15 chloride since 2002 with no adverse effects, there is little to no chance of harm expanding the stay
16 to additional provisions.

17 In addition, if a stay were issued, the Regional Board's regulatory oversight of the City will
18 remain unchanged. *See* Levitt Decl. at ¶16. All other effluent limitations, monitoring and reporting
19 requirements, and substantive provisions contained in the Permit and accompanying TSO will
20 remain in effect, and fully enforceable by the Regional Board. *Id.* Specifically, the Permit will
21 continue to require the City to operate its facilities in the same manner as before the stay was
22 issued, and will continue to require the City to monitor and submit detailed reports regarding the
23 facility's performance and compliance with the limitations in the Permit, including the stayed
24 limitations. *Id.* Thus, during the period of the requested stay, the City will continue its existing,
25 protective level of treatment and recycled water production, and will continue to implement source
26 control efforts and pretreatment requirements. *See* Levitt Decl. at ¶16. Finally, the issuance of a
27 stay will benefit the public by providing orderly resolution of the issues raised by the City in this
28 Petition for Stay as well as the City's Petition for Review. *Id.*

1 **3. SUBSTANTIAL QUESTIONS OF FACT OR LAW EXIST.**

2 In addition to the facts and laws discussed herein, the City raised numerous substantial
3 questions of fact and law regarding provisions contained in the Permit in the Petition for Review
4 that was filed with the State Board, including whether the challenged limits were legal and
5 necessary. *See Levitt Decl.* at ¶17. These issues of fact and law are incorporated herein by
6 reference. The fact that serious questions of fact and law exist weighs heavily in favor of granting
7 a stay and maintaining the status quo until such disputes can be resolved. *See Mason v. Superior*
8 *Court*, 23 Cal.App.3d 913, 916 (1972) (“the purpose of the various stays which are set forth in the
9 code is maintenance of the status quo”).

10 However, in order for the State Board to grasp the importance and gravity of the issues the
11 City is are grappling with, the following is a summary of the factual and legal issues that are raised
12 in the City’s Petition for Review, related to the effluent limitations for which a stay is requested.
13 Other issues related to the monitoring and reporting requirements are detailed above or in the
14 Petition for Review, and incorporated herein by reference.

15 Numeric Final Salinity Limits

16 The final effluent limitations for salinity in the Permit are inappropriate or improper for the
17 following reasons:

- 18 a. Inconsistency with the Clean Water Act and Basin Plan provisions, including the
19 Salts TMDL;
- 20 b. Ignoring the Watershed Approach to water quality regulation; and
- 21 c. Placing the City in compliance jeopardy unnecessarily by including final effluent
22 limitations without compliance schedules approved in the applicable TMDL.

23 Numeric Chronic Toxicity Limits

24 The Regional Board’s action to include the Permit’s chronic toxicity effluent limitations
25 based on a Pass/Fail approach using the two concentration Test of Significant Toxicity (TST)
26 guidance methodology was inappropriate or improper for the following reasons:

- 27 a. Premature until the State Water Board adopts a statewide Toxicity Policy or Plan;
- 28

DOWNEY BRAND LLP

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28


While progress has been made to reduce the salts impairment, more work is needed to meet TMDL milestones and final targets. Multiple projects are under consideration, in design, or under construction to remove the impairment. The Permit must be modified to reflect that the Salts TMDL included an implementation plan and schedule to reach compliance with the salts objectives in the watershed. Until that is done, a stay is vitally important to the City.

The City, in concert with the other appealing permittees, has requested that the Regional Board enter into a stipulated stay as has been in place for more than 10 years for chloride, but had not received an answer on that request prior to submission of this Stay Petition. A copy of the draft Stay Stipulation is attached hereto as Exhibit A.

Respectfully Submitted,

DATED: June 4, 2014

DOWNEY BRAND LLP

By: 

MELISSA A. THORME
Attorneys for Petitioner
CITY OF SIMI VALLEY

EXHIBIT A

1 DOWNEY, BRAND LLP
2 MELISSA A. THORME
3 621 Capitol Mall, 18th Floor
4 Sacramento, CA 95814-4686
5 Tel.: (916) 520-5376
6 Fax: (916) 520-5776

7 Special Counsel for Petitioner
8 CITY OF SIMI VALLEY

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
BEFORE THE
CALIFORNIA STATE WATER RESOURCES CONTROL BOARD

10)
11)
12 In the Matter of the City of Simi Valley's)
13 Petition for Review of Action and Failure to)
14 Act by the California Regional Water)
15 Quality Control Board, Los Angeles Region,)
16 in Adopting Order Nos. R4-2014-0066 and)
17 R4-2014-0067 for the Simi Valley Water)
18 Quality Control Plant and Request for Stay.)

10)
11)
12) **DECLARATION OF ERIC J. LEVITT IN**
13) **SUPPORT OF CITY OF SIMI VALLEY'S**
14) **PETITION FOR STAY AND**
15) **COMPLIANCE SCHEDULE**
16) **MODIFICATION FOR SPECIFIC**
17) **PROVISIONS IN ORDER NOS. R4-2014-**
18) **0066 AND R4-2014-0067 ISSUED BY THE**
19) **CALIFORNIA REGIONAL WATER**
20) **QUALITY CONTROL BOARD, LOS**
21) **ANGELES REGION**

22) [WATER CODE §13320 and §13321; 23
23) C.C.R. §2053]

19 I, Eric J. Levitt, declare:

20 1. I am the City Manager for the City of Simi Valley (the "City"). My business
21 address is 2929 Tapo Canyon Road, Simi Valley, CA, US, 93063. I have personal knowledge of
22 the facts stated herein and, if necessary, could testify thereto.

23 2. I am responsible for the administration of the City, including oversight of the
24 administrators of the City's water quality control plant ("WQCP") and the wastewater quality and
25 compliance programs. My duties include working with my staff to review discharge permits,
26 develop technical and policy comments related to wastewater and recycling, compliance with
27 regulations and state and federal laws, and participating in other regulatory activities such as
28 Water Quality Control Plans, Total Maximum Daily Loads, and state and federal policies.

1 3. I have a Masters of Public Administration Degree from the University of Kansas.
2 I have been a City Manager in Simi Valley for one year and was previously a City Manager for
3 over twelve years prior to being hired at the City of Simi Valley.

4 4. In extensive comments submitted to the Regional Water Quality Control Board -
5 Los Angeles Region ("Regional Board") on the NPDES Permit and Time Schedule Order
6 ("TSO") for the City of Simi Valley, the City asserted that the final numeric effluent limits for
7 chloride, sulfate, total dissolved solids ("TDS") and boron were not immediately attainable and
8 alleged substantial questions of law and fact. The City's tertiary treatment system, using
9 nitrification, denitrification, and biological nutrient removal ("BNR"), exceed the secondary
10 treatment requirements of the Clean Water Act. Yet, the City's advanced treatment facilities are
11 not capable of removing substantial amounts of salts, and thus cannot meet the effluent
12 limitations for salinity in the Permit. The City has asserted that compliance schedules and interim
13 limits should be provided by the Regional Board in the Permit to allow the City time to comply
14 with the final effluent limits for chloride, sulfate, boron and TDS, or, at the least, that the TSO
15 expressly states that the interim effluent limits modify the final effluent limits contained in the
16 Permit for the duration of the TSO. Without compliance schedules and interim limits in the
17 Permit, the City will be subject to enforcement liability and potentially liable for citizen suits for
18 failure to immediately and consistently comply with the challenged final effluent limits in the
19 Permit.

20 5. Without interim limits and compliance schedules in the Permit, the City would
21 have to commit to design and construct additional treatment at the WQCP before other activities,
22 such as the Regional Salinity Management Conveyance (RSMC or brine line) are complete and
23 may obviate the need for such POTW treatment (*e.g.*, influent source control). It is impractical to
24 begin construction of costly end-of-pipe treatment options when a plan is already in place and
25 being implemented to address the actual source of the pollutants, which, if successful, will render
26 additional end-of-pipe treatment unnecessary. The City would have to undertake these activities
27 before the review of the propriety of the new permit limits is complete. Given the many legal
28 deficiencies with the permit limits being inconsistent with adopted TMDLs and Basin Plan

1 amendments, it is impractical and a waste of public resources to begin design and construction of
2 costly end-of-pipe treatment options until this review has been completed, since the outcome may
3 render additional end-of-pipe treatment unnecessary or may result in focusing on the watershed
4 approach relying on alternative types and/or levels of treatment or source control activities.

5 6. The installation of additional advanced treatment facilities to meet the final
6 numeric salinity effluent limits in the Permit cannot be completed and placed in operation by the
7 effective date of the Permit. At the time the Permit was adopted, the Regional Board was aware
8 of the inability of the City to comply with the final salinity effluent limits in the Permit. *See* TSO
9 No. R4-2011-0126-A02 at pg. 7, para. 20 (“The Discharger cannot consistently meet the final
10 effluent limitations”). Nevertheless, the Regional Board failed to include necessary compliance
11 schedules in the Permit for such limits even though a compliance schedule was authorized in the
12 Calleguas Watershed Salts TMDL. The Regional Board’s failure to include compliance
13 schedules and interim limits in the Permit places the City in jeopardy of being in violation of the
14 final effluent limits set forth in the Permit on July 1, 2014, the effective date of the Permit. The
15 Regional Board’s failure unnecessarily subjects the City to civil and criminal liability for
16 violations that cannot be avoided pending the construction of facilities necessary to meet the final
17 salinity effluent limits contained in the Permit, which are not required to be met until December
18 8, 2023 under the Salts TMDL.

19 7. All of this is ignored by the Regional Board in the Permit even during a declared
20 drought emergency when there is widespread recognition that source water salinity levels are
21 increasing. On April 14, 2014, the City requested in writing higher interim limits for salts based
22 on anticipated changes to its potable water supply and supplemental information was sent to the
23 Regional Board on April 24th. The City is concerned that the effluent concentrations may exceed
24 the proposed interim and will exceed the final effluent limitations due to changes in the water
25 supply, which is higher in salt content.

26 8. The failure to provide compliance schedules for facility upgrades, disregards the
27 lead times required for facility planning, design, environmental documentation and review under
28 the California Environmental Quality Act, evaluation and mitigation of potential impacts,

1 development of construction financing (including debt service and approval of user rates),
2 construction, and process start-up. A compressed schedule will result in a waste of public funds
3 by requiring the City to pay premium costs for expedited environmental reviews and construction.

4 9. If the City is required to begin preparation for the installation of advanced
5 treatment facilities, without the benefit of the review of possible regulatory relief, like compliance
6 with the TMDL or a variance for the salinity water quality standards as proposed to be adopted in
7 the Central Valley, sewer services fees will have to be substantially increased to fund that project.
8 Based upon a cost study performed for the County Sanitation District of Los Angeles County in
9 2002 by Montgomery Watson Harza, a leading international engineering firm, the capital cost for
10 the addition of advanced treatment technologies necessary to meet the final chloride effluent
11 limitations can reach into the hundreds of millions to install a treatment train consisting of micro-
12 filtration, reverse osmosis, and brine disposal. These estimates do not include costs for possible
13 site acquisition if needed or flow equalization upstream of the membrane units. The additional
14 annual operation and maintenance costs necessary to meet the final effluent limitations will also
15 be in the millions annually. These costs are considerable, and should not be incurred without the
16 benefit of careful analysis.

17 10. Once expended, these costs are irretrievable and will result in significant rate
18 increases for area residents even if the RO system is ultimately mothballed as unnecessary.
19 Given the fact that a separate watershed approach is currently being implemented, the costs of
20 compliance with these end-of-pipe final effluent limits are wildly disproportionate to any minor
21 water quality benefits in the short term particularly when the agricultural users of this water have
22 not voiced any complaints about the current salinity levels. In this drought, the farmers may be
23 thankful to have wet water available for use.

24 11. In addition to the specific harm to the City discussed herein, and in the City's
25 Petition for Stay, the general public will also be substantially harmed if the State Board does not
26 grant the City's stay request. If the requirements contained in the Permit are not immediately
27 stayed, businesses in the City's service area, already under substantial strain from the recent
28 recession and other increasing utility cost increases, will immediately be forced to factor

1 anticipated future sewer rate increases into their critical decisions of whether to remain in the
2 area, and whether to increase or reduce their workforces. These decisions will begin occurring
3 immediately and may have irreversible impacts on investment and employment in the service area
4 of the City.

5 12. A 2001 analysis of the economic impacts of the installation of advanced treatment
6 facilities for the Santa Clarita Valley Joint Sewerage System ("SCVJSS"), which serves a
7 population of approximately 150,000, conducted by M.Cubed and updated by Advent in October
8 of 2003, concluded that, as a result of the cost increases associated with constructing advanced
9 treatment facilities, employment would be reduced in the SCVJSS service area by 423 jobs, total
10 labor income would decline by about \$15.8 million, local tax revenue would fall by over \$2.6
11 million annually, total industry output would drop by nearly \$55.5 million per year, and total
12 value added would decline by more than \$26 million annually. *See* M.Cubed, "Economic
13 Implications of Proposed NPDES Permits for the Sanitation City of Los Angeles County" (May
14 2001). Although the City has not done a similar study, the results would likely be similarly
15 detrimental.

16 13. Using rough estimates, the City anticipates the costs for planning, pre-design, and
17 CEQA-compliance costs to eventually come into compliance with the final effluent limitations to
18 be approximately \$12 million to build a 2.5 mgd RO facility in order to blend the effluent and the
19 RO flows to meet standards and approximately \$1 million annually to operate. However, the City
20 cannot guarantee compliance until this construction project (or the entirety of the projects
21 contemplated in the Salts TMDL) are complete. This would be in addition to the costs that the
22 local residents have already been asked to pay for local water quality-related projects. The City
23 has thus far spent upwards of \$20 million in capital expenditures for upgrading the plant to
24 comply with the nutrient TMDL (nitrogen), and approximately \$1.5 on TMDL development and
25 \$1.0 million on TMDL implementation. The City on the water side is planning for future capital
26 expenditures as much as \$40 million on a groundwater desalter. The City on the stormwater side
27 has spent about \$.5 million on TMDL implementation. The overall watershed group has spent
28 over \$6.6 million on TMDL development, and \$16 million on TMDL implementation. In

1 addition, Calleguas Municipal Water District customers have had to bear the cost to build the
2 brine line of over \$230 million. Taking on additional costs to this very proactive watershed is not
3 only unnecessary, it is unduly burdensome.

4 14. The forced implementation of costly requirements that ultimately prove
5 unnecessary, or the commencement of enforcement actions based on such requirements, is a
6 misdirection of scarce public resources, and should be avoided to prevent substantial harm to the
7 public. The adoption of effluent limitations in violation of federal and state law also causes
8 substantial harm to the public who have a vested interest in the government complying with its
9 own laws and regulations. Similarly, requirements to prepare studies, reports, or pollution
10 prevention plans the necessity of which have not been adjudged should be stayed and delayed
11 until resolution of the appeal of the Permit to avoid unnecessary expenditures and misuse of
12 limited staff resources. If a stay and modification to toll the challenged deadlines are not granted,
13 the City will be harmed if the final compliance date cannot be met and the City is subject to
14 enforcement for violating the TSO in addition to the underlying effluent limitations.

15 15. Granting a stay of the requested provisions will not operate to alter or eliminate
16 these provisions. Nor will the issuance of the stay eliminate or alter any other requirements set
17 forth in the Permit. Instead, the requested stay will simply temporarily suspend the necessity to
18 pursue tasks in an illogical manner, and to prematurely begin to construct costly facility upgrades,
19 resulting in immediate and substantial increases in sewer service fees and concomitant economic
20 impacts, to comply with improper or unlawful requirements that are being administratively
21 reviewed. The requested stay will also temporarily suspend administrative and civil liability for
22 non-compliance with final effluent limits that the City cannot meet, and will be unable to meet
23 until additional treatment facilities are constructed. Further, a stay will defer actions to begin
24 design and construction of additional wastewater treatment facilities to meet limits, which may
25 ultimately be replaced or removed from the Permit if the requested changes to the Permit are
26 authorized by the State Board. Thus, issuance of a stay by the State Board simply suspends the
27 unnecessary imposition of increased sewer service fees, onerous fines, and penalties that will be
28 passed on to the public via increased sewer rates or special assessments, and susceptibility to

1 third-party lawsuits pending review of pending review of the City's Petition for Review.

2 16. The current advanced design of the City's tertiary treatment plant, using
3 nitrification, denitrification, and BNR, does not allow for immediate compliance with the salinity
4 effluent limitations in the Permit or with the numeric chronic toxicity effluent limitations in the
5 Permit due to the statistical guarantee of a 5% false failure rate. If a stay were issued, the
6 Regional Board's regulatory oversight of the City's WQCP will remain unchanged. All other
7 effluent limitations contained in the Permit will remain in effect, and fully enforceable by the
8 Regional Board, U.S. EPA, and third parties. Additionally, the Permit will continue to require the
9 City to operate their facilities in the same manner as before the stay was issued, and will continue
10 to require the City to monitor and submit detailed reports regarding the facility's performance and
11 compliance with the limitations in the Permit, including the stayed limitations. Thus, during the
12 period of the requested stay, the City will continue its existing, protective level of treatment, and
13 will continue to implement source control efforts and any applicable pretreatment requirements.
14 Finally, the issuance of a stay will benefit the public by providing orderly resolution of the issues
15 raised by the City in its Petition for Stay as well as the City's Petition for Review.

16 17. The City raised numerous and substantial questions of fact and law regarding
17 provisions contained in the Permit in the Petition for Review that is being filed simultaneously
18 with the State Board. A stay should be granted. For the duration of the stay of the final salinity
19 effluent limits and the chronic toxicity limit, the City will agree to comply with the corresponding
20 interim limits in the TSO, unless additional changes are needed and requested to address
21 worsening drought and source water conditions, and with the narrative chronic toxicity effluent
22 limit implementing through a numeric trigger of 1 TUc for additional monitoring.

23 I declare under penalty of perjury pursuant to the laws of the California that the foregoing
24 is true and correct.

25 Executed this 4th day of June, 2014 at Simi Valley, California.


26
27 
28 _____
Eric J. Levitt, Declarant

EXHIBIT B

the State Board, the Office of Administrative Law (OAL), and USEPA, the Regional Board's Salts TMDL superseded an earlier March 22, 2002 USEPA-promulgated TMDL for chloride.

7. The permittees have actively participated with other stakeholders in the Calleguas Creek Watershed Management Plan Committee to develop a watershed-wide solution to the salts and other water quality-related problems. Those solutions are reflected in the TMDLs for the watershed and the associated implementation plans and compliance schedules.

8. The Regional Board reissued NPDES permits for each of the three facilities described in Recital 1 on May 8, 2014, however final numeric effluent limits that would be derived from the water quality objectives in the Basin Plan or the TMDLs' WLAs cannot yet be consistently met because the implementation activities for the Regional Board TMDLs are not yet complete.

9. Other effluent limitations (chronic toxicity for all permittees and a copper mass limit for Thousand Oaks) and a few other permit and time schedule order requirements also pose compliance problems for which a stay is appropriate until the Permittees' appeals are resolved.

STIPULATION

1. The parties stipulate that maintaining the stay of the otherwise applicable chloride effluent limits on the terms and conditions set forth below is appropriate and in the public interest. In addition, the parties stipulate that a broader stay is appropriate and in the public interest given new issues that have arisen related to the most recent permits and time schedule orders. This stipulation shall not, however, constitute or be construed as an admission on any issues of law or fact relevant to the final disposition of the petitions.

2. The parties stipulate to the entry of an Order by the State Water Resources Control Board providing that the stays in place for the petitions for review in Files A-1577, A-1578, and A-1579 shall be deemed to be amended to assert challenges to the chloride limits in the new permit and shall impose a continued stay of the chloride limits along with a stay of the challenged new provisions of the Permits and Time Schedule Orders ("TSOs") as described below:

Permits:

- (i) **Camarillo WRP Effluent Limitations** in Provision IV.A.1.a, Table 4, contained in Regional Board Order No. R4-2014-0062 (NPDES NO. CA0053597):
 - a) The 51,400 lbs/day final average monthly dry weather effluent limitation for Total Dissolved Solids ("TDS") and the 850 mg/L final average monthly effluent limitation for TDS under wet weather conditions;
 - b) The 15,100 lbs/day final average monthly dry weather effluent limitation for sulfate and the 250 mg/L final average monthly effluent limitation for sulfate under wet weather conditions;

- c) The 9,070 lbs/day final average monthly dry weather effluent limitation for chloride and the 150 mg/L final average monthly effluent limitation for chloride under wet weather conditions; and
- d) The “pass” median monthly effluent limitation and “pass or %effect < 50” maximum daily effluent limitation for chronic toxicity.

(ii) **Thousand Oaks Hill Canyon WWTP Effluent Limitations** in Provision IV.A.1.a, Table 4, contained in Regional Board Order No. R4-2014-0064 (NPDES NO. CA0056294):

- a) The 17,500 lbs/day final average monthly dry weather effluent limitation for chloride and the 150 mg/L final average monthly effluent limitation for chloride under wet weather conditions;
- b) The 0.4 lbs/day final mass effluent limitation for copper; and
- c) The “pass” median monthly effluent limitation and “pass or %effect < 50” maximum daily effluent limitation for chronic toxicity.

(iii) **Simi Valley WQCP Effluent Limitations** in Provision IV.A.1.a, Table 4, contained in Regional Board Order No. R4-2014-0066 (NPDES NO. CA0055221):

- a) The 88,610 lbs/day final average monthly effluent limitation for TDS and the 850 mg/L final average monthly effluent limitation for TDS under wet weather conditions;
- b) The 26,060 lbs/day final average monthly effluent limitation for sulfate and the 250 mg/L final average monthly effluent limitation for sulfate under wet weather conditions;
- c) The 15,640 lbs/day final average monthly dry weather effluent limitation for chloride and the 150 mg/L final average monthly wet weather effluent limitation for chloride under wet weather conditions;
- d) The 104 lbs/day final average monthly effluent limitation for boron and the 1 mg/L final average monthly effluent limitation for boron; and
- e) The “pass” median monthly effluent limitation and “pass or %effect < 50” maximum daily effluent limitation for chronic toxicity.

Time Schedule Orders:

- (i) **Compliance Deadlines:** Stay of Provision in Paragraph 2 on page 7 of the Thousand Oaks TSO, Order No. R4-2014-0065, limiting application of the interim limits for chloride “from May 8, 2014 to January 31, 2015;” and stay of Provision in Paragraph 3 on page 11 of the Camarillo TSO, Order No. R4-2011-0126-A02, which requires: “Achieve full compliance with the final effluent limitations as soon as possible, but no later than December 31, 2015, the date by which Camarillo SD committed to achieving compliance, for TDS and sulfate contained in Order No.R4-2014-0062.”

- (ii) Compliance Schedule: Stay of Provision in Paragraph 3 on page 7 of the Thousand Oaks TSO, Order No. R4-2014-0065, requiring implementation and completion of studies, actions, and milestones according to the schedule included since such a schedule would not be needed if the copper mass-limit had been modified as suggested.
- (iii) Compliance Workplan: Stay of Provision in Paragraph 5 on page 8 of the Thousand Oaks TSO, Order No. R4-2014-0065, which requires: “By August 6, 2014, the Permittee shall submit a work plan for achieving compliance with the final chloride effluent limitations in Order No. R4-2014-0064 to the Regional Water Board.”
- (iv) Pollution Prevention Plan Workplan: Stay of Provision in Paragraph 6 on page 8 of the Thousand Oaks TSO, Order No. R4-2014-0065; in Paragraph 4 on page 11 of the Camarillo TSO, Order No. R4-2011-0126-A02; and in Paragraph 4 on page 7 of the Simi Valley TSO, Order No. R4-2014-0067, which require: “submit a Pollution Prevention Plan (PPP) work plan, with the time schedule for implementation, for approval of the Executive Officer no later than August 8, 2014, pursuant to CWC section 13263.3.”
- (v) Quarterly Progress Reports: Stay of Provision in Paragraph 7 on page 8 of the Thousand Oaks TSO, Order No. R4-2014-0065; in Paragraph 7 on page 8 of the Camarillo TSO, Order No. R4-2011-0126-A02; and in Paragraph 5 on page 7 of the Simi Valley TSO, Order No. R4-2014-0067, which require submission of quarterly progress reports, the first due October 15, 2014, of efforts taken by the Permittee to comply with the final mass-based limitation for copper and the final effluent limitation for chloride, and the requirements for the content of those reports.

3. The effect of this stay, in accordance with the intent of the parties, is that the interim effluent limitations contained in the TSOs will remain in effect until the petitions for review are completed, and the deadlines contained in the TSOs will be tolled and modified to run from the completion date of the petitions for review, unless a further stay is sought and received from a Superior Court. For chronic toxicity, the previous permit requirements, including a narrative effluent limitation and a 1 TUc trigger for additional monitoring, will remain in place during the pendency of the stay.

4. The parties further stipulate that the Findings in the Permits' Fact Sheets related to the “requirement” to conduct and/or update and submit a feasibility study related to recycling/water reuse are merely findings, not substantive, enforceable provisions, and thus no stay is necessary for Camarillo (Regional Board Order No. R4-2014-0062 at pg. F-16, Section III.C.11, and pg. F-61, Section VIII.G); Thousand Oaks (Regional Board Order No. R4-2014-0064 at pg. F-16, Section III.C.11, and pg. F-59, Section VIII.G); or Simi Valley (Regional Board Order No. R4-2014-0066 at pg. F-17, Section III.C.11, and pg. F-57, Section VIII.G) .


So stipulated and agreed:

LOS ANGELES REGIONAL WATER
QUALITY BOARD

DATE: _____, 2014

By: _____
Sam Unger, Executive Officer

DATE: June 4, 2014

DOWNEY BRAND LLP
By: 
Melissa Thorne
Attorneys for Petitioners
Camarillo Sanitary District, City of
Thousand Oaks, and City of Simi Valley.