

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION**

1515 Clay Street, Suite 1400, Oakland, California 94612
waterboards.ca.gov/sanfranciscobay

**TENTATIVE ORDER R2-2022-00XX
NPDES PERMIT CA0038776**

The following Discharger is subject to the waste discharge requirements (WDRs) set forth in this Order:

Discharger **City of Pacifica**
Name of Facility **Calera Creek Water Recycling Plant
and its wastewater collection system**
Facility Address **700 Coast Highway
Pacifica, CA 94044
San Mateo County**

Table 1. Discharge Locations

| Discharge Point | Effluent Description | Discharge Point Latitude (North) | Discharge Point Longitude (West) | Receiving Water |
|------------------------|---|---|---|------------------------|
| 001 | Advanced-Secondary Treated Municipal Wastewater | 37.614617° | -122.488933° | Calera Creek |

This Order was adopted on: **Month XX, 2022**
This Order shall become effective on: **December 1, 2022**
This Order shall expire on: **November 30, 2027**
CIWQS regulatory measure number: **XXXXX**

The Discharger shall file a Report of Waste Discharge as an application for updated WDRs in accordance with title 23, California Code of Regulations, and an application for reissuance of a National Pollutant Discharge Elimination System (NPDES) permit no later than **March 1, 2027**. The U.S. Environmental Protection Agency (U.S. EPA) and the California Regional Water Quality Control Board, San Francisco Bay Region (Regional Water Board) have classified this discharge as “**major**.”

I hereby certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the Regional Water Board on the date indicated above.

Eileen White, Executive Officer

CONTENTS

| | |
|--------------------------------------|---|
| 1. FACILITY INFORMATION | 3 |
| 2. FINDINGS | 3 |
| 3. DISCHARGE PROHIBITIONS | 4 |
| 4. EFFLUENT LIMITATIONS | 4 |
| 5. RECEIVING WATER LIMITATIONS | 6 |
| 6. PROVISIONS | 7 |

TABLES

| | |
|-------------------------------------|---|
| TABLE 1. DISCHARGE LOCATIONS | 1 |
| TABLE 2. EFFLUENT LIMITATIONS | 4 |

ATTACHMENTS

| | |
|--|-----|
| ATTACHMENT A - DEFINITIONS AND ABBREVIATIONS | A-1 |
| ATTACHMENT B - MAP | B-1 |
| ATTACHMENT C - FLOW SCHEMATIC | C-1 |
| ATTACHMENT D - STANDARD PROVISIONS | D-1 |
| ATTACHMENT E - MONITORING AND REPORTING PROGRAM | E-1 |
| ATTACHMENT F - FACT SHEET | F-1 |
| ATTACHMENT G - REGIONAL STANDARD PROVISIONS, AND MONITORING AND REPORTING REQUIREMENTS (SUPPLEMENT TO ATTACHMENT D) | G-1 |

1. FACILITY INFORMATION

Information describing the Calera Creek Water Recycling Plant and its collection system (collectively, Facility) is summarized on the cover page and in Fact Sheet (Attachment F) sections 1 and 2. Fact Sheet section 1 also includes information regarding the permit application.

2. FINDINGS

The Regional Water Board finds the following:

- 2.1. Legal Authorities.** This Order serves as WDRs pursuant to California Water Code article 4, chapter 4, division 7 (commencing with § 13260). This Order is also issued pursuant to federal Clean Water Act (CWA) section 402 and implementing regulations adopted by U.S. EPA and Water Code chapter 5.5, division 7 (commencing with § 13370). It shall serve as an NPDES permit authorizing the Discharger to discharge into waters of the United States as described in Table 1 subject to the WDRs in this Order.
- 2.2. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information the Discharger submitted as part of its application, information obtained through monitoring and reporting programs, and other available information. The Fact Sheet contains background information and rationale for the requirements in this Order and is hereby incorporated into and constitutes findings for this Order. Attachments A through E and G are also incorporated into this Order.
- 2.3. Notification of Interested Parties.** The Regional Water Board notified the Discharger and interested agencies and persons of its intent to prescribe these WDRs and has provided an opportunity to submit written comments and recommendations. Fact Sheet section 8.1 provides details regarding the notification.
- 2.4. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Fact Sheet section 8.3 provides details regarding the public hearing.

THEREFORE, IT IS HEREBY ORDERED that Order R2-2017-0013 (previous order), as amended by Order R2-2021-0019, is rescinded upon the effective date of this Order, except for enforcement purposes, and, in order to meet the provisions contained in Water Code division 7 (commencing with § 13000) and regulations adopted thereunder and the provisions of the CWA and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order. This action in no way prevents the Regional Water Board from taking enforcement action for violations of the previous order.

3. DISCHARGE PROHIBITIONS

- 3.1. Discharge of treated or partially-treated wastewater at a location or in a manner different from that described in this Order is prohibited.
- 3.2. Bypass of untreated or partially-treated wastewater to waters of the United States is prohibited, except as provided for in Attachment D, section 1.7 of this Order.
- 3.3. Average dry weather influent flow in excess of 4.0 MGD is prohibited. Average dry weather influent flow shall be determined from three consecutive dry weather months each year, with compliance measured at Monitoring Location INF-001 as described in the Monitoring and Reporting Program (MRP, Attachment E).
- 3.4. Any sanitary sewer overflow that results in a discharge of untreated or partially treated wastewater to waters of the United States is prohibited.

4. EFFLUENT LIMITATIONS

- 4.1. **Effluent Limitations.** The discharge at Discharge Point 001 shall meet the following effluent limitations, with compliance measured at Monitoring Location EFF-001 as described in the MRP:

Table 2. Effluent Limitations

| Parameter | Units | Average Monthly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
|--|----------------|------------------------|------------------------|-----------------------|-----------------------|
| Biochemical Oxygen Demand 5-day @ 20°C | mg/L | 10 | 20 | --- | --- |
| Total Suspended Solids | mg/L | 10 | 20 | --- | --- |
| Turbidity | NTU | --- | 10 | --- | --- |
| pH ^[1] | standard units | --- | --- | 6.5 | 8.5 |
| Ammonia, Total | mg/L as N | 3.1 | 7.1 | --- | --- |
| Chronic Toxicity | TUc | 1.0 ^{[2],[3]} | 1.8 ^{[2],[4]} | | |
| Chlorine, Total Residual | mg/L | --- | --- | --- | 0.0 ^[5] |

Footnotes:

- ^[1] If the Discharger monitors pH continuously, pursuant to 40 C.F.R. section 401.17 the Discharger shall be in compliance with this pH limitation provided that both of the following conditions are satisfied: (i) the total time during which the pH is outside the required range shall not exceed 7 hours and 26 minutes in any calendar month; and (ii) no individual excursion from the required pH range shall exceed 60 minutes.
- ^[2] These average monthly and maximum daily effluent limitations shall be replaced by the new maximum daily effluent limit (MDEL) and median monthly effluent limit (MMEL) described in section 4.5 on the first day of the month following U.S. EPA approval of the State Water Board's *State Policy for Water Quality Control: Toxicity Provisions* (Toxicity Provisions).
- ^[3] The average monthly effluent limitation for chronic toxicity shall be the median test result for the month.
- ^[4] The maximum daily effluent limitation for chronic toxicity shall be the maximum test result for the month.
- ^[5] This instantaneous maximum total residual chlorine effluent limitation shall be replaced by a one-hour average effluent limitation of 0.019 mg/L on the first day of the month following U.S. EPA approval of the chlorine water quality objectives established in the Basin Plan amendment adopted by Regional Water Board Resolution R2-2020-0031.

- 4.2. **Percent Removal.** The average monthly percent removal of biochemical oxygen demand (5-day @ 20°C) (BOD) and total suspended solids (TSS) at Discharge

Point 001 shall not be less than 85 percent (i.e., in each calendar month, the arithmetic mean of BOD and TSS, by concentration, of effluent samples collected at Monitoring Location EFF-001 as described in the MRP shall not exceed 15 percent of the arithmetic mean of BOD and TSS, by concentration, for influent samples collected at Monitoring Location INF-001 as described in the MRP at approximately the same times during the same periods).

4.3. *E. Coli* Bacteria. The discharge at Discharge Point 001 shall meet the following *Escherichia coli* (*E. coli*) effluent limitations, with compliance measured at Monitoring Location EFF-001 as described in the MRP:

4.3.1. The six-week rolling geometric mean of *E. coli* bacteria shall not exceed 100 colony forming units per 100 milliliters (CFU/100 mL). Compliance with this limit shall be determined weekly by calculating the geometric mean of all *E. coli* sample results from the past six weeks.

4.3.2. No more than 10 percent of all *E. coli* bacteria samples collected in a calendar month shall exceed 320 CFU/100 mL. Compliance with this limit shall be determined based on measured sample results. The Discharger shall not report interpolated results. If the Discharger has 9 or fewer sample results in a calendar month, compliance shall be based on the highest result. If the Discharger has 10 to 19 sample results, compliance shall be based on the second highest result, and so on.

4.4. Whole Effluent Acute Toxicity (Prior to U.S. EPA Approval of Toxicity Provisions). The discharge at Discharge Point 001 shall comply with the following limitations until the first day of the month following U.S. EPA approval of the State Water Board's *State Policy for Water Quality Control: Toxicity Provisions* (Toxicity Provisions), at which point these limits shall no longer apply. Compliance shall be measured at Monitoring Location EFF-001 as described in the MRP. If the Discharger can demonstrate that toxicity exceeding these acute toxicity limits is caused solely by ammonia and that the ammonia in the discharge complies with the ammonia effluent limits in Table 2 of this Order, then such toxicity shall not constitute a violation of these acute toxicity limits.

4.4.1. The three-sample median shall not exhibit less than 90 percent survival (i.e., a bioassay test showing survival of less than 90 percent shall represent a violation of this effluent limitation if one or more the past two bioassay tests also show less than 90 percent survival); and

4.4.2. The single-sample value shall not exhibit less than 70 percent survival (i.e., a bioassay showing survival of less than 70 percent shall represent a violation of this effluent limitation).

4.5. Chronic Toxicity (After U.S. EPA Approval of Toxicity Provisions). As of the first day of the month following U.S. EPA approval of the Toxicity Provisions, the discharge at Discharge Point 001 shall meet the following maximum daily effluent

limit (MDEL) and median monthly effluent limit (MMEL) at the instream waste concentration (IWC) of 100 percent effluent, with compliance measured at Monitoring Location EFF-001 as described in the MRP:

- MDEL: No test result of “fail” for the sub-lethal endpoint and no percent effect greater than or equal to 50 percent for the survival endpoint.
- MMEL: No more than one result of “fail” in a calendar month for any endpoint.

5. RECEIVING WATER LIMITATIONS

5.1. The discharge shall not cause the following conditions at any place in receiving waters:

- 5.1.1. Floating material, including solids, liquids, foams, and scum, in concentrations that cause nuisance or adversely affect beneficial uses;
- 5.1.2. Alteration of suspended sediment in such a manner as to cause nuisance or adversely affect beneficial uses or detrimental increase in the concentrations of toxic pollutants in sediments or aquatic life;
- 5.1.3. Suspended material in concentrations that cause nuisance or adversely affect beneficial uses;
- 5.1.4. Bottom deposits or aquatic growths to the extent that such deposits or growths cause nuisance or adversely affect beneficial uses;
- 5.1.5. Alteration of temperature beyond present natural background levels unless it can be demonstrated to the satisfaction of the Regional Water Board that such alteration in temperature does not adversely affect beneficial uses;
- 5.1.6. Changes in turbidity that cause nuisance or adversely affect beneficial uses, or increases from normal background light penetration or turbidity greater than 10 percent in areas where natural turbidity is greater than 50 nephelometric turbidity units, or above 55 nephelometric turbidity units in areas where natural turbidity is less than or equal to 50 nephelometric turbidity units;
- 5.1.7. Coloration that causes nuisance or adversely affects beneficial uses;
- 5.1.8. Visible, floating, suspended, or deposited oil or other products of petroleum origin; or
- 5.1.9. Toxic or other deleterious substances in concentrations or quantities that cause deleterious effects on wildlife, waterfowl, or other aquatic biota, or render any of these unfit for human consumption, either at levels created in the receiving waters or as a result of biological concentration.

5.2. The discharge shall not cause the following limits to be exceeded at any place in receiving waters within one foot of the water surface:

5.2.1. Dissolved Oxygen 5.0 mg/L, minimum

The median dissolved oxygen concentration for any three consecutive months shall not be less than 80 percent of the dissolved oxygen content at saturation. When natural factors cause concentrations less than that specified above, the discharge shall not cause further reduction in ambient dissolved oxygen concentrations

5.2.2. Dissolved Sulfide Natural background levels

5.2.3. pH The pH shall not be depressed below 6.5 nor raised above 8.5. The discharge shall not cause changes greater than 0.5 pH units in normal ambient pH levels.

5.2.4. Nutrients Waters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that such growths cause nuisance or adversely affect beneficial uses.

5.3. The discharge shall not cause a violation of any water quality standard for receiving waters adopted by the Regional Water Board or State Water Resources Control Board (State Water Board) as required by the CWA and regulations adopted thereunder beyond any mixing zone established through this Order. If more stringent water quality standards are promulgated or approved pursuant to CWA section 303, or amendments thereto, the Regional Water Board may revise or modify this Order in accordance with the more stringent standards.

6. PROVISIONS

6.1. Standard Provisions

6.1.1. The Discharger shall comply with all “Standard Provisions” in Attachment D.

6.1.2. The Discharger shall comply with all applicable provisions of the “Regional Standard Provisions, and Monitoring and Reporting Requirements for NPDES Wastewater Discharge Permits” in Attachment G.

6.1.3. If there is any conflict, duplication, or overlap between provisions in this Order, the more stringent provision shall apply.

6.2. Monitoring and Reporting Provisions. The Discharger shall comply with the Monitoring and Reporting Program (MRP, Attachment E) and future revisions thereto, and applicable monitoring and reporting requirements in Attachments D and G.

6.3. Special Provisions

6.3.1. Reopener Provisions. The Regional Water Board may modify or reopen this Order prior to its expiration date in any of the following circumstances as allowed by law or as otherwise authorized by law. The Discharger may request a permit modification based on any of these circumstances. With any such request, the Discharger shall include antidegradation and anti-backsliding analyses as necessary.

- 6.3.1.1. If present or future investigations demonstrate that the discharges governed by this Order have or will have a reasonable potential to cause or contribute to adverse impacts on water quality or beneficial uses of the receiving waters;
- 6.3.1.2. If new or revised water quality objectives or total maximum daily loads (TMDLs) come into effect for Calera Creek or contiguous water bodies (whether statewide, regional, or site-specific). In such cases, effluent limitations in this Order may be modified as necessary to reflect the updated water quality objectives or wasteload allocations. Adoption of the effluent limitations in this Order is not intended to restrict in any way future modifications based on legally-adopted water quality objectives or TMDLs or as otherwise permitted under federal regulations governing NPDES permit modifications;
- 6.3.1.3. If translator, dilution, or other water quality studies provide a basis for determining that a permit condition should be modified;
- 6.3.1.4. If a State Water Board precedential decision, new policy, new law, or new regulation is adopted;
- 6.3.1.5. If an administrative or judicial decision on a separate NPDES permit or WDRs addresses requirements similar to this discharge; or
- 6.3.1.6. If the Discharger requests adjustments in effluent limits due to the implementation of stormwater diversion pursuant to the Municipal Regional Stormwater Permit (NPDES Permit CAS612008) for redirecting dry weather and first flush discharges from a storm drain system to the sanitary sewer system as a stormwater pollutant control strategy.

6.3.2. Effluent and Receiving Water Characterization Study and Report

- 6.3.2.1. **Study Elements.** The Discharger shall characterize and evaluate the discharge from Discharge Point 001 and the receiving waters at RSW-001 required by the MRP to verify that the reasonable potential analysis conclusions of this Order remain valid and to inform the next permit reissuance. Once per calendar year for its effluent and once per permit term for its receiving water, the Discharger shall evaluate if the concentrations of any of the priority pollutants listed in Attachment G, Table B, significantly

increase over past performance. The Discharger shall investigate the cause of any such increase. The investigation may include, but need not be limited to, an increase in monitoring frequency, monitoring of internal process streams, and monitoring of influent sources. The Discharger shall establish remedial measures addressing any increase resulting in reasonable potential to cause or contribute to an exceedance of applicable water quality objectives. This requirement may be satisfied through identification of the constituent as a “pollutant of concern” in the Discharger’s Pollutant Minimization Program, described in Provision 6.3.3.

6.3.2.2. **Reporting Requirements**

- 6.3.2.2.1. **Routine Reporting.** The Discharger shall report the pollutants detected at or above applicable water quality objectives (see Fact Sheet Table F-7 for the objectives) in the transmittal letter for the self-monitoring report associated with the month in which samples were collected. This requirement does not apply to pollutants with effluent limitations (see Table 2 of this Order).
- 6.3.2.2.2. **Final Reporting.** The Discharger shall summarize the data evaluation and source investigation in the applicable annual self-monitoring report.

6.3.3. **Pollutant Minimization Program**

- 6.3.3.1. The Discharger shall continue to improve its existing Pollutant Minimization Program to promote minimization of pollutant loadings to the treatment plant and therefore to the receiving waters.
- 6.3.3.2. The Discharger shall submit an annual report no later than February 28 of each calendar year. Each annual report shall include at least the following information:
 - 6.3.3.2.1. **Brief description of treatment plant.** The description shall include the service area and treatment plant processes.
 - 6.3.3.2.2. **Discussion of current pollutants of concern.** Periodically, the Discharger shall analyze its circumstances to determine which pollutants are currently a problem and which pollutants may be potential future problems. This discussion shall include the reasons for choosing the pollutants.
 - 6.3.3.2.3. **Identification of sources for pollutants of concern.** This discussion shall include how the Discharger intends to estimate and identify pollutant sources. The Discharger shall include sources or potential sources not directly within the ability or authority of the Discharger to control, such as pollutants in the potable water supply and air deposition.

- 6.3.3.2.4. **Identification of tasks to reduce the sources of pollutants of concern.** This discussion shall identify and prioritize tasks to address the Discharger's pollutants of concern. The Discharger may implement the tasks by itself or participate in group, regional, or national tasks that address its pollutants of concern. The Discharger is strongly encouraged to participate in group, regional, or national tasks that address its pollutants of concern whenever it is efficient and appropriate to do so. An implementation timeline shall be included for each task.
- 6.3.3.2.5. **Outreach to employees.** The Discharger shall inform employees about the pollutants of concern, potential sources, and how they might be able to help reduce the discharge of these pollutants of concern into the Facility. The Discharger may provide a forum for employees to provide input.
- 6.3.3.2.6. **Continuation of Public Outreach Program.** The Discharger shall prepare a pollution prevention public outreach program for its service area. Outreach may include participation in existing community events, such as county fairs; initiating new community events, such as displays and contests during Pollution Prevention Week; conducting school outreach programs; conducting plant tours; and providing public information in newspaper articles or advertisements, radio or television stories or spots, newsletters, utility bill inserts, or web sites. Information shall be specific to target audiences. The Discharger shall coordinate with other agencies as appropriate.
- 6.3.3.2.7. **Discussion of criteria used to measure Pollutant Minimization Program and task effectiveness.** The Discharger shall establish criteria to evaluate the effectiveness of its Pollutant Minimization Program. This discussion shall identify the specific criteria used to measure the effectiveness of each task in Provisions 6.3.3.2.3, 6.3.3.2.4, 6.3.3.2.5, and 6.3.3.2.6.
- 6.3.3.2.8. **Documentation of efforts and progress.** This discussion shall detail all of the Discharger's Pollutant Minimization Program activities during the reporting year.
- 6.3.3.2.9. **Evaluation of Pollutant Minimization Program and task effectiveness.** The Discharger shall use the criteria established in Provision 6.3.3.2.7. to evaluate the program and task effectiveness.
- 6.3.3.2.10. **Identification of specific tasks and timelines for future efforts.** Based on the evaluation, the Discharger shall explain how it intends to continue or change its tasks to more effectively reduce the amount of pollutants flowing to the treatment plant, and subsequently in its effluent.
- 6.3.3.3. The Discharger shall develop and conduct a Pollutant Minimization Program as described below when there is evidence that a priority pollutant is present

in the effluent above an effluent limitation (e.g., sample results reported as detected but not quantified [DNQ] when the effluent limitation is less than the method detection limit [MDL], sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, or results of benthic or aquatic organism tissue sampling) and either:

- 6.3.3.3.1. A sample result is reported as DNQ and the effluent limitation is less than the Reporting Level (RL); or
- 6.3.3.3.2. A sample result is reported as not detected (ND) and the effluent limitation is less than the MDL, using definitions described in Attachment A and reporting protocols described in the MRP.
- 6.3.3.4. If triggered for a reason set forth in Provision 6.3.3.3, above, the Discharger's Pollutant Minimization Program shall include, but not be limited to, the following actions and submittals:
 - 6.3.3.4.1. An annual review and semi-annual monitoring of potential sources of the reportable priority pollutants, which may include fish tissue monitoring and other bio-uptake sampling, or alternative measures when source monitoring is unlikely to produce useful analytical data;
 - 6.3.3.4.2. Quarterly monitoring for the reportable priority pollutants in the influent to the wastewater treatment system. The Executive Officer may approve alternative measures when influent monitoring is unlikely to produce useful analytical data;
 - 6.3.3.4.3. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutants in the effluent at or below the effluent limitation;
 - 6.3.3.4.4. Implementation of appropriate cost-effective control measures for the reportable priority pollutants, consistent with the control strategy; and
 - 6.3.3.4.5. Inclusion of the following specific items within the annual report required by Provision 6.3.3.2, above:
 - 6.3.3.4.5.1. All Pollutant Minimization Program monitoring results for the previous year;
 - 6.3.3.4.5.2. List of potential sources of the reportable priority pollutants;
 - 6.3.3.4.5.3. Summary of all actions undertaken pursuant to the control strategy; and
 - 6.3.3.4.5.4. Description of actions to be taken in the following year.

6.3.4. Special Provisions for Publicly-Owned Treatment Works

6.3.4.1. Sludge and Biosolids Management

- 6.3.4.1.1. Sludge and biosolids treatment and storage shall not create a nuisance, such as objectionable odors or flies, or result in groundwater contamination.
- 6.3.4.1.2. Sludge and biosolids treatment and storage site shall have facilities adequate to divert surface runoff from adjacent areas, to protect site boundaries from erosion, and to prevent conditions that would cause drainage from the stored materials. Adequate protection is defined as protection from at least a 100-year storm and the highest possible tidal stage that may occur.
- 6.3.4.1.3. This Order does not authorize permanent onsite sludge or biosolids storage or disposal. The Discharger shall file a Report of Waste Discharge and bring the site into compliance with applicable regulations prior to commencement of any such activity.

- 6.3.4.2. **Collection System Management.** The Discharger shall properly operate and maintain its collection system (see Attachments D and G, section 1.4), report any noncompliance with respect to its collection system (see Attachment D, section 5.5.1, and Attachment G, sections 5.5.1 and 5.5.2), and mitigate any discharges in violation of this Order associated with its collection system (see Attachments D and G, section 1.3).

State Water Board Order 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems, as amended by State Water Board Order WQ 2013-0058-EXEC (statewide WDRs), contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. The statewide WDRs clearly and specifically stipulate requirements for operation and maintenance and for reporting and mitigating sanitary sewer overflows. Implementing the requirements for operation and maintenance and mitigation of sanitary sewer overflows set forth in the statewide WDRs (and any subsequent order updating these requirements) shall satisfy the corresponding federal NPDES requirements specified in Attachments D and G of this Order for the collection systems. Following the reporting requirements set forth in the statewide WDRs (and any subsequent order updating those requirements) shall satisfy the NPDES reporting requirements for sanitary sewer overflows specified in Attachments D and G.

- 6.3.4.3. **Resource Recovery from Anaerobically Digestible Material.** If the Discharger receives hauled-in anaerobically-digestible material for injection into an anaerobic digester, the Discharger shall notify the Regional Water Board and develop and implement Standard Operating Procedures for this

activity. The Standard Operating Procedures shall be developed prior to initiation of hauling. The Standard Operating Procedures shall address material handling, including unloading, screening, or other processing prior to anaerobic digestion; transportation; spill prevention; spill response; avoidance of the introduction of materials that could cause interference, pass through, or upset of the treatment processes; avoidance of prohibited material; vector control; odor control; operation and maintenance; and the disposition of any solid waste segregated from introduction to the digester. The Discharger shall train its staff on the Standard Operating Procedures and maintain records for a minimum of three years for each load received, describing the hauler, waste type, and quantity received. In addition, the Discharger shall maintain records for a minimum of three years for the disposition, location, and quantity of cumulative pre-digestion segregated solid waste hauled offsite.

- 6.3.4.4. **Chlorine Disinfection and Dechlorination System Installation.** If the Discharger elects to use chlorine disinfection and dechlorination during construction of its ultraviolet (UV) disinfection system upgrade project, it shall submit the following documentation and wait for the Executive Officer's written concurrence prior to commencing use of the chlorine disinfection and dechlorination system:
- 6.3.5.4.1. Certification by a licensed professional that the chlorine disinfection and dechlorination system has been constructed as designed and is ready for use;
 - 6.3.5.4.2. Updates to the Operations and Maintenance Manual and Contingency Plan to include the temporary chlorine disinfection and dechlorination system; and
 - 6.3.5.4.3. The specific dates the Discharger proposes to begin and end use of the chlorine disinfection and dechlorination system.

ATTACHMENT A - DEFINITIONS AND ABBREVIATIONS

DEFINITIONS

Alternative Hypothesis

Statement used to propose a statistically significant relationship in a set of given observations. Under the TST approach, when the Null Hypothesis is rejected, the Alternative Hypothesis is accepted in its place, indicating a relationship between variables and an acceptable level of toxicity.

Arithmetic Mean (μ)

Also called the average, sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n$$

where: Σx is the sum of the measured ambient water concentrations,
and n is the number of samples

Average Monthly Effluent Limitation (AMEL)

Highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL)

Highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative

Taken up by an organism from its surrounding medium through gill membranes, through epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Calendar Month(s)

Period from the first day of a month through the last day of a month (e.g., January 1 to January 31). For toxicity monitoring, the period is from the first day of a routine monitoring test to the day before the corresponding day of the next month (e.g., from June 15 to July 14), or to the last day of the next month if there is no corresponding day (e.g., January 31 to February 28).

Carcinogenic

Known to cause cancer in living organisms.

Coefficient of Variation (CV)

Measure of data variability calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge

Either: (1) the total mass of a constituent discharged over a calendar day (12:00 a.m. through 11:59 p.m.) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit) for a constituent with limitations expressed in units of mass; or (2) the unweighted arithmetic mean measurement of a constituent over a day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period is considered the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ)

Sample results less than the RL, but greater than or equal to the laboratory's MDL. Sample results reported as DNQ are estimated concentrations.

Dilution Credit

Amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effective Concentration (EC).

The EC is a point estimate of the toxicant concentration that would cause an adverse effect on a quantal, "all or nothing," response (such as death, immobilization, or serious incapacitation) in a given percent of the test organisms. If the effect is death or immobility, the term lethal concentration (LC) may be used. EC values may be calculated using point estimation techniques such as probit, logit, and Spearman-Kärber. EC25 is the concentration of toxicant (in percent effluent) that causes a response in 25 percent of the test organisms.

Effluent Concentration Allowance (ECA)

Value derived from the water quality criterion or objective, dilution credit, and ambient background concentration that is used, in conjunction with the CV for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as wasteload allocation (WLA) as used in U.S. EPA guidance (*Technical Support Document for Water Quality-based Toxics Control*, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays

Indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest

distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration

Concentration that results from the confirmed detection of a substance below the ML by the analytical method.

Estuaries

Waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters are considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220; Suisun Bay; Carquinez Strait downstream to the Carquinez Bridge; and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inhibition Concentration (IC).

The IC is a point estimate of the toxicant concentration that would cause a given percent reduction in a nonlethal, nonquantal biological measurement, such as growth. For example, an IC25 is the estimated concentration of toxicant that would cause a 25 percent reduction in average young per female or growth. IC values may be calculated using a linear interpolation method such as U.S. EPA's Bootstrap Procedure.

Inland Surface Waters

All surface waters of the state that are not the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation

Highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

Lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Instream Waste Concentration (IWC)

Concentration of effluent in the receiving water after any dilution credit is applied. The IWC is the inverse of 1 plus the dilution credit, D, or $IWC = 1/(1+D)$, expressed as a percentage (e.g., if D = 9, the IWC is 10 percent). If no dilution credit is granted, the IWC is 100 percent.

Maximum Daily Effluent Limitation (MDEL)

Highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For toxicity, the MDEL is based on the outcome of the TST and the percent effect at the IWC (applied to the results of any single bioassay). For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median

Middle measurement in a data set. The median of a data set is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2+1)})/2$ (i.e., the midpoint between $n/2$ and $n/2+1$).

Median Monthly Effluent Limitation (MMEL)

Highest allowable median of daily discharges over a calendar month, calculated as the median of all daily discharges measured during a calendar month. For aquatic toxicity, the MMEL is an effluent limitation based on a maximum of three independent toxicity tests analyzed using the TST during a calendar month.

Median Monthly Effluent Target (MMET)

Target based on a maximum of three independent toxicity tests using the TST during a calendar month used to determine whether a TRE should be conducted. Not meeting a MMET is not a violation of an effluent limitation. The MMET only applies to discharges with no numeric toxicity limits or to testing with *Ceriodaphnia dubia* prior to January 1, 2024.

Method Detection Limit (MDL)

Minimum concentration of a substance that can be reported with 99 percent confidence that the measured concentration is distinguishable from method blank results, as defined in 40 C.F.R. part 136, Appendix B.

Minimum Level (ML)

Concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone

Limited volume of receiving water allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

MMEL Compliance Test

For chronic toxicity monitoring, one of up to two tests used in addition to a routine monitoring test to determine compliance with the chronic toxicity MMEL and MDEL.

No Observed Effect Concentration (NOEC).

The NOEC is the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation. It is determined using hypothesis testing.

No Observed Effect level (NOEL).

For compliance determination, the NOEL is equal to IC25 or EC25. If the IC25 or EC25 cannot be statistically determined, the NOEL shall be equal to the NOEC derived using hypothesis testing.

Not Detected (ND)

Sample results less than the laboratory's MDL.

Null Hypothesis

Statement used in statistical testing that has been put forward either because it is believed to be true or because it is to be used as a basis for argument, but has not been proved.

Percent Effect

Value that denotes the difference in response between a test concentration and a control, divided by the mean control response and multiplied by 100.

Persistent Pollutants

Substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program

Program of waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of a Pollutant Minimization Program is to reduce all potential sources of a priority pollutant through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. Cost effectiveness may be considered when establishing the requirements of a Pollutant Minimization Program. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), is considered to fulfill the Pollutant Minimization Program requirements.

Pollution Prevention

Any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product

reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State Water Resources Control Board or Regional Water Board.

Regulatory Management Decision (RMD)

Decision that represents the maximum allowable error rates and thresholds for toxicity and non-toxicity that would result in an acceptable risk to aquatic life.

Reporting Level (RL)

ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order, including an additional factor if applicable as discussed herein. For priority pollutants, the MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from State Implementation Plan (SIP) Appendix 4 in accordance with SIP section 2.4.2 or established in accordance with SIP section 2.4.3. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Response

Measured biological effect (e.g., on survival, reproduction, growth) of exposure to a stimulus.

Routine Monitoring

Regular chronic toxicity monitoring required during the permit term. Routine monitoring results may trigger MMEL compliance tests. If a violation of the MDEL or MMEL occurs, Routine monitoring also includes one sample collected during the following month (regardless of the regular monitoring frequency), which is used to determine if a TRE is necessary. Routine monitoring does not include surveillance monitoring.

Source of Drinking Water

Any water designated as municipal or domestic supply (MUN) beneficial use.

Standard Deviation (σ)

Measure of variability calculated as follows:

$$\text{Standard deviation} = \sigma = (\Sigma[(x - \mu)^2]/(n - 1))^{0.5}$$

where: x is the observed value

μ is the arithmetic mean of the observed values

n is the number of samples

Surveillance Monitoring

Chronic toxicity monitoring performed using the most sensitive species at an effluent concentration at least double the IWC. Surveillance monitoring results are not for assessing compliance with the chronic toxicity MMEL or MDEL.

Test of Significant Toxicity (TST)

Statistical approach used to analyze aquatic toxicity test data, as described in section IV.B.1.c of State Water Board's *State Policy for Water Quality Control: Toxicity Provisions*.

Toxicity Reduction Evaluation (TRE)

Study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. A TIE is a set of procedures to identify the specific chemicals responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.

ABBREVIATIONS


| | |
|-------------------------|-------------------------------------|
| % | Percent |
| °C | Degrees Celsius |
| °F | Degrees Fahrenheit |
| µg/L | Micrograms per liter |
| 1/Blending Event | Once per blending event |
| 1/Day | Once per day |
| 1/Month | Once per month |
| 1/Quarter | Once per quarter |
| 1/Week | Once per week |
| 1/Year | Once per year |
| 2/Month | Two times per month |
| 2/Week | Twice per week |
| 2/Year | Twice per year |
| 3/Week | Three times per week |
| 4/Week | Four times per week |
| 5/Week | Five times per week |
| AMEL | Average monthly effluent limitation |

| | |
|---------------------|---|
| AWEL | Average weekly effluent limitation |
| B | Background concentration |
| C | Water quality criterion or objective |
| C-24 | 24-hour composite |
| CFU/100 mL | Colony forming units per 100 milliliters |
| CIWQS | California Integrated Water Quality System |
| Continuous | Measured continuously |
| Continuous/D | Measured continuously, and recorded and reported daily |
| Continuous/H | Measured continuously, and recorded and reported hourly |
| CTR | California Toxics Rule |
| CV | Coefficient of Variation |
| DMR | Discharge Monitoring Report |
| DNQ | Detected, but not quantified |
| DL | Detection level |
| ECA | Effluent Concentration Allowance |
| Grab | Grab sample |
| MDEL | Maximum Daily Effluent Limitation |
| MDL | Method detection limit |
| MEC | Maximum effluent concentration |
| MG | Million gallons |
| mg/L | Milligrams per liter |
| mg/L as N | Milligrams per liter as nitrogen |
| MGD | Million gallons per day |
| ML | Minimum level |
| MPN/100 mL | Most probable number per 100 milliliters |
| NTR | National Toxics Rule |
| ND | Not detected |
| NTU | Nephelometric turbidity units |
| RL | Reporting level |
| RPA | Reasonable potential analysis |
| SIP | <i>Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California</i> (State Implementation Policy) |

| | |
|--------------|---|
| SMR | Self Monitoring Report |
| s.u. | Standard pH units |
| TIE | Toxicity identification evaluation |
| TRE | Toxicity reduction evaluation |
| TUa | Acute toxicity units |
| TUc | Chronic toxicity units |
| WDRs | Waste discharge requirements |
| WQBEL | Water quality-based effluent limitation |


ATTACHMENT B - MAP

Figure B. Facility Map



ATTACHMENT C - FLOW SCHEMATIC

Figure C. Process Flow Diagram



ATTACHMENT D - STANDARD PROVISIONS

CONTENTS

| | | |
|-----------|--|-------------|
| 1. | STANDARD PROVISIONS – PERMIT COMPLIANCE | D-2 |
| 2. | STANDARD PROVISIONS – PERMIT ACTION | D-5 |
| 3. | STANDARD PROVISIONS – MONITORING | D-6 |
| 4. | STANDARD PROVISIONS – RECORDS | D-6 |
| 5. | STANDARD PROVISIONS – REPORTING | D-7 |
| 6. | STANDARD PROVISIONS – ENFORCEMENT | D-12 |
| 7. | ADDITIONAL PROVISIONS – NOTIFICATION LEVELS | D-12 |

ATTACHMENT D – STANDARD PROVISIONS

1. STANDARD PROVISIONS – PERMIT COMPLIANCE

1.1. Duty to Comply

- 1.1.1. The Discharger must comply with all of the terms, requirements, and conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action; permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof. (40 C.F.R. § 122.41(a); Wat. Code, §§ 13261, 13263, 13265, 13268, 13000, 13001, 13304, 13350, 13385.)
- 1.1.2. The Discharger shall comply with effluent standards or prohibitions established under CWA section 307(a) for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. § 122.41(a)(1).)

1.2. Need to Halt or Reduce Activity Not a Defense. It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. § 122.41(c).)

1.3. Duty to Mitigate. The Discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. § 122.41(d).)

1.4. Proper Operation and Maintenance. The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 C.F.R. § 122.41(e).)

1.5. Property Rights

- 1.5.1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. § 122.41(g).)
- 1.5.2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. § 122.5(c).)

1.6. Inspection and Entry. The Discharger shall allow the Regional Water Board, State Water Board, U.S. EPA, and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (33 U.S.C. § 1318(a)(4)(B); 40 C.F.R. § 122.41(i); Wat. Code, §§ 13267, 13383):

- 1.6.1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (33 U.S.C. § 1318(a)(4)(B)(i); 40 C.F.R. § 122.41(i)(1); Wat. Code, §§ 13267, 13383);
- 1.6.2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (33 U.S.C. § 1318(a)(4)(B)(ii); 40 C.F.R. § 122.41(i)(2); Wat. Code, §§ 13267, 13383);
- 1.6.3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (33 U.S.C. § 1318(a)(4)(B)(ii); 40 C.F.R. § 122.41(i)(3); Wat. Code, §§ 13267, 13383); and
- 1.6.4. Sample or monitor, at reasonable times, for the purposes of ensuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (33 U.S.C. § 1318(a)(4)(B); 40 C.F.R. § 122.41(i)(4); Wat. Code, §§ 13267, 13383.)

1.7. Bypass

1.7.1. Definitions

- 1.7.1.1. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. § 122.41(m)(1)(i).)
- 1.7.1.2. "Severe property damage" means substantial physical damage to property; damage to the treatment facilities, which causes them to become inoperable; or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. § 122.41(m)(1)(ii).)
- 1.7.2. **Bypass not exceeding limitations.** The Discharger may allow any bypass to occur that does not cause exceedances of effluent limitations, but only if it is for essential maintenance to ensure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance sections 1.7.3, 1.7.4, and 1.7.5 below. (40 C.F.R. § 122.41(m)(2).)
- 1.7.3. **Prohibition of bypass.** Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. § 122.41(m)(4)(i)):

- 1.7.3.1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. § 122.41(m)(4)(i)(A));
- 1.7.3.2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. § 122.41(m)(4)(i)(B)); and
- 1.7.3.3. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance section 1.7.5 below. (40 C.F.R. § 122.41(m)(4)(i)(C).)
- 1.7.4. **Approval.** The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance section 1.7.3 above. (40 C.F.R. § 122.41(m)(4)(ii).)
- 1.7.5. **Notice**
 - 1.7.5.1. **Anticipated bypass.** If the Discharger knows in advance of the need for a bypass, it shall submit prior notice, if possible, at least 10 days before the date of the bypass. The notice shall be sent to the Regional Water Board. As of December 21, 2025, a notice shall also be submitted electronically to the initial recipient defined in Standard Provisions – Reporting section 5.10 below. Notices shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(m)(3)(i).)
 - 1.7.5.2. **Unanticipated bypass.** The Discharger shall submit a notice of an unanticipated bypass as required in Standard Provisions – Reporting section 5.5 below (24-hour notice). The notice shall be sent to the Regional Water Board. As of December 21, 2025, a notice shall also be submitted electronically to the initial recipient defined in Standard Provisions – Reporting section 5.10 below. Notices shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(m)(3)(ii).)
- 1.8. **Upset.** Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. § 122.41(n)(1).)

- 1.8.1. **Effect of an upset.** An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance section 1.8.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. § 122.41(n)(2).)
- 1.8.2. **Conditions necessary for a demonstration of upset.** A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. § 122.41(n)(3)):
- 1.8.2.1. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. § 122.41(n)(3)(i));
- 1.8.2.2. The permitted facility was, at the time, being properly operated (40 C.F.R. § 122.41(n)(3)(ii));
- 1.8.2.3. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting section 5.5.2.2 below (24-hour notice) (40 C.F.R. § 122.41(n)(3)(iii)); and
- 1.8.2.4. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance section 1.3 above. (40 C.F.R. § 122.41(n)(3)(iv).)
- 1.8.3. **Burden of proof.** In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. § 122.41(n)(4).)

2. STANDARD PROVISIONS – PERMIT ACTION

- 2.1. **General.** This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. § 122.41(f).)
- 2.2. **Duty to Reapply.** If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. § 122.41(b).)
- 2.3. **Transfers.** This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and Water Code. (40 C.F.R. §§ 122.41(l)(3), 122.61.)

3. STANDARD PROVISIONS – MONITORING

- 3.1.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. § 122.41(j)(1).)
- 3.2.** Monitoring must be conducted according to test procedures approved under 40 C.F.R. part 136 for the analyses of pollutants unless another method is required under 40 C.F.R. chapter 1, subchapter N. Monitoring must be conducted according to sufficiently sensitive test methods approved under 40 C.F.R. part 136 for the analysis of pollutants or pollutant parameters or as required under 40 C.F.R. chapter 1, subchapter N. For the purposes of this paragraph, a method is sufficiently sensitive when:
- 3.2.1.** The method minimum level (ML) is at or below the level of the most stringent effluent limitation established in the permit for the measured pollutant or pollutant parameter, and either the method ML is at or below the level of the most stringent applicable water quality criterion for the measured pollutant or pollutant parameter or the method ML is above the applicable water quality criterion but the amount of the pollutant or pollutant parameter in the facility's discharge is high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge; or
- 3.2.2.** The method has the lowest ML of the analytical methods approved under 40 C.F.R. part 136 or required under 40 C.F.R. chapter 1, subchapter N, for the measured pollutant or pollutant parameter.

In the case of pollutants or pollutant parameters for which there are no approved methods under 40 C.F.R. part 136 or otherwise required under 40 C.F.R. chapter 1, subchapter N, monitoring must be conducted according to a test procedure specified in this Order for such pollutants or pollutant parameters. (40 C.F.R. §§ 122.21(e)(3), 122.41(j)(4), 122.44(i)(1)(iv).)

4. STANDARD PROVISIONS – RECORDS

- 4.1.** The Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report, or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 C.F.R. § 122.41(j)(2).)
- 4.2.** Records of monitoring information shall include:
- 4.2.1.** The date, exact place, and time of sampling or measurements (40 C.F.R. § 122.41(j)(3)(i));

- 4.2.2. The individual(s) who performed the sampling or measurements (40 C.F.R. § 122.41(j)(3)(ii));
- 4.2.3. The date(s) analyses were performed (40 C.F.R. § 122.41(j)(3)(iii));
- 4.2.4. The individual(s) who performed the analyses (40 C.F.R. § 122.41(j)(3)(iv));
- 4.2.5. The analytical techniques or methods used (40 C.F.R. § 122.41(j)(3)(v)); and
- 4.2.6. The results of such analyses. (40 C.F.R. § 122.41(j)(3)(vi).)
- 4.3.** Claims of confidentiality for the following information will be denied (40 C.F.R. § 122.7(b)):
 - 4.3.1. The name and address of any permit applicant or Discharger (40 C.F.R. § 122.7(b)(1)); and
 - 4.3.2. Permit applications and attachments, permits, and effluent data. (40 C.F.R. § 122.7(b)(2).)

5. STANDARD PROVISIONS – REPORTING

5.1. Duty to Provide Information. The Discharger shall furnish to the Regional Water Board, State Water Board, or U.S. EPA within a reasonable time, any information that the Regional Water Board, State Water Board, or U.S. EPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or U.S. EPA copies of records required to be kept by this Order. (40 C.F.R. § 122.41(h); Wat. Code, §§ 13267, 13383.)

5.2. Signatory and Certification Requirements

- 5.2.1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or U.S. EPA shall be signed and certified in accordance with Standard Provisions – Reporting sections 5.2.2, 5.2.3, 5.2.4, 5.2.5, and 5.2.6 below. (40 C.F.R. § 122.41(k).)
- 5.2.2. For a corporation, all permit applications shall be signed by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (1) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (2) the manager of one or more manufacturing, production, or operating facilities, provided the manager is authorized to make management decisions that govern the operation of the regulated facility, including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to ensure long term environmental

compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. (40 C.F.R. § 122.22(a)(1).)

For a partnership or sole proprietorship, all permit applications shall be signed by a general partner or the proprietor, respectively. (40 C.F.R. § 122.22(a)(2).)

For a municipal, state, federal, or other public agency, all permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes (1) the chief executive officer of the agency, or (2) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of U.S. EPA). (40 C.F.R. § 122.22(a)(3).)

- 5.2.3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or U.S. EPA shall be signed by a person described in Standard Provisions – Reporting section 5.2.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 5.2.3.1. The authorization is made in writing by a person described in Standard Provisions – Reporting section 5.2.2 above (40 C.F.R. § 122.22(b)(1));
 - 5.2.3.2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. § 122.22(b)(2)); and
 - 5.2.3.3. The written authorization is submitted to the Regional Water Board and State Water Board. (40 C.F.R. § 122.22(b)(3).)
- 5.2.4. If an authorization under Standard Provisions – Reporting section 5.2.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting section 5.2.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications to be signed by an authorized representative. (40 C.F.R. § 122.22(c).)
- 5.2.5. Any person signing a document under Standard Provisions – Reporting section 5.2.2 or 5.2.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. § 122.22(d).)

- 5.2.6. Any person providing the electronic signature for documents described in Standard Provisions – Reporting sections 5.2.1, 5.2.2, or 5.2.3 that are submitted electronically shall meet all relevant requirements of Standard Provisions – Reporting section 5.2, and shall ensure that all relevant requirements of 40 C.F.R. part 3 (Cross-Media Electronic Reporting) and 40 C.F.R. part 127 (NPDES Electronic Reporting Requirements) are met for that submission. (40 C.F.R. § 122.22(e).)

5.3. Monitoring Reports

- 5.3.1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 C.F.R. § 122.41(l)(4).)
- 5.3.2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board. All reports and forms must be submitted electronically to the initial recipient defined in Standard Provisions – Reporting section 5.10 and comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(l)(4)(i).)
- 5.3.3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 C.F.R. part 136, or another method required for an industry-specific waste stream under 40 C.F.R. chapter 1, subchapter N, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or reporting form specified by the Regional Water Board or State Water Board. (40 C.F.R. § 122.41(l)(4)(ii).)
- 5.3.4. Calculations for all limitations that require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. § 122.41(l)(4)(iii).)

- 5.4. Compliance Schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order shall be submitted no later than 14 days following each schedule date. (40 C.F.R. § 122.41(l)(5).)

5.5. Twenty-Four Hour Reporting

- 5.5.1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written report shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and, if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

For noncompliance related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (i.e., combined sewer overflow, sanitary sewer overflow, or bypass event), type of overflow structure (e.g., manhole, combined sewer overflow outfall), discharge volume untreated by the treatment works treating domestic sewage, types of human health and environmental impacts of the event, and whether the noncompliance was related to wet weather.

As of December 21, 2025, all reports related to combined sewer overflows, sanitary sewer overflows, or bypass events must be submitted to the Regional Water Board and must be submitted electronically to the initial recipient defined in Standard Provisions – Reporting section 5.10. The reports shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. The Regional Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. § 122.41(l)(6)(i).)

- 5.5.2. The following shall be included as information that must be reported within 24 hours:
- 5.5.2.1. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(A).)
- 5.5.2.2. Any upset that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(B).)
- 5.5.3. The Regional Water Board may waive the above required written report on a case-by-case basis if an oral report has been received within 24 hours. (40 C.F.R. § 122.41(l)(6)(ii)(B).)

- 5.6. Planned Changes.** The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. § 122.41(l)(1)):

- 5.6.1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 C.F.R. section 122.29(b) (40 C.F.R. § 122.41(l)(1)(i)); or
- 5.6.2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order unless the discharge is an existing manufacturing, commercial, mining, or silvicultural discharge as referenced in 40 C.F.R. section 122.42(a). (40 C.F.R. § 122.41(l)(1)(ii).) If the discharge is an existing manufacturing, commercial, mining, or silvicultural discharge as referenced in 40 C.F.R. section 122.42(a), this notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements under 40 C.F.R. section 122.42(a)(1) (see Additional Provisions – Notification Levels section 7.1.1). (40 C.F.R. § 122.41(l)(1)(ii).)
- 5.7. Anticipated Noncompliance.** The Discharger shall give advance notice to the Regional Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with this Order's requirements. (40 C.F.R. § 122.41(l)(2).)
- 5.8. Other Noncompliance.** The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting sections 5.3, 5.4, and 5.5 above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting section 5.5 above. For noncompliance related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports shall contain the information described in Standard Provision – Reporting section 5.5 and the applicable required data in appendix A to 40 C.F.R. part 127. The Regional Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. § 122.41(l)(7).)
- 5.9. Other Information.** When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or U.S. EPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. § 122.41(l)(8).)
- 5.10. Initial Recipient for Electronic Reporting Data.** The owner, operator, or duly authorized representative is required to electronically submit NPDES information specified in appendix A to 40 C.F.R. part 127 to the initial recipient defined in 40 C.F.R. section 127.2(b). U.S. EPA will identify and publish the list of initial recipients on its website and in the Federal Register, by state and by NPDES data group [see 40 C.F.R. section 127.2(c)]. U.S. EPA will update and maintain this list. (40 C.F.R. § 122.41(l)(9).)

6. STANDARD PROVISIONS – ENFORCEMENT

- 6.1. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, Water Code sections 13268, 13385, 13386, and 13387.

7. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

- 7.1. **Non-Municipal Facilities.** Existing manufacturing, commercial, mining, and silvicultural Dischargers shall notify the Regional Water Board as soon as they know or have reason to believe (40 C.F.R. § 122.42(a)):

- 7.1.1. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following “notification levels” (40 C.F.R. § 122.42(a)(1)):
- 7.1.1.1. 100 micrograms per liter (µg/L) (40 C.F.R. § 122.42(a)(1)(i));
 - 7.1.1.2. 200 µg/L for acrolein and acrylonitrile; 500 µg/L for 2,4 dinitrophenol and 2-methyl 4,6 dinitrophenol; and 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(1)(ii));
 - 7.1.1.3. Five (5) times the maximum concentration reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(1)(iii)); or
 - 7.1.1.4. The level established by the Regional Water Board in accordance with 40 C.F.R. section 122.44(f). (40 C.F.R. § 122.42(a)(1)(iv).)
- 7.1.2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following “notification levels” (40 C.F.R. § 122.42(a)(2)):
- 7.1.2.1. 500 micrograms per liter (µg/L) (40 C.F.R. § 122.42(a)(2)(i));
 - 7.1.2.2. 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(2)(ii));
 - 7.1.2.3. Ten (10) times the maximum concentration reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(2)(iii)); or
 - 7.1.2.4. The level established by the Regional Water Board in accordance with 40 C.F.R. section 122.44(f). (40 C.F.R. § 122.42(a)(2)(iv).)

7.2 Publicly Owned Treatment Works (POTWs)

- 7.2.1. All POTWs shall provide adequate notice to the Regional Water Board of any new introduction of pollutants into the POTW from an indirect discharger that

would be subject to CWA sections 301 or 306 if it were directly discharging those pollutants (40 C.F.R. § 122.42(b)(1)).

- 7.2.2. All POTWs shall provide adequate notice to the Regional Water Board of any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of this Order. (40 C.F.R. § 122.42(b)(2).)
- 7.2.3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. § 122.42(b)(3).)

ATTACHMENT E - MONITORING AND REPORTING PROGRAM

CONTENTS

| | |
|---|-------------|
| 1. GENERAL MONITORING PROVISIONS..... | E-2 |
| 2. MONITORING LOCATIONS | E-3 |
| 3. INFLUENT MONITORING..... | E-3 |
| 4. EFFLUENT MONITORING | E-3 |
| 5. TOXICITY MONITORING..... | E-5 |
| 6. RECEIVING WATER MONITORING | E-14 |
| 7. RECYLED WATER POLICY ANNUAL REPORTS | E-14 |
| 8. REPORTING REQUIREMENTS | E-15 |
| APPENDIX E-1 CHRONIC TOXICITY DEFINITION OF TERMS AND SPECIES SENSITIVITY SCREENING REQUIREMENTS | E-19 |
| APPENDIX E-2: SUMMARY OF TOXICITY TEST SPECIES REQUIREMENTS | E-21 |
| APPENDIX E-3: TOXICITY REDUCTION EVALUATION PROCESS FLOWCHART ROUTINE MONITORING | E-23 |

TABLES

| | |
|---|-------------|
| TABLE E-1. MONITORING LOCATIONS..... | E-3 |
| TABLE E-2. INFLUENT MONITORING | E-3 |
| TABLE E-3. EFFLUENT MONITORING | E-4 |
| TABLE E-4. TOXICITY REDUCTION EVALUATION (TRE) TRIGGERS | E-13 |
| TABLE E-5. RECEIVING WATER MONITORING..... | E-14 |
| TABLE E-6. CIWQS REPORTING | E-15 |
| TABLE E-7. MONITORING PERIODS..... | E-16 |
| TABLE AE-1. WEST COAST MARINE CHRONIC TOXICITY TEST SPECIES AND METHODS | E-21 |
| TABLE AE-2. FRESHWATER CHRONIC TOXICITY TEST SPECIES AND METHOD | E-21 |
| TABLE AE-3. TOXICITY TEST REQUIREMENTS FOR SPECIES SENSITIVITY SCREENING | E-22 |

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Clean Water Act (CWA) section 308 and 40 C.F.R. sections 122.41(h), (j)-(l), 122.44(i), and 122.48 require that all NPDES permits specify monitoring and reporting requirements. Water Code section 13383 also authorizes the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. This MRP establishes monitoring, reporting, and recordkeeping requirements that implement the federal and State laws and regulations.

1. GENERAL MONITORING PROVISIONS

- 1.1. The Discharger shall comply with this MRP. The Executive Officer may amend this MRP pursuant to 40 C.F.R. section 122.63. If any discrepancies exist between this MRP and the “Regional Standard Provisions, and Monitoring and Reporting Requirements (Supplement to Attachment D) for NPDES Wastewater Discharge Permits” (Attachment G), this MRP shall prevail.
- 1.2. The Discharger shall conduct all monitoring in accordance with Attachment D section 3, as supplemented by Attachment G. Equivalent test methods must be more sensitive than those specified in 40 C.F.R. section 136 and must be specified in this permit.
- 1.3. For the analysis of monitoring samples, the Discharger shall use laboratories certified by the State Water Resources Control Board (State Water Board) in accordance with Water Code section 13176 and shall obtain quality assurance/quality control data with laboratory reports. For any onsite field tests (e.g., turbidity, pH, temperature, dissolved oxygen, conductivity, disinfectant residual) analyzed by a noncertified laboratory, the Discharger shall implement a Quality Assurance-Quality Control Program. The Discharger shall keep a manual onsite containing the steps followed in this program and shall demonstrate sufficient capability to adequately perform these field tests (e.g., qualified and trained employees, properly calibrated and maintained field instruments). The program shall conform to U.S. EPA guidelines or other approved procedures.
- 1.4. The Discharger shall ensure that the results of the Discharge Monitoring Report-Quality Assurance (DMR-QA) Study or most recent Water Pollution Performance Evaluation Study are submitted annually to the State Water Board at the following address:

State Water Resources Control Board;
Quality Assurance Program Officer;
Office of Information Management and Analysis;
1001 I Street
Sacramento, CA 95814

2. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements of this Order:

Table E-1. Monitoring Locations

| Monitoring Location Type | Monitoring Location | Monitoring Location Description |
|--------------------------|---------------------|---|
| Influent | INF-001 | A point in the treatment plant headworks at which all waste tributary to the treatment system is present and preceding any phase of treatment |
| Effluent | EFF-001 | A point following all treatment, including disinfection, at which all waste tributary to Discharge Point 001 is present but prior to discharge to Calera Creek |
| Receiving Water | RSW-001 | A point in Calera Creek approximately 1,250 feet upstream of Discharge Point 001 |
| Receiving Water | RSW-002 | A point in Calera Creek immediately downstream of Discharge Point 001 at which the effluent and receiving water are completely mixed across the creek's cross section |
| Receiving Water | RSW-003 | A point in Calera Creek downstream of the culvert and approximately 1,600 feet downstream of Discharge Point 001 |
| Receiving Water | RSW-004 | A point in Calera Creek approximately 2,300 feet downstream of Discharge Point 001 |

3. INFLUENT MONITORING

The Discharger shall monitor treatment plant influent at Monitoring Location INF-001 as follows:

Table E-2. Influent Monitoring

| Parameter | Unit | Sample Type | Minimum Sampling Frequency |
|--|--------|-------------|----------------------------|
| Flow ^[1] | MG/MGD | Continuous | Continuous/D |
| Biochemical Oxygen Demand (5-day @ 20°C) (BOD) | mg/L | C-24 | 1/Week |
| Total Suspended Solids (TSS) | mg/L | C-24 | 1/Week |

Footnote:

^[1] Flow shall be monitored continuously and the following information shall be reported in monthly self-monitoring reports:

- Daily average flow rate (MGD)
- Total monthly flow volume (MG)

4. EFFLUENT MONITORING

4.1. The Discharger shall monitor treatment plant effluent at Monitoring Location EFF-001 as follows:

Table E-3. Effluent Monitoring

| Parameter | Unit | Sample Type | Minimum Sampling Frequency |
|---|---------------------------------------|---------------------------|----------------------------|
| Flow ^[1] | MG/MGD | Continuous | Continuous/D |
| BOD ^[2] | mg/L | C-24 | 1/Week |
| TSS ^[2] | mg/L | C-24 | 1/Week |
| pH ^[3] | s.u. | Grab | 1/Day |
| Temperature ^[3] | °C | Grab | 1/Day |
| Turbidity | NTU | C-24 | 1/Day |
| <i>E. Coli</i> Bacteria ^[4] | CFU/100 mL ^[5] | Grab | 2/Week |
| Acute Toxicity ^[6] | % survival | Flow-through | 1/Year |
| Chronic Toxicity (Prior to U.S. EPA Approval of Toxicity Provisions) ^[7] | TUc ^[8] | C-24 | 2/Year |
| Chronic Toxicity (After U.S. EPA Approval of Toxicity Provisions) ^[9] | Pass/Fail % effect ^[10] | C-24 | 1/Quarter |
| Ammonia, Total ^[3] | mg/L as N | C-24 | 1/Week |
| Chlorine, Total Residual ^{[11],[12]} | mg/L | Grab ^{[13],[14]} | 1/Day ^{[13],[14]} |
| Standard Observations ^[15] | --- | --- | 1/Month |
| Priority Pollutants ^[16] | µg/L | Grab | 1/Year |

Footnotes:

- ^[1] The following flow information shall be reported in monthly self-monitoring reports:
- Daily average flow rate (MGD)
 - Total monthly flow volume (MG)
- ^[2] BOD and TSS effluent samples shall be collected concurrently with BOD and TSS influent samples. BOD and TSS percent removal shall be reported for each calendar month in accordance with section 4.2 of this Order.
- ^[3] Ammonia monitoring shall be performed concurrently with pH and temperature monitoring.
- ^[4] U.S. EPA Method 1603 or an equivalent method is suggested to measure culturable *E. coli*.
- ^[5] Results may be reported as either Most Probable Number (MPN)/100 mL if the laboratory method used provides results in MPN/100 mL or Colony Forming Units (CFU)/100 mL if the laboratory method used provides results in CFU/100 mL.
- ^[6] Acute bioassay tests shall be performed in accordance with MRP section 5.1. As of the first day of the month following U.S. EPA approval of the State Water Board's *State Policy for Water Quality Control: Toxicity Provisions* (Toxicity Provisions), acute toxicity monitoring at Monitoring Location EFF-001 shall no longer be required.
- ^[7] Chronic toxicity tests shall be performed in accordance with MRP section 5.2 until the first day of the month following U.S. EPA approval of the Toxicity Provisions, at which point MRP section 5.2 shall no longer apply and chronic toxicity tests shall be performed in accordance with MRP section 5.3.
- ^[8] Chronic toxicity monitoring results shall be reported in TUc until the first day of the month following U.S. EPA approval of the Toxicity Provisions, at which point this requirement shall no longer apply.
- ^[9] Chronic toxicity tests shall be performed in accordance with MRP section 5.3 as of the first day of the month following U.S. EPA approval of the Toxicity Provisions. The Executive Officer may reduce the minimum sampling frequency as described in Toxicity Provisions § III.C.4.b.i(B) if the Discharger has complied with chronic toxicity requirements for the prior five consecutive years.
- ^[10] Chronic toxicity monitoring results shall be reported as "pass" or "fail" and percent effect as of the first day of the month following U.S. EPA approval of the Toxicity Provisions.
- ^[11] Total residual chlorine monitoring shall be required only when the discharger uses a chlorine disinfection and dechlorination system pursuant to Provision 6.3.4.4 of this Order.
- ^[12] The Discharger may elect to use continuous on-line monitoring systems for measuring or determining that a residual dechlorinating agent (e.g., sodium bisulfite) is present. Such monitoring systems may be used to prove that anomalous residual chlorine exceedances measured by online chlorine analyzers are false positives and are not valid total residual chlorine detections because it is chemically improbable to have chlorine present in the presence of a dechlorinating agent. If the data from continuous total residual chlorine analyzers provide convincing evidence that chlorine residual exceedances are false positives, the exceedances shall not be violations of this Order's total residual chlorine effluent limits.
- ^[13] If the Discharger uses chlorine as a disinfectant, the Discharger shall collect total residual chlorine grab samples at the top of each hour during its standard hours of operation, 5:30am to 5:30pm daily.
- ^[14] The Discharger shall describe all excursions of the chlorine limit in the transmittal letter of self-monitoring reports as required by Attachment G section 5.3.1.1. The Discharger shall report through data upload to CIWQS, from grab samples at the top of each hour during its standard hours of operation, 5:30am to 5:30pm daily, the maximum for each day and any other discrete hourly

reading that exceed the effluent limits, and, for the purpose of mandatory minimum penalties required by Water Code section 13385(i), compliance shall be based only on these discrete readings. The Discharger shall retain monitoring readings for at least three years. The Regional Water Board reserves the right to use all monitoring data for discretionary enforcement.

^[15] Standard observations are specified in Attachment G section 3.2.

^[16] The Discharger shall monitor for the pollutants listed in Attachment G, Table B.

5. TOXICITY MONITORING

5.1. Acute Toxicity

- 5.1.1. When required, compliance with the acute toxicity effluent limitations shall be evaluated at Monitoring Location EFF-001 by measuring survival of test organisms exposed to 96-hour continuous flow-through bioassays.
- 5.1.2. Test organisms shall be rainbow trout (*Oncorhynchus mykiss*). Alternatively, the Executive Officer may specify a more sensitive organism or, if testing a particular organism proves unworkable, the most sensitive organism available.
- 5.1.3. All bioassays shall be performed according to the most up-to-date protocols in 40 C.F.R. part 136, currently *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms*, 5th Edition (EPA-821-R-02-012). If these protocols prove unworkable, the Executive Officer and the Environmental Laboratory Accreditation Program may grant exceptions in writing upon the Discharger's request with justification.
- 5.1.4. If the Discharger demonstrates that specific identifiable substances in the discharge are rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after test samples are adjusted to remove the influence of those substances. Written acknowledgement that the Executive Officer concurs with the Discharger's demonstration and that the adjustment will not remove the influence of other substances must be obtained prior to any such adjustment. The Discharger is authorized to adjust the effluent pH in order to suppress the level of un-ionized (free) ammonia. This adjustment shall be achieved by continuously monitoring test tank pH and automatic addition of analytical grade acid as needed, using a combination of continuous pH-sensor/analyzer and pump.
- 5.1.5. Effluent used for fish bioassays must be dechlorinated prior to testing. If biological growth in the dechlorinated effluent sample line is a potential problem, chlorinated effluent that is dechlorinated separately from the plant dechlorination process may be used for the bioassay test. The sample may be taken from final secondary effluent prior to disinfection. Bioassay monitoring shall include, on a daily basis, pH, dissolved oxygen, ammonia (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be reported. If final or intermediate results of an acute bioassay test indicate a violation or threatened violation (e.g., the percentage of surviving test organisms is less than 70 percent), the Discharger shall initiate a new test as soon as practical and shall investigate the cause of the mortalities and report its findings in the next self-monitoring report. The Discharger shall repeat the test

until a test fish survival rate of 90 percent or greater is observed. If the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new fish and shall continue as soon as practical until an acceptable test is completed (i.e., control fish survival rate is 90 percent or greater).

5.2. Chronic Toxicity (Before U.S. EPA Approval of Toxicity Provisions)

5.2.1. Monitoring Requirements

- 5.2.1.1. **Sampling.** The Discharger shall collect 24-hour composite effluent samples at Monitoring Location EFF-001 for critical life stage toxicity testing as indicated below. Effluent samples may be before disinfection for toxicity tests. For toxicity tests requiring renewals, the Discharger shall collect 24-hour composite samples on consecutive or alternating days.
- 5.2.1.2. **Test Species.** The test species shall be the water flea (*Ceriodaphnia dubia*). The Discharger shall conduct a screening chronic toxicity test as described in Appendix E-1, following any significant change in the nature of the effluent. If there is no significant change in the nature of the effluent, the Discharger shall conduct a screening test if required by an applicable State Water Board plan and submit the results with its application for permit reissuance. Upon completion of the chronic toxicity screening, the Discharger shall use the most sensitive species to conduct subsequent monitoring.
- 5.2.1.3. **Frequency.** Chronic toxicity monitoring shall be as specified in Table E-3 above.
 - 5.2.1.3.1. The Discharger shall accelerate monitoring to monthly after exceeding a single-sample maximum of 1 TUc. Based on the TUc results, the Executive Officer may specify a different accelerated monitoring frequency to ensure that accelerated monitoring provides useful information.
 - 5.2.1.3.2. The Discharger shall return to routine monitoring if accelerated monitoring does not exceed the trigger in section 5.2.1.3.1, above.
 - 5.2.1.3.3. If accelerated monitoring confirms consistent toxicity greater than the trigger in section 5.2.1.3.1, above, the Discharger shall continue accelerated monitoring and initiate toxicity reduction evaluation (TRE) procedures in accordance with section 5.2.3, below.
 - 5.2.1.3.4. The Discharger shall return to routine monitoring after implementing appropriate elements of the TRE, and either the toxicity drops below the trigger in 5.2.1.3.1, above, or, based on the TRE results, the Executive Officer determines that accelerated monitoring would no longer provide useful information.
 - 5.2.1.3.5. Monitoring conducted pursuant to a TRE shall satisfy the requirements for routine and accelerated monitoring while the TRE is underway.

- 5.2.1.4. **Methodology.** Sample collection, handling, and preservation shall be in accordance with U.S. EPA protocols. Bioassays shall be conducted in compliance with the most recently promulgated test methods, as shown in Appendix E-2. These are *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms*, currently 1st edition (EPA/600/R-95-136), *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, currently third edition (EPA-821-R-02-014) and *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, currently fourth edition (EPA-821-R2-02-013). If these protocols prove unworkable, the Executive Officer and the Environmental Laboratory Accreditation Program may grant exceptions in writing upon the Discharger's request with justification.

If the Discharger demonstrates that specific identifiable substances in the discharge are rapidly rendered harmless upon discharge to the receiving water, compliance with the chronic toxicity limit may be determined after test samples are adjusted to remove the influence of those substances. The adjustment shall not remove the influence of other substances. Written acknowledgement that the Executive Officer concurs with the Discharger's demonstration must be obtained prior to any such adjustment.

- 5.2.1.5. **Dilution Series.** The Discharger shall conduct tests at 100%, 75%, 55.6%, 25%, 12.5%, 0%. The "%" represents percent effluent as discharged. Test sample pH may be controlled to the level of the effluent sample as received prior to being salted up.

- 5.2.2. **Reporting Requirements.** The Discharger shall provide toxicity test results with self-monitoring reports and shall include the following, at a minimum, for each test:

- 5.2.2.1. Sample date;
- 5.2.2.2. Test initiation date;
- 5.2.2.3. Test species;
- 5.2.2.4. End point values for each dilution (e.g., number of young, growth rate, percent survival);
- 5.2.2.5. No Observable Effect Level (NOEL) values in percent effluent. The NOEL shall equal the IC25 or EC25 (see Attachment A). If the IC25 or EC25 cannot be statistically determined, the NOEL shall equal the No Observable Effect Concentration (NOEC) derived using hypothesis testing. The NOEC is the maximum percent effluent concentration that causes no observable effect on test organisms based on a critical life stage toxicity test;

- 5.2.2.6. IC15, IC25, IC40, and IC50 values (or EC15, EC25, EC40, and EC50) as percent effluent;
- 5.2.2.7. TUc values (100/NOEL and upper and lower confidence intervals, where NOEL = IC25, EC25, or NOEC);
- 5.2.2.8. Mean percent mortality (\pm standard deviation) after 96 hours in 100% effluent (if applicable);
- 5.2.2.9. IC50 or EC50 values for reference toxicant tests; and
- 5.2.2.10. Available water quality measurements for each test (e.g., pH, dissolved oxygen, temperature, conductivity, hardness, salinity, ammonia.)

5.2.3. Toxicity Reduction Evaluation (TRE)

- 5.2.3.1. The Discharger shall prepare a generic TRE work plan within 90 days of the effective date of this Order to be ready to respond to toxicity events. The Discharger shall review and update the work plan as necessary so that it remains current and applicable to the discharge and discharge facilities.
- 5.2.3.2. Within 30 days of exceeding the chronic toxicity trigger in section 5.2.1.3.1, above, the Discharger shall submit a TRE work plan, which shall be the generic work plan revised as appropriate for this toxicity event after consideration of available discharge data.
- 5.2.3.3. Within 30 days of completing an accelerated monitoring test observed to exceed the trigger in section 5.2.1.3.1, above, the Discharger shall initiate a TRE in accordance with a TRE work plan that incorporates any and all Executive Officer comments.
- 5.2.3.4. The TRE shall be specific to the discharge and be in accordance with current technical guidance and reference materials, including U.S. EPA guidance materials. The Discharger shall conduct the TRE as a tiered evaluation as summarized below:
 - 5.2.3.4.1. Tier 1 shall consist of basic data collection (routine and accelerated monitoring).
 - 5.2.3.4.2. Tier 2 shall consist of evaluation of treatment process, including operational practices and in-plant process chemicals.
 - 5.2.3.4.3. Tier 3 shall consist of a toxicity identification evaluation (TIE).
 - 5.2.3.4.4. Tier 4 shall consist of a toxicity source evaluation.
 - 5.2.3.4.5. Tier 5 shall consist of a toxicity control evaluation, including options for modifications of in-plant treatment processes.

- 5.2.3.4.6. Tier 6 shall consist of implementation of selected toxicity control measures, and follow-up monitoring and confirmation of implementation success.
- 5.2.3.5. The Discharger may end the TRE at any stage if monitoring finds there is no longer consistent toxicity (i.e., compliance with the trigger in section 5.2.1.3.1, above).
- 5.2.3.6. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity. The Discharger shall employ all reasonable efforts using currently available TIE methodologies.
- 5.2.3.7. As toxic substances are identified or characterized, the Discharger shall continue the TRE by determining the sources and evaluating alternative strategies for reducing or eliminating the toxic substances from the discharge. The Discharger shall take all reasonable steps to reduce toxicity to levels below the chronic toxicity trigger.
- 5.2.3.8. Many recommended TRE elements parallel required or recommended efforts related to source control, pollution prevention, and stormwater control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements or recommended efforts of such programs may be acceptable to demonstrate compliance with TRE requirements.

5.3. Chronic Toxicity (After U.S. EPA Approval of Toxicity Provisions)

5.3.1. Compliance Monitoring

- 5.3.1.1. **Sampling.** The Discharger shall collect 24-hour composite effluent samples at Monitoring Location EFF-001 for critical life stage toxicity testing as indicated below. Effluent samples may be collected before disinfection for toxicity tests. For toxicity tests requiring renewals, the Discharger shall collect 24-hour composite samples on consecutive or alternating days.
- 5.3.1.2. **Test Species.** The test species shall be the water flea (*Ceriodaphnia dubia*) unless a more sensitive species is identified in accordance with MRP, Appendix E-1. The Discharger shall conduct chronic toxicity species sensitivity screening as required in Appendix E-1. Upon completion of the chronic toxicity screening, the Executive Officer may specify the most sensitive species or, if testing a particular species proves unworkable (e.g., the discharger encounters unresolvable test interference or cannot secure a reliable supply of test organisms), the most sensitive species available of

those listed in MRP Tables AE-1 and AE-2. The Executive Officer will specify changes in test species in writing.

5.3.1.3. **Frequency.** The Discharger shall monitor chronic toxicity as specified below:

5.3.1.3.1. **Routine Monitoring.** The Discharger shall conduct routine monitoring once per quarter at the Instream Waste Concentration (IWC) set forth in section 4.5 of the Order, and continue routine monitoring during any Toxicity Reduction Evaluation (TRE) consistent with MRP section 5.3.3.7.

5.3.1.3.2. **Additional Routine Monitoring Tests for Compliance and TRE Determination.** If the Discharger violates the maximum daily effluent limit (MDEL) or median monthly effluent limit (MMEL) during a calendar month and is not already conducting a TRE, the Discharger shall conduct an additional routine monitoring test during the following calendar month. This additional routine monitoring test shall be used to determine if a TRE is necessary according to the process shown in Appendix E-3. If there is not enough effluent available to test in the following calendar month, the Discharger shall return to quarterly routine monitoring as soon as enough effluent is available. The Executive Officer may also require the Discharger to conduct a TRE.

5.3.1.3.3 **MMEL Compliance Tests and TRE Determination.** If any routine monitoring test result is “fail,” the Discharger shall conduct at least one and at most two MMEL compliance tests. The results of these tests shall be used to determine if a TRE is necessary according to the process shown in Appendix E-3. The Discharger shall initiate these tests within the same calendar month as the failed routine monitoring test. (For the purposes of MMEL compliance tests, the “calendar month” shall begin on the calendar day that the failed routine monitoring test was initiated. The “calendar month” shall end on the day before the corresponding day of the following month, or on the last day of the following month if it has no corresponding day [e.g., January 31 through February 28]).

5.3.1.3.3.1. If the first MMEL compliance test result is “pass,” then the Discharger shall conduct a second MMEL compliance test. If the first MMEL compliance test result is “fail,” that result constitutes an MMEL violation and a second MMEL compliance test is not required. If any of the failed tests were also an MDEL violation, the discharger shall conduct a TRE (see MRP § 5.3.3).

5.3.1.3.3.2. If the second MMEL compliance test result is “pass,” then the Discharger shall return to routine monitoring as described in MRP section 5.3.1.3.1.¹ If the second MMEL compliance Test result is “fail,” that result constitutes an MMEL violation. If any of the failed tests were

¹ See Appendix E-5, Toxicity Reduction Evaluation Process Flowchart.

also an MDEL violation, the discharger shall conduct a TRE (see MRP § 5.3.3).

- 5.3.1.3.3.3. If the Discharger cannot conduct an MMEL compliance test because not enough effluent is available to test, the Discharger shall return to routine monitoring as soon as enough effluent is available.

- 5.3.1.4. **Methodology.** Sample collection, handling, and preservation shall be in accordance with U.S. EPA protocols. Bioassays shall be conducted in compliance with the most recently promulgated test methods, as shown in Appendix E-2. These are *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms*, currently 1st edition (EPA/600/R-95/136); *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, currently 3rd edition (EPA-821-R-02-014); and *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, currently 4th edition (EPA-821-R-02-013). If these protocols prove unworkable, the Executive Officer and the Environmental Laboratory Accreditation Program may grant exceptions in writing upon the Discharger's request with justification.

Chronic toxicity shall be evaluated using the Test of Significant Toxicity (TST) as described in the State Water Board's *State Policy for Water Quality Control: Toxicity Provisions* (Toxicity Provisions), section III.B.3. The selected test concentrations shall include the IWC. The TST shall be conducted using the IWC sample and a control as described in Toxicity Provisions section III.B.3. Test sample pH may be controlled to the level of the effluent sample as received by the laboratory prior to being salted up. A result of "fail" indicates toxicity at the IWC.

If the Discharger demonstrates that specific identifiable substances in the discharge are rapidly rendered harmless upon discharge to the receiving water, compliance with the chronic toxicity limit may be determined after test samples are adjusted to remove the influence of those substances. The adjustment shall not remove the influence of other substances. Written acknowledgement that the Executive Officer concurs with the Discharger's demonstration must be obtained prior to any such adjustment.

- 5.3.2. Reporting.** The Discharger shall provide toxicity test results with self-monitoring reports and shall include the following, at a minimum, for each test:

- 5.3.2.1. Sample date
- 5.3.2.2. Test initiation date
- 5.3.2.3. Test species

- 5.3.2.4. End point values for the control and IWC sample (e.g., number of young, growth rate, percent survival). For routine monitoring and MMEL compliance tests, the Discharger shall report the results as either “pass” or “fail,” and the percent effect at the IWC for each endpoint.
- 5.3.2.5. End point values for each replicate of the control and IWC sample (e.g., number of young, growth rate, percent survival).
- 5.3.2.6. Available water quality measurements for each test (e.g., pH, dissolved oxygen, temperature, conductivity, hardness, salinity, ammonia).

5.3.3. Toxicity Reduction Evaluation (TRE)

- 5.3.3.1. The Discharger shall prepare a generic TRE work plan within 90 days of the effective date of this Order to be ready to respond to toxicity events. The Discharger shall review and update the generic work plan as necessary so it remains current and applicable to the discharge and discharge facilities.
- 5.3.3.2. Within 30 days of the following circumstances, the Discharger shall submit a TRE work plan that shall be the generic work plan revised as appropriate for the particular toxicity observed. The circumstances triggering a TRE are as follows:
 - 5.3.3.2.1. The Discharger has any combination of two or more MDEL or MMEL violations within a single calendar month or two successive calendar months; or
 - 5.3.3.2.2. The Discharger violates the MDEL or MMEL during a calendar month, there is no effluent available to test in the following calendar month, and the Executive Officer requires a TRE.
- 5.3.3.3. Within 30 days of submitting the TRE work plan, the Discharger shall initiate a TRE in accordance with the TRE work plan. The TRE shall be specific to the discharge and be in accordance with current technical guidance and reference materials, including U.S. EPA guidance materials. The Discharger shall conduct the TRE as a tiered evaluation as summarized below:
 - 5.3.3.3.1. Tier 1 shall consist of basic data collection (routine monitoring, additional routine monitoring, and MMEL compliance tests);
 - 5.3.3.3.2. Tier 2 shall consist of evaluating treatment processes, including operational practices and process chemicals;
 - 5.3.3.3.3. Tier 3 shall consist of a toxicity identification evaluation (TIE) to identify the substance or combination of substances causing the observed toxicity. The Discharger shall employ all reasonable efforts using currently available TIE methodologies;

- 5.3.3.3.4. Tier 4 shall consist of a toxicity source evaluation;
- 5.3.3.3.5. Tier 5 shall consist of a toxicity control evaluation that considers alternative strategies, including treatment process modifications, to reduce or eliminate the toxic substances from the discharge; and
- 5.3.3.3.6. Tier 6 shall consist of implementing all reasonable toxicity control measures, and follow-up monitoring and confirmation of implementation success.
- 5.3.3.4. The Discharger may end the TRE at any stage if monitoring finds there is no longer consistent toxicity (i.e., two consecutive test results of “pass”).
- 5.3.3.5. The Executive Officer may authorize the Discharger to end a TRE if the Discharger documents that it has exhausted all reasonable efforts to identify the cause of the toxicity.
- 5.3.3.6. Many recommended TRE elements parallel required or recommended efforts related to source control, pollution prevention, and stormwater control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements or recommended efforts of such programs may be acceptable to demonstrate compliance with TRE requirements.
- 5.3.3.7. The routine monitoring frequency shall be a minimum of two tests per calendar year at the IWC when the Discharger is conducting toxicity testing as part of a TRE during that calendar year. The Discharger must return to the routine monitoring frequency specified in MRP section 5.3.1.3.1 at the conclusion of the TRE or one year after the initiation of the TRE, whichever occurs sooner.

TRE triggers are set forth below.

Table E-4. Toxicity Reduction Evaluation (TRE) Triggers

| Monitoring Type and Frequency | Triggers | TRE Required? |
|---|---|--------------------|
| Routine and MMEL compliance monitoring, less than monthly frequency | 1. Violation of MDEL or MMEL in a calendar month, AND 2. No discharge during the following calendar month | EO may require TRE |
| Routine and MMEL compliance monitoring | Any combination of two or more MDEL or MMEL violations in a single calendar month or successive calendar months | TRE is required |

| Monitoring Type and Frequency | Triggers | TRE Required? |
|-------------------------------|---|-----------------|
| Other monitoring | Any combination of two or more MDEL or MMET exceedances for <i>C. dubia</i> in a single calendar month or successive calendar months. | TRE is required |

6. RECEIVING WATER MONITORING

The Discharger shall monitor ambient receiving water conditions in Calera Creek at Monitoring Locations RSW-001, RSW-002, RSW-003, and RSW-004 as follows:

Table E-5. Receiving Water Monitoring

| Parameter | Unit | Sample Type | Minimum Sampling Frequency |
|--------------------------------------|---------------------------|--------------|----------------------------|
| pH ^[1] | s.u. | Grab | 1/Quarter |
| Temperature ^[1] | °C | Grab | 1/Quarter |
| Dissolved Oxygen | mg/L | Grab | 1/Quarter |
| Dissolved Oxygen | % Saturation | Grab | 1/Quarter |
| Dissolved Sulfide ^[2] | mg/L | Grab | 1/Quarter |
| Ammonia, Total ^[1] | mg/L as N | Grab | 1/Quarter |
| Hardness | mg/L as CaCO ₃ | Grab | 1/Quarter |
| Salinity | ppt | Grab | 1/Quarter |
| Standard Observations ^[3] | --- | Observations | 1/Quarter |
| Priority Pollutants ^[4] | µg/L | Grab | Once |

Footnotes:

- ^[1] Ammonia, temperature, and pH monitoring shall occur concurrently to allow for calculation of the un-ionized ammonia fraction.
- ^[2] Dissolved sulfide monitoring is only required if the dissolved oxygen concentration is less than 2.0 mg/L.
- ^[3] Standard Observations are specified in Attachment G section 3.2.1.
- ^[4] The Discharger shall monitor for the pollutants listed in Attachment G, Table B.

7. RECYLED WATER POLICY ANNUAL REPORTS

In accordance with Section 3 of the Water Quality Control Policy for Recycled Water (Recycled Water Policy), the Discharger shall electronically submit an annual report of monthly data to the State Water Board by 30 April annually covering the previous calendar year using the State Water Board's [GeoTracker website](https://geotracker.waterboards.ca.gov/) (<https://geotracker.waterboards.ca.gov/>). Information for setting up and using the GeoTracker system can be found in the ESI Guide for Responsible Parties document on the State Water Board's website for [Electronic Submittal of Information](https://waterboards.ca.gov/ust/electronic_submittal/index.html) (https://waterboards.ca.gov/ust/electronic_submittal/index.html).

The annual report to GeoTracker must include the volumetric reporting of the items listed in [Section 3.2 of the Recycled Water Policy](https://www.waterboards.ca.gov/board_decisions/adopted_orders/resolutions/2018/121118_7_final_amendment_oal.pdf) (https://www.waterboards.ca.gov/board_decisions/adopted_orders/resolutions/2018/121118_7_final_amendment_oal.pdf).

8. REPORTING REQUIREMENTS

8.1. General Monitoring and Reporting Requirements. The Discharger shall comply with all Standard Provisions (Attachments D and G) related to monitoring, reporting, and recordkeeping.

8.2. Self-Monitoring Reports (SMRs)

8.2.1. SMR Format. The Discharger shall electronically submit SMRs using the State Water Board's [California Integrated Water Quality System \(CIWQS\) Program website](https://waterboards.ca.gov/water_issues/programs/ciwqs/) (waterboards.ca.gov/water_issues/programs/ciwqs). The CIWQS website will provide additional information for SMR submittal in the event of a planned service interruption for electronic submittal.

8.2.2. SMR Due Dates and Contents. The Discharger shall submit SMRs by the due dates, and with the contents, specified below:

8.2.2.1. Monthly SMRs — Monthly SMRs shall be due 30 days after the end of each calendar month, covering that calendar month. Each SMR shall contain the applicable items described in Provision 6.3.2 (Effluent Characterization Study and Report) of the Order, Attachment D section 5.2, and Attachment G section 5.3. Each SMR shall include all new monitoring results obtained since the last SMR was submitted. If the Discharger monitors any pollutant more frequently than required by this Order, the Discharger shall include the results of such monitoring in the calculations and reporting for the SMR.

8.2.2.2. Annual SMR — Annual SMRs shall be due February 1 each year, covering the previous calendar year. The annual SMR shall contain the applicable items described in Provisions 6.3.2 (Effluent Characterization Study and Report) and 6.3.4.3 (Anaerobically-Digestible Material) of the Order, and Attachment G section 5.3.1.6.

8.2.3. Specifications for Submitting SMRs to CIWQS. The Discharger shall submit analytical results and other information using one of the following methods:

Table E-6. CIWQS Reporting

| Parameter | Method of Reporting: EDF/CDF data upload | Record Keeping |
|--|--|--|
| All parameters identified in influent, effluent, and receiving water monitoring tables (except Dissolved Oxygen and Temperature) | Required for all results | - |
| Dissolved Oxygen, Temperature | Required for monthly maximum and minimum results only ^[1] | Discharger may use this method for all results or keep records |
| Antimony, Arsenic, Beryllium, Cadmium, Chromium, Copper, Cyanide, Lead, Mercury, Nickel, Selenium, Silver, Thallium, Zinc, Dioxins & Furans (by U.S. EPA Method 1613), | Required for all results ^[2] | - |

| Parameter | Method of Reporting: EDF/CDF data upload | Record Keeping |
|--|--|----------------|
| Other Pollutants (by U.S. EPA Methods 601, 602, 608, 610, 614, 624, and 625) | | |
| Volume and Duration of Blended Discharge ^[3] | Required for all blended effluent discharges | - |
| Analytical Method | Not required (Discharger may select "data unavailable") ^[1] | - |
| Collection Time, Analysis Time | Not required | - |

Footnotes:

- ^[1] The Discharger shall continue to monitor at the minimum frequency specified in this MRP, keep records of the measurements, and make the records available upon request.
- ^[2] These parameters require EDF/CDF data upload or manual entry regardless of whether monitoring is required by this MRP or other provisions of this Order (except for biosolids, sludge, or ash provisions).
- ^[3] The requirement for volume and duration of blended discharge applies only if this Order authorizes the Discharger to discharge blended effluent.

The Discharger shall arrange all reported data in a tabular format and summarize data to clearly illustrate whether the Facility is operating in compliance with effluent limitations. The Discharger is not required to duplicate the submittal of data entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format, the Discharger shall electronically submit the data in a tabular format as an attachment.

8.2.4. Monitoring Periods. Monitoring periods for all required monitoring shall be as set forth below unless otherwise specified:

Table E-7. Monitoring Periods

| Sampling Frequency | Monitoring Period Begins On... | Monitoring Period |
|--------------------------------------|--|--|
| Continuous/D | Order effective date | All times |
| 1/Hour | Order effective date | Every hour on the hour |
| 1/Day | Order effective date | Any 24-hour period that reasonably represents a calendar day for sampling purposes (e.g., beginning at midnight and continuing through 11:59 p.m.) |
| 1/Week 2/Week 4/Week 5/Week | First Sunday following or on Order effective date | Sunday through Saturday |
| 1/Month | First day of calendar month following or on Order effective date | First day of calendar month through last day of calendar month ^[2] |
| 1/Quarter | Closest January 1, April 1, July 1, or October 1 before or after Order effective date ^[1] | January 1 through March 31 July 1 through September 30 April 1 through June 30 October 1 through December 31 |
| 1/Year | Closest January 1 before or after Order effective date ^[1] | January 1 through December 31 |

| Sampling Frequency | Monitoring Period Begins On... | Monitoring Period |
|--------------------|---|--|
| 2/Year | Closest January 1 or July 1 before or after Order effective date ^[1] | January through June 30 July 1 through December 31 |
| Once | Order effective date | Once during the term of the Order within 12 months prior to applying for permit reissuance |

Footnotes:

^[1] Monitoring performed during the previous order term may be used to satisfy monitoring required by this Order.

^[2] See Attachment A for the definition of a calendar month for chronic toxicity testing.

8.2.5. RL and MDL Reporting. The Discharger shall report with each sample result the Reporting Level (RL) and Method Detection Limit (MDL) as determined by the procedure in 40 C.F.R. part 136. The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

8.2.5.1. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).

8.2.5.2. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For purposes of data collection, the Discharger shall require the laboratory to write the estimated chemical concentration next to DNQ. The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means the laboratory considers appropriate.

8.2.5.3. Sample results less than the laboratory's MDL shall be reported as "Not Detected", or ND.

8.2.5.4. The Discharger shall instruct laboratories to establish calibration standards so that the minimum level (ML) value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.

8.2.6. Compliance Determination. Compliance with effluent limitations shall be determined using sample reporting protocols defined above, in the Fact Sheet, and in Attachments A, D, and G. For purposes of reporting and administrative enforcement by the Regional Water Board and State Water Board, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the pollutant in the monitoring sample is greater than the effluent limitation and, if applicable, greater than or equal to the RL.

8.3. Discharge Monitoring Reports (DMRs). DMRs are U.S. EPA reporting requirements. The Discharger shall electronically certify and submit DMRs together with SMRs using Electronic Self-Monitoring Reports module eSMR 2.5 or the latest upgraded version. Electronic DMR submittal shall be in addition to electronic SMR submittal. Information about electronic DMR submittal is available at the [DMR website](https://waterboards.ca.gov/water_issues/programs/discharge_monitoring) (waterboards.ca.gov/water_issues/programs/discharge_monitoring).

**APPENDIX E-1
CHRONIC TOXICITY
DEFINITION OF TERMS AND
SPECIES SENSITIVITY SCREENING REQUIREMENTS**

1. Definition of Terms

- 1.1. Continuous Discharger.** Discharger that discharges without interruption throughout its operating hours, except for infrequent shutdowns for maintenance, process changes, or other similar activities, and that discharges throughout the calendar year.
- 1.2. Non-Continuous Discharger.** Discharger that does not discharge in a continuous manner or does not discharge throughout the calendar year (e.g., intermittent and seasonal dischargers).

2. Chronic Toxicity Species Sensitivity Screening

- 2.1.** The Discharger shall perform species sensitivity screening as specified in Toxicity Provisions section III.C.2:
- 2.1.1. The Discharger shall conduct species sensitivity screening and submit a technical report that identifies the most sensitive test species within 18 months of the effective date of this Order if the Discharger has not previously conducted a species sensitivity screening as specified in Toxicity Provisions section III.C.2.
- 2.1.2. The Discharger shall conduct species sensitivity screening and submit a technical report that identifies the most sensitive test species with the application for permit reissuance. Alternatively, the Discharger may provide species sensitivity screening results from a previous sensitive species screening conducted within the 10 years before the expiration date of this Order if that sensitive species screening was conducted as specified in Toxicity Provisions section III.C.2.
- 2.1.3. The Discharger shall conduct species sensitivity screening and submit a technical report that identifies the most sensitive test species no later than 18 months after any significant change in the nature of the effluent discharged due to changes in sources or treatment, except those changes resulting from reductions in pollutant concentrations attributable to source control efforts.
- 2.2.** Species sensitivity screening shall, at a minimum, reflect the following elements:
- 2.2.1. Test species specified in Appendix E-2, attached, and protocols referenced in those tables. Test species shall be Tier I unless those species are unavailable. In such cases, the Executive Officer may approve a Tier II test species.
- 2.2.2. Continuous Dischargers: four sets of tests, one in each calendar quarter of a calendar year.

Non-continuous Dischargers: at least two sets of tests, one in each calendar quarter with at least 15 days of discharge, unless the Discharger discharges in only one quarter of a calendar year; in that case, both sets of testing shall occur during the same calendar quarter. Testing in a specific species sensitivity screening can be conducted using effluent that is not discharged into surface waters (e.g., effluent discharged onto land because of a summer prohibition on discharges into surface waters) as long as the effluent tested is representative of the effluent that will be discharged to surface waters.

- 2.2.3. Appropriate controls.
- 2.2.4. Tests conducted at a waste concentration of 10 percent or the IWC, whichever represents a higher concentration of effluent. Alternatively, the Executive Officer may specify a higher waste concentration if needed to increase the likelihood that potential effects might be observed.
- 2.3. The Discharger shall submit a species sensitivity screening proposal at least 30 days prior to initiating any species sensitivity screening. The proposal shall address each of the elements listed above.
- 2.4. Unless the Executive Officer specifies otherwise, the most sensitive species shall be the species exhibiting the highest percent effect.

APPENDIX E-2: SUMMARY OF TOXICITY TEST SPECIES REQUIREMENTS

Table AE-1. West Coast Marine Chronic Toxicity Test Species and Methods

| Species | (Scientific Name) | Tier | Effect | Test Duration | Reference |
|------------------------------|---|------|---|--------------------|-----------|
| Giant kelp | (<i>Macrocystis pyrifera</i>) | I | Percent germination; germ tube length | 48 hours | 1 |
| Red Abalone | (<i>Haliotis rufescens</i>) | I | Larval development | 48 hours | 1 |
| Oyster Mussel | (<i>Crassostrea gigas</i>) (<i>Mytilus sp.</i>) | I | Larval development | 48 hours | 1 |
| Purple Urchin Sand dollar | (<i>Strongylocentrotus purpuratus</i>) (<i>Dendraster excentricus</i>) | I | Percent fertilization or larval development | 1 hour or 72 hours | 1 |
| Shrimp | (<i>Americamysis bahia</i>) | II | Percent survival; growth | 7 days | 2 |
| Topsmelt | (<i>Atherinops affinis</i>) | I | Percent survival; growth | 7 days | 2 |
| Silverside | (<i>Menidia beryllina</i>) | II | Larval growth rate; percent survival | 7 days | 2 |

Toxicity Test References:

1. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms. EPA/600/R-95/136. August 1995.
2. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to Marine and Estuarine Organisms. EPA/821/R-02/014. October 2002.

Table AE-2. Freshwater Chronic Toxicity Test Species and Method

| Species | Scientific Name | Tier | Effect | Test Duration | Reference |
|----------------|----------------------------------|------|---------------------------|---------------|-----------|
| Fathead minnow | <i>Pimephales promelas</i> | I | Survival; growth rate | 7 days | 1 |
| Water flea | <i>Ceriodaphnia dubia</i> | I | Survival; number of young | 7 days | 1 |
| Green Alga | <i>Selenastrum capricornutum</i> | I | Final cell density | 4 days | 1 |

Toxicity Test Reference:

1. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, fourth Edition Chronic manual (EPA-821-R-02-013, October 2002).


Table AE-3. Toxicity Test Requirements for Species Sensitivity Screening

| Requirements | Discharges to Marine or Estuarine Water (San Francisco Bay) ^[1] | Discharges to Freshwater ^[1] |
|-----------------------|---|--|
| Taxonomic diversity | 1 plant 1 invertebrate 1 fish | 1 plant 1 invertebrate 1 fish |
| Screening Requirement | A total of 3 Marine and/or Freshwater species from Table AE-1 and Table AE-2 | 3 Freshwater species from Table AE-2 ^[2] |

Footnotes:

- ^[1] (a) "Marine" refers to receiving water salinities greater than 1.0 parts per thousand (ppt) at least 95 percent of the time during a normal water year.
- (b) "Freshwater" refers to receiving water with salinities less than 1.0 ppt at least 95 percent of the time during a normal water year.
- (c) "Estuarine" refers to all other cases (i.e., when receiving water salinity is above 1.0 less than 95 percent of the time and below 1.0 less than 95% of the time).
- ^[2] The freshwater species may be substituted with a marine species if:
- (a) The salinity of the effluent is above 1 ppt greater than 95 percent of the time, or
- (b) The ionic strength (TDS or conductivity) of the effluent at the IWC is documented to be toxic to the test species.

APPENDIX E-3: TOXICITY REDUCTION EVALUATION PROCESS FLOWCHART ROUTINE MONITORING



ATTACHMENT F - FACT SHEET

CONTENTS

| | | |
|----|---|------|
| 1. | PERMIT INFORMATION..... | F-2 |
| 2. | FACILITY DESCRIPTION..... | F-3 |
| 3. | APPLICABLE PLANS, POLICIES, AND REGULATIONS | F-8 |
| 4. | RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS | F-11 |
| 5. | RATIONALE FOR RECEIVING WATER LIMITATIONS..... | F-31 |
| 6. | RATIONALE FOR PROVISIONS | F-31 |
| 7. | RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS | F-34 |
| 8. | PUBLIC PARTICIPATION | F-36 |

TABLES

| | |
|---|------|
| TABLE F-1. FACILITY INFORMATION | F-2 |
| TABLE F-2. PREVIOUS EFFLUENT LIMITATIONS AND MONITORING DATA | F-5 |
| TABLE F-3. EFFLUENT LIMITATION VIOLATIONS..... | F-6 |
| TABLE F-4. COLLECTION SYSTEM AND CATEGORY 1 SSO RATES (SSOS/100 MILES)..... | F-7 |
| TABLE F-5. BENEFICIAL USES..... | F-9 |
| TABLE F-6. SECONDARY TREATMENT STANDARDS | F-13 |
| TABLE F-7. REASONABLE POTENTIAL ANALYSIS | F-19 |
| TABLE F-8 WQBEL CALCULATIONS..... | F-27 |
| TABLE F-9. MONITORING REQUIREMENTS SUMMARY | F-35 |

ATTACHMENT F – FACT SHEET

This Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order. As described in section 2.2 of the Order, the Regional Water Board incorporates this Fact Sheet as findings supporting the issuance of the Order.

1. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

| | |
|--|---|
| WDID | 2 417022002 |
| CIWQS Place ID | 212585 |
| Discharger | City of Pacifica |
| Facility Name | Calera Creek Water Recycling Plant and its collection system |
| Facility Address | 700 Coast Highway Pacifica, CA 94044 San Mateo County |
| Facility Contact, Title, and Phone | Maria Aguilar, Plant Manager, (415) 336-4750 |
| Authorized Person to Sign and Submit Reports | Maria Aguilar, Plant Manager, (415) 336-4750 |
| Mailing Address | 170 Santa Maria Avenue Pacifica, CA 94044 |
| Billing Address | Same as mailing address |
| Facility Type | Publicly Owned Treatment Works (POTW) |
| Major or Minor Facility | Major |
| Water Quality Threat | 1 |
| Complexity | A |
| Pretreatment Program | No |
| Recycling Requirements | State Water Board Order WQ 2016-0068-DDW |
| Facility Permitted Flow | 4.0 million gallons per day (MGD) – average dry weather flow |
| Facility Design Flow | 4.0 million gallons per day (MGD) – average dry weather treatment capacity 7.0 million gallons per day (MGD) – peak dry weather treatment capacity 20 million gallons per day (MGD) – peak wet weather treatment capacity |
| Watershed | San Mateo Coastal |
| Receiving Water | Calera Creek |
| Receiving Water Type | Freshwater |
| Date of Last Inspection | June 29, 2022 |

- 1.1.** The City of Pacifica (Discharger) owns and operates the Calera Creek Water Recycling Plant and its associated collection system (collectively, Facility). The Facility is a publicly-owned treatment works (POTW) that provides advanced

secondary treatment of wastewater collected from its service area and discharges to Calera Creek.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and State laws, regulations, plans, and policies are held to be equivalent to references to the Discharger herein.

- 1.2. The Discharger is regulated pursuant to National Pollutant Discharge Elimination System (NPDES) Permit CA0038776. The Discharger was previously subject to Order R2-2017-0013 (previous order) as amended by Order R2-2021-0019. The previous order expired on May 31, 2022. The terms and conditions of the previous order have been automatically continued and remain in effect until new Waste Discharge Requirements and NPDES permit are adopted pursuant to this Order. The Discharger filed a Report of Waste Discharge and submitted an application for reissuance of its Waste Discharge Requirements (WDRs) and NPDES permit on September 2, 2021.

Order R2-2021-0019 amended the previous order to remove the oil and grease limits and update the chlorine effluent limit subject to U.S. EPA approval of the Basin Plan amendment set forth in Regional Water Board Resolution R2-2020-0031. This Order reflects those changes.

- 1.3. The Discharger is authorized to discharge subject to the WDRs in this Order at the discharge location described in Table 1 of this Order. Regulations in 40 C.F.R. section 122.46 limit the duration of NPDES permits to a fixed term not to exceed five years. Accordingly, this Order limits the effective period for the discharge authorization. Pursuant to 40 C.F.R. section 122.6(d) and California Code of Regulations, title 23, section 2235.4, the terms and conditions of an expired permit are automatically continued pending reissuance of the permit if the Discharger complies with all requirements for continuation of expired permits.
- 1.4. When applicable, State law requires dischargers to file a petition with the State Water Resources Control Board (State Water Board), Division of Water Rights, and receive approval for any change in the point of discharge, place of use, or purpose of use of treated wastewater that decreases the flow in any portion of a watercourse. The State Water Board retains separate jurisdictional authority to enforce such requirements under Water Code section 1211. This is not an NPDES permit requirement.

2. FACILITY DESCRIPTION

2.1. Wastewater and Biosolids Treatment

- 2.1.1. **Service Area and Collection System.** The plant is located at 700 Coast Highway in Pacifica. It provides advanced secondary treatment of domestic and commercial wastewater from the City of Pacifica. The population within the service area is approximately 40,000 people. Attachment B shows the area

around the Facility. The Discharger owns and operates about 100 miles of sewer lines and five pump stations.

- 2.1.2. Wastewater Treatment.** The Facility provides advanced secondary treatment as described below and as shown in the Process Flow Diagram in Attachment C. The treatment process consists of screening, grit removal, sequencing batch reactors, sand filtration, and ultraviolet (UV) disinfection. The screening occurs at two of the Discharger's pump stations.

The Discharger either diverts its effluent to its cascade aerator, where the effluent discharges into Calera Creek and travels to the Discharger's constructed wetlands to the Pacific Ocean, or routes it to the North Coast County Water District, where it receives additional disinfection and distribution for recycled water use.

- 2.1.3. Wastewater Storage.** In 2019, the Discharger built a 2.1 million gallon equalization basin near its Linda Mar pump station. The Discharger completed this project in accordance with Cease and Desist Order (CDO) R2-2011-0031, as amended by CDO R2-2013-0005, to reduce sanitary sewer overflows (SSOs).
- 2.1.4. Sludge and Biosolids Management.** Sludge from the sequencing batch reactors is aerated and contained in waste activated sludge tanks before being diverted to the gravity belt thickeners. Next, thickened solids are digested in autothermal thermophilic aerobic digesters and dewatered with centrifuges. The Discharger hires a contractor to pick up the sludge for land application, composting, or landfill disposal.
- 2.1.5. Stormwater Management.** The Discharger directs all onsite stormwater to the plant headworks for treatment; therefore, coverage under the State Water Board's *General NPDES Permit for Stormwater Dischargers Associated with Industrial Activities* (NPDES General Permit CAS000001) is unnecessary.
- 2.1.6. Recycled Water.** The Discharger supplies tertiary treated effluent to the North Coast County Water District. The District provides additional disinfection and distributes the recycled water for golf course irrigation (east side of Sharp Park Golf Course), athletic field irrigation (Fairway Park), school facility irrigation (Oceana High School and Ingrid B. Lacy Middle School), roadway landscape irrigation (Palmetto streetscape and Highway 1 median) and operation of a residential filling station. The District uses about 50 percent of its allocated share of the Discharger's effluent. Opportunities to expand the recycled water distribution system, such as potentially partnering with the San Francisco Public Utilities Commission to irrigate the west side of Sharp Park Golf Course, are under evaluation.
- 2.1.7. Planned Upgrades.** By late fall of 2024, the Discharger plans to design and construct a new UV disinfection system that will include two channels, replacing

the existing one-channel system. During construction of this project, the Discharger may use a temporary UV disinfection system or a temporary chlorination and dechlorination disinfection system.

By June 30, 2027, the Discharger also anticipates completing a headworks improvement project that will include replacing its grit removal system, replacing the lining of the headworks influent channel, installing bar screens at the treatment plant, and decommissioning the Discharger's hypochlorite tank.

Other projects scheduled for the next permit term include upgrading the roof covering the digester tanks and replacing the solar panels with more efficient technology.

2.2. Discharge Points and Receiving Waters. Discharge of treated wastewater into Calera Creek is via a cascade aerator at Discharge Point 001. From Calera Creek, the effluent travels 0.52 miles within the Discharger's constructed wetlands before entering the Pacific Ocean. The discharge elevation at the cascade aerator is approximately 2 to 3 feet above the surface water elevation of Calera Creek based on a 100-year storm.

Calera Creek is located within the San Mateo Coastal watershed. It is freshwater at the point of discharge and transitions to brackish and saltwater before flowing to the Pacific Ocean. The discharge to Calera Creek is a shallow water discharge because the discharge does not receive 10:1 dilution.

Prior to restoration, Calera Creek was highly degraded and was modified to flow through a man-made ditch in a former rock quarry. The Discharger restored the last half-mile of Calera Creek to a natural meandering stream and restored 8.7 acres of adjacent wetlands, including two ponds, downstream from the discharge point. The restored section of Calera Creek provides habitat for the endangered San Francisco garter snake, the threatened California red-legged frog, and the Pacific tree frog. The wetland design was based on a hydrogeomorphic approach that incorporated data from similar coastal creeks along the San Mateo coastline and set quantifiable design and monitoring targets for restoration.

2.3. Previous Requirements and Monitoring Data. The table below presents the previous order's effluent limitations and representative monitoring data from June 1, 2017, through January 31, 2022.

Table F-2. Previous Effluent Limitations and Monitoring Data

| Parameter | Units | Average Monthly Limit | Maximum Daily Limit | Other Limit | Average | Highest Daily Value |
|---|-------|-----------------------|---------------------|-------------|--------------------|---------------------|
| Biochemical Oxygen Demand, 5-day @ 20°C (BOD ₅) | mg/L | 10 | 20 | | 1.6 ^[1] | 9.7 |

| Parameter | Units | Average Monthly Limit | Maximum Daily Limit | Other Limit | Average | Highest Daily Value |
|----------------------------------|-----------------|-----------------------|---------------------|---|--------------------|--------------------------|
| Total Suspended Solids (TSS) | mg/L | 10 | 20 | | 0.6 ^[1] | 7.1 |
| BOD ₅ percent removal | % | 85 (minimum) | | | 99.3 | 98.6 ^[2] |
| TSS percent removal | % | 85 (minimum) | | | 99.7 | 99.3 ^[2] |
| Oil and Grease | mg/L | 5 | 10 | | 0.16 | 1.7 |
| Turbidity | NTU | | 10 | | 0.84 | 5.6 |
| pH | standard units | | | 6.5 – 8.5 ^[3] | 7.2 | 6.6 ^[2] - 7.9 |
| Copper, Total | µg/L | 10 | 15 | | 4.7 | 7.2 |
| Ammonia, Total | mg/L as N | 3.1 | 7.1 | | 0.45 | 3.4 |
| Chronic Toxicity | TU _c | 1.0 ^[4] | 1.8 ^[5] | | ND ^[1] | 12 |
| Fecal Coliform | MPN/100 mL | 200 ^[6] | | 400 ^[7] | ND ^[1] | 100 |
| Acute Toxicity | % survival | | | Not less than 90% (11-sample median) Not less than 70% (11-sample 90 th percentile) | 100 | 100 ^[2] |

Footnotes:

^[1] Median of data set.

^[2] Minimum of data set.

^[3] Instantaneous minimum and instantaneous maximum.

^[4] Median test result for the month.

^[5] Maximum test result for the month.

^[6] Monthly geometric mean.

^[7] 11-sample 90th percentile.

2.4. Compliance Summary

2.4.1. **Treatment Plant.** The Discharger violated its effluent limitations two times during the period from June 1, 2017, through January 31, 2022.

Table F-3. Effluent Limitation Violations

| Monitoring Location | Date of Violation | Violation | Units | Effluent Limitation | Reported Value |
|---------------------|-------------------|------------------|-----------------|---------------------|---------------------|
| EFF-001 | 8/02/2017 | Chronic Toxicity | TU _c | 1.8 (maximum daily) | 12.1 (reproduction) |
| EFF-001 | 2/10/2019 | Chronic Toxicity | TU _c | 1.8 (maximum daily) | 4.9 (reproduction) |

In August 2017, the Discharger exceeded its maximum daily effluent limitation for chronic toxicity. The Discharger believes this high result was caused by the sampler touching the interior of a pipe within the UV system. This pipe may have contained pathogenic bacteria that affected reproduction. The Discharger

performed accelerated monitoring using a temporary PVC pipe rather than the existing steel pipe and demonstrated a return to compliance.

In February 2019, the Discharger exceeded its maximum daily effluent limitation for chronic toxicity again. The Discharger's contract lab believes this high result could have been caused by microorganism interference during sample collection. The Discharger completed accelerated monitoring and demonstrated a return to compliance.

2.4.2. Collection System. The table below summarizes the Discharger's Category 1 sanitary sewer overflow (SSO) rates for the last five years. Category 1 SSOs are those that reach waters of the United States and thus may violate Prohibition 3.4 of this Order.

Table F-4. Collection System and Category 1 SSO Rates (SSOs/100 miles)

(Values based on CIWQS August 2022 data) ^[1]

| | Length (miles) | Average Pipe Age (years) | 2017 | 2018 | 2019 | 2020 | 2021 |
|--------------------------|-------------------|-----------------------------|------|------|------|------|------|
| Discharger | 100.2 | 63 | 5.0 | 2.0 | 0.00 | 0.00 | 2.0 |
| San Francisco Bay Region | 19,600 | 48 ^[2] | 1.5 | 0.64 | 1.2 | 0.61 | 1.0 |
| State of California | 113,000 | 46 ^[2] | 0.67 | 0.38 | 0.56 | 0.33 | 0.46 |

Footnotes:

^[1] The State Water Board's *Enrollees's Guide to the SSO Database* defines "Total number of SSOs per 100 miles of Sewer" as "...the number of SSOs, for which the reporting enrollee is responsible, for every 100 miles of pipe or sewer lines in an enrollee's sanitary sewer system. Due to the large variation in facility specific characteristics, this metric should only be viewed as a rough comparison of the operation and maintenance performance of enrollees and their sanitary sewer systems."

^[2] The average pipe age for the State of California is estimated based on the percentage of piping constructed during each decade as reported by enrollees under State Water Board Order 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems, as amended by State Water Board Order WQ 2013-0058-EXEC.

The Regional Water Board adopted CDO R2-2011-0031 on May 11, 2011, and amended that order by Order R2-2013-0005 on February 14, 2013. The CDO required the Discharger to implement improvements to reduce SSOs. Specifically, it required the Discharger to prepare an SSO Reduction Plan; meet recordkeeping requirements; purchase a Computerized Maintenance Management System (CMMS); develop and implement enhanced system-wide cleaning, root control, and illicit discharge elimination programs; complete a condition assessment; complete a System Evaluation and Capacity Assurance Plan (SECAP); prepare and implement a Capital Improvement Plan (CIP); develop a 20-year Financial Plan; develop and implement a private sewer lateral replacement program; achieve minimum SSO performance standards; conduct a training assessment; and develop and implement a new training program.

In accordance with CDO R2-2011-0031 as amended by Order R2-2013-0005, the Discharger built a 2.1-million-gallon equalization basin near its Linda Mar pump station in 2019. This equalization basin temporarily stores high influent flows during wet weather, reducing backups and SSOs.

The Discharger's collection system experienced two Category 1 SSOs during 2021, both of which began on October 24, 2021, during an atmospheric river that caused sewage spills throughout the San Francisco Bay region. The Discharger reported one of these SSOs to have a 2.94-million-gallon spill volume from three manholes and the Linda Mar pump station. The Discharger's staff opened the valve connecting the Linda Mar sewage wet well to the Linda Mar stormwater wet well, bypassing treatment and discharging directly onto Pacifica State Beach. The Discharger's recently completed 2.1-million-gallon equalization basin had reached capacity, and sewage started to backup into the collection system. Opening the valve minimized SSO-related flooding at adjacent properties. The beach was closed, and public warning signs were posted on October 24, 2021; the beach reopened on October 29, 2021.

- 2.5. Sea Level Rise.** The plant is geographically located in an area where sea level rise due to climate change does not pose a significant risk within the next 50 years; however, the Discharger is currently assessing the vulnerability of its collection system.

3. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the requirements and authorities described in this section.

- 3.1. Legal Authorities.** This Order serves as WDRs pursuant to California Water Code article 4, chapter 4, division 7 (commencing with § 13260). This Order is also issued pursuant to federal Clean Water Act (CWA) section 402 and implementing regulations adopted by the U.S. EPA, and Water Code chapter 5.5, division 7 (commencing with § 13370). It serves as an NPDES permit authorizing the Discharger to discharge into waters of the United States at the discharge location described in Table 1 subject to the WDRs in this Order.
- 3.2. California Environmental Quality Act (CEQA).** Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of the California Environmental Quality Act (CEQA), Public Resources Code division 13, chapter 3 (commencing with § 21100).
- 3.3. State and Federal Laws, Regulations, Policies, and Plans**
- 3.3.1. Water Quality Control Plan.** The Regional Water Board adopted the *Water Quality Control Plan for the San Francisco Bay Basin* (Basin Plan), which designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Requirements in this Order implement the Basin Plan. State Water Board Resolution 88-63 establishes as State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply (MUN). Regional Water Board staff examined uses of Calera Creek downstream of the discharge point and

confirmed that municipal or domestic supply are not actual or potential uses of the creek. Beneficial uses applicable to the Calera Creek are listed below:

Table F-5. Beneficial Uses

| Discharge Point | Receiving Water | Beneficial Uses |
|-----------------|-----------------|---|
| 001 | Calera Creek | Preservation of Rare and Endangered Species (RARE) Warm Freshwater Habitat (WARM) Wildlife Habitat (WILD) Water Contact Recreation (REC-1) Non-Contact Water Recreation (REC-2) |

3.3.2. National Toxics Rule (NTR) and California Toxics Rule (CTR). The NTR and CTR contain federal water quality criteria for priority pollutants. U.S. EPA adopted the NTR on December 22, 1992, and amended it on May 4, 1995, and November 9, 1999. About 40 NTR criteria apply in California. U.S. EPA adopted the CTR on May 18, 2000. The CTR promulgated new toxics criteria for California and incorporated the NTR criteria that applied in the State. U.S. EPA amended the CTR on February 13, 2001.

3.3.3. State Implementation Policy. The State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP) on March 2, 2000. The SIP establishes implementation provisions for priority pollutant criteria and objectives, and provisions for chronic toxicity control. The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria U.S. EPA promulgated for California through the NTR and the priority pollutant objectives the Regional Water Board established through the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria U.S. EPA promulgated through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. Requirements of this Order implement the SIP.

3.3.4. Bacteria Objectives. The State Water Board adopted the *Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California – Part 3, Bacteria Provisions and a Water Quality Standards Variance Policy* on August 7, 2018, and it became effective on March 22, 2019. This plan establishes *Escherichia coli* bacteria water quality objectives and related implementation provisions for discharges to freshwaters that support the water contact recreation (REC-1) beneficial use.

3.3.5. Mercury Provisions. On May 2, 2017, the State Water Board adopted Resolution 2017-0027, which approved *Final Part 2 of the Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California – Tribal and Subsistence Fishing Beneficial Uses and Mercury Provisions* (Mercury Provisions), thereby establishing water quality objectives for mercury in most State waters. The Mercury Provisions establish mercury fish tissue

water quality objectives based on beneficial uses and translate those objectives into mercury water column criteria. Requirements of this Order implement the Mercury Provisions.

- 3.3.6. **Toxicity Provisions.** The State Water Board adopted the *State Policy for Water Quality Control: Toxicity Provisions* (Toxicity Provisions) on October 5, 2021. Following U.S. EPA approval, Toxicity Provisions sections II.C.1 and II.C.2 will establish numeric chronic and acute toxicity objectives that apply to all inland surface waters, enclosed bays, and estuaries in the State with aquatic life beneficial uses. The Toxicity Provisions include related implementation provisions and require that compliance with the chronic toxicity water quality objectives be assessed using U.S. EPA's Test of Significant Toxicity (TST) (U.S. EPA, *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* [EPA/833-R-10-003], June 2010). This Order will implement the Toxicity Provisions on the first day of the month following U.S. EPA approval.
- 3.3.7. **Antidegradation Policy.** Federal regulations at 40 C.F.R. section 131.12 require that state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy through State Water Board Resolution 68-16, *Statement of Policy with Respect to Maintaining High Quality of Waters in California*, which incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. Permitted discharges must be consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and State Water Board Resolution 68-16.
- 3.3.8. **Anti-Backsliding Requirements.** CWA sections 402(o) and 303(d)(4) and 40 C.F.R. section 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.
- 3.3.9. **Endangered Species Act Requirements.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code §§ 2050 to 2097) or Federal Endangered Species Act (16 U.S.C.A. §§ 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the State, including protecting rare, threatened, or endangered species. The Discharger is responsible for meeting all applicable Endangered Species Act requirements.

3.3.10. **Sewage Sludge and Biosolids.** U.S. EPA administers 40 C.F.R. part 503, Standards for the Use or Disposal of Sewage Sludge, which regulates the final use or disposal of sewage sludge generated during the treatment of domestic sewage in a municipal wastewater treatment facility. The Discharger is responsible for meeting applicable requirements of 40 C.F.R. part 503. This Order does not authorize any act that violates those requirements.

3.4. **Impaired Water Bodies on CWA Section 303(d) List.** On May 11, 2022, U.S. EPA approved a revised list of impaired waters pursuant to CWA section 303(d), which requires identification of specific water bodies where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. Where it has not done so already, the Regional Water Board plans to adopt total maximum daily loads (TMDLs) for pollutants on the 303(d) list. Calera Creek is not on the 303(d) list.

4. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants discharged into waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations: 40 C.F.R. section 122.44(a) requires that permits include applicable technology-based limitations and standards, and 40 C.F.R. section 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of receiving waters.

4.1. Discharge Prohibitions

4.1.1. Prohibitions in this Order

- 4.1.1.1. **Discharge Prohibition 3.1 (No discharge other than as described):** This prohibition is based on 40 C.F.R. section 122.21(a) and Water Code section 13260, which require filing an application and Report of Waste Discharge before a discharge can occur. Discharges not described in the application and Report of Waste Discharge, and subsequently in this Order, are prohibited.
- 4.1.1.2. **Discharge Prohibition 3.2 (No bypass to waters of the United States):** This prohibition is based on 40 C.F.R. section 122.41(m) (see Attachment D section 1.7).
- 4.1.1.3. **Discharge Prohibition 3.3 (No average dry weather influent flow in excess of 4.0 MGD):** This Order prohibits average dry weather influent flows greater than 4.0 MGD because the plant design average dry weather treatment capacity (i.e., its historical and tested treatment reliability) is 4.0 MGD. Exceeding this flow could result in lower treatment reliability and greater potential to violate water quality requirements.

4.1.1.4. **Discharge Prohibition 3.4 (No sanitary sewer overflows to waters of the United States):** Basin Plan Table 4-1, Discharge Prohibition 15, and the CWA prohibit the discharge of wastewater to surface waters, except as authorized under an NPDES permit. Publicly-owned treatment works must achieve secondary treatment at a minimum and any more stringent limitations necessary to meet water quality standards. A sanitary sewer overflow that results in the discharge to waters of the United States of raw sewage or wastewater not meeting this Order's effluent limitations is therefore prohibited under the Basin Plan and CWA.

4.1.2. **Basin Plan Discharge Prohibition 1.** Basin Plan Table 4-1, Discharge Prohibition 1, prohibits discharges of wastewater that do not receive a minimum initial dilution of at least 10:1 or discharges into any nontidal water. Basin Plan section 4.2 provides for exceptions to Basin Plan Discharge Prohibition 1 under certain circumstances:

- An inordinate burden would be placed on the Discharger relative to the beneficial uses protected, and an equivalent level of environmental protection can be achieved by alternate means;
- A discharge is approved as part of a reclamation project;
- Net environmental benefits will be derived as a result of the discharge; or
- A discharge is approved as part of a groundwater cleanup project.

The Basin Plan further states:

In reviewing requests for exceptions, the Water Board will consider the reliability of the discharger's system in preventing inadequately treated wastewater from being discharged to the receiving water and the environmental consequences of such discharges.

Discharge Point 001 discharges to Calera Creek without providing at least 10:1 dilution. Nevertheless, this Order grants an exception to Basin Plan Discharge Prohibition 1 for the following reasons:

- Ensuring that Facility discharges receive a minimum initial dilution of 10:1 would be an inordinate burden for the Discharger because the Discharger would have to construct and operate a deep water ocean outfall.
- The Discharger provides an equivalent level of protection by providing advanced-secondary treatment (i.e., by removing more BOD, TSS, and turbidity than required by the Basin Plan and Secondary Treatment Standards; see Fact Sheet section 4.2.2).

4.2. Technology-Based Effluent Limitations

- 4.2.1. **Scope and Authority.** CWA section 301(b) and 40 C.F.R. section 122.44 require that permits include conditions meeting technology-based requirements, at a minimum, and any more stringent effluent limitations necessary to meet water quality standards. The discharges authorized by this Order must meet minimum federal technology-based requirements based on the secondary treatment standards at 40 C.F.R. section 133 as summarized below. Basin Plan Table 4-2 contains additional requirements for certain pollutants.

Table F-6. Secondary Treatment Standards

| Parameter | Monthly Average | Weekly Average |
|--|--------------------------|----------------|
| Biochemical Oxygen Demand (BOD) ^[1,2] | 30 mg/L | 45 mg/L |
| Carbonaceous Biochemical Oxygen Demand (CBOD) ^[1,2] | 25 mg/L | 40 mg/L |
| Total Suspended Solids TSS ^[2] | 30 mg/L | 45 mg/L |
| pH | 6.0 – 9.0 standard units | |

Footnotes:

^[1] CBOD effluent limitations may be substituted for BOD limitations.

^[2] The monthly average percent removal, by concentration, is also not to be less than 85 percent.

4.2.2. Technology-Based Effluent Limitations

- 4.2.2.1. **BOD and TSS.** This Order's BOD and TSS effluent limitations, excluding the 85 percent removal requirement, are more stringent than the secondary treatment standards. These more stringent limits demonstrate a level of water quality protection equivalent to complying with Basin Plan Discharge Prohibition 1 (see Fact Sheet section 4.1.2). Effluent data show that compliance with these limits is feasible.
- 4.2.2.2. **pH.** Basin Plan Table 4-2 prescribes a pH effluent limitation of 6.5 – 8.5 standard units for shallow water discharge, which are more stringent than the secondary treatment standards.
- 4.2.2.3. **Total Residual Chlorine.** Basin Plan Table 4-2 requires a technology-based total residual chlorine effluent limitation of 0.0 mg/L. Regional Water Board Resolution R2-2020-0031 adopted a Basin Plan amendment establishing new chlorine water quality objectives and related implementation provisions and removing the technology-based limit from the Basin Plan. Under Resolution R2-2020-0031, the Basin Plan amendment, including the new objectives, will become effective upon approval by the U.S. EPA. This Order contains a new water-quality based effluent limitation that implements the new water quality objectives (see Fact Sheet section 4.3.4.5). Thus, the technology-based effluent limit will be replaced by the water quality-based effluent limit on the first day of the month following U.S. EPA approval of the objectives.

The Monitoring and Reporting Program (MRP, Attachment E) provides an allowance for determining false positives when using continuous devices based on the fact that continuous instruments occasionally have anomalous spikes, and it is chemically improbable to have free chlorine in the presence of sodium bisulfite.

- 4.2.2.4. **Turbidity.** The turbidity effluent limitation is representative of adequate and reliable advanced-secondary treatment. This limitation is a technologically feasible standard for the Discharger's advanced-secondary wastewater treatment technologies and justifies, in part, an exception to Basin Plan Prohibition 1 (see Fact Sheet section 4.1.2). Effluent data show that compliance with this limit is feasible.

4.3. Water Quality-Based Effluent Limitations

- 4.3.1. **Scope and Authority.** CWA section 301(b) and 40 C.F.R. section 122.44(d) require permits to include limitations more stringent than federal technology-based requirements where necessary to achieve water quality standards. According to 40 C.F.R. section 122.44(d)(1)(i), permits must include effluent limitations for all pollutants that are or may be discharged at levels that have a reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective, water quality-based effluent limitations (WQBELs) must be established using (1) U.S. EPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting a narrative criterion, supplemented with relevant information. The process for determining reasonable potential and calculating WQBELs when necessary is intended to achieve applicable water quality objectives and criteria, and thereby protect designated beneficial uses of receiving waters.
- 4.3.2. **Beneficial Uses and Water Quality Criteria and Objectives.** Discharge Point 001 discharges to Calera Creek. Fact Sheet section 3.3.1 identifies the beneficial uses of Calera Creek. Water quality criteria and objectives to protect these beneficial uses are described below.
- 4.3.2.1. **Basin Plan Objectives.** The Basin Plan specifies numerous water quality objectives, including numeric objectives for 10 priority pollutants, temperature, un-ionized ammonia, and total residual chlorine, and narrative objectives for toxicity.
- 4.3.2.1.1. **Temperature.** Calera Creek supports the warm water habitat beneficial use; therefore, the temperature water quality objectives in Basin Plan section 3.3.17 apply:

- The natural receiving water temperature of inland surface waters shall not be altered unless it can be demonstrated to the satisfaction of the Regional Water Board that such alteration in temperature does not adversely affect beneficial uses.
- The temperature of any warm freshwater habitat shall not be increased by more than 5°F (2.8°C) above the natural receiving water temperature.

4.3.2.1.2. **Un-ionized Ammonia.** Basin Plan section 3.3.20 contains a water quality objective for un-ionized ammonia of 0.025 mg/L (as nitrogen) as an annual median. To determine the un-ionized ammonia fraction, pH and temperature data were used from Monitoring Locations EFF-001 and RSW-002. These data were collected on the same days and at the same locations as the receiving water ammonia samples. Between June 1, 2017 and January 31, 2022, the Discharger measured salinity 19 times (n=19) at Monitoring Location RSW-001. Salinity was less than 1 ppt in 100 percent of the samples and greater than 10 ppt in 0 percent of the samples. The un-ionized fraction of total ammonia was calculated as follows:

$$\text{Fraction of un-ionized ammonia} = (1 + 10^{[pK - pH]})^{-1}$$

Where, for salinity less than 1 ppt:

$$pK = 0.09018 + 2729.92/T$$

T = temperature in Kelvin

4.3.2.1.3. **Total Residual Chlorine.** On November 18, 2020, the Regional Water Board adopted Resolution R2-2020-0031, which amended the Basin Plan to eliminate the technology-based effluent limit for total residual chlorine of 0.0 mg/L and established new water quality objectives for chlorine. U.S. EPA must approve the new objectives before they become effective. The Discharger's receiving water, Calera Creek, is freshwater based on its salinity monitoring data (see section 4.3.2.6); therefore, the freshwater chlorine objectives will apply to the discharger's receiving water. For freshwater, the new objectives are 0.011 mg/L as a four-day average and 0.019 mg/L as a one-hour average (see Basin Plan section 3.3.23).

4.3.2.1.4. **Chronic Toxicity**

4.3.2.1.4.1. **Prior to U.S. EPA Approval of the Toxicity Provisions.** Basin Plan section 3.3.18 contains the following chronic toxicity water quality objective:

"All waters shall be maintained free of toxic substances in concentrations that are lethal to or that produce other detrimental

responses in aquatic organisms.... There shall be no chronic toxicity in ambient waters. Chronic toxicity is a detrimental biological effect on growth rate, reproduction, fertilization success, larval development, population abundance, community composition, or any other relevant measure of the health of an organism, population, or community. Attainment of this objective will be determined by analyses of indicator organisms, species diversity, population density, growth anomalies, or toxicity tests..., or other methods selected by the Water Board.”

For this Order, prior to U.S. EPA approval of the Toxicity Provisions, this narrative objective is translated into a numeric criterion of 1.0 TUc. At 1.0 TUc, there is no observable detrimental effect when the indicator organism is exposed to 100 percent effluent; therefore, 1.0 TUc is a direct translation of the narrative objective into a number. Moreover, in the Technical Support Document (see section 3.3.3, “Step 3: Decision Criteria for Permit Limit Development”), U.S. EPA recommends that 1.0 TUc be used as a criterion continuous concentration (typically a four-day average). It further states that reasonable potential is shown where an effluent is projected to cause an excursion above the criterion continuous concentration. The Technical Support Document applies here as guidance because it directly addresses effluent characterization for whole effluent toxicity.

4.3.2.1.4.2. **After U.S. EPA Approval of the Toxicity Provisions.** After U.S. EPA approves the Toxicity Provisions, the following additional chronic toxicity water quality objective will apply:

H_o : Mean Response (ambient water) $\leq 0.75 \times$ Mean Response (control water)

H_a : Mean Response (ambient water) $> 0.75 \times$ Mean Response (control water).

Where:

H_o = Null Hypothesis

H_a = Alternative Hypothesis,

0.75 = Regulatory Management Decision criterion (i.e., 75 percent)

H_o means the ambient water is toxic when the test organism response in a bioassay is less than or equal to 75 percent of the control response; H_a means the ambient water is not toxic when the test organism response is greater than 75 percent of the control response. For example, if an average of 75 percent of bioassay test organisms or fewer survive when exposed to ambient water relative to the average

number that survive when exposed to control water, the ambient water is toxic (i.e., the test result is “fail”). Conversely, if an average of more than 75 percent of bioassay test organisms survive relative to those exposed to control water, the ambient water is not toxic (i.e., the test result is “pass”).

- 4.3.2.2. **CTR Criteria.** The CTR specifies numeric aquatic life and human health criteria for numerous priority pollutants. These criteria apply to inland surface waters and enclosed bays and estuaries. Some human health criteria are for consumption of “water and organisms” and others are for consumption of “organisms only.” The criteria applicable to “organisms only” apply to Calera Creek because it is not a source of drinking water.
- 4.3.2.3. **NTR Criteria.** The NTR establishes numeric aquatic life and human health criteria for a number of toxic pollutants for inland waters of the State. The NTR criteria apply to Calera Creek.
- 4.3.2.4. **Bacteria Objectives.** The *Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California – Part 3, Bacteria Provisions and a Water Quality Standards Variance Policy* establishes *E. coli* bacteria water quality objectives to limit cases of gastrointestinal illness from water contact recreation. The *E. coli* bacteria objectives apply to freshwater.
- 4.3.2.5. **Mercury Objectives.** The Mercury Provisions specify water column criteria for mercury depending on water body type and beneficial uses. Calera Creek is a flowing water body that supports warm freshwater habitat; preservation of rare, threatened, or endangered species; and wildlife habitat beneficial uses. Mercury Provisions section IV.D.2.b, Table 1, establishes an annual average total mercury criterion of 0.012 µg/L for Calera Creek.
- 4.3.2.6. **Receiving Water Salinity.** Basin Plan section 4.6.2 (like the CTR and NTR) states that the salinity characteristics (i.e., freshwater vs. saltwater) of the receiving water are to be considered in determining the applicable water quality objectives. Freshwater criteria apply to discharges to waters with salinities equal to or less than one part per thousand (ppt) at least 95 percent of the time. Saltwater criteria apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to water with salinities in between these two categories, or tidally-influenced freshwaters that support estuarine beneficial uses, the water quality objectives are the lower of the salt or freshwater criteria (the latter calculated based on ambient hardness) for each substance.

Between June 1, 2017 and January 31, 2022, the Discharger measured salinity 19 times (n=19) at Monitoring Location RSW-001. Salinity was less than 1 ppt in 100 percent of the samples and greater than 10 ppt in 0 percent of the samples. The waters in Calera Creek in the vicinity of the discharge

are therefore freshwater, and the reasonable potential analysis and WQBELs in this Order are based on freshwater quality criteria and objectives.

- 4.3.2.7. **Receiving Water Hardness.** Ambient hardness data were used to derive freshwater quality objectives that are hardness-dependent. The Discharger collected 19 receiving water samples at Monitoring Location RSW-001 from June 1, 2017, through January 31, 2022. The geometric mean of the dataset, 260 mg/L as calcium carbonate (CaCO_3), was used to determine the water quality objectives.
- 4.3.2.8. **Metals Translators.** Regulations at 40 C.F.R. section 122.45(c), require effluent limitations for metals to be expressed as total recoverable metal. Since the water quality objectives for metals are typically expressed as dissolved metal, translators must be used to convert metals concentrations from dissolved to total recoverable and vice versa. The CTR contains default translators; however, site-specific conditions, such as water temperature, pH, total suspended solids, and organic carbon may affect the form of metal (dissolved, non-filterable, or otherwise) present and therefore available to cause toxicity. In general, dissolved metals are more available and more toxic to aquatic life than other forms. Site-specific translators can account for site-specific conditions, thereby preventing overly stringent or under-protective water quality objectives. CTR default translators were used for all metals in this Order's reasonable potential analysis and WQBEL calculations.

4.3.3. Reasonable Potential Analysis

- 4.3.3.1. **Available Information.** The reasonable potential analysis for this Order is based on effluent data the Discharger collected from June 1, 2017, through January 31, 2022, and receiving water data collected from June 1, 2017, through February 28, 2022.

This Order does not contain WQBELs for constituents that do not demonstrate reasonable potential; however, the MRP still requires monitoring for those pollutants. If concentrations are found to have increased significantly, Provision 6.3.2 of the Order requires the Discharger to investigate the sources of the increases and implement remedial measures if the increases pose a threat to receiving water quality.

- 4.3.3.2. **Priority Pollutants.** SIP section 1.3 sets forth the methodology used to assess whether priority pollutants have reasonable potential to exceed CTR and NTR water quality objectives.

The analysis begins with identifying the maximum effluent concentration (MEC) observed for each pollutant based on available effluent concentration data and the ambient background concentrations (B). SIP section 1.4.3 states that ambient background concentrations are either the maximum ambient concentration observed or, for water quality objectives intended to

protect human health, the arithmetic mean of observed concentrations. There are three triggers in determining reasonable potential:

- **Trigger 1** is activated if the maximum effluent concentration is greater than or equal to the lowest applicable water quality objective ($MEC \geq$ water quality objective).
- **Trigger 2** is activated if the ambient background concentration observed in the receiving water is greater than the lowest applicable water quality objective ($B >$ water quality objective) and the pollutant is detected in any effluent sample.
- **Trigger 3** is activated if a review of other information indicates that a WQBEL is needed to protect beneficial uses.

The maximum effluent concentrations, most stringent applicable water quality criteria and objectives, and ambient background concentrations used in the analysis are presented in the following table, along with the reasonable potential analysis results (yes, no, or unknown) for each pollutant. Based on this analysis, no priority pollutants were determined to exhibit reasonable potential.

Table F-7. Reasonable Potential Analysis

| CTR No. | Pollutants | C or Governing Criterion or Objective ($\mu\text{g/L}$) | MEC or Minimum DL ($\mu\text{g/L}$) ^{[1],[2]} | B or Minimum DL ($\mu\text{g/L}$) ^{[1],[2]} | RPA Results ^[3] |
|---------|-------------------------------|---|--|--|----------------------------|
| 1 | Antimony | 4300 | 0.50 | 0.14 | No |
| 2 | Arsenic | 150 | 0.84 | 0.32 | No |
| 3 | Beryllium | No Criterion | < 0.09 | < 0.09 | U |
| 4 | Cadmium | 2.4 | < 0.05 | < 0.05 | No |
| 5a | Chromium (III) ^[4] | 450 | 0.42 | 0.86 | No |
| 5b | Chromium (VI) | 11 | < 0.7 | < 0.7 | No |
| 6 | Copper | 21 | 7.2 | 2.9 | No |
| 7 | Lead | 11 | 1.5 | 1.0 | No |
| 8 | Mercury (303d listed) | 0.012 | 0.00063 | 0.0030 | No |
| 9 | Nickel | 120 | 2.4 | 2.3 | No |
| 10 | Selenium (303d listed) | 5.0 | 0.82 | < 0.4 | No |
| 11 | Silver | 21 | < 0.02 | < 0.05 | No |
| 12 | Thallium | 6.3 | < 0.05 | < 0.05 | No |
| 13 | Zinc | 270 | 63 | 2.4 | No |
| 14 | Cyanide | 5.2 | 2.3 | < 0.9 | No |
| 15 | Asbestos (fibers/L) | No Criterion | Unavailable | Unavailable | U |
| 16 | 2,3,7,8-TCDD (Dioxin) | 0.000000014 | ND | ND | No |

| CTR No. | Pollutants | C or Governing Criterion or Objective (µg/L) | MEC or Minimum DL (µg/L) ^{[1],[2]} | B or Minimum DL (µg/L) ^{[1],[2]} | RPA Results ^[3] |
|---------|----------------------------|--|---|---|----------------------------|
| 17 | Acrolein | 780 | < 0.81 | < 0.81 | No |
| 18 | Acrylonitrile | 0.66 | < 0.75 | < 0.75 | No |
| 19 | Benzene | 71 | < 0.18 | < 0.18 | No |
| 20 | Bromoform | 360 | < 0.15 | < 0.15 | No |
| 21 | Carbon Tetrachloride | 4.4 | < 0.16 | < 0.16 | No |
| 22 | Chlorobenzene | 21000 | < 0.18 | < 0.18 | No |
| 23 | Chlorodibromomethane | 34 | < 0.17 | < 0.17 | No |
| 24 | Chloroethane | No Criterion | < 0.15 | < 0.15 | U |
| 25 | 2-Chloroethylvinyl Ether | No Criterion | < 0.28 | < 0.28 | U |
| 26 | Chloroform | No Criterion | < 0.19 | < 0.19 | U |
| 27 | Dichlorobromomethane | 46 | < 0.16 | < 0.16 | No |
| 28 | 1,1-Dichloroethane | No Criterion | < 0.19 | < 0.19 | U |
| 29 | 1,2-Dichloroethane | 99 | < 0.18 | < 0.18 | No |
| 30 | 1,1-Dichloroethylene | 3.2 | < 0.21 | < 0.21 | No |
| 31 | 1,2-Dichloropropane | 39 | < 0.18 | < 0.18 | No |
| 32 | 1,3-Dichloropropylene | 1700 | < 0.25 | < 0.25 | No |
| 33 | Ethylbenzene | 29000 | < 0.1 | < 0.1 | No |
| 34 | Methyl Bromide | 4000 | < 0.3 | < 0.3 | No |
| 35 | Methyl Chloride | No Criterion | < 0.3 | < 0.3 | U |
| 36 | Methylene Chloride | 1600 | < 0.4 | < 0.4 | No |
| 37 | 1,1,2,2-Tetrachloroethane | 11 | < 0.15 | < 0.15 | No |
| 38 | Tetrachloroethylene | 8.9 | 0.69 | < 0.19 | No |
| 39 | Toluene | 200000 | < 0.19 | < 0.19 | No |
| 40 | 1,2-Trans-Dichloroethylene | 140000 | < 0.22 | < 0.22 | No |
| 41 | 1,1,1-Trichloroethane | No Criterion | < 0.19 | < 0.19 | U |
| 42 | 1,1,2-Trichloroethane | 42 | < 0.16 | < 0.16 | No |
| 43 | Trichloroethylene | 81 | < 0.2 | < 0.2 | No |
| 44 | Vinyl Chloride | 530 | < 0.25 | < 0.25 | No |
| 45 | 2-Chlorophenol | 400 | < 0.4 | < 0.9 | No |
| 46 | 2,4-Dichlorophenol | 790 | < 0.4 | < 0.9 | No |
| 47 | 2,4-Dimethylphenol | 2300 | < 0.4 | < 0.4 | No |
| 48 | 2-Methyl-4,6-Dinitrophenol | 770 | < 0.3 | < 2 | No |
| 49 | 2,4-Dinitrophenol | 14000 | < 0.2 | < 2 | No |
| 50 | 2-Nitrophenol | No Criterion | < 0.4 | < 1 | U |
| 51 | 4-Nitrophenol | No Criterion | < 0.5 | < 1 | U |
| 52 | 3-Methyl-4-Chlorophenol | No Criterion | < 0.5 | < 0.5 | U |
| 53 | Pentachlorophenol | 5.1 | < 0.4 | < 0.4 | No |
| 54 | Phenol | 4600000 | < 0.3 | < 0.3 | No |

| CTR No. | Pollutants | C or Governing Criterion or Objective (µg/L) | MEC or Minimum DL (µg/L) ^{[1],[2]} | B or Minimum DL (µg/L) ^{[1],[2]} | RPA Results ^[3] |
|---------|-----------------------------|--|---|---|----------------------------|
| 55 | 2,4,6-Trichlorophenol | 6.5 | < 0.5 | < 2 | No |
| 56 | Acenaphthene | 2700 | < 0.02 | < 0.02 | No |
| 57 | Acenaphthylene | No Criterion | < 0.02 | < 0.02 | U |
| 58 | Anthracene | 110000 | < 0.01 | < 0.03 | No |
| 59 | Benzidine | 0.00054 | < 4 | < 4 | No |
| 60 | Benzo(a)Anthracene | 0.049 | < 0.02 | < 0.02 | No |
| 61 | Benzo(a)Pyrene | 0.049 | < 0.02 | < 0.04 | No |
| 62 | Benzo(b)Fluoranthene | 0.049 | < 0.02 | < 0.02 | No |
| 63 | Benzo(ghi)Perylene | No Criterion | < 0.02 | < 0.05 | U |
| 64 | Benzo(k)Fluoranthene | 0.049 | < 0.02 | < 0.02 | No |
| 65 | Bis(2-Chloroethoxy)Methane | No Criterion | < 0.5 | < 0.5 | U |
| 66 | Bis(2-Chloroethyl)Ether | 1.4 | < 0.4 | < 0.9 | No |
| 67 | Bis(2-Chloroisopropyl)Ether | 170000 | < 0.4 | < 0.9 | No |
| 68 | Bis(2-Ethylhexyl)Phthalate | 5.9 | 0.70 | < 0.5 | No |
| 69 | 4-Bromophenyl Phenyl Ether | No Criterion | < 0.5 | < 2 | U |
| 70 | Butylbenzyl Phthalate | 5200 | < 0.5 | < 2 | No |
| 71 | 2-Chloronaphthalene | 4300 | < 0.4 | < 1 | No |
| 72 | 4-Chlorophenyl Phenyl Ether | No Criterion | < 0.5 | < 1.5 | U |
| 73 | Chrysene | 0.049 | < 0.02 | < 0.02 | No |
| 74 | Dibenzo(a,h)Anthracene | 0.049 | < 0.02 | < 0.02 | No |
| 75 | 1,2-Dichlorobenzene | 17000 | < 0.27 | < 0.27 | No |
| 76 | 1,3-Dichlorobenzene | 2600 | < 0.18 | < 0.18 | No |
| 77 | 1,4-Dichlorobenzene | 2600 | < 0.18 | < 0.18 | No |
| 78 | 3,3'-Dichlorobenzidine | 0.077 | < 5 | < 5 | No |
| 79 | Diethyl Phthalate | 120000 | 4.7 | < 0.5 | No |
| 80 | Dimethyl Phthalate | 2900000 | < 0.5 | < 0.5 | No |
| 81 | Di-n-Butyl Phthalate | 12000 | < 0.4 | < 0.4 | No |
| 82 | 2,4-Dinitrotoluene | 9.1 | < 0.4 | < 0.9 | No |
| 83 | 2,6-Dinitrotoluene | No Criterion | < 0.4 | < 0.4 | U |
| 84 | Di-n-Octyl Phthalate | No Criterion | < 0.4 | < 0.4 | U |
| 85 | 1,2-Diphenylhydrazine | 0.54 | < 0.5 | < 0.5 | No |
| 86 | Fluoranthene | 370 | < 0.02 | < 0.02 | No |
| 87 | Fluorene | 14000 | < 0.01 | < 0.02 | No |
| 88 | Hexachlorobenzene | 0.00077 | < 0.4 | < 1 | No |
| 89 | Hexachlorobutadiene | 50 | < 0.4 | < 0.4 | No |
| 90 | Hexachlorocyclopentadiene | 17000 | < 0.3 | < 0.9 | No |
| 91 | Hexachloroethane | 8.9 | < 0.4 | < 0.9 | No |
| 92 | Indeno(1,2,3-cd) Pyrene | 0.049 | < 0.02 | < 0.02 | No |

| CTR No. | Pollutants | C or Governing Criterion or Objective (µg/L) | MEC or Minimum DL (µg/L) ^{[1],[2]} | B or Minimum DL (µg/L) ^{[1],[2]} | RPA Results ^[3] |
|---------|---------------------------|--|---|---|----------------------------|
| 93 | Isophorone | 600 | < 0.5 | < 0.5 | No |
| 94 | Naphthalene | No Criterion | < 0.02 | < 0.02 | U |
| 95 | Nitrobenzene | 1900 | < 0.5 | < 0.5 | No |
| 96 | N-Nitrosodimethylamine | 8.1 | < 0.3 | < 0.7 | No |
| 97 | N-Nitrosodi-n-Propylamine | 1.4 | < 0.5 | < 0.5 | No |
| 98 | N-Nitrosodiphenylamine | 16 | < 0.3 | < 0.7 | No |
| 99 | Phenanthrene | No Criterion | < 0.02 | < 0.02 | U |
| 100 | Pyrene | 11000 | < 0.02 | < 0.02 | No |
| 101 | 1,2,4-Trichlorobenzene | No Criterion | < 0.4 | < 0.9 | U |
| 102 | Aldrin | 0.00014 | < 0.002 | < 0.003 | No |
| 103 | alpha-BHC | 0.013 | < 0.003 | < 0.004 | No |
| 104 | beta-BHC | 0.046 | < 0.003 | < 0.004 | No |
| 105 | gamma-BHC | 0.063 | < 0.003 | < 0.003 | No |
| 106 | delta-BHC | No Criterion | < 0.003 | < 0.002 | U |
| 107 | Chlordane | 0.00059 | < 0.007 | < 0.003 | No |
| 108 | 4,4'-DDT | 0.00059 | < 0.003 | < 0.004 | No |
| 109 | 4,4'-DDE | 0.00059 | < 0.004 | < 0.001 | No |
| 110 | 4,4'-DDD | 0.00084 | < 0.003 | < 0.001 | No |
| 111 | Dieldrin | 0.00014 | < 0.004 | < 0.002 | No |
| 112 | alpha-Endosulfan | 0.056 | < 0.003 | < 0.004 | No |
| 113 | beta-Endosulfan | 0.056 | < 0.003 | < 0.004 | No |
| 114 | Endosulfan Sulfate | 240 | < 0.003 | < 0.003 | No |
| 115 | Endrin | 0.036 | < 0.003 | < 0.003 | No |
| 116 | Endrin Aldehyde | 0.81 | < 0.004 | < 0.004 | No |
| 117 | Heptachlor | 0.00021 | < 0.003 | < 0.004 | No |
| 118 | Heptachlor Epoxide | 0.00011 | < 0.003 | < 0.001 | No |
| 119-125 | PCBs sum | 0.00017 | < 0.34 | < 0.21 | No |
| 126 | Toxaphene | 0.0002 | < 0.2 | < 0.2 | No |

Footnotes:

- ^[1] The MEC and ambient background concentration are the actual detected concentrations unless preceded by a "<" sign, in which case the value shown is the method detection level (MDL).
- ^[2] The MEC or ambient background concentration is "Unavailable" when there are no monitoring data for the constituent.
- ^[3] RPA Results = Yes, if MEC ≥ WQC, B > WQC and MEC is detected, or Trigger 3
= No, if MEC and B are < WQC or all effluent data are undetected
= Unknown (U) if no criteria have been promulgated or data are insufficient.
- ^[4] The maximum effluent concentration and the maximum ambient background concentration are the chromium concentrations. The chromium (III) concentrations are unknown but less than these values.

4.3.3.3. **Acute Toxicity**

4.3.3.3.1. **Prior to U.S. EPA Approval of the Toxicity Provisions.** Basin Plan section 4.5.5.3.1 requires acute toxicity monitoring and limitations.

4.3.3.3.2. **After U.S. EPA Approval of the Toxicity Provisions.** When approved, the Toxicity Provisions will supersede Basin Plan section 4.5.5.3.1 and acute toxicity monitoring and limitations will not necessarily be required. During the previous order term, the Discharger monitored its effluent monthly for acute toxicity and all results showed 100 percent survival. Therefore, there is no reasonable potential for the discharge to cause or contribute to acute toxicity in the receiving water.

4.3.3.4. **Chronic Toxicity**

4.3.3.4.1. **Prior to U.S. EPA Approval of the Toxicity Provisions.** The previous order required chronic toxicity tests twice per year using the water flea (*Ceriodaphnia dubia*). During the previous order term, the Discharger observed intermittent chronic toxicity. Out of 10 chronic toxicity tests conducted on samples collected at Monitoring Location EFF-001 between June 1, 2017, and January 31, 2022, using the water flea, two (20%) exceeded 1.0 TUc. Therefore, there is reasonable potential for the discharge to cause or contribute to exceedances of the translated chronic toxicity water quality objective (1.0 TUc).

4.3.3.4.2. **After U.S. EPA Approval of the Toxicity Provisions.** Toxicity Provisions section III.C.3.a requires a chronic toxicity reasonable potential analysis for publicly owned treatment works permitted to discharge less than 5.0 MGD. The Discharger's facility is a publicly owned treatment works and is permitted to discharge 4.0 MGD. Therefore, the Toxicity Provisions require a reasonable potential analysis.

Toxicity Provisions section III.C.3.c. states that reasonable potential exists if any of at least four chronic toxicity tests at the IWC within five years prior to permit reissuance (1) results in a "fail" or (2) has a greater than 10 percent effect. If data from these tests were not analyzed using the TST, the data must be re-analyzed using the TST. If previous tests were not conducted at the IWC, then a concentration of effluent higher than the IWC may be used. Data from older tests may also be considered. If a minimum of four chronic toxicity tests is unavailable, the Regional Water Board must require the Discharger to conduct a minimum of four chronic toxicity tests at the IWC and analyze the data using the TST.

The Discharger conducted chronic toxicity tests twice per year during the previous order term. Two samples resulted in a "fail" using the TST; therefore, the discharge exhibits reasonable potential for chronic toxicity pursuant to the Toxicity Provisions.

4.3.3.5. **Temperature.** Basin Plan section 3.3.17 prohibits the alteration of natural receiving water temperatures such that beneficial uses are adversely affected and temperature increases greater than 2.8°C above natural receiving water temperatures. Since Calera Creek is effluent dominated, the discharge does not have reasonable potential to alter receiving water temperatures.

4.3.3.6. **Ammonia**

4.3.3.6.1. **Methodology.** Ammonia is a toxic pollutant but not a priority pollutant as defined by the CTR; therefore, the procedure outlined in the Technical Support Document was used to determine if ammonia in the discharge has reasonable potential to cause a water quality objective to be exceeded in the receiving water. According to the Technical Support Document, the reasonable potential analyses can be performed based on the receiving water concentrations projected using effluent data or measured receiving water concentrations. Both values may be compared directly with the Basin Plan un-ionized ammonia objective.

The following steps summarize the process for determining reasonable potential for a pollutant using the Technical Support Document method:

- **Step 1.** Determine the total number of samples (n) and the MEC.
- **Step 2.** Determine the coefficient of variation (CV). For a data set where $n < 10$, the CV is estimated to equal 0.6. For a dataset where $n \geq 10$, the CV is calculated as the standard deviation divided by the mean.
- **Step 3.** Determine a ratio (R) for projecting the upper bound concentration based on a selected confidence interval (e.g., 95th or 99th percentile) and assuming a lognormal distribution as follows:

Calculate the percentile (P_n) represented by the MEC in the data set of n samples based on the selected confidence level.

$$P_n = (1 - \text{confidence interval})^{1/n}$$

Calculate the concentration multiplying factors (C) for the MEC percentile and the chosen upper bound percentile (typically the 99th) using the following equation:

$$C_P = \exp(Z_P\sigma - 0.5\sigma^2)$$

Where:

$$\sigma^2 = \ln(CV^2 + 1)$$

P is the percentile (either P_n or the selected $P_{\text{upper bound}}$)

Z_p is the standard normal distribution value for the percentile P
(available from statistical references)

Finally, calculate R as:

$$R = C_{\text{upper bound}} / C_{Pn}$$

- **Step 4.** Calculate the projected maximum receiving water concentration (RWC) as follows:

$$\text{RWC} = (\text{MEC} \times R) / \text{dilution ratio}$$

The dilution ratio can be defined as:

$$\text{Dilution ratio} = (D + [1 \text{ part effluent}]) / (1 \text{ part effluent})$$

Where D is the parts receiving water available to dilute 1 part effluent

Therefore:

$$\text{RWC} = (\text{MEC} \times R) / (D + 1)$$

- **Step 5.** Compare the RWC to the most stringent water quality objective for the pollutant. There is reasonable potential if the RWC is greater than or equal to the lowest applicable water quality objective.

For purpose of this analysis, no dilution was assumed ($D=0$) and the receiving water concentration projected from effluent data was assumed to be the same as the projected upper bound concentration:

$$\text{RWC} = \text{MEC} \times R \text{ (see Step 4 above).}$$

4.3.3.6.2. **Analysis Based on Effluent Data.** The 250-sample data set of translated un-ionized ammonia effluent data from June 1, 2017, through January 31, 2022, were used to evaluate reasonable potential for ammonia. The highest actual running annual median un-ionized ammonia concentration based on the effluent data was calculated and compared with the objective, which itself is expressed as an annual median. No projection is needed to establish the central tendency of the data. The maximum annual median, 0.0025 mg/L, is less than the annual median objective of 0.025 mg/L. Therefore, there is no reasonable potential for ammonia based on the effluent data.

4.3.3.6.3. **Analysis Based on Receiving Water Data.** Reasonable potential was also evaluated using the translated un-ionized ammonia data from Receiving Water Monitoring Location RSW-002 collected from June 1, 2017 through February 31, 2022. The highest running annual median was calculated to be 0.0064 mg/L, which is less than the annual median water

quality objective of 0.025 mg/L. Therefore, there is no reasonable potential for ammonia based on the receiving water data.

- 4.3.3.6.4. **Conclusion.** The discharge does not exhibit reasonable potential for ammonia. However, this Order retains the previous order's total ammonia limits to ensure that the Discharger continues to successfully operate its treatment plant to reduce ammonia concentrations. Doing so will also ensure that effluent ammonia concentrations remain below the Basin Plan objective.
- 4.3.3.7. **Total Residual Chlorine.** Following U.S. EPA approval of the chlorine water quality objectives set forth in the Basin Plan amendment adopted by Regional Water Board Resolution R2-2020-0031, a water quality-based effluent limitation for total residual chlorine will be required because the Facility may elect to temporarily disinfect its effluent with chlorine during the construction of its UV disinfection system upgrade project and, without sufficient dechlorination, the discharge could contain chlorine concentrations above the new water quality objective. Until the water quality objective becomes effective, there cannot be reasonable potential for the objective to be exceeded. Therefore, to control chlorine in the discharge in the interim, this Order contains a technology-based effluent limit of 0.0 mg/L chlorine.
- 4.3.3.8. ***E. coli.*** The *Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California – Part 3, Bacteria Provisions and a Water Quality Standards Variance Policy* requires *E. coli* bacteria effluent limitations for discharges to freshwater receiving waters that support the water contact recreation (REC-1) beneficial use.
- 4.3.4. **Water Quality-Based Effluent Limitations.** WQBELs were developed for the pollutants determined to have reasonable potential to cause or contribute to exceedances of water quality objectives. The WQBEL calculations are based on the procedures in SIP section 1.4, with the exception of those for acute toxicity, chronic toxicity (after U.S. EPA approval of the Toxicity Provisions), total residual chlorine (after U.S. EPA approval of the new water quality objectives), and *E. coli* bacteria. This Order also retains the previous order's total ammonia limits to ensure that existing treatment performance is maintained.
- 4.3.4.1. **WQBEL Expression.** NPDES regulations at 40 C.F.R. section 122.45(d) require that permit limits for publicly-owned treatment works be expressed as average weekly and average monthly limits, unless impracticable. This Order contains daily limits instead of weekly limits because daily limits better protect against acute water quality effects and are necessary to prevent fish kills or mortality to aquatic organisms. Weekly limits could allow acute and chronic toxicity to occur over shorter periods (acute and chronic aquatic life criteria are typically expressed as one-hour and four-day averages).

4.3.4.2. **Mixing Zones and Dilution Credits.** The Discharger has not provided evidence to support a mixing zone; therefore, this order establishes WQBELs without dilution credits.

4.3.4.3. **Chronic Toxicity.** The following table shows the WQBEL calculations for chronic toxicity prior to U.S. EPA approval of the Toxicity Provisions. These calculations use the SIP methodology as guidance because U.S. EPA recommends that toxicity WQBELs be derived using a statistical approach (see Technical Support Document, section 5.4.2) and the SIP-based procedure is one such approach. When U.S. EPA approves the Toxicity Provisions, this Order implements chronic toxicity effluent limitations based on Toxicity Provisions section III.C.3.c.

Table F-8 WQBEL Calculations

| Pollutant | Chronic Toxicity |
|--|------------------|
| Units | TUc |
| Basis and Criteria type | BP Narrative |
| CTR Aquatic Life Criteria - Acute | --- |
| CTR Aquatic Life Criteria - Chronic | 1.0 |
| Water Effects ratio (WER) | 1 |
| Lowest WQO | 1.0 |
| Site Specific Translator - MDEL | --- |
| Site Specific Translator - AMEL | --- |
| Dilution Factor (D) (if applicable) | 0 |
| No. of samples per month | 4 |
| Aquatic life criteria analysis required? (Y/N) | Y |
| HH criteria analysis required? (Y/N) | N |
| | |
| Applicable Acute WQO | --- |
| Applicable Chronic WQO | 1.0 |
| HH criteria | --- |
| Background (Maximum Conc for Aquatic Life calc) | 0.0 |
| Background (Average Conc for Human Health calc) | --- |
| Is the pollutant on the 303d list (Y/N)? | N |
| | |
| ECA acute | No acute WQO |
| ECA chronic | 1.0 |
| ECA HH | --- |
| | |
| No. of data points <10 or at least 80% of data reported non detect? (Y/N) | N |
| Avg of effluent data points | 2.5 |

| | |
|--|--------------------|
| Std Dev of effluent data points | 3.6 |
| CV calculated | 1.4 |
| CV (Selected) - Final | 1.4 |
| | |
| ECA acute mult99 | 0.15 |
| ECA chronic mult99 | 0.27 |
| LTA acute | --- |
| LTA chronic | 0.27 |
| minimum of LTAs | 0.27 |
| | |
| AMEL mult95 | 2.3 |
| MDEL mult99 | 6.7 |
| AMEL (aq life) | 0.64 |
| MDEL(aq life) | 1.8 |
| | |
| MDEL/AMEL Multiplier | 2.9 |
| AMEL (human hlth) | --- |
| MDEL (human hlth) | --- |
| | |
| minimum of AMEL for Aq. life vs HH | 0.64 |
| minimum of MDEL for Aq. Life vs HH | 1.8 |
| | |
| Current limit in permit (30-day average) | 0.66 |
| Current limit in permit (daily) | 1.8 |
| | |
| Final limit - AMEL | 1.0 ^[1] |
| Final limit - MDEL | 1.8 |

Footnote:

^[1] In "EPA Regions 8, 9 and 10 Toxicity Training Tool" (January 2010), U.S. EPA recommends a median monthly limit of 1.0 TUc when the statistically-calculated AMEL is less than 1.0 TUc.

4.3.4.4. **Acute Toxicity.** Until the first day of the month following U.S. EPA approval of the Toxicity Provisions, this Order includes effluent limitations for acute toxicity based on Basin Plan Table 4-3.

4.3.4.5. **Total Residual Chlorine.** To calculate the water quality-based total residual chlorine effluent limits, this Order uses a simplified equation from SIP section 1.4 because background concentrations for total residual chlorine are assumed to be zero:

$$ECA = (D + 1) \times C$$

Where

ECA = Effluent Concentration Allowance (effluent limitation)

C = water quality objective (0.019 mg/L)

D = dilution factor (D = 0, no mixing zone has been established)

Therefore, the resulting WQBEL = ECA = $1 \times 0.019 = 0.019$ mg/L.

- 4.3.4.6. **E. Coli Bacteria.** This Order includes *E. coli* effluent limitations based on the *Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California – Part 3, Bacteria Provisions and a Water Quality Standards Variance Policy*, which requires these limitations for discharges to receiving waters with the water contact recreation beneficial use.

4.4. Discharge Requirement Considerations

- 4.4.1. **Anti-Backsliding.** This Order complies with the anti-backsliding provisions of CWA sections 402(o) and 303(d)(4), and 40 C.F.R. section 122.44(l), which generally require comparable effluent limitations in a reissued permit to be as stringent as those in the previous order. The requirements of this Order are at least as stringent as those in the previous order, except for copper, chronic toxicity, acute toxicity, oil and grease, and fecal coliform as discussed below.

This Order does not retain copper effluent limits from the previous order because data no longer indicate reasonable potential for this pollutant to exceed water quality objectives. This is consistent with State Water Board Order WQ 2001-16.

This Order does not retain the 11-sample median and 90th percentile effluent limits for acute toxicity from the previous order because Basin Plan Table 4-3 specifies three-sample median and single-sample acute toxicity limits for continuous discharges with a monitoring frequency of once per year. These revised acute toxicity effluent limits are more stringent than those from the previous order.

On the first day of the month following U.S. EPA approval of the Toxicity Provisions, new chronic toxicity effluent limits set forth in Section 4.5 of this Order will become effective. As of that same date, the chronic toxicity effluent limits and acute toxicity effluent limits in Table 2 and Section 4.4 of this Order, respectively, will no longer be in effect. This complies with anti-backsliding requirements because the new chronic toxicity effluent limits, based on the TST, are not comparable to the pre-approval chronic toxicity effluent limits, which were based on point estimates of chronic toxicity. Furthermore, effluent data do not indicate reasonable potential for acute toxicity. These findings are consistent with State Water Board Orders WQ 2001-16 and WQ 2001-06.

Order R2-2021-0019 removed the previous order's technology-based effluent limits for oil and grease. These changes complied with federal and state antidegradation policies as explained in Order R2-2021-0019.

This Order contains new *E. Coli* effluent limits based on the *Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California – Part 3, Bacteria Provisions and a Water Quality Standards Variance Policy*. The new effluent limits for *E. Coli* are not comparable to the previous order's limits for fecal coliform.

- 4.4.2. **Antidegradation.** This Order complies with the antidegradation provisions of 40 C.F.R. section 131.12 and State Water Board Resolution 68-16. Federal regulations at 40 C.F.R. section 131.12 require that state water quality standards include an antidegradation policy consistent with federal requirements. The State Water Board's "Statement of Policy with Respect to Maintaining High Quality of Waters in California" (Resolution 68-16) sets forth California's antidegradation policy. Where the federal antidegradation policy is applicable, the State Water Board has interpreted Resolution 68-16 to incorporate the federal antidegradation policy. A permitted discharge must be consistent with the antidegradation provision of 40 C.F.R. section 131.12 and State Water Board Resolution 68-16.

Where a receiving water is of higher quality than applicable water quality standards, the higher water quality must be maintained unless certain conditions are met. Any decrease in water quality must be consistent with the maximum benefit to the people of the State, not unreasonably affect any current or anticipated beneficial uses, and not result in lower water quality than that prescribed in the policies. Activities that produce an increased volume or concentration of waste and that discharge to existing high quality waters must meet waste discharge requirements that will "result in the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with maximum benefit to the people of the State will be maintained" (Resolution 68-16).

This Order does not authorize lowering water quality as compared to the level of discharge authorized in the previous order, which is the baseline by which to measure whether degradation will occur. This Order does not allow for an increased flow or a reduced level of treatment relative to the previous order. Although this Order includes *E. Coli* limits instead of fecal coliform limits, the new limits serve a comparable purpose and reflect the most up-to-date water quality objectives for protecting water contact recreation.

This Order imposes new aquatic toxicity requirements. The previous order required acute and chronic toxicity monitoring at a waste concentration of 100 percent effluent, imposed effluent limits on acute and chronic toxicity, and imposed TRE triggers on chronic toxicity. This Order instead requires chronic toxicity monitoring at the IWC (routine monitoring and MMEL compliance tests). This Order continues to implement numeric chronic toxicity limits at one hundred percent effluent but uses a different statistical method to determine compliance.

These new requirements serve a comparable purpose and reflect the most up-to-date water quality objectives for evaluating toxicity.

During the construction of its UV disinfection upgrade project, the Discharger may need to use chlorine as a disinfectant to ensure it complies with effluent limits for *E. Coli*. This Order contains a new total residual chlorine limit that will ensure aquatic life is protected in the unlikely event that the Discharger must temporarily use chlorine.

- 4.4.3. **Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based requirements implement minimum, applicable federal technology-based requirements. In addition, this Order contains more stringent effluent limitations as necessary to meet water quality standards. Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement CWA requirements.

This Order's WQBELs have been derived to implement water quality objectives that protect beneficial uses. The beneficial uses and water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 C.F.R. section 131.38. The procedures for calculating these WQBELs are based on the CTR, as implemented in accordance with the SIP, which U.S. EPA approved on May 18, 2000. U.S. EPA approved most Basin Plan beneficial uses and water quality objectives prior to May 30, 2000. Beneficial uses and water quality objectives submitted to U.S. EPA prior to May 30, 2000, but not approved by U.S. EPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 C.F.R. section 131.21(c)(1). U.S. EPA approved the remaining beneficial uses and water quality objectives, so they are also applicable water quality standards pursuant to 40 C.F.R. section 131.21(c)(2).

5. RATIONALE FOR RECEIVING WATER LIMITATIONS

The receiving water limitations in sections 5.1 and 5.2 of the Order are based on Basin Plan narrative and numeric water quality objectives. The receiving water limitation in section 5.3 of the Order requires compliance with federal and State water quality standards in accordance with the CWA and regulations adopted thereunder.

6. RATIONALE FOR PROVISIONS

- 6.1. **Standard Provisions.** Attachment D contains standard provisions that apply to all NPDES permits in accordance with 40 C.F.R. section 122.41 and additional conditions applicable to specific categories of permits in accordance with 40 C.F.R. section 122.42. The Discharger must comply with these provisions. The conditions set forth in 40 C.F.R. sections 122.41(a)(1) and (b) through (n) apply to

all state-issued NPDES permits and must be incorporated into permits either expressly or by reference.

In accordance with 40 C.F.R. section 123.25(a)(12), states may omit or modify conditions to impose more stringent requirements. Attachment G contains standard provisions that supplement the provisions in Attachment D. This Order omits the federal conditions that address enforcement authority specified in 40 C.F.R. sections 122.41(j)(5) and (k)(2) because the State's enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates Water Code section 13387(e) by reference.

6.2. Monitoring and Reporting Provisions. CWA section 308 and 40 C.F.R. sections 122.41(h), 122.41(j)-(l), 122.44(i), and 122.48 require that NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The MRP establishes monitoring, reporting, and recordkeeping requirements that implement federal and State requirements. For more background regarding these requirements, see Fact Sheet section 7.

6.3. Special Provisions

6.3.1. Reopener Provisions. These provisions are based on 40 C.F.R. sections 122.62 and 122.63 and allow modification of this Order and its effluent limitations as necessary in response to updated water quality objectives, regulations, or other new and relevant information that may become available in the future, and other circumstances as allowed by law.

6.3.2. Effluent and Receiving Water Characterization Study and Report. This Order does not include WQBELs for pollutants that do not demonstrate reasonable potential, but this provision requires the Discharger to evaluate monitoring data to verify that the reasonable potential analysis conclusions of this Order remain valid. This requirement is authorized pursuant to 40 C.F.R. section 122.41(h) and Water Code section 13383, and it is necessary to inform the next permit reissuance and to ensure that the Discharger takes timely steps in response to any unanticipated change in effluent quality during the term of this Order.

6.3.3. Pollutant Minimization Program. This provision is based on Basin Plan section 4.13.2 and SIP section 2.4.5.

6.3.4. Special Provisions for Publicly-Owned Treatment Works

6.3.4.1. Sludge and Biosolids Management. This provision is based on Basin Plan section 4.17. "Sludge" refers to the solid, semisolid, and liquid residue removed during primary, secondary, and advanced wastewater treatment processes. "Biosolids" refers to sludge that has been treated and may be beneficially reused.

- 6.3.4.2. **Collection System Management.** The Discharger's collection system is part of the Facility regulated through this Order. This provision requires compliance with Attachments D and G and states that these requirements may be satisfied by separately complying with State Water Board Order 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems, as amended by State Water Board Order WQ 2013-0058-EXEC and any subsequent order updating these requirements. These statewide WDRs require public agencies that own or operate sanitary sewer systems with one or more miles of sewer lines to enroll for coverage and comply with requirements to develop sanitary sewer management plans and report sanitary sewer overflows, among other provisions and prohibitions. The statewide WDRs contain requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows that are more extensive and, therefore, more stringent than the standard provisions in Attachments D and G. Compliance with the statewide WDRs will satisfy the corresponding requirements in Attachments D and G.
- 6.3.4.3. **Resource Recovery from Anaerobically Digestible Material.** Standard Operating Procedures are required for publicly-owned treatment works that accept hauled waste food, fats, oil, and grease for injection into anaerobic digesters. The development and implementation of Standard Operating Procedures for management of these materials is intended to allow the California Department of Resources Recycling and Recovery to exempt this activity from separate and redundant permitting programs. Some POTWs choose to accept organic material, such as waste food, fats, oils, and grease, into their anaerobic digesters to increase production of methane and other biogases for energy production and to prevent such materials from being discharged into the collection system and potentially causing sanitary sewer overflows. The California Department of Resources Recycling and Recovery has proposed to exempt publicly-owned treatment works from Process Facility/Transfer Station permit requirements when the same activity is regulated under WDRs or NPDES permits. The proposed exemption is restricted to anaerobically digestible materials that have been prescreened, slurried, processed, and conveyed in a closed system for co-digestion with regular sewage sludge. The exemption requires that the publicly-owned treatment works develop Standard Operating Procedures for proper handling, processing, tracking, and management of anaerobically digestible material.
- 6.3.4.4. **Chlorine Disinfection and Dechlorination System Installation.** This provision is necessary to ensure that if a chlorine disinfection and dechlorination system is used during the UV disinfection system upgrade project, it is installed correctly to operate effectively and reliably. MRP Table E-3 requires total residual chlorine monitoring if the Discharger uses chlorine as a disinfectant.

7. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

The following provides the rationale for the monitoring and reporting requirements in the MRP.

7.1. Monitoring Requirements Rationale

- 7.1.1. **Influent Monitoring.** Influent flow monitoring is necessary to understand Facility operations and to evaluate compliance with Discharge Prohibition 3.3, which prohibits average dry weather influent flow greater than 4.0 MGD. Influent BOD and TSS monitoring is necessary to evaluate compliance with this Order's 85 percent removal requirements.
- 7.1.2. **Effluent Monitoring.** Effluent flow monitoring at Monitoring Location EFF-001 is necessary to understand Facility operations. Monitoring for the other parameters specified in the MRP is necessary to evaluate compliance with this Order's effluent limitations and to conduct future reasonable potential analyses.
- 7.1.3. **Toxicity Testing.** Toxicity tests are necessary to evaluate compliance with this Order's effluent limitations. Chronic toxicity tests are also necessary to evaluate whether Toxicity Reduction Evaluations are needed and to conduct future reasonable potential analyses.

The Discharger conducted a chronic toxicity species sensitive screening during the period from May through July 2016. The screening satisfies the Toxicity Provisions' minimum screening requirements because the data were analyzed using the TST, and test species included one vertebrate, one invertebrate, and one aquatic plant/algae from Table 1 of Toxicity Provisions section III.B.2. This Order retains the requirement to use the water flea for chronic toxicity tests because the 2016 screening and previous order identified it as the most sensitive species.

- 7.1.4. **Receiving Water Monitoring.** Receiving water monitoring is necessary to evaluate compliance with receiving water limitations. Monitoring for hardness and salinity is necessary to determine applicable water quality objectives. Monitoring for pH and temperature is necessary to provide data to translate the Basin Plan's un-ionized ammonia water quality objectives into total ammonia criteria. Monitoring for total ammonia and priority pollutants is needed to conduct future reasonable potential analyses.
- 7.1.5. **Other Monitoring Requirements.** Pursuant to CWA section 308, U.S. EPA requires some dischargers to participate in a Discharge Monitoring Report-Quality Assurance (DMR-QA) Study Program that evaluates the analytical abilities of laboratories that perform or support NPDES permit-required monitoring. The program applies to discharger laboratories and contract laboratories, and evaluates each laboratory's ability to analyze wastewater samples to produce quality data that ensure the integrity of the NPDES program. There are two options to comply: (1) the Discharger may obtain and

analyze DMR-QA samples, or (2) pursuant to a waiver U.S. EPA issued to the State Water Board, the Discharger may submit results from the most recent Water Pollution Performance Evaluation Study. MRP section 1.4 requires the Discharger to ensure that the results of the DMR-QA Study or most recent Water Pollution Performance Evaluation Study are submitted to the State Water Board, which forwards the results to U.S. EPA.

7.2. Monitoring Requirements Summary. The table below summarizes routine monitoring requirements. This table is for informational purposes only. The actual requirements are specified in the MRP and elsewhere in this Order.

Table F-9. Monitoring Requirements Summary

| Parameter | Influent INF-001 ^[1] | Effluent EFF-001 ^[1] | Receiving Water RSW-001, RSW-002, RSW-003, and RSW-004 ^[1] |
|--|------------------------------------|------------------------------------|---|
| Flow | 1/Day | Continuous/D | --- |
| BOD | 1/Week | 1/Week | --- |
| TSS | 1/Week | 1/Week | --- |
| pH | --- | Continuous/D | 1/Quarter |
| Temperature | --- | 1/Day | 1/Quarter |
| Turbidity | --- | 1/Day | --- |
| <i>E. Coli</i> Bacteria | --- | 2/Week | --- |
| Dissolved Oxygen | --- | --- | 1/Quarter |
| Dissolved Sulfide | --- | --- | 1/Quarter |
| Chronic Toxicity (Prior to U.S. EPA Approval of Toxicity Provisions) | --- | 2/Year | --- |
| Chronic Toxicity (After U.S. EPA Approval of Toxicity Provisions) | --- | 1/Quarter | --- |
| Acute Toxicity | --- | 1/Year ^[2] | --- |
| Ammonia, Total | --- | 1/Week | 1/Quarter |
| Chlorine, Total Residual ^{[3],[4]} | --- | 1/Day | --- |
| Hardness | --- | --- | 1/Quarter |
| Salinity | --- | --- | 1/Quarter |
| Standard Observations | --- | 1/Month | 1/Quarter |
| Priority Pollutants ^[5] | --- | 1/Year | Once ^[6] |

Footnotes:

^[1] The MRP defines these sampling locations and frequencies.

^[2] As of the first day of the month following U.S. EPA approval of the Toxicity Provisions, acute toxicity sampling will no longer be required.

^[3] Total residual chlorine monitoring is required if the discharger commences use of a chlorine disinfection and dechlorination system pursuant to Provision 6.3.4.4 of this Order for the duration of its use.

^[4] As of the first day of the month following U.S. EPA approval of Resolution R2-2020-0031, if the Discharger uses chlorine as a disinfectant, the Discharger must collect effluent total residual chlorine grab samples at the top of each hour during its standard hours of operation, 5:30am to 5:30pm daily.

^[5] Priority pollutants are listed in Attachment G, Table B. This monitoring is required by provision 6.3.2 of the Order.

^[6] This monitoring is required only at Monitoring Location RSW-001.

8. PUBLIC PARTICIPATION

The Regional Water Board considered the issuance of WDRs that will serve as an NPDES permit for the Facility. As a step in the WDR adoption process, Regional Water Board staff developed tentative WDRs and encouraged public participation in the WDR adoption process.

8.1. Notification of Interested Parties. The Regional Water Board notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge, and provided an opportunity to submit written comments and recommendations. The public had access to the agenda and any changes in dates and locations through the [Regional Water Board's website](https://waterboards.ca.gov/sanfranciscobay) (waterboards.ca.gov/sanfranciscobay).

8.2. Written Comments. Interested persons were invited to submit written comments concerning the tentative WDRs as explained through the notification process. Comments were to be submitted either in person or by mail to the Executive Office at the Regional Water Board at 1515 Clay Street, Suite 1400, Oakland, California 94612, to the attention of Kerry O'Connor.

For full staff response and Regional Water Board consideration, the written comments were due at the Regional Water Board office by 5:00 p.m. on September 19, 2022.

8.3. Public Hearing. The Regional Water Board held a public hearing on the tentative WDRs during its meeting at the following date and time:

Date: October 12, 2022
Time: 9:00 a.m.

Contact: Kerry O'Connor, (510) 622-2465,
Kerry.OConnor@waterboards.ca.gov

Interested persons were provided notice of the hearing and information on how to participate. At the public hearing, the Regional Water Board heard testimony pertinent to the discharge, WDRs, and permit. For accuracy of the record, important testimony was requested to be in writing.

If the date or venue of any public hearing changes, the changes will be reflected in the most current agenda posted on the [Regional Water Board's website](https://waterboards.ca.gov/sanfranciscobay) (waterboards.ca.gov/sanfranciscobay).

8.4. Reconsideration of Waste Discharge Requirements. Any person aggrieved by this Regional Water Board action may petition the State Water Board to review the action in accordance with Water Code section 13320 and California Code of Regulations, title 23, sections 2050. The State Water Board must receive the petition at the following address within 30 calendar days of the date of Regional Water Board action:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

A petition may also be filed by email at waterqualitypetitions@waterboards.ca.gov.

For instructions on how to file a water quality petition for review, see the [Water Board's petition instructions](https://waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instr.shtml) (waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instr.shtml).

- 8.5. Information and Copying.** The Report of Waste Discharge, related supporting documents, and comments received are on file and may be inspected at the Regional Water Board address above at any time online or by contacting the Regional Water Board's custodian of records. Document copying may be arranged by calling (510) 622-2300.
- 8.6. Register of Interested Persons.** Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference the Facility, and provide a name, address, and phone number.
- 8.7. Additional Information.** Requests for additional information or questions regarding this Order should be directed to Kerry O'Connor, (510) 622-2465, Kerry.OConnor@waterboards.ca.gov.

**ATTACHMENT G - REGIONAL STANDARD PROVISIONS,
AND MONITORING AND REPORTING REQUIREMENTS
(SUPPLEMENT TO ATTACHMENT D)**

Contents

| | | |
|-----------|--|-------------|
| 1. | STANDARD PROVISIONS – PERMIT COMPLIANCE | G-2 |
| 2. | STANDARD PROVISIONS – PERMIT ACTION – NOT SUPPLEMENTED | G-4 |
| 3. | STANDARD PROVISIONS – MONITORING | G-4 |
| 4. | STANDARD PROVISIONS – RECORDS | G-8 |
| 5. | STANDARD PROVISIONS – REPORTING | G-10 |
| 6. | STANDARD PROVISIONS – ENFORCEMENT – NOT SUPPLEMENTED | G-16 |
| 7. | ADDITIONAL PROVISIONS – NOTIFICATION LEVELS – NOT SUPPLEMENTED..... | G-16 |
| 8. | DEFINITIONS – ADDITION TO ATTACHMENT D | G-16 |

**ATTACHMENT G – REGIONAL STANDARD PROVISIONS,
AND MONITORING AND REPORTING REQUIREMENTS
(SUPPLEMENT TO ATTACHMENT D)**

APPLICABILITY

This document supplements the requirements of Federal Standard Provisions (Attachment D). For clarity, these provisions are arranged using the same headings as those used in Attachment D.

1. STANDARD PROVISIONS – PERMIT COMPLIANCE

1.1. Duty to Comply – Not Supplemented

1.2. Need to Halt or Reduce Activity Not a Defense – Not Supplemented

1.3. Duty to Mitigate – Supplement to Attachment D, Provision 1.3.

1.3.1. Contingency Plan. The Discharger shall maintain a Contingency Plan as prudent in accordance with current facility emergency planning. The Contingency Plan shall describe procedures to ensure that existing facilities remain in, or are rapidly returned to, operation in the event of a process failure or emergency incident, such as employee strike, strike by suppliers of chemicals or maintenance services, power outage, vandalism, earthquake, or fire. The Discharger may combine the Contingency Plan and Spill Prevention Plan (see Provision 1.3.2, below) into one document. In accordance with Regional Water Board Resolution No. 74-10, discharge in violation of the permit where the Discharger has failed to develop and implement a Contingency Plan as described below may be the basis for considering the discharge a willful and negligent violation of the permit pursuant to California Water Code section 13387. The Contingency Plan shall, at a minimum, provide for the following:

- 1.3.1.1. Sufficient personnel for continued facility operation and maintenance during employee strikes or strikes against contractors providing services;
- 1.3.1.2. Maintenance of adequate chemicals or other supplies, and spare parts necessary for continued facility operations;
- 1.3.1.3. Emergency standby power;
- 1.3.1.4. Protection against vandalism;
- 1.3.1.5. Expedition action to repair failures of, or damage to, equipment, including any sewer lines;
- 1.3.1.6. Reporting of spills and discharges of untreated or inadequately treated wastes, including measures taken to clean up the effects of such discharges; and

- 1.3.1.7. Maintenance, replacement, and surveillance of physical condition of equipment and facilities, including any sewer lines.
- 1.3.2. **Spill Prevention Plan.** The Discharger shall maintain a Spill Prevention Plan to prevent accidental discharges and to minimize the effects of any such discharges. The Spill Prevention Plan shall do the following:
 - 1.3.2.1. Identify the possible sources of accidental discharge, untreated or partially-treated waste bypass, and polluted drainage;
 - 1.3.2.2. State when current facilities and procedures became operational and evaluate their effectiveness; and
 - 1.3.2.3. Predict the effectiveness of any proposed facilities and procedures and provide an implementation schedule with interim and final dates when the proposed facilities and procedures will be constructed, implemented, or operational.
- 1.4. **Proper Operation and Maintenance** – Supplement to Attachment D, Provision 1.4
 - 1.4.1. **Operation and Maintenance Manual.** The Discharger shall maintain an Operation and Maintenance Manual to provide the plant and regulatory personnel with a source of information describing all equipment, recommended operational strategies, process control monitoring, and maintenance activities. To remain a useful and relevant document, the Operation and Maintenance Manual shall be kept updated to reflect significant changes in treatment facility equipment and operational practices. The Operation and Maintenance Manual shall be maintained in usable condition and be available for reference and use by all relevant personnel and Regional Water Board staff.
 - 1.4.2. **Wastewater Facilities Status Report.** The Discharger shall maintain a Wastewater Facilities Status Report and regularly review, revise, or update it, as necessary. This report shall document how the Discharger operates and maintains its wastewater collection, treatment, and disposal facilities to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary to provide adequate and reliable transport, treatment, and disposal of all wastewater from both existing and planned future wastewater sources under the Discharger's service responsibilities.
 - 1.4.3. **Proper Supervision and Operation of Publicly-Owned Treatment Works (POTWs).** POTWs shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to Title 23, section 3680, of the California Code of Regulations.

1.5. Property Rights – Not Supplemented

1.6. Inspection and Entry – Not Supplemented

1.7. Bypass – Not Supplemented

1.8. Upset – Not Supplemented

1.9. Other – Addition to Attachment D

- 1.9.1. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or nuisance as defined by California Water Code section 13050.
- 1.9.2. Collection, treatment, storage, and disposal systems shall be operated in a manner that precludes public contact with wastewater. If public contact with wastewater could reasonably occur on public property, warning signs shall be posted.
- 1.9.3. If the Discharger submits a timely and complete Report of Waste Discharge for permit reissuance, this permit shall continue in force and effect until the permit is reissued or the Regional Water Board rescinds the permit.

2. STANDARD PROVISIONS – PERMIT ACTION – NOT SUPPLEMENTED

3. STANDARD PROVISIONS – MONITORING

3.1. Sampling and Analyses – Supplement to Attachment D, Provisions 3.1 and 3.2

- 3.1.1. **Certified Laboratories.** Water and waste analyses shall be performed by a laboratory certified for these analyses in accordance with California Water Code section 13176.
- 3.1.2. **Minimum Levels.** For the 126 priority pollutants, the Discharger should use the analytical methods listed in Table B unless the Monitoring and Reporting Program (MRP, Attachment E) requires a particular method or minimum level (ML). All monitoring instruments and equipment shall be properly calibrated and maintained to ensure accuracy of measurements.
- 3.1.3. **Monitoring Frequency.** The MRP specifies the minimum sampling and analysis schedule.
 - 3.1.3.1. **Sample Collection Timing**
 - 3.1.3.1.1. The Discharger shall collect influent samples on varying days selected at random and shall not include any plant recirculation or other sidestream wastes, unless otherwise stipulated in the MRP. The Executive Officer may approve an alternative influent sampling plan if it is representative of plant influent and complies with all other permit requirements.

- 3.1.3.1.2. The Discharger shall collect effluent samples on days coincident with influent sampling, unless otherwise stipulated by the MRP. If influent sampling is not required, the Discharger shall collect effluent samples on varying days selected at random, unless otherwise stipulated in the MRP. The Executive Officer may approve an alternative effluent sampling plan if it is representative of plant discharge and in compliance with all other permit requirements.
- 3.1.3.1.3. The Discharger shall collect effluent grab samples during periods of daytime maximum peak flows (or peak flows through secondary treatment units for facilities that recycle effluent).
- 3.1.3.1.4. Effluent sampling for conventional pollutants shall occur on at least one day of any multiple-day bioassay the MRP requires. During the course of the bioassay, on at least one day, the Discharger shall collect and retain samples of the discharge. In the event that a bioassay result does not comply with effluent limitations, the Discharger shall analyze the retained samples for pollutants that could be toxic to aquatic life and for which it has effluent limitations.
- 3.1.3.1.4.1. The Discharger shall perform bioassays on final effluent samples; when chlorine is used for disinfection, bioassays shall be performed on effluent after chlorination and dechlorination; and
- 3.1.3.1.4.2. The Discharger shall analyze for total ammonia nitrogen and calculate the amount of un-ionized ammonia whenever test results fail to meet effluent limitations.

3.1.3.2. **Conditions Triggering Accelerated Monitoring**

- 3.1.3.2.1. **Average Monthly Effluent Limitation Exceedance.** If the results from two consecutive samples of a constituent monitored in a particular month exceed the average monthly effluent limitation for any parameter (or if the required sampling frequency is once per month or less and the monthly sample exceeds the average monthly effluent limitation), the Discharger shall, within 24 hours after the results are received, increase its sampling frequency to daily until the results from the additional sampling show that the parameter complies with the average monthly effluent limitation.
- 3.1.3.2.2. **Maximum Daily Effluent Limitation Exceedance.** If a sample result exceeds a maximum daily effluent limitation, the Discharger shall, within 24 hours after the result is received, increase its sampling frequency to daily until the results from two samples collected on consecutive days show compliance with the maximum daily effluent limitation.
- 3.1.3.2.3. **Acute Toxicity.** If final or intermediate results of an acute bioassay indicate a violation or threatened violation (e.g., the percentage of surviving test organisms of any single acute bioassay is less than

70 percent), the Discharger shall initiate a new test as soon as practical or as described in applicable State Water Board plan provisions that become effective after adoption of these Regional Standard Provisions. The Discharger shall investigate the cause of the mortalities and report its findings in the next self-monitoring report.

- 3.1.3.2.4. **Chlorine.** The Discharger shall calibrate chlorine residual analyzers against grab samples as frequently as necessary to maintain accurate control and reliable operation. If an effluent violation is detected, the Discharger shall collect grab samples at least every 30 minutes until compliance with the limitation is achieved, unless the Discharger monitors chlorine residual continuously. In such cases, the Discharger shall continue to conduct continuous monitoring.
- 3.1.3.2.5. **Bypass.** Except as indicated below, if a Discharger bypasses any portion of its treatment facility, it shall monitor flows and collect samples at affected discharge points and analyze samples for all constituents with effluent limitations on a daily basis for the duration of the bypass. The Discharger need not accelerate chronic toxicity monitoring. The Discharger also need not collect and analyze samples for mercury, dioxin-TEQ, and PCBs after the first day of the bypass. The Discharger may satisfy the accelerated acute toxicity monitoring requirement by conducting a flow-through test or static renewal test that captures the duration of the bypass (regardless of the method specified in the MRP). If bypassing disinfection units only, the Discharger shall only monitor bacteria indicators daily.
- 3.1.3.2.5.1. **Bypass for Essential Maintenance.** If a Discharger bypasses a treatment unit for essential maintenance pursuant to Attachment D section 1.7.2, the Executive Officer may reduce the accelerated monitoring requirements above if the Discharger (i) monitors effluent at affected discharge points on the first day of the bypass for all constituents with effluent limitations, except chronic toxicity; and (ii) identifies and implements measures to ensure that the bypass will continue to comply with effluent limitations.
- 3.1.3.2.5.2. **Approved Wet Weather Bypasses.** If a Discharger bypasses a treatment unit or permitted outfall during wet weather with Executive Officer approval pursuant to Attachment D section 1.7.4, the Discharger shall monitor flows and collect and retain samples for affected discharge points on a daily basis for the duration of the bypass. The Discharger shall analyze daily for TSS using 24 hour composites (or more frequent increments) and for bacteria indicators with effluent limitations using grab samples. If TSS exceeds 45 mg/L in any composite sample, the Discharger shall also analyze daily the retained samples for all other constituents with effluent limitations, except oil and grease, mercury, PCBs, dioxin-TEQ, and acute and chronic toxicity.

Additionally, at least once each year, the Discharger shall analyze the retained samples for one approved bypass for all other constituents with effluent limitations, except oil and grease, mercury, PCBs, dioxin-TEQ, and acute and chronic toxicity. This monitoring shall be in addition to the minimum monitoring specified in the MRP.

3.2. Standard Observations – Addition to Attachment D

3.2.1. Receiving Water Observations. The following requirements only apply when the MRP requires standard observations of receiving waters. Standard observations shall include the following:

- 3.2.1.1. Floating and Suspended Materials (e.g., oil, grease, algae, and other macroscopic particulate matter)** — presence or absence, source, and size of affected area.
- 3.2.1.2. Discoloration and Turbidity** — color, source, and size of affected area.
- 3.2.1.3. Odor** — presence or absence, characterization, source, and distance of travel.
- 3.2.1.4. Beneficial Water Use** — estimated number of water-associated waterfowl or wildlife, fisherpeople, and other recreational activities.
- 3.2.1.5. Hydrographic Condition** — time and height of high and low tides (corrected to nearest National Oceanic and Atmospheric Administration location for the sampling date and time).
- 3.2.1.6. Weather Conditions** — wind direction, air temperature, and total precipitation during five days prior to observation.

3.2.2. Wastewater Effluent Observations. The following requirements only apply when the MRP requires standard observations of wastewater effluent. Standard observations shall include the following:

- 3.2.2.1. Floating and Suspended Material of Wastewater Origin** (e.g., oil, grease, algae, and other macroscopic particulate matter) — presence or absence.
- 3.2.2.2. Odor** — presence or absence, characterization, source, distance of travel, and wind direction.

3.2.3. Beach and Shoreline Observations. The following requirements only apply when the MRP requires standard observations of beaches or shorelines. Standard observations shall include the following:

- 3.2.3.1. Material of Wastewater Origin** — presence or absence, description of material, estimated size of affected area, and source.

3.2.3.2. **Beneficial Use** — estimate of number of people participating in recreational water contact, non-water contact, and fishing activities.

3.2.4. **Waste Treatment and/or Disposal Facility Periphery Observations.**
The following requirements only apply when the MRP requires standard observations of the periphery of waste treatment or disposal facilities. Standard observations shall include the following:

3.2.4.1. **Odor** — presence or absence, characterization, source, and distance of travel.

3.2.4.2. **Weather Conditions** — wind direction and estimated velocity.

4. STANDARD PROVISIONS – RECORDS

4.1. Records to be Maintained – Supplement to Attachment D, Provision 4.1

The Discharger shall maintain records in a manner and at a location (e.g., the wastewater treatment plant or the Discharger's offices) such that the records are accessible to Regional Water Board staff. The minimum retention period specified in Attachment D, Provision 4, shall be extended during the course of any unresolved litigation regarding permit-related discharges, or when requested by Regional Water Board or U.S. EPA, Region IX, staff.

A copy of the permit shall be maintained at the discharge facility and be available at all times to operating personnel.

4.2. Records of Monitoring – Supplement to Attachment D, Provision 4.2

Monitoring records shall include the following:

4.2.1. **Analytical Information.** Records shall include analytical method detection limits, minimum levels, reporting levels, and related quantification parameters.

4.2.2. **Disinfection Process.** For the disinfection process, records shall include the following:

4.2.2.1. For bacteriological analyses:

4.2.2.1.1. Wastewater flow rate at the time of sample collection; and

4.2.2.1.2. Required statistical parameters for cumulative bacterial values (e.g., moving median or geometric mean for the number of samples or sampling period identified in the MRP).

4.2.2.2. For the chlorination process (when chlorine is used for disinfection), at least daily average values for the following:

- 4.2.2.2.1. Chlorine residual of treated wastewater as it enters the chlorine contact basin (mg/L);
- 4.2.2.2.2. Chlorine dosage (kg/day); and
- 4.2.2.2.3. Dechlorination chemical dosage (kg/day).
- 4.2.3. **Wastewater Treatment Process Solids.** For each treatment unit process that involves solids removal from the wastewater stream, records shall include the following:
 - 4.2.3.1. Total volume or mass of solids removed from each collection unit (e.g., grit, skimmings, undigested biosolids, or combination) for each calendar month or other time period as appropriate, but not to exceed annually; and
 - 4.2.3.2. Final disposition of such solids (e.g., landfill, other subsequent treatment unit).
- 4.2.4. **Treatment Process Bypasses.** For all treatment process bypasses, including wet weather blending, records shall include the following:
 - 4.2.4.1. Chronological log of treatment process bypasses;
 - 4.2.4.2. Identification of treatment processes bypassed;
 - 4.2.4.3. Beginning and ending dates and times of bypasses;
 - 4.2.4.4. Bypass durations;
 - 4.2.4.5. Estimated bypass volumes; and
 - 4.2.4.6. Description of, or reference to other reports describing, the bypasses, their cause, the corrective actions taken (except for wet weather blending explicitly approved within the permit and in compliance with any related permit conditions), and any additional monitoring conducted.
- 4.2.5. **Treatment Plant Overflows.** The Discharger shall retain a chronological log of overflows at the treatment plant, including the headworks and all units and appurtenances downstream, and records supporting the information provided in accordance with Provision 5.5.2, below.

4.3. Claims of Confidentiality – Not Supplemented

5. STANDARD PROVISIONS – REPORTING

5.1. Duty to Provide Information – Not Supplemented

5.2. Signatory and Certification Requirements – Not Supplemented

5.3. Monitoring Reports – Supplement to Attachment D, Provision 5.3

5.3.1. Self-Monitoring Reports. For each reporting period established in the MRP, the Discharger shall submit a self-monitoring report to the Regional Water Board in accordance with the requirements listed in the MRP and below:

5.3.1.1. Transmittal Letter. Each self-monitoring report shall be submitted with a transmittal letter that includes the following:

- 5.3.1.1.1. Identification of all violations of effluent limitations or other waste discharge requirements found during the reporting period;
- 5.3.1.1.2. Details regarding the violations, such as parameters, magnitude, test results, frequency, and dates;
- 5.3.1.1.3. Causes of the violations;
- 5.3.1.1.4. Corrective actions taken or planned to resolve violations and prevent recurrences, and dates or time schedules for implementation (the Discharger may refer to previously submitted reports that address the corrective actions);
- 5.3.1.1.5. Explanation for any data invalidation. Data should not be submitted in a self-monitoring report if it does not meet quality assurance/quality control standards. However, if the Discharger wishes to invalidate a measurement after submitting it in a self-monitoring report, the Discharger shall identify the measurement suspected to be invalid and state the Discharger's intent to submit, within 60 days, a formal request to invalidate the measurement. The formal request shall include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports invalidation (e.g., laboratory sheet, log entry, test results), and a discussion of the corrective actions taken or planned (with a time schedule for completion) to prevent recurrence of the sampling or measurement problem;
- 5.3.1.1.6. Description of blending, if any. If the Discharger blends, it shall describe the duration of blending events and certify whether the blending complied with all conditions for blending;

- 5.3.1.1.7. Description of other bypasses, if any. If the Discharger bypasses any treatment units (other than blending), it shall describe the duration of the bypasses and effluent quality during those times; and
- 5.3.1.1.8. Signature. The transmittal letter shall be signed in accordance with Attachment D, Provision 5.2.
- 5.3.1.2. **Compliance Evaluation Summary.** Each self-monitoring report shall include a compliance evaluation summary that addresses each parameter for which the permit specifies effluent limitations, the number of samples taken during the monitoring period, and the number of samples that exceed the effluent limitations.
- 5.3.1.3. **More Frequent Monitoring.** If the Discharger monitors any pollutant more frequently than required by the MRP, the Discharger shall include the results of such monitoring in the calculation and reporting of the data submitted in the self-monitoring report.
- 5.3.1.4. **Analysis Results**
 - 5.3.1.4.1. **Tabulation.** Each self-monitoring report shall include tabulations of all required analyses and observations, including parameters, dates, times, sample stations, types of samples, test results, method detection limits, method minimum levels, and method reporting levels (if applicable), signed by the laboratory director or other responsible official.
 - 5.3.1.4.2. **Multiple Samples.** Unless the MRP specifies otherwise, when determining compliance with effluent limitations (other than instantaneous effluent limitations) and more than one sample result is available, the Discharger shall compute the arithmetic mean. If the data set contains one or more results that are “Detected, but Not Quantified (DNQ) or “Not Detected” (ND), the Discharger shall instead compute the median in accordance with the following procedure:
 - 5.3.1.4.2.1. The data set shall be ranked from low to high, reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - 5.3.1.4.2.2. The median of the data set shall be determined. If the data set has an odd number of data points, the median is the middle value. If the data set has an even number of data points, the median is the average of the two values around the middle, unless one or both of these values is ND or DNQ, in which case the median shall be the lower of the two results (where DNQ is lower than a quantified value and ND is lower than DNQ).

5.3.1.4.3. **Duplicate Samples.** The Discharger shall report the average of duplicate sample analyses when reporting for a single sample result (or the median if one or more of the duplicates is DNQ or ND [see Provision 5.3.1.4.2, above]). For bacteria indicators, the Discharger shall report the geometric mean of the duplicate analyses.

5.3.1.4.4. **Dioxin-TEQ.** The Discharger shall report for each dioxin and furan congener the analytical results of effluent monitoring, including the reporting level, the method detection limit, and the measured concentration. The Discharger shall report all measured values of individual congeners, including data qualifiers. When calculating dioxin-TEQ, the Discharger shall set congener concentrations below the minimum levels (MLs) to zero. The Discharger shall calculate and report dioxin-TEQ using the following formula, where the MLs, toxicity equivalency factors (TEFs), and bioaccumulation equivalency factors (BEFs) are as provided in Table A:

$$\text{Dioxin-TEQ} = \sum (C_x \times \text{TEF}_x \times \text{BEF}_x)$$

where: C_x = measured or estimated concentration of congener x
 TEF_x = toxicity equivalency factor for congener x
 BEF_x = bioaccumulation equivalency factor for congener x

Table A
Minimum Levels, Toxicity Equivalency Factors,
and Bioaccumulation Equivalency Factors

| Dioxin or Furan Congener | Minimum Level (pg/L) | 2005 Toxicity Equivalency Factor (TEF) | Bioaccumulation Equivalency Factor (BEF) |
|--------------------------|----------------------|--|--|
| 2,3,7,8-TCDD | 10 | 1.0 | 1.0 |
| 1,2,3,7,8-PeCDD | 50 | 1.0 | 0.9 |
| 1,2,3,4,7,8-HxCDD | 50 | 0.1 | 0.3 |
| 1,2,3,6,7,8-HxCDD | 50 | 0.1 | 0.1 |
| 1,2,3,7,8,9-HxCDD | 50 | 0.1 | 0.1 |
| 1,2,3,4,6,7,8-HpCDD | 50 | 0.01 | 0.05 |
| OCDD | 100 | 0.0003 | 0.01 |
| 2,3,7,8-TCDF | 10 | 0.1 | 0.8 |
| 1,2,3,7,8-PeCDF | 50 | 0.03 | 0.2 |
| 2,3,4,7,8-PeCDF | 50 | 0.3 | 1.6 |
| 1,2,3,4,7,8-HxCDF | 50 | 0.1 | 0.08 |
| 1,2,3,6,7,8-HxCDF | 50 | 0.1 | 0.2 |
| 1,2,3,7,8,9-HxCDF | 50 | 0.1 | 0.6 |
| 2,3,4,6,7,8-HxCDF | 50 | 0.1 | 0.7 |
| 1,2,3,4,6,7,8-HpCDF | 50 | 0.01 | 0.01 |
| 1,2,3,4,7,8,9-HpCDF | 50 | 0.01 | 0.4 |
| OCDF | 100 | 0.0003 | 0.02 |

- 5.3.1.5. **Results Not Yet Available.** The Discharger shall make all reasonable efforts to obtain analytical data for required parameter sampling in a timely manner. Certain analyses may require additional time to complete analytical processes and report results. In these cases, the Discharger shall describe the circumstances in the self-monitoring report and include the data for these parameters and relevant discussions of any violations in the next self-monitoring report due after the results are available.
- 5.3.1.6. **Annual Self-Monitoring Reports.** By the date specified in the MRP, the Discharger shall submit an annual self-monitoring report covering the previous calendar year. The report shall contain the following:
- 5.3.1.6.1. Comprehensive discussion of treatment plant performance, including documentation of any blending or other bypass events, and compliance with the permit. This discussion shall include any corrective actions taken or planned, such as changes to facility equipment or operation practices that may be needed to achieve compliance, and any other actions taken or planned that are intended to improve the performance and reliability of wastewater collection, treatment, or disposal practices;
 - 5.3.1.6.2. List of approved analyses, including the following:
 - 5.3.1.6.2.1. List of analyses for which the Discharger is certified;
 - 5.3.1.6.2.2. List of analyses performed for the Discharger by a separate certified laboratory (copies of reports signed by the laboratory director of that laboratory need not be submitted but shall be retained onsite); and
 - 5.3.1.6.2.3. List of “waived” analyses, as approved;
 - 5.3.1.6.3. Plan view drawing or map showing the Discharger’s facility, flow routing, and sampling and observation station locations; and
 - 5.3.1.6.4. Results of facility report reviews. The Discharger shall regularly review, revise, and update, as necessary, the Operation and Maintenance Manual, Contingency Plan, Spill Prevention Plan, and Wastewater Facilities Status Report so these documents remain useful and relevant to current practices. At a minimum, reviews shall be conducted annually. The Discharger shall describe or summarize its review and evaluation procedures, recommended or planned actions, and estimated time schedule for implementing these actions. The Discharger shall complete changes to these documents to ensure that they remain up-to-date.

5.4. Compliance Schedules – Not supplemented

5.5. Twenty-Four Hour Reporting – Supplement to Attachment D, Provision 5.5

5.5.1. Oil or Other Hazardous Material Spills

- 5.5.1.1. Within 24 hours of becoming aware of a spill of oil or other hazardous material not contained onsite and completely cleaned up, the Discharger shall report as follows:
 - 5.5.1.1.1. If the spill exceeds reportable quantities for hazardous materials listed in 40 C.F.R. part 302. The Discharger shall call the California Office of Emergency Services (800 852-7550).
 - 5.5.1.1.2. If the spill does not exceed reportable quantities for hazardous materials listed in 40 C.F.R., part 302, the Discharger shall call the Regional Water Board (510-622-2369).
- 5.5.1.2. The Discharger shall submit a written report to the Regional Water Board within five working days following either of the above telephone notifications unless directed otherwise by Regional Water Board staff. A report submitted electronically is acceptable. The written report shall include the following:
 - 5.5.1.2.1. Date and time of spill, and duration if known;
 - 5.5.1.2.2. Location of spill (street address or description of location);
 - 5.5.1.2.3. Nature of material spilled;
 - 5.5.1.2.4. Quantity of material spilled;
 - 5.5.1.2.5. Receiving water body affected, if any;
 - 5.5.1.2.6. Cause of spill;
 - 5.5.1.2.7. Estimated size of affected area;
 - 5.5.1.2.8. Observed impacts to receiving waters (e.g., oil sheen, fish kill, water discoloration);
 - 5.5.1.2.9. Corrective actions taken to contain, minimize, or clean up the spill;
 - 5.5.1.2.10. Future corrective actions planned to prevent recurrence, and implementation schedule; and
 - 5.5.1.2.11. Persons or agencies notified.

5.5.2. Unauthorized Municipal Wastewater Treatment Plant Discharges¹

5.5.2.1. **Two-Hour Notification.** For any unauthorized discharge that enters a drainage channel or surface water, the Discharger shall, as soon as possible, but not later than two hours after becoming aware of the discharge, notify the California Office of Emergency Services (800-852-7550) and the local health officer or director of environmental health with jurisdiction over the affected water body. Notification shall include the following:

- 5.5.2.1.1. Incident description and cause;
- 5.5.2.1.2. Location of threatened or involved waterways or storm drains;
- 5.5.2.1.3. Date and time that the unauthorized discharge started;
- 5.5.2.1.4. Estimated quantity and duration of the unauthorized discharge (to the extent known), and estimated amount recovered;
- 5.5.2.1.5. Level of treatment prior to discharge (e.g., raw wastewater, primary-treated wastewater, or undisinfected secondary-treated wastewater); and
- 5.5.2.1.6. Identity of person reporting the unauthorized discharge.

5.5.2.2. **Five-Day Written Report.** Within five business days following the two-hour notification, the Discharger shall submit a written report that includes, in addition to the information listed in Provision 5.5.2.1, above, the following:

- 5.5.2.2.1. Methods used to delineate the geographical extent of the unauthorized discharge within receiving waters;
- 5.5.2.2.2. Efforts implemented to minimize public exposure to the unauthorized discharge;
- 5.5.2.2.3. Visual observations of the impacts (if any) noted in the receiving waters (e.g., fish kill, discoloration of receiving water) and extent of sampling if conducted;
- 5.5.2.2.4. Corrective measures taken to minimize the impact of the unauthorized discharge;
- 5.5.2.2.5. Measures to be taken to minimize the potential for a similar unauthorized discharge in the future;

¹ California Code of Regulations, Title 23, section 2250(b), defines an unauthorized discharge to be a discharge, not regulated by waste discharge requirements, of treated, partially-treated, or untreated wastewater resulting from the intentional or unintentional diversion of wastewater from a collection, treatment, or disposal system.

5.5.2.2.6. Summary of Spill Prevention Plan or Operation and Maintenance Manual modifications to be made, if necessary, to minimize the potential for future unauthorized discharges; and

5.5.2.2.7. Quantity and duration of the unauthorized discharge, and the amount recovered.

5.6. Planned Changes – Not supplemented

5.7. Anticipated Noncompliance – Not supplemented

5.8. Other Noncompliance – Not supplemented

5.9. Other Information – Not supplemented

6. STANDARD PROVISIONS – ENFORCEMENT – NOT SUPPLEMENTED

7. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS – NOT SUPPLEMENTED

8. DEFINITIONS – ADDITION TO ATTACHMENT D

More definitions can be found in Attachment A of this NPDES Permit.

8.1. Arithmetic Calculations

8.1.1. **Geometric Mean.** The antilog of the log mean or the back-transformed mean of the logarithmically transformed variables, which is equivalent to the multiplication of the antilogarithms. The geometric mean can be calculated with either of the following equations:

$$\text{Geometric Mean} = \text{Anti log } (1/N \sum \text{Log } C_i)$$

or

$$\text{Geometric Mean} = (C_1 \times C_2 \times \dots \times C_N)^{1/N}$$

Where “N” is the number of data points for the period analyzed and “C” is the concentration for each of the “N” data points.

8.1.2. **Mass Emission Rate.** The rate of discharge expressed in mass. The mass emission rate is obtained from the following calculation for any calendar day:

$$\text{Mass emission rate (lb/day)} = \frac{8.345}{N} \sum_{i=1}^N Q_i C_i$$

$$\text{Mass emission rate (kg/day)} = \frac{3.785}{N} \sum_{i=1}^N Q_i C_i$$

In which “N” is the number of samples analyzed in any calendar day and “Q_i” and “C_i” are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the “N” grab samples that may be taken in any calendar day. If a composite sample is taken, “C_i” is the concentration measured in the composite sample and “Q_i” is the average flow rate occurring during the period over which the samples are composited. The daily concentration of a constituent measured over any calendar day shall be determined from the flow weighted average of the same constituent in the combined waste streams as follows:

$$C_d = \text{Average daily concentration} = \frac{1}{Q_t} \sum_{i=1}^N Q_i C_i$$

In which “N” is the number of component waste streams and “Q” and “C” are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the “N” waste streams. “Q_t” is the total flow rate of the combined waste streams.

- 8.1.3. **Removal Efficiency.** The ratio of pollutants removed by the treatment facilities to pollutants entering the treatment facilities (expressed as a percentage). The Discharger shall determine removal efficiencies using monthly averages (by calendar month unless otherwise specified) of pollutant concentration of influent and effluent samples collected at about the same time and using the following equation (or its equivalent):

$$\text{Removal Efficiency (\%)} = 100 \times [1 - (\text{Effluent Concentration} / \text{Influent Concentration})]$$

- 8.2. **Blending** – the practice of bypassing biological treatment units and recombining the bypass wastewater with biologically-treated wastewater.
- 8.3. **Composite Sample** – a sample composed of individual grab samples collected manually or by an automatic sampling device on the basis of time or flow as specified in the MRP. For flow-based composites, the proportion of each grab sample included in the composite sample shall be within plus or minus five percent (+/-5%) of the representative flow of the waste stream being measured at the time of grab sample collection. Alternatively, equal volume grab samples may be individually analyzed with the flow-weighted average calculated by averaging flow-weighted ratios of each grab sample analytical result. Grab samples comprising time-based composite samples shall be collected at intervals not greater than those specified in the MRP. The quantity of each grab sample comprising a time-based composite sample shall be a set of flow proportional volumes as specified in the MRP. If a particular time-based or flow-based composite sampling protocol is not specified in the MRP, the Discharger shall determine and implement the most representative protocol.

- 8.4. Duplicate Sample** – a second sample taken from the same source and at the same time as an initial sample (such samples are typically analyzed identically to measure analytical variability).
- 8.5. Grab Sample** – an individual sample collected during a short period not exceeding 15 minutes. Grab samples represent only the condition that exists at the time the sample is collected.
- 8.6. Overflow** – the intentional or unintentional spilling or forcing out of untreated or partially-treated waste from a transport system (e.g., through manholes, at pump stations, or at collection points) upstream of the treatment plant headworks or from any part of a treatment plant.
- 8.7. Priority Pollutants** – those constituents referred to in 40 C.F.R. part 122 as promulgated in the Federal Register, Vol. 65, No. 97, Thursday, May 18, 2000, also known as the California Toxics Rule.
- 8.8. Untreated waste** – raw wastewater.

Table B
List of Monitoring Parameters, Analytical Methods, and Minimum Levels (µg/L)^[1]

| CTR No. | Pollutant / Parameter | Analytical Method ^[2] | GC | GC MS | LC | Color | FAA | GFAA | ICP | ICP MS | SPGF AA | HYD RIDE | CVAA | DCP |
|---------|---|----------------------------------|-----|-------|----|-------|-----|------|-----|--------|---------|----------|------|--------|
| 1 | Antimony | 204.2 | - | - | - | - | 10 | 5 | 50 | 0.5 | 5 | 0.5 | - | 1000 |
| 2 | Arsenic | 206.3 | - | - | - | 20 | - | 2 | 10 | 2 | 2 | 1 | - | 1000 |
| 3 | Beryllium | - | - | - | - | - | 20 | 0.5 | 2 | 0.5 | 1 | - | - | 1000 |
| 4 | Cadmium | 200 or 213 | - | - | - | - | 10 | 0.5 | 10 | 0.25 | 0.5 | - | - | 1000 |
| 5a | Chromium (III) | SM 3500 | - | - | - | - | - | - | - | - | - | - | - | - |
| 5b | Chromium (VI) | SM 3500 | - | - | - | 10 | 5 | - | - | - | - | - | - | 1000 |
| | Chromium (total) ^[3] | SM 3500 | - | - | - | - | 50 | 2 | 10 | 0.5 | 1 | - | - | 1000 |
| 6 | Copper | 200.9 | - | - | - | - | 25 | 5 | 10 | 0.5 | 2 | - | - | 1000 |
| 7 | Lead | 200.9 | - | - | - | - | 20 | 5 | 5 | 0.5 | 2 | - | - | 10,000 |
| 8 | Mercury | 1631 ^[4] | - | - | - | - | - | - | - | - | - | - | - | - |
| 9 | Nickel | 249.2 | - | - | - | - | 50 | 5 | 20 | 1 | 5 | - | - | 1000 |
| 10 | Selenium | 200.8 or SM 3114B or C | - | - | - | - | - | 5 | 10 | 2 | 5 | 1 | - | 1000 |
| 11 | Silver | 272.2 | - | - | - | - | 10 | 1 | 10 | 0.25 | 2 | - | - | 1000 |
| 12 | Thallium | 279.2 | - | - | - | - | 10 | 2 | 10 | 1 | 5 | - | - | 1000 |
| 13 | Zinc | 200 or 289 | - | - | - | - | 20 | - | 20 | 1 | 10 | - | - | - |
| 14 | Cyanide | SM 4500 CN ⁻ C or I | - | - | - | 5 | - | - | - | - | - | - | - | - |
| 15 | Asbestos (only required for dischargers to MUN waters) ^[5] | 0100.2 ^[6] | - | - | - | - | - | - | - | - | - | - | - | - |
| 16 | 2,3,7,8-TCDD and 17 congeners (Dioxin) | 1613 | - | - | - | - | - | - | - | - | - | - | - | - |
| 17 | Acrolein | 603 | 2.0 | 5 | - | - | - | - | - | - | - | - | - | - |
| 18 | Acrylonitrile | 603 | 2.0 | 2 | - | - | - | - | - | - | - | - | - | - |
| 19 | Benzene | 602 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 33 | Ethylbenzene | 602 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 39 | Toluene | 602 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 20 | Bromoform | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 21 | Carbon Tetrachloride | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |

| CTR No. | Pollutant / Parameter | Analytical Method ^[2] | GC | GC MS | LC | Color | FAA | GFAA | ICP | ICP MS | SPGF AA | HYD RIDE | CVAA | DCP |
|---------|--|----------------------------------|-----|-------|----|-------|-----|------|-----|--------|---------|----------|------|-----|
| 22 | Chlorobenzene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 23 | Chlorodibromomethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 24 | Chloroethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 25 | 2-Chloroethylvinyl Ether | 601 | 1 | 1 | - | - | - | - | - | - | - | - | - | - |
| 26 | Chloroform | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 75 | 1,2-Dichlorobenzene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 76 | 1,3-Dichlorobenzene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 77 | 1,4-Dichlorobenzene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 27 | Dichlorobromomethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 28 | 1,1-Dichloroethane | 601 | 0.5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 29 | 1,2-Dichloroethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 30 | 1,1-Dichloroethylene or 1,1-Dichloroethene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 31 | 1,2-Dichloropropane | 601 | 0.5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 32 | 1,3-Dichloropropylene or 1,3-Dichloropropene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 34 | Methyl Bromide or Bromomethane | 601 | 1.0 | 2 | - | - | - | - | - | - | - | - | - | - |
| 35 | Methyl Chloride or Chloromethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 36 | Methylene Chloride or Dichloromethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 37 | 1,1,2,2-Tetrachloroethane | 601 | 0.5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 38 | Tetrachloroethylene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 40 | 1,2-Trans-Dichloroethylene | 601 | 0.5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 41 | 1,1,1-Trichloroethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 42 | 1,1,2-Trichloroethane | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 43 | Trichloroethene | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 44 | Vinyl Chloride | 601 | 0.5 | 2 | - | - | - | - | - | - | - | - | - | - |
| 45 | 2-Chlorophenol | 604 | 2 | 5 | - | - | - | - | - | - | - | - | - | - |
| 46 | 2,4-Dichlorophenol | 604 | 1 | 5 | - | - | - | - | - | - | - | - | - | - |
| 47 | 2,4-Dimethylphenol | 604 | 1 | 2 | - | - | - | - | - | - | - | - | - | - |

| CTR No. | Pollutant / Parameter | Analytical Method ^[2] | GC | GC MS | LC | Color | FAA | GFAA | ICP | ICP MS | SPGF AA | HYD RIDE | CVAA | DCP |
|---------|--|----------------------------------|----|-------|------|-------|-----|------|-----|--------|---------|----------|------|-----|
| 48 | 2-Methyl-4,6-Dinitrophenol or Dinitro-2-methylphenol | 604 | 10 | 5 | - | - | - | - | - | - | - | - | - | - |
| 49 | 2,4-Dinitrophenol | 604 | 5 | 5 | - | - | - | - | - | - | - | - | - | - |
| 50 | 2-Nitrophenol | 604 | - | 10 | - | - | - | - | - | - | - | - | - | - |
| 51 | 4-Nitrophenol | 604 | 5 | 10 | - | - | - | - | - | - | - | - | - | - |
| 52 | 3-Methyl-4-Chlorophenol | 604 | 5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 53 | Pentachlorophenol | 604 | 1 | 5 | - | - | - | - | - | - | - | - | - | - |
| 54 | Phenol | 604 | 1 | 1 | - | 50 | - | - | - | - | - | - | - | - |
| 55 | 2,4,6-Trichlorophenol | 604 | 10 | 10 | - | - | - | - | - | - | - | - | - | - |
| 56 | Acenaphthene | 610 HPLC | 1 | 1 | 0.5 | - | - | - | - | - | - | - | - | - |
| 57 | Acenaphthylene | 610 HPLC | - | 10 | 0.2 | - | - | - | - | - | - | - | - | - |
| 58 | Anthracene | 610 HPLC | - | 10 | 2 | - | - | - | - | - | - | - | - | - |
| 60 | Benzo(a)Anthracene or 1,2 Benzanthracene | 610 HPLC | 10 | 5 | - | - | - | - | - | - | - | - | - | - |
| 61 | Benzo(a)Pyrene | 610 HPLC | - | 10 | 2 | - | - | - | - | - | - | - | - | - |
| 62 | Benzo(b) Fluoranthene or 3,4 Benzofluoranthene | 610 HPLC | - | 10 | 10 | - | - | - | - | - | - | - | - | - |
| 63 | Benzo(ghi)Perylene | 610 HPLC | - | 5 | 0.1 | - | - | - | - | - | - | - | - | - |
| 64 | Benzo(k)Fluoranthene | 610 HPLC | - | 10 | 2 | - | - | - | - | - | - | - | - | - |
| 74 | Dibenzo(a,h)Anthracene | 610 HPLC | - | 10 | 0.1 | - | - | - | - | - | - | - | - | - |
| 86 | Fluoranthene | 610 HPLC | 10 | 1 | 0.05 | - | - | - | - | - | - | - | - | - |
| 87 | Fluorene | 610 HPLC | - | 10 | 0.1 | - | - | - | - | - | - | - | - | - |
| 92 | Indeno(1,2,3-cd)Pyrene | 610 HPLC | - | 10 | 0.05 | - | - | - | - | - | - | - | - | - |
| 100 | Pyrene | 610 HPLC | - | 10 | 0.05 | - | - | - | - | - | - | - | - | - |
| 68 | Bis(2-Ethylhexyl)Phthalate | 606 or 625 | 10 | 5 | - | - | - | - | - | - | - | - | - | - |
| 70 | Butylbenzyl Phthalate | 606 or 625 | 10 | 10 | - | - | - | - | - | - | - | - | - | - |
| 79 | Diethyl Phthalate | 606 or 625 | 10 | 2 | - | - | - | - | - | - | - | - | - | - |
| 80 | Dimethyl Phthalate | 606 or 625 | 10 | 2 | - | - | - | - | - | - | - | - | - | - |
| 81 | Di-n-Butyl Phthalate | 606 or 625 | - | 10 | - | - | - | - | - | - | - | - | - | - |
| 84 | Di-n-Octyl Phthalate | 606 or 625 | - | 10 | - | - | - | - | - | - | - | - | - | - |
| 59 | Benzidine | 625 | - | 5 | - | - | - | - | - | - | - | - | - | - |
| 65 | Bis(2-Chloroethoxy)Methane | 625 | - | 5 | - | - | - | - | - | - | - | - | - | - |

| CTR No. | Pollutant / Parameter | Analytical Method ^[2] | GC | GC MS | LC | Color | FAA | GFAA | ICP | ICP MS | SPGF AA | HYD RIDE | CVAA | DCP |
|---------|--------------------------------------|----------------------------------|-------|-------|------|-------|-----|------|-----|--------|---------|----------|------|-----|
| 66 | Bis(2-Chloroethyl)Ether | 625 | 10 | 1 | - | - | - | - | - | - | - | - | - | - |
| 67 | Bis(2-Chloroisopropyl) Ether | 625 | 10 | 2 | - | - | - | - | - | - | - | - | - | - |
| 69 | 4-Bromophenyl Phenyl Ether | 625 | 10 | 5 | - | - | - | - | - | - | - | - | - | - |
| 71 | 2-Chloronaphthalene | 625 | - | 10 | - | - | - | - | - | - | - | - | - | - |
| 72 | 4-Chlorophenyl Phenyl Ether | 625 | - | 5 | - | - | - | - | - | - | - | - | - | - |
| 73 | Chrysene | 625 | - | 10 | 5 | - | - | - | - | - | - | - | - | - |
| 78 | 3,3'-Dichlorobenzidine | 625 | - | 5 | - | - | - | - | - | - | - | - | - | - |
| 82 | 2,4-Dinitrotoluene | 625 | 10 | 5 | - | - | - | - | - | - | - | - | - | - |
| 83 | 2,6-Dinitrotoluene | 625 | - | 5 | - | - | - | - | - | - | - | - | - | - |
| 85 | 1,2-Diphenylhydrazine ^[7] | 625 | - | 1 | - | - | - | - | - | - | - | - | - | - |
| 88 | Hexachlorobenzene | 625 | 5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 89 | Hexachlorobutadiene | 625 | 5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 90 | Hexachlorocyclopentadiene | 625 | 5 | 5 | - | - | - | - | - | - | - | - | - | - |
| 91 | Hexachloroethane | 625 | 5 | 1 | - | - | - | - | - | - | - | - | - | - |
| 93 | Isophorone | 625 | 10 | 1 | - | - | - | - | - | - | - | - | - | - |
| 94 | Naphthalene | 625 | 10 | 1 | 0.2 | - | - | - | - | - | - | - | - | - |
| 95 | Nitrobenzene | 625 | 10 | 1 | - | - | - | - | - | - | - | - | - | - |
| 96 | N-Nitrosodimethylamine | 625 | 10 | 5 | - | - | - | - | - | - | - | - | - | - |
| 97 | N-Nitrosodi-n-Propylamine | 625 | 10 | 5 | - | - | - | - | - | - | - | - | - | - |
| 98 | N-Nitrosodiphenylamine | 625 | 10 | 1 | - | - | - | - | - | - | - | - | - | - |
| 99 | Phenanthrene | 625 | - | 5 | 0.05 | - | - | - | - | - | - | - | - | - |
| 101 | 1,2,4-Trichlorobenzene | 625 | 1 | 5 | - | - | - | - | - | - | - | - | - | - |
| 102 | Aldrin | 608 | 0.005 | - | - | - | - | - | - | - | - | - | - | - |
| 103 | α-BHC | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 104 | β-BHC | 608 | 0.005 | - | - | - | - | - | - | - | - | - | - | - |
| 105 | γ-BHC (Lindane) | 608 | 0.02 | - | - | - | - | - | - | - | - | - | - | - |
| 106 | δ-BHC | 608 | 0.005 | - | - | - | - | - | - | - | - | - | - | - |
| 107 | Chlordane | 608 | 0.1 | - | - | - | - | - | - | - | - | - | - | - |
| 108 | 4,4'-DDT | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 109 | 4,4'-DDE | 608 | 0.05 | - | - | - | - | - | - | - | - | - | - | - |
| 110 | 4,4'-DDD | 608 | 0.05 | - | - | - | - | - | - | - | - | - | - | - |

| CTR No. | Pollutant / Parameter | Analytical Method ^[2] | GC | GC MS | LC | Color | FAA | GFAA | ICP | ICP MS | SPGF AA | HYD RIDE | CVAA | DCP |
|---------|---|----------------------------------|------|-------|----|-------|-----|------|-----|--------|---------|----------|------|-----|
| 111 | Dieldrin | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 112 | Endosulfan (alpha) | 608 | 0.02 | - | - | - | - | - | - | - | - | - | - | - |
| 113 | Endosulfan (beta) | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 114 | Endosulfan Sulfate | 608 | 0.05 | - | - | - | - | - | - | - | - | - | - | - |
| 115 | Endrin | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 116 | Endrin Aldehyde | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 117 | Heptachlor | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 118 | Heptachlor Epoxide | 608 | 0.01 | - | - | - | - | - | - | - | - | - | - | - |
| 119-125 | PCBs: Aroclors 1016, 1221, 1232, 1242, 1248, 1254, 1260 | 608 | 0.5 | - | - | - | - | - | - | - | - | - | - | - |
| 126 | Toxaphene | 608 | 0.5 | - | - | - | - | - | - | - | - | - | - | - |

Footnotes:

- ^[1] Minimum levels are from the *State Implementation Policy*. They are the concentration of the lowest calibration standard for that technique based on a survey of contract laboratories. Laboratory techniques are defined as follows: GC = Gas Chromatography; GCMS = Gas Chromatography/Mass Spectrometry; LC = High Pressure Liquid Chromatography; Color = Colorimetric; FAA = Flame Atomic Absorption; GFAA = Graphite Furnace Atomic Absorption; ICP = Inductively Coupled Plasma; ICPMS = Inductively Coupled Plasma/Mass Spectrometry; SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e., U.S. EPA 200.9); Hydride = Gaseous Hydride Atomic Absorption; CVAA = Cold Vapor Atomic Absorption; DCP = Direct Current Plasma.
- ^[2] The suggested method is the U.S. EPA Method unless otherwise specified (SM = Standard Methods). The Discharger may use another U.S. EPA-approved or recognized method if that method has a level of quantification below the applicable water quality objective. Where no method is suggested, the Discharger has the discretion to use any standard method.
- ^[3] Analysis for total chromium may be substituted for analysis of chromium (III) and chromium (VI) if the concentration measured is below the lowest hexavalent chromium criterion (11 ug/l).
- ^[4] The Discharger shall use ultra-clean sampling (U.S. EPA Method 1669) and ultra-clean analytical methods (U.S. EPA Method 1631) for mercury monitoring. The minimum level for mercury is 2 ng/l (or 0.002 ug/l).
- ^[5] MUN = Municipal and Domestic Supply. This designation, if applicable, is in the Findings of the permit.
- ^[6] Determination of Asbestos Structures over 10 [micrometers] in Length in Drinking Water Using MCE Filters, U.S. EPA 600/R-94-134, June 1994.
- ^[7] Detected as azobenzene.