

Table 4-5: Conditions that Require Monthly Monitoring of Toxicity Levels

Discharger Monitoring Frequency	Shallow Water Dischargers	Deep Water Dischargers
QUARTERLY		
Three-sample median ^a	>1 TU _C	>10 TU _C
Single-sample maximum	>2 TU _C	>20 TU _C
SEMI-ANNUALLY OR ANNUALLY		
Single-sample maximum	>1TU _C	>10 TU _C

^a. Exceedance of the three-sample median is defined as follows: If one of the past two or fewer samples shows greater than the toxicity threshold listed above, then a chronic toxicity value greater than the threshold on the next sample represents an exceedance.