

**Table C2  
CHRONIC TOXICITY  
REASONABLE POTENTIAL ANALYSIS  
(Camarillo Sanitary District - Camarillo WRP)**

<b>CONSTITUENT</b>	<b>Units</b>	<b>Number of Samples</b>	<b>Maximum Observed Effluent Concentration</b>	<b>CV</b>	<b>Multiplier</b>	<b>Projected Maximum Effluent Concentration (99/99)</b>	<b>Dilution Ratio</b>	<b>Background Seawater Concentration</b>	<b>Projected Maximum Receiving Water Concentration</b>	<b>Water Quality Objectives</b>	<b>C-Human carcinogen NC-Human noncarcinogen AP-Aquatic life protection</b>	<b>REASONABLE POTENTIAL</b>
TOXICITY (chronic) survival HC	Tuc	26	5.6	0.15	1.22	6.84	0		6.84	1	AP	YES
TOXICITY (chronic) reproduction HC	Tuc	26	10	0.38	1.64	16.37	0		16.37	1	AP	YES
TOXICITY (acute)	Tua											

\* Effluent limits are prescribed for these constituents whose projected maximum receiving water concentrations exceed criteria.