

ATTACHMENT K-3
San Jose Creek Water Reclamation Plant (CA0053911)
Ammonia Effluent Data at Discharge Point 001

Name	Date	Unit	Detect	Value
AMMONIA NITROGEN	1/19/2004	MG/L	Yes	5.06
AMMONIA NITROGEN	2/23/2004	MG/L	Yes	1.17
AMMONIA NITROGEN	3/8/2004	MG/L	Yes	3.36
AMMONIA NITROGEN	4/20/2004	MG/L	Yes	2.20
AMMONIA NITROGEN	4/21/2004	MG/L	Yes	1.40
AMMONIA NITROGEN	4/22/2004	MG/L	Yes	1.50
AMMONIA NITROGEN	5/10/2004	MG/L	Yes	3.29
AMMONIA NITROGEN	6/16/2004	MG/L	Yes	1.30
AMMONIA NITROGEN	7/26/2004	MG/L	Yes	1.27
AMMONIA NITROGEN	8/3/2004	MG/L	Yes	1.36
AMMONIA NITROGEN	8/11/2004	MG/L	Yes	1.34
AMMONIA NITROGEN	8/18/2004	MG/L	Yes	1.22
AMMONIA NITROGEN	8/25/2004	MG/L	Yes	1.20
AMMONIA NITROGEN	8/26/2004	MG/L	Yes	1.34
AMMONIA NITROGEN	9/1/2004	MG/L	Yes	1.47
AMMONIA NITROGEN	9/8/2004	MG/L	Yes	1.90
AMMONIA NITROGEN	9/27/2004	MG/L	Yes	2.30
AMMONIA NITROGEN	9/29/2004	MG/L	Yes	1.70
AMMONIA NITROGEN	10/6/2004	MG/L	Yes	1.51
AMMONIA NITROGEN	10/13/2004	MG/L	Yes	1.99
AMMONIA NITROGEN	10/20/2004	MG/L	Yes	1.90
AMMONIA NITROGEN	10/24/2004	MG/L	Yes	3.30
AMMONIA NITROGEN	10/27/2004	MG/L	Yes	1.10
AMMONIA NITROGEN	11/3/2004	MG/L	Yes	2.16
AMMONIA NITROGEN	11/7/2004	MG/L	Yes	1.60
AMMONIA NITROGEN	11/8/2004	MG/L	Yes	1.05
AMMONIA NITROGEN	11/9/2004	MG/L	Yes	1.10
AMMONIA NITROGEN	11/10/2004	MG/L	Yes	1.05
AMMONIA NITROGEN	11/11/2004	MG/L	Yes	1.19
AMMONIA NITROGEN	11/12/2004	MG/L	Yes	1.34
AMMONIA NITROGEN	11/13/2004	MG/L	Yes	1.85
AMMONIA NITROGEN	11/14/2004	MG/L	Yes	2.02
AMMONIA NITROGEN	11/15/2004	MG/L	Yes	1.10
AMMONIA NITROGEN	11/16/2004	MG/L	Yes	0.89
AMMONIA NITROGEN	11/17/2004	MG/L	Yes	0.85
AMMONIA NITROGEN	11/18/2004	MG/L	Yes	1.05
AMMONIA NITROGEN	11/19/2004	MG/L	Yes	1.50
AMMONIA NITROGEN	11/20/2004	MG/L	Yes	1.82
AMMONIA NITROGEN	11/21/2004	MG/L	Yes	1.43
AMMONIA NITROGEN	11/22/2004	MG/L	Yes	0.95
AMMONIA NITROGEN	11/23/2004	MG/L	Yes	0.99
AMMONIA NITROGEN	11/24/2004	MG/L	Yes	1.09
AMMONIA NITROGEN	11/25/2004	MG/L	Yes	2.12
AMMONIA NITROGEN	11/26/2004	MG/L	Yes	2.24
AMMONIA NITROGEN	11/27/2004	MG/L	Yes	2.27
AMMONIA NITROGEN	11/28/2004	MG/L	Yes	1.50
AMMONIA NITROGEN	11/29/2004	MG/L	Yes	1.10
AMMONIA NITROGEN	11/30/2004	MG/L	Yes	1.19

ATTACHMENT K-3
San Jose Creek Water Reclamation Plant (CA0053911)
Ammonia Effluent Data at Discharge Point 001

AMMONIA NITROGEN	12/1/2004	MG/L	Yes	1.43
AMMONIA NITROGEN	12/2/2004	MG/L	Yes	1.30
AMMONIA NITROGEN	12/3/2004	MG/L	Yes	1.34
AMMONIA NITROGEN	12/4/2004	MG/L	Yes	1.99
AMMONIA NITROGEN	12/5/2004	MG/L	Yes	1.83
AMMONIA NITROGEN	12/6/2004	MG/L	Yes	1.29
AMMONIA NITROGEN	12/7/2004	MG/L	Yes	1.24
AMMONIA NITROGEN	12/15/2004	MG/L	Yes	1.21
AMMONIA NITROGEN	12/20/2004	MG/L	Yes	1.94
AMMONIA NITROGEN	12/27/2004	MG/L	Yes	1.89
AMMONIA NITROGEN	1/5/2005	MG/L	Yes	1.47
AMMONIA NITROGEN	1/13/2005	MG/L	Yes	1.81
AMMONIA NITROGEN	1/19/2005	MG/L	Yes	1.62
AMMONIA NITROGEN	1/25/2005	MG/L	Yes	1.62
AMMONIA NITROGEN	2/2/2005	MG/L	Yes	1.28
AMMONIA NITROGEN	2/9/2005	MG/L	Yes	1.16
AMMONIA NITROGEN	2/14/2005	MG/L	Yes	1.33
AMMONIA NITROGEN	2/15/2005	MG/L	Yes	1.16
AMMONIA NITROGEN	2/28/2005	MG/L	Yes	1.55
AMMONIA NITROGEN	3/2/2005	MG/L	Yes	1.62
AMMONIA NITROGEN	3/9/2005	MG/L	Yes	1.45
AMMONIA NITROGEN	3/16/2005	MG/L	Yes	1.41
AMMONIA NITROGEN	3/21/2005	MG/L	Yes	1.51
AMMONIA NITROGEN	3/30/2005	MG/L	Yes	1.07
AMMONIA NITROGEN	4/7/2005	MG/L	Yes	1.30
AMMONIA NITROGEN	4/13/2005	MG/L	Yes	0.79
AMMONIA NITROGEN	4/18/2005	MG/L	Yes	0.95
AMMONIA NITROGEN	4/20/2005	MG/L	Yes	0.88
AMMONIA NITROGEN	4/27/2005	MG/L	Yes	0.92
AMMONIA NITROGEN	5/4/2005	MG/L	Yes	0.86
AMMONIA NITROGEN	5/10/2005	MG/L	Yes	1.36
AMMONIA NITROGEN	5/11/2005	MG/L	Yes	1.39
AMMONIA NITROGEN	5/18/2005	MG/L	Yes	1.51
AMMONIA NITROGEN	5/25/2005	MG/L	Yes	1.20
AMMONIA NITROGEN	6/1/2005	MG/L	Yes	1.15
AMMONIA NITROGEN	6/8/2005	MG/L	Yes	1.25
AMMONIA NITROGEN	6/13/2005	MG/L	Yes	1.15
AMMONIA NITROGEN	6/15/2005	MG/L	Yes	1.16
AMMONIA NITROGEN	6/22/2005	MG/L	Yes	1.89
AMMONIA NITROGEN	6/29/2005	MG/L	Yes	1.14
AMMONIA NITROGEN	7/6/2005	MG/L	Yes	1.07
AMMONIA NITROGEN	7/13/2005	MG/L	Yes	0.59
AMMONIA NITROGEN	7/20/2005	MG/L	Yes	0.62
AMMONIA NITROGEN	7/27/2005	MG/L	Yes	0.48
AMMONIA NITROGEN	8/3/2005	MG/L	Yes	0.39
AMMONIA NITROGEN	8/10/2005	MG/L	Yes	0.41
AMMONIA NITROGEN	8/17/2005	MG/L	Yes	1.25
AMMONIA NITROGEN	8/24/2005	MG/L	Yes	1.35
AMMONIA NITROGEN	8/31/2005	MG/L	Yes	1.84
AMMONIA NITROGEN	9/7/2005	MG/L	Yes	1.33

ATTACHMENT K-3
San Jose Creek Water Reclamation Plant (CA0053911)
Ammonia Effluent Data at Discharge Point 001

AMMONIA NITROGEN	9/14/2005	MG/L	Yes	1.53
AMMONIA NITROGEN	9/23/2005	MG/L	Yes	1.13
AMMONIA NITROGEN	9/28/2005	MG/L	Yes	1.56
AMMONIA NITROGEN	10/5/2005	MG/L	Yes	1.14
AMMONIA NITROGEN	10/12/2005	MG/L	Yes	1.34
AMMONIA NITROGEN	10/26/2005	MG/L	Yes	1.18
AMMONIA NITROGEN	11/2/2005	MG/L	Yes	1.73
AMMONIA NITROGEN	11/9/2005	MG/L	Yes	1.27
AMMONIA NITROGEN	11/16/2005	MG/L	Yes	1.35
AMMONIA NITROGEN	11/21/2005	MG/L	Yes	1.54
AMMONIA NITROGEN	11/30/2005	MG/L	Yes	1.20
AMMONIA NITROGEN	12/7/2005	MG/L	Yes	1.20
AMMONIA NITROGEN	12/14/2005	MG/L	Yes	1.30
AMMONIA NITROGEN	12/21/2005	MG/L	Yes	1.41
AMMONIA NITROGEN	12/28/2005	MG/L	Yes	1.09
AMMONIA NITROGEN	1/11/2006	MG/L	Yes	1.31
AMMONIA NITROGEN	1/12/2006	MG/L	Yes	1.31
AMMONIA NITROGEN	1/18/2006	MG/L	Yes	1.30
AMMONIA NITROGEN	1/25/2006	MG/L	Yes	1.06
AMMONIA NITROGEN	2/1/2006	MG/L	Yes	1.37
AMMONIA NITROGEN	2/8/2006	MG/L	Yes	1.40
AMMONIA NITROGEN	2/15/2006	MG/L	Yes	1.26
AMMONIA NITROGEN	2/22/2006	MG/L	Yes	1.20
AMMONIA NITROGEN	2/27/2006	MG/L	Yes	1.82
AMMONIA NITROGEN	3/9/2006	MG/L	Yes	1.38
AMMONIA NITROGEN	3/15/2006	MG/L	Yes	1.52
AMMONIA NITROGEN	3/23/2006	MG/L	Yes	1.32
AMMONIA NITROGEN	3/27/2006	MG/L	Yes	2.14
AMMONIA NITROGEN	4/3/2006	MG/L	Yes	1.39
AMMONIA NITROGEN	4/12/2006	MG/L	Yes	0.89
AMMONIA NITROGEN	4/19/2006	MG/L	Yes	1.06
AMMONIA NITROGEN	4/26/2006	MG/L	Yes	1.84
AMMONIA NITROGEN	5/3/2006	MG/L	Yes	1.34
AMMONIA NITROGEN	5/10/2006	MG/L	Yes	1.38
AMMONIA NITROGEN	5/17/2006	MG/L	Yes	1.51
AMMONIA NITROGEN	5/25/2006	MG/L	Yes	1.46
AMMONIA NITROGEN	5/31/2006	MG/L	Yes	1.67
AMMONIA NITROGEN	6/7/2006	MG/L	Yes	1.26
AMMONIA NITROGEN	6/14/2006	MG/L	Yes	1.47
AMMONIA NITROGEN	6/21/2006	MG/L	Yes	1.47
AMMONIA NITROGEN	6/28/2006	MG/L	Yes	1.90
AMMONIA NITROGEN	7/12/2006	MG/L	Yes	1.29
AMMONIA NITROGEN	7/26/2006	MG/L	Yes	1.12
AMMONIA NITROGEN	8/9/2006	MG/L	Yes	1.46
AMMONIA NITROGEN	8/16/2006	MG/L	Yes	1.18
AMMONIA NITROGEN	8/23/2006	MG/L	Yes	1.41
AMMONIA NITROGEN	8/30/2006	MG/L	Yes	1.30
AMMONIA NITROGEN	9/6/2006	MG/L	Yes	0.88
AMMONIA NITROGEN	9/13/2006	MG/L	Yes	1.13
AMMONIA NITROGEN	9/20/2006	MG/L	Yes	1.31

ATTACHMENT K-3
San Jose Creek Water Reclamation Plant (CA0053911)
Ammonia Effluent Data at Discharge Point 001

AMMONIA NITROGEN	9/27/2006	MG/L	Yes	0.84
AMMONIA NITROGEN	10/4/2006	MG/L	Yes	1.20
AMMONIA NITROGEN	10/11/2006	MG/L	Yes	1.10
AMMONIA NITROGEN	10/18/2006	MG/L	Yes	1.21
AMMONIA NITROGEN	10/25/2006	MG/L	Yes	1.18
AMMONIA NITROGEN	11/1/2006	MG/L	Yes	1.29
AMMONIA NITROGEN	11/15/2006	MG/L	Yes	0.88
AMMONIA NITROGEN	11/22/2006	MG/L	Yes	0.85
AMMONIA NITROGEN	11/29/2006	MG/L	Yes	1.12
AMMONIA NITROGEN	12/6/2006	MG/L	Yes	1.16
AMMONIA NITROGEN	12/13/2006	MG/L	Yes	1.10
AMMONIA NITROGEN	12/20/2006	MG/L	Yes	1.22
AMMONIA NITROGEN	12/27/2006	MG/L	Yes	1.25
AMMONIA NITROGEN	1/3/2007	MG/L	Yes	1.66
AMMONIA NITROGEN	1/10/2007	MG/L	Yes	1.78
AMMONIA NITROGEN	1/17/2007	MG/L	Yes	3.10
AMMONIA NITROGEN	1/24/2007	MG/L	Yes	2.48
AMMONIA NITROGEN	1/25/2007	MG/L	Yes	2.50
AMMONIA NITROGEN	1/26/2007	MG/L	Yes	1.99
AMMONIA NITROGEN	1/27/2007	MG/L	Yes	1.50
AMMONIA NITROGEN	1/28/2007	MG/L	Yes	1.79
AMMONIA NITROGEN	1/29/2007	MG/L	Yes	1.45
AMMONIA NITROGEN	1/30/2007	MG/L	Yes	1.67
AMMONIA NITROGEN	3/7/2007	MG/L	Yes	1.32
AMMONIA NITROGEN	3/14/2007	MG/L	Yes	1.17
AMMONIA NITROGEN	3/21/2007	MG/L	Yes	1.15
AMMONIA NITROGEN	3/28/2007	MG/L	Yes	1.09
AMMONIA NITROGEN	4/4/2007	MG/L	Yes	1.15
AMMONIA NITROGEN	4/11/2007	MG/L	Yes	1.25
AMMONIA NITROGEN	4/18/2007	MG/L	Yes	1.14
AMMONIA NITROGEN	4/25/2007	MG/L	Yes	1.05
AMMONIA NITROGEN	5/2/2007	MG/L	Yes	1.10
AMMONIA NITROGEN	5/9/2007	MG/L	Yes	1.65
AMMONIA NITROGEN	5/16/2007	MG/L	Yes	1.30
AMMONIA NITROGEN	5/23/2007	MG/L	Yes	1.13
AMMONIA NITROGEN	5/30/2007	MG/L	Yes	1.16
AMMONIA NITROGEN	6/6/2007	MG/L	Yes	1.07
AMMONIA NITROGEN	6/13/2007	MG/L	Yes	1.21
AMMONIA NITROGEN	6/20/2007	MG/L	Yes	1.27
AMMONIA NITROGEN	7/4/2007	MG/L	Yes	1.23
AMMONIA NITROGEN	7/18/2007	MG/L	Yes	1.03
AMMONIA NITROGEN	7/25/2007	MG/L	Yes	1.15
AMMONIA NITROGEN	8/8/2007	MG/L	Yes	1.10
AMMONIA NITROGEN	8/15/2007	MG/L	Yes	1.05
AMMONIA NITROGEN	8/22/2007	MG/L	Yes	1.01
AMMONIA NITROGEN	8/29/2007	MG/L	Yes	1.00
AMMONIA NITROGEN	9/5/2007	MG/L	Yes	0.98
AMMONIA NITROGEN	9/12/2007	MG/L	Yes	1.01
AMMONIA NITROGEN	9/19/2007	MG/L	Yes	0.93
AMMONIA NITROGEN	9/26/2007	MG/L	Yes	1.02

ATTACHMENT K-3
San Jose Creek Water Reclamation Plant (CA0053911)
Ammonia Effluent Data at Discharge Point 001

AMMONIA NITROGEN	10/10/2007	MG/L	Yes	1.00
AMMONIA NITROGEN	10/17/2007	MG/L	Yes	1.00
AMMONIA NITROGEN	10/24/2007	MG/L	Yes	0.93
AMMONIA NITROGEN	10/31/2007	MG/L	Yes	0.97
AMMONIA NITROGEN	11/7/2007	MG/L	Yes	1.11
AMMONIA NITROGEN	11/14/2007	MG/L	Yes	0.94
AMMONIA NITROGEN	11/20/2007	MG/L	Yes	1.58
AMMONIA NITROGEN	11/28/2007	MG/L	Yes	1.34
AMMONIA NITROGEN	12/5/2007	MG/L	Yes	1.40
AMMONIA NITROGEN	12/12/2007	MG/L	Yes	1.37
AMMONIA NITROGEN	12/19/2007	MG/L	Yes	1.18
AMMONIA NITROGEN	12/26/2007	MG/L	Yes	1.31
AMMONIA NITROGEN	1/2/2008	MG/L	Yes	1.32
AMMONIA NITROGEN	1/9/2008	MG/L	Yes	1.38
AMMONIA NITROGEN	1/16/2008	MG/L	Yes	1.32
AMMONIA NITROGEN	1/23/2008	MG/L	Yes	1.78
AMMONIA NITROGEN	1/31/2008	MG/L	Yes	1.33
AMMONIA NITROGEN	2/6/2008	MG/L	Yes	1.33
AMMONIA NITROGEN	2/13/2008	MG/L	Yes	1.05
AMMONIA NITROGEN	2/20/2008	MG/L	Yes	1.29
AMMONIA NITROGEN	2/27/2008	MG/L	Yes	1.03
AMMONIA NITROGEN	3/5/2008	MG/L	Yes	1.20
AMMONIA NITROGEN	3/12/2008	MG/L	Yes	1.11
AMMONIA NITROGEN	3/19/2008	MG/L	Yes	1.14
AMMONIA NITROGEN	3/26/2008	MG/L	Yes	1.04
AMMONIA NITROGEN	4/2/2008	MG/L	Yes	1.19
AMMONIA NITROGEN	4/9/2008	MG/L	Yes	1.10
AMMONIA NITROGEN	4/16/2008	MG/L	Yes	1.18
AMMONIA NITROGEN	4/23/2008	MG/L	Yes	1.01
AMMONIA NITROGEN	5/7/2008	MG/L	Yes	1.21
AMMONIA NITROGEN	5/21/2008	MG/L	Yes	1.29
AMMONIA NITROGEN	5/28/2008	MG/L	Yes	1.01
AMMONIA NITROGEN	6/4/2008	MG/L	Yes	1.00
AMMONIA NITROGEN	6/19/2008	MG/L	Yes	1.05
AMMONIA NITROGEN	6/23/2008	MG/L	Yes	1.06
AMMONIA NITROGEN	6/25/2008	MG/L	Yes	1.20
AMMONIA NITROGEN	7/2/2008	MG/L	Yes	1.07
AMMONIA NITROGEN	7/9/2008	MG/L	Yes	0.99
AMMONIA NITROGEN	7/16/2008	MG/L	Yes	0.99
AMMONIA NITROGEN	7/30/2008	MG/L	Yes	1.06
AMMONIA NITROGEN	8/6/2008	MG/L	Yes	1.03
AMMONIA NITROGEN	8/13/2008	MG/L	Yes	1.39
AMMONIA NITROGEN	8/20/2008	MG/L	Yes	1.33
AMMONIA NITROGEN	8/27/2008	MG/L	Yes	1.16
AMMONIA NITROGEN	9/3/2008	MG/L	Yes	1.42
AMMONIA NITROGEN	9/10/2008	MG/L	Yes	1.32
AMMONIA NITROGEN	9/17/2008	MG/L	Yes	1.21
AMMONIA NITROGEN	9/24/2008	MG/L	Yes	1.29
AMMONIA NITROGEN	10/1/2008	MG/L	Yes	1.26
AMMONIA NITROGEN	10/8/2008	MG/L	Yes	1.06

ATTACHMENT K-3
San Jose Creek Water Reclamation Plant (CA0053911)
Ammonia Effluent Data at Discharge Point 001

AMMONIA NITROGEN	10/15/2008	MG/L	Yes	1.05
AMMONIA NITROGEN	10/22/2008	MG/L	Yes	1.02
AMMONIA NITROGEN	10/29/2008	MG/L	Yes	0.98
AMMONIA NITROGEN	11/6/2008	MG/L	Yes	0.96
AMMONIA NITROGEN	11/12/2008	MG/L	Yes	1.13
AMMONIA NITROGEN	11/24/2008	MG/L	Yes	1.03
AMMONIA NITROGEN	12/3/2008	MG/L	Yes	1.10
AMMONIA NITROGEN	12/10/2008	MG/L	Yes	0.96
AMMONIA NITROGEN	12/17/2008	MG/L	Yes	1.00
AMMONIA NITROGEN	12/23/2008	MG/L	Yes	1.00

MAX	5.06
STD	0.473153118
AVG	1.34
CV	0.352719982

ECA Multiplier 1-HR 99%	0.478132673
ECA Multiplier 4-Day 99%	0.675865086
ECA Multiplier 30-Day 99%	0.862806742
MDEL Multiplier 99%	2.091469706
AMEL Multiplier 95%	1.109328829