

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD**

**LOS ANGELES REGION**

320 W. 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013  
 Phone (213) 576-6600 • Fax (213) 576-6640  
 http://www.waterboards.ca.gov

**ORDER NO. R4-2007-0057**  
**NPDES NO. CA0055247**

The following Discharger is subject to waste discharge requirements as set forth in this Order:

**Table 1. Discharger Information**

<b>Discharger</b>	Vopak Terminal Los Angeles, Inc.
<b>Name of Facility</b>	Marine Terminal, Wilmington
<b>Facility Address</b>	401 Canal Street at Berths 187-188, Port of Los Angeles
	Wilmington, California 90744
	Los Angeles County
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a minor discharge.	

The discharge by Vopak Terminal Los Angeles, Inc. from the discharge points identified below is subject to waste discharge requirements as set forth in this Order:

**Table 2. Discharge Location**


Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001	Storm water, steam condensate, boiler blowdown and external truck rinse water	33 °, 45 ', 54.1 " N	118 °, 15 ', 35.4 " W	Los Angeles Inner Harbor

**Table 3. Administrative Information**

This Order was adopted by the Regional Water Quality Control Board on:	November 1, 2007
This Order shall become effective on:	December 1, 2007
This Order shall expire on:	October 10, 2012
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	180 days prior to the Order expiration date

IT IS HEREBY ORDERED, that Order No. R4-2002-0079 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA), and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, Tracy J. Egoscue, Executive Officer, do hereby certify the following is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on November 1, 2007.

  
 \_\_\_\_\_  
 Tracy J. Egoscue, Executive Officer

**TABLE OF CONTENTS**

I. Facility Information ..... 3

II. Findings ..... 4

III. Discharge Prohibitions..... 9

IV. Effluent Limitations and Discharge Specifications ..... 10

    A. Effluent Limitations – Discharge Point 001 ..... 10

    B. Land Discharge Specifications..... 11

    C. Reclamation Specifications..... 11

V. Receiving Water Limitations ..... 12

    A. Surface Water Limitations..... 12

    B. Groundwater Limitations ..... 13

VI. Provisions ..... 13

    A. Standard Provisions..... 13

    B. Monitoring and Reporting Program Requirements..... 15

    C. Special Provisions..... 15

        1. Reopener Provisions..... 15

        2. Special Studies, Technical Reports and Additional Monitoring Requirements..... 16

        3. Best Management Practices and Pollution Prevention ..... 16

        4. Compliance Schedules ..... 17

        5. Construction, Operation and Maintenance Specifications..... 17

        6. Special Provisions for Municipal Facilities (POTWs Only) ..... 17

        7. Other Special Provisions..... 17

VII. Compliance Determination ..... 17

    A. Single Constituent Effluent Limitation. .... 17

    B. Effluent Limitations Expressed as a Sum of Several Constituents..... 17

    C. Multiple Sample Data..... 17

    E. Instantaneous Minimum Effluent Limitation. .... 18

Attachment A – Definitions..... A-1

Attachment B – Topographic Map..... B-1

Attachment C – Flow Schematic ..... C-1

Attachment D – Federal Standard Provisions ..... D-1

Attachment E – Monitoring and Reporting Program (MRP) ..... E-1

Attachment F – Fact Sheet ..... F-1

Attachment G – SWPPP Requirements ..... G-1

Attachment H – State Water Board Minimum Levels ..... H-1

Attachment I – Priority Pollutants ..... I-1

**I. FACILITY INFORMATION**

The following Discharger is subject to waste discharge requirements as set forth in this Order:

**Table 4. Facility Information**

<b>Discharger</b>	Vopak Terminal Los Angeles, Inc.
<b>Name of Facility</b>	Marine Terminal
<b>Facility Address</b>	401 Canal Street
	Wilmington, CA 90744
	Los Angeles County
<b>Facility Contact, Title, and Phone</b>	Jeff Spagg, Safety, Health & Environmental Supervisor (310) 518-6409
<b>Mailing Address</b>	SAME
<b>Type of Facility</b>	Petroleum transfer and bulk storage facility
<b>Facility Design Flow</b>	Up to 12,000 gallons per day (gpd)

## II. FINDINGS

The California Regional Water Quality Control Board, Los Angeles Region (hereinafter Regional Water Board), finds:

- A. **Background.** The Vopak Terminal Los Angeles Inc. (hereinafter Discharger) is currently discharging pursuant to Order No. R4-2002-0079 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0055247. Vopak Terminal Los Angeles, Inc. was previously called Paktank, but the name was changed in 2001. The Discharger submitted a Report of Waste Discharge (ROWD), dated September 20, 2006, and applied for a NPDES permit renewal to discharge up to 12,000 gpd of treated wastewater from the Marine Terminal, hereinafter Facility. The application was deemed complete on March 7, 2007.
- B. **Facility Description.** The Discharger owns and operates the oil transfer and bulk storage facility. The facility consists of 61 bulk storage tanks, vehicle loading and off-loading areas, five berths for vessels and barges, and a wastewater treatment system. Storage tanks hold primarily petroleum products (i.e. diesel fuel, fuel oil, and lube oil); however, volatile organic compounds, vegetable oils, caustic soda, and caustic potash are stored as well. Wastewater (i.e., storm water runoff, tank truck external rinse water, boiler blowdown, and steam condensate) is collected via isolated drains throughout the Facility and pumped through four settling/holding tanks, then into a 12-stage, weir-type clarifier and finally into four carbon canisters for polishing. Under normal circumstances, the treated wastewater is pumped to the publicly owned treatment works (POTW) of Joint Outfall System, under industrial pretreatment permit No. 387757 after clarification, but prior to polishing. During an emergency situation, when the storm water runoff exceeds the storage capacity of the facility's holding tanks (527,000 gallons) the treated wastewater (up to 12,000 gpd) is discharged from Discharge Point 001 (see table on cover page) to the Los Angeles Inner Harbor, a water of the United States within Los Angeles County Coastal watershed. Attachment B provides a topographic map of the area around the facility. Attachment C provides a flow schematic of the facility. No discharge has occurred during the past 25 years.
- C. **Legal Authorities.** This Order is issued pursuant to section 402 of the Federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).
- D. **Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and through special studies. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E and G through I are also incorporated into this Order.
- E. **California Environmental Quality Act (CEQA).** Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of the CEQA, Public Resources Code sections 21100 – 21177.

**F. Technology-based Effluent Limitations.** Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations<sup>1</sup>, require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Best Professional Judgment (BPJ) in accordance with Part 125, section 125.3. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet.

**G. Water Quality-based Effluent Limitations.** Section 301 of the CWA and section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

Section 122.44(d) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state’s narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

**H. Water Quality Control Plans.** The Regional Water Board adopted a Water Quality Control Plan for the Los Angeles Region (hereinafter Basin Plan) on June 13, 1994 that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to Los Angeles Inner Harbor are as follows:

**Table 5. Basin Plan Beneficial Uses**

Discharge Point	Receiving Water Name	Beneficial Uses
001	Los Angeles Inner Harbor	<u>Existing:</u> Industrial service supply (IND), navigation (NAV), Non-contact water recreation (REC-2), commercial and sport fishing (COMM), marine habitat (MAR), and rare, threatened or endangered species (RARE). <u>Potential:</u> Water contact recreation (REC-1), and shellfish harvesting (SHELL).

The 1994 Basin Plan provided water quality objectives for ammonia to protect aquatic life, in Table 3-1 through Table 3-4. However, on March 4, 2004, the ammonia objectives were revised by the Regional Water Board with the adoption of Resolution No. 2004-022, Amendment to the Water Quality Plan for the Los Angeles Region to Update the Ammonia Objectives for Inland Surface Waters Not Characteristic of Freshwater (including enclosed bays, estuaries and

<sup>1</sup> All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

wetlands) with the Beneficial Use designations for protection of “Aquatic Life”. The ammonia Basin Plan amendment was approved by the Office of Administrative Law on September 15, 2004, and by USEPA on May 19, 2005. The amendment revised the Basin Plan by updating the ammonia objectives for inland surface waters not characteristic of freshwater such that they are consistent with the USEPA “Ambient Water Quality Criteria for Ammonia (Saltwater) – 1989.” The amendment revised the regulatory provisions of the Basin Plan by adding language to Chapter 3, “Water Quality Objectives.”

The amendment contains objectives for a 4-day average concentration of un-ionized ammonia of 0.035 mg/L, and a 1-hour average concentration of un-ionized ammonia of 0.233 mg/L. The objectives are fixed concentrations of un-ionized ammonia, independent of pH, temperature, or salinity. The amendment also contains an implementation procedure to convert un-ionized ammonia objectives to total ammonia effluent limitations.

No limitation for ammonia is included in this Order because there is no monitoring data to conduct reasonable potential analysis (RPA). The Order includes requirements for monitoring of ammonia for both effluent and receiving waters.

The State Water Board adopted a Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. This plan contains temperature objectives for surface waters. Requirements of this Order implement the Thermal Plan.

- I. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later was amended it on May 4, 1995 and November 9, 1999. USEPA adopted the CTR on May 18, 2000. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. On February 13, 2001, the CTR was amended. These rules contain water quality criteria for priority pollutants.
- J. **State Implementation Policy.** On March 2, 2000, State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. Requirements of this Order implement the SIP.
- K. **Compliance Schedules and Interim Requirements.** Section 2.1 of the SIP provides that, based on a Discharger’s request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed five years from the date that the permit is issued or reissued, nor may it extend beyond ten years from the effective date of the SIP (or May 18, 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation exceeds one year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Water Quality Control Plan Los Angeles Region, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to

implement a new or revised water quality objective. This Order does not include compliance schedules and interim effluent limitations.

- L. **Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes (40 C.F.R. § 131.21, 65 Fed. Reg. 24641 (April 27, 2000).) Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- M. **Stringency of Requirements.** This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on biochemical oxygen demand (BOD), total suspended solids (TSS), oil and grease, phenols, sulfides, and turbidity that are discussed in section IV.B in the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. These limitations are not more stringent than required by the CWA.

Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to section 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

- N. **Antidegradation Policy.** Section 131.12 requires that state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet the permitted discharge is consistent with the antidegradation provision of section 131.12 and State Water Board Resolution No. 68-16.
- O. **Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.

- P. **Monitoring and Reporting.** Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- Q. **Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The Discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.
- R. **Provisions and Requirements of Implementing State Law.** The provisions and requirements in subsections IV.B, IV.C, V.B, and VI.C of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- S. **Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- T. **Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet of this Order.

### III. DISCHARGE PROHIBITIONS

- A. Wastes discharged shall be limited to the discharge of storm water as described in the findings. Discharges are prohibited except when the storage capacity of the surface impoundment and the allowable capacity for discharge into the sanitary sewer are exceeded, or other unforeseen circumstances beyond the reasonable control of the Discharger prevent the use of the storage basins and discharge to the sanitary sewer. The discharge of wastes from accidental spills or other sources is prohibited.
- B. Discharges of water, materials, thermal wastes, elevated temperature wastes, toxic wastes, deleterious substances, or wastes other than those authorized by this Order, to a storm drain system, Los Angeles Inner Harbor, or other waters of the State, are prohibited.
- C. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or a nuisance as defined by section 13050 of the Water Code.
- D. Wastes discharged shall not contain any substances in concentrations toxic to human, animal, plant, or aquatic life.
- E. The discharge shall not cause a violation of any applicable water quality standards for receiving waters adopted by the Regional Water Board or the State Water Resources Control Board as required by the Federal CWA and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the Federal CWA, and amendments thereto, the Board will revise and modify this Order in accordance with such more stringent standards.
- F. The discharge of any radiological, chemical, or biological warfare agent or high level radiological waste is prohibited.
- G. Any discharge of wastes at any point(s) other than specifically described in this Order is prohibited, and constitutes a violation of the Order.

**IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS**

- A. Effluent Limitations – Discharge Point 001
  - 1. Final Effluent Limitations – Discharge Point 001
    - a. The discharge of storm water, steam condensate, boiler blowdown, and truck washing water shall maintain compliance with the following effluent limitations at Discharge Point 001, with compliance measured at Monitoring Location EFF-001 as described in the attached MRP (Attachment E):

**Table 6. Effluent Limitations**

Parameter	Units	Effluent Limitations		
		Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
BOD <sub>5</sub> 20°C	mg/L	30	--	--
Oil and grease	mg/L	15	--	--
pH	s.u.		6.5	8.5
Total Suspended Solids (TSS)	mg/L	75	--	--
Turbidity	NTU	75		
Arsenic, Total Recoverable	µg/L	50	--	--
Cadmium, Total Recoverable	µg/L	10	--	--
Chromium, Total	µg/L	50	--	--
Copper, Total Recoverable	µg/L	1,000	--	--
Lead, Total Recoverable	µg/L	50	--	--
Mercury, Total	µg/L	2.0	--	--
Selenium, Total Recoverable	µg/L	10	--	--
Silver, Total Recoverable	µg/L	50	--	--
Zinc, Total Recoverable	µg/L	5,000	--	--
Benzene	µg/L	1.0	--	--
Ethylbenzene	µg/L	10	--	--
Toluene	µg/L	10	--	--
Phenols	mg/L	1.0	--	--
Sulfides	mg/L	1.0	--	--
Temperature	°F		--	86
Xylene	µg/L	10	--	--

- b. **Toxicity.** There shall be no acute toxicity in the discharge. The acute toxicity of the effluent shall be such that:
  - (1) The average survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay tests shall be at least 90%, and
  - (2) No single test producing less than 70% survival. Compliance with the toxicity objectives will be determined by the method described in section V of the MRP No. 5985 (Attachment E).
  
- c. **Ammonia.** Total un-ionized ammonia (NH<sub>3</sub>) water quality objectives of 0.035 mg/L for the 4-day average and 0.233 mg/L for the 1-hour average. These values are to be translated utilizing the implementation procedure included in Resolution No. 2004-022 which revised the saltwater ammonia water quality objectives in the 1994 Basin Plan.

The implementation procedure requires:

1. Determine the downstream applicable water quality objectives for ammonia for the receiving water immediately downstream of the discharge (utilize the Determination of Freshwater, Brackish Water, or Saltwater Conditions included in the Implementation section of Resolution No. 2004-022).
  
2. Since there is no mixing zone established:  
ECA = WQO
  
3. To adjust the un-ionized saltwater ammonia objective to an ECA expressed as total ammonia, the following equation shall be used:

$$[\text{NH}_4^+] + [\text{NH}_3] = [\text{NH}_3] + [\text{NH}_3] \cdot 10^{(\text{pK}_a^s + 0.0324(298 - T) + 0.0415 \text{ P/T-pH})}$$

Where: P = 1 atm  
 T = temperature (°K)  
 $\text{pK}_a^s = 0.116 \cdot I + 9.425$ , the stoichiometric acid hydrolysis constant of ammonium ions in saltwater based on i  
 $i = 19.9273 \text{ S} (1000 - 1.005109 \text{ S})^{-1}$ , the molal ionic strength of saltwater based on S  
 S = salinity

(Per USEPA *Ambient Water Quality Criteria for Ammonia (Saltwater) – 1989*)

**B. Land Discharge Specifications**

[Not applicable]

**C. Reclamation Specifications**

[Not applicable]

## V. RECEIVING WATER LIMITATIONS

### A. Surface Water Limitations

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in Los Angeles Inner Harbor:

1. The normal ambient pH to fall below 6.5 nor exceed 8.5 units nor vary from normal ambient pH levels by more than 0.5 units.
2. Depress the concentration of dissolved oxygen to fall below 5.0 mg/L anytime, and the median dissolved oxygen concentration for any three consecutive months shall not be less than 80 percent of the dissolved oxygen content at saturation.
3. Surface water temperature to rise greater than 5°F above the natural temperature of the receiving waters at any time or place. At no time shall the temperature be raised above 80°F as a result of waste discharged.
4. Exceed total ammonia (as N) concentrations specified in the Regional Water Board Resolution No. 2004-022. Resolution No. 2004-022 revised the ammonia water quality objectives for inland surface waters not characteristic of freshwater in the 1994 Basin Plan, to be consistent with USEPA's "*Ambient Water Quality Criteria for Ammonia (Saltwater) – 1989.*" Adopted on March 4, 2004, Resolution No. 2004-022 was approved by State Water Board, Office of Administrative Law (OAL) and USEPA respectively on July 22, 2004, September 14, 2004, and May 19, 2005, and is now in effect.
5. The presence of visible, floating, suspended or deposited macroscopic particulate matter or foam.
6. Oils, greases, waxes, or other materials in concentrations that result in a visible film or coating on the surface of the receiving water or on objects in the water.
7. Suspended or settleable materials, chemical substances or pesticides in amounts that cause nuisance or adversely affect any designated beneficial use.
8. Toxic or other deleterious substances in concentrations or quantities which cause deleterious effects on aquatic biota, wildlife, or waterfowl or render any of these unfit for human consumption either at levels created in the receiving waters or as a result of biological concentration.
9. Accumulation of bottom deposits or aquatic growths.
10. Biostimulatory substances at concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses.
11. The presence of substances that result in increases of BOD that adversely affect beneficial uses.
12. Taste or odor-producing substances in concentrations that alter the natural taste, odor, and/or color of fish, shellfish, or other edible aquatic resources; cause nuisance; or adversely affect beneficial uses.

13. Alteration of turbidity, or apparent color beyond present natural background levels.
14. Damage, discolor, nor cause formation of sludge deposits on flood control structures or facilities nor overload the design capacity.
15. Degrade surface water communities and populations including vertebrate, invertebrate, and plant species.
16. Problems associated with breeding of mosquitoes, gnats, black flies, midges, or other pests.
17. Create nuisance, or adversely effect beneficial uses of the receiving water.
18. Violation of any applicable water quality standards for receiving waters adopted by the Regional Water Board or State Water Board. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments thereto, the Regional Water Board will revise or modify this Order in accordance with such standards.

B. Groundwater Limitations  
[Not applicable]

## VI. PROVISIONS

A. Standard Provisions

1. Federal Standard Provisions. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
2. Regional Water Board Standard Provisions. The Discharger shall comply with the following provisions:
  - a. This Order may be modified, revoked, reissued, or terminated in accordance with the provisions of sections 122.44, 122.62, 122.63, 122.64, 125.62 and 125.64. Causes for taking such actions include, but are not limited to: failure to comply with any condition of this Order; endangerment to human health or the environment resulting from the permitted activity; or acquisition of newly-obtained information which would have justified the application of different conditions if known at the time of Order adoption. The filing of a request by the Discharger for an Order modification, revocation, and issuance or termination, or a notification of planned changes or anticipated noncompliance does not stay any condition of this Order.
  - b. The Discharger must comply with the lawful requirements of municipalities, counties, drainage districts, and other local agencies regarding discharges of storm water to storm drain systems or other water courses under their jurisdiction; including applicable requirements in the municipal storm water management program developed to comply with NPDES permits issued by the Regional Water Board to local agencies.
  - c. Discharge of wastes to any point other than specifically described in this Order and permit is prohibited and constitutes a violation thereof.

- d. The Discharger shall comply with all applicable effluent limitations, national standards of performance, toxic effluent standards, and all federal regulations established pursuant to sections 301, 302, 303(d), 304, 306, 307, 316, 318, 405, and 423 of the Federal CWA and amendments thereto.
- e. These requirements do not exempt the operator of the waste disposal facility from compliance with any other laws, regulations, or ordinances which may be applicable; they do not legalize this waste disposal facility, and they leave unaffected any further restraints on the disposal of wastes at this site which may be contained in other statutes or required by other agencies.
- f. Oil or oily material, chemicals, refuse, or other pollutionable materials shall not be stored or deposited in areas where they may be picked up by rainfall and carried off of the property and/or discharged to surface waters. Any such spill of such materials shall be contained and removed immediately.
- g. A copy of these waste discharge specifications shall be maintained at the discharge facility so as to be available at all times to operating personnel.
- h. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
  - (1) Violation of any term or condition contained in this Order;
  - (2) Obtaining this Order by misrepresentation, or failure to disclose all relevant facts;
  - (3) A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- i. If there is any storage of hazardous or toxic materials or hydrocarbons at this facility and if the facility is not manned at all times, a 24-hour emergency response telephone number shall be prominently posted where it can easily be read from the outside.
- j. The Discharger shall notify the Regional Water Board not later than 120 days in advance of implementation of any plans to alter production capacity of the product line of the manufacturing, producing or processing facility by more than ten percent. Such notification shall include estimates of proposed production rate, the type of process, and projected effects on effluent quality. Notification shall include submittal of a new report of waste discharge appropriate filing fee.
- k. The Discharger shall file with the Regional Water Board a report of waste discharge at least 120 days before making any material change or proposed change in the character, location or volume of the discharge.
- l. All existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Regional Water Board as soon as they know or have reason to believe that they have begun or expect to begin to use or manufacture intermediate or final product or byproduct of any toxic pollutant that was not reported on their application.
- m. In the event of any change in name, ownership, or control of these waste disposal facilities, the discharger shall notify this Regional Water Board of such change and shall notify the succeeding owner or operator of the existence of this Order by letter, copy of which shall be forwarded to the Regional Water Board.

- n. The Water Code provides that any person who violates a waste discharge requirement or a provision of the Water Code is subject to civil penalties of up to \$5,000 per day, \$10,000 per day, or \$25,000 per day of violation, or when the violation involves the discharge of pollutants, is subject to civil penalties of up to \$10 per gallon per day or \$25 per gallon per day of violation; or some combination thereof, depending on the violation, or upon the combination of violations.

Violation of any of the provisions of the NPDES program or of any of the provisions of this Order may subject the violator to any of the penalties described herein, or any combination thereof, at the discretion of the prosecuting authority; except that only one kind of penalty may be applied for each kind of violation.

- o. The discharge of any product registered under the Federal Insecticide, Fungicide, and Rodenticide Act to any waste stream which may ultimately be released to waters of the United States, is prohibited unless specifically authorized elsewhere in this permit or another NPDES permit. This requirement is not applicable to products used for lawn and agricultural purposes.
- p. The discharge of any waste resulting from the combustion of toxic or hazardous wastes to any waste stream that ultimately discharges to waters of the United States is prohibited, unless specifically authorized elsewhere in this permit.
- q. The Discharger shall notify the Executive Officer in writing no later than 6 months prior to planned discharge of any chemical, other than the products previously reported to the Executive Officer, which may be toxic to aquatic life. Such notification shall include:
  - (1) Name and general composition of the chemical,
  - (2) Frequency of use,
  - (3) Quantities to be used,
  - (4) Proposed discharge concentrations, and
  - (5) USEPA registration number, if applicable.

## B. Monitoring and Reporting Program Requirements

The Discharger shall comply with the MRP and future revisions thereto, in Attachment E of this Order. If there is any conflict between provisions stated in the MRP and the Regional Water Board Standard Provisions, those provisions stated in the MRP shall prevail.

## C. Special Provisions

### 1. Reopener Provisions

- a. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the Federal CWA, and amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such more stringent standards.
- b. This Order may be reopened to include effluent limitations for toxic constituents determined to be present in significant amounts in the discharge through a more comprehensive monitoring program included as part of this Order and based on the results of the RPA.

- c. This Order may be reopened and modified, in accordance with the provisions set forth in 40 CFR Parts 122 and 124, to include requirements for the implementation of the watershed management approach or to include new MLs.
- d. This Order may be reopened and modified to revise effluent limitations as a result of future Basin Plan Amendments, such as an update of an objective or the adoption of a TMDL for the Los Angeles Inner Harbor.
- e. This Order may be reopened upon submission by the Discharger of adequate information, as determined by the Regional Water Board, to provide for dilution credits or a mixing zone, as may be appropriate.

## 2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. Initial Investigation Toxicity Reduction Evaluation (TRE) Workplan. The Discharger shall submit to the Regional Water Board an Initial Investigation Toxicity Reduction Evaluation (TRE) workplan (1-2 pages) within 180 days of the effective date of this permit. This plan shall describe the steps the permittee intends to follow in the event that acute toxicity is detected, and should include at a minimum:
  - 1) A description of the investigation and evaluation techniques that will be used to identify potential causes/sources of toxicity, effluent variability, and treatment system efficiency;
  - 2) A description of the facility's method of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in operation of the facility;
  - 3) If a toxicity identification evaluation (TIE) is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor) (section V of the MRP, Attachment E) provides references for the guidance manuals that should be used for performing TIEs).

## 3. Best Management Practices and Pollution Prevention

The Discharger shall submit, within 180 days of the effective date of this Order:

- a. An updated SWPPP that describes site-specific management practices for minimizing contamination of storm water runoff and for preventing contaminated storm water runoff from being discharged directly to waters of the State. The BMPs shall address the following specific areas of concern: petroleum storage tanks, equipment washing, vehicle traffic, and chemical storage. The SWPPP shall be developed in accordance with the requirements in Attachment G.
- b. Best Management Practice Plan (BMPP) that entail site-specific plans and procedures implemented and/or to be implemented to prevent hazardous waste/material from being discharged to waters of the State. The updated BMPP shall be consistent with the general guidance contained in the USEPA *Guidance Manual for Developing Best Management Practices (BMPs)* (EPA 833-B-93-004). In particular, a risk assessment of each area identified by the Discharger shall be performed to determine the potential for hazardous or toxic waste/material discharge to surface waters.

The plans shall cover all areas of the facility and shall include an updated drainage map for the facility. The Discharger shall identify on a map of appropriate scale the areas that

contribute runoff to the permitted discharge points (e.g., petroleum storage tanks); describe the activities in each area and the potential for contamination of storm water runoff and the discharge of hazardous waste/material.

- c. An updated Spill Contingency Plan that shall be site specific and shall cover all areas of the facility including the tank farm.

The Discharger shall implement SWPPP, BMPP, and Spill Contingency Plan within 10 days of the approval by the Executive Officer. The plans shall be reviewed annually and at the same time. Updated information shall be submitted within 30 days of revision.

#### 4. Compliance Schedules

- a. Compliance Plan.  
[Not applicable]

#### 5. Construction, Operation and Maintenance Specifications

- a. The Discharger shall at all times properly operate and maintain all facilities and systems installed or used to achieve compliance with this Order

#### 6. Special Provisions for Municipal Facilities (POTWs Only) [Not applicable]

#### 7. Other Special Provisions [Not applicable]

### VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

#### A. Single Constituent Effluent Limitation.

If the concentration of the pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reported Minimum Level (see Reporting Requirement I.G. of the MRP), then the Discharger is out of compliance.

#### B. Effluent Limitations Expressed as a Sum of Several Constituents.

If the sum of the individual pollutant concentrations is greater than the effluent limitation, then the Discharger is out of compliance. In calculating the sum of the concentrations of a group of pollutants, consider constituents reported as ND or DNQ to have concentrations equal to zero, provided that the applicable ML is used.

#### C. Multiple Sample Data.

When determining compliance with an MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

D. Maximum Daily Effluent Limitations (MDEL).

If a daily discharge exceeds the MDEL for a given parameter, an alleged violation will be flagged and the discharger will be considered out of compliance for that parameter for that 1 day only within the reporting period. For any 1 day during which no sample is taken, no compliance determination can be made for that day.

E. Instantaneous Minimum Effluent Limitation.

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

F. Instantaneous Maximum Effluent Limitation.

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

## ATTACHMENT A – DEFINITIONS

### DEFINITIONS

**Average Monthly Effluent Limitation (AMEL):** the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

**Average Weekly Effluent Limitation (AWEL):** the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

**Daily Discharge:** Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

**Instantaneous Maximum Effluent Limitation:** the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

**Instantaneous Minimum Effluent Limitation:** the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

**Maximum Daily Effluent Limitation (MDEL):** the highest allowable daily discharge of a pollutant.

**µg/L:** micrograms per Liter

**mg/L:** milligrams per Liter

**MGD:** million gallons per day


**Six-month Median Effluent Limitation:** the highest allowable moving median of all daily discharges for any 180-day period.

## ACRONYMS AND ABBREVIATIONS

AMEL	Average Monthly Effluent Limitation
B	Background Concentration
BAT	Best Available Technology Economically Achievable
Basin Plan	<i>Water Quality Control Plan for the Coastal Watersheds of Los Angeles and Ventura Counties</i>
BCT	Best Conventional Pollutant Control Technology
BMP	Best Management Practices
BMPPP	Best Management Practices Plan
BPJ	Best Professional Judgment
BOD	Biochemical Oxygen Demand 5-day @ 20 °C
BPT	Best Practicable Treatment Control Technology
C	Water Quality Objective
CCR	California Code of Regulations
CEQA	California Environmental Quality Act
CFR	Code of Federal Regulations
CTR	California Toxics Rule
CV	Coefficient of Variation
CWA	Clean Water Act
CWC	California Water Code
Discharger	Vopak Terminal Los Angeles, Inc.
DMR	Discharge Monitoring Report
DNQ	Detected But Not Quantified
ELAP	California Department of Health Services Environmental Laboratory Accreditation Program
ELG	Effluent Limitations, Guidelines and Standards
Facility	Marine Terminal
gpd	gallons per day
IC	Inhibition Coefficient
IC <sub>15</sub>	Concentration at which the organism is 15% inhibited
IC <sub>25</sub>	Concentration at which the organism is 25% inhibited
IC <sub>40</sub>	Concentration at which the organism is 40% inhibited
IC <sub>50</sub>	Concentration at which the organism is 50% inhibited
LA	Load Allocations
LOEC	Lowest Observed Effect Concentration
µg/L	micrograms per Liter
mg/L	milligrams per Liter
MDEL	Maximum Daily Effluent Limitation
MEC	Maximum Effluent Concentration
MGD	Million Gallons Per Day
ML	Minimum Level
MRP	Monitoring and Reporting Program
ND	Not Detected
NOEC	No Observable Effect Concentration
NPDES	National Pollutant Discharge Elimination System
NSPS	New Source Performance Standards
NTR	National Toxics Rule
OAL	Office of Administrative Law
PMEL	Proposed Maximum Daily Effluent Limitation
PMP	Pollutant Minimization Plan


POTW	Publicly Owned Treatment Works
QA	Quality Assurance
QA/QC	Quality Assurance/Quality Control
Ocean Plan	<i>Water Quality Control Plan for Ocean Waters of California</i>
Regional Water Board	California Regional Water Quality Control Board, Los Angeles Region
RPA	Reasonable Potential Analysis
SCP	Spill Contingency Plan
SIP	State Implementation Policy ( <i>Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California</i> )
SMR	Self Monitoring Reports
State Water Board	California State Water Resources Control Board
SWPPP	Storm Water Pollution Prevention Plan
TAC	Test Acceptability Criteria
Thermal Plan	<i>Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California</i>
TIE	Toxicity Identification Evaluation
TMDL	Total Maximum Daily Load
TOC	Total Organic Carbon
TRE	Toxicity Reduction Evaluation
TSD	Technical Support Document
TSS	Total Suspended Solid
TU <sub>c</sub>	Chronic Toxicity Unit
USEPA	United States Environmental Protection Agency
WDR	Waste Discharge Requirements
WET	Whole Effluent Toxicity
WLA	Waste Load Allocations
WQBELS	Water Quality-Based Effluent Limitations
WQS	Water Quality Standards
%	Percent

**ATTACHMENT B – TOPOGRAPHIC MAP**



**ATTACHMENT C – FLOW SCHEMATIC**

**Attachment Page #2  
 Part VI Design & Flow Diagram  
 Sept. 20, 2006**



Storm water treatment system at  
 Vopak Terminal Los Angeles:  
 401 Canal Street  
 Wilmington, CA

## **ATTACHMENT D – FEDERAL STANDARD PROVISIONS**

### **I. STANDARD PROVISIONS – PERMIT COMPLIANCE**

#### **A. Duty to Comply**

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the CWA and the Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application [*section 122.41(a)*].
2. The Discharger shall comply with effluent standards or prohibitions established under section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not been modified to incorporate the requirement [ *section 122.41(a)(1)*].

#### **B. Need to Halt or Reduce Activity Not a Defense**

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order [*section 122.41(c)*].

#### **C. Duty to Mitigate**

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment [*section 122.41(d)*].

#### **D. Proper Operation and Maintenance**

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order [*section 122.41(e)*].

#### **E. Property Rights**

1. This Order does not convey any property rights of any sort or any exclusive privileges [*section 122.41(g)*].
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of State or local law or regulations [*section 122.5(c)*].

## F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, USEPA, and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to [section 122.41(i)] [Water Code section 13383(c)]:

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order [section 122.41(i)(1)];
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order [section 122.41(i)(2)];
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order [section 122.41(i)(3)];
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location [section 122.41(i)(4)].

## G. Bypass

1. Definitions
  - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility [section 122.41(m)(1)(i)].
  - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production [section 122.41(m)(1)(ii)].
2. Bypass not exceeding limitations – The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3 and I.G.5 below [section 122.41(m)(2)].
3. Prohibition of bypass – Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless [section 122.41(m)(4)(i)]:
  - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage [section 122.41(m)(4)(A)];
  - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance [section 122.41(m)(4)(B)]; and

- c. The Discharger submitted notice to the Regional Water Board as required under Standard Provision – Permit Compliance I.G.5 below [*section 122.41(m)(4)(C)*].
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above [*section 122.41(m)(4)(ii)*].
5. Notice
  - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass [*section 122.41(m)(3)(i)*].
  - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below [*section 122.41(m)(3)(ii)*].

## H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation [*section 122.41(n)(1)*].

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph H.2 of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review [*section 122.41(n)(2)*].
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that [*section 122.41(n)(3)*]:
  - a. An upset occurred and that the Discharger can identify the cause(s) of the upset [*section 122.41(n)(3)(i)*];
  - b. The permitted facility was, at the time, being properly operated [*section 122.41(n)(3)(ii)*];
  - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b [*section 122.41(n)(3)(iii)*]; and
  - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above [*section 122.41(n)(3)(iv)*].
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof [*section 122.41(n)(4)*].

## II. STANDARD PROVISIONS – PERMIT ACTION

### A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition [section 122.41(f)].

### B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit [section 122.41(b)].

### C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the CWC [section 122.41(l)(3) and section 122.61].

## III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity [section 122.41(j)(1)].
- B. Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order [section 122.41(j)(4) and section 122.44(i)(1)(iv)].

## IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time [section 122.41(j)(2)].
- B. Records of monitoring information shall include:
  - 1. The date, exact place, and time of sampling or measurements [section 122.41(j)(3)(i)];
  - 2. The individual(s) who performed the sampling or measurements [section 122.41(j)(3)(ii)];
  - 3. The date(s) analyses were performed [section 122.41(j)(3)(iii)];

4. The individual(s) who performed the analyses [*section 122.41(j)(3)(iv)*];
5. The analytical techniques or methods used [*section 122.41(j)(3)(v)*]; and
6. The results of such analyses [*section 122.41(j)(3)(vi)*].

**C. Claims of confidentiality for the following information will be denied [40 CFR §122.7(b)]:**

1. The name and address of any permit applicant or Discharger [*section 122.7(b)(1)*]; and
2. Permit applications and attachments, permits and effluent data [*section 122.7(b)(2)*].

**V. STANDARD PROVISIONS – REPORTING**

**A. Duty to Provide Information**

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order [*section 122.41(h)*] [*Water Code section 13267*].

**B. Signatory and Certification Requirements**

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, AND V.B.5 below [*section 122.41(k)*].
2. All permit applications shall be signed as follows:
  - a. For a corporation: By a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures [*section 122.22(a)(1)*];
  - b. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively [*section 122.22(a)(2)*]; or
  - c. For a municipality, State, federal, or other public agency: by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a

senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA) [*section 122.22(a)(3)*].

3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in paragraph (b) of this provision, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described in paragraph (2.) of this provision [*section 122.22(b)(1)*];
  - b. The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company (a duly authorized representative may thus be either a named individual or any individual occupying a named position) [*section 122.22(b)(2)*]; and
  - c. The written authorization is submitted to the Regional Water Board, State Water Board, or USEPA [*section 122.22(b)(3)*].
4. If an authorization under paragraph (3.) of this provision is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph (3.) of this provision must be submitted to the Regional Water Board, State Water Board or USEPA prior to or together with any reports, information, or applications, to be signed by an authorized representative [*section 122.22(c)*].
5. Any person signing a document under paragraph (2.) or (3.) of this provision shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations” [*section 122.22(d)*].

### **C. Monitoring Reports**

1. Monitoring results shall be reported at the intervals specified in the MRP in this Order [*section 122.41(l)(4)*].
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices [*section 122.41(l)(4)(i)*].
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved

under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board [section 122.41(l)(4)(ii)].

4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order [section 122.41(l)(4)(iii)].

#### **D. Compliance Schedules**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date [section 122.41(l)(5)].

#### **E. Twenty-Four Hour Reporting**

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance [section 122.41(l)(6)(i)].
2. The following shall be included as information that must be reported within 24 hours under this paragraph [section 122.41(l)(6)(ii)]:
  - a. Any unanticipated bypass that exceeds any effluent limitation in this Order [section 122.41(l)(6)(ii)(A)].
  - b. Any upset that exceeds any effluent limitation in this Order [section 122.41(l)(6)(ii)(B)].
  - c. Violation of a maximum daily discharge limitation for any of the pollutants listed in this Order to be reported within 24 hours [section 122.41(l)(6)(ii)(C)].
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours [section 122.41(l)(6)(iii)].

#### **F. Planned Changes**

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when [section 122.41(l)(1)]:

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) [section 122.41(l)(1)(i)]; or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to

effluent limitations in this Order nor to notification requirements under section 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1) [*section 122.41(l)(1)(iii)*].

3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan [*section 122.41(l)(1)(iii)*].

#### **G. Anticipated Noncompliance**

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements [*section 122.41(l)(2)*].

#### **H. Other Noncompliance**

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E [*section 122.41(l)(7)*].

#### **I. Other Information**

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information [*section 122.41(l)(8)*].

### **VI. STANDARD PROVISIONS – ENFORCEMENT**

- A. The CWA provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The CWA provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15

years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions [section 122.41(a)(2)] [Water Code sections 13385 and 13387].

- B. Any person may be assessed an administrative penalty by the Regional Water Board for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000 [section 122.41(a)(3)].
- C. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both [section 122.41(j)(5)].
- D. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this Order, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both [section 122.41(k)(2)].

## VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

### A. Non-Municipal Facilities

Existing manufacturing, commercial, mining, and silvicultural Dischargers shall notify the Regional Water Board as soon as they know or have reason to believe [section 122.42(a)]:

1. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" [section 122.42(a)(1)]:
  - a. 100 micrograms per liter ( $\mu\text{g/L}$ ) [section 122.42(a)(1)(i)];
  - b. 200  $\mu\text{g/L}$  for acrolein and acrylonitrile; 500  $\mu\text{g/L}$  for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and 1 milligram per liter ( $\text{mg/L}$ ) for antimony [section 122.42(a)(1)(ii)];
  - c. Five (5) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge [section 122.42(a)(1)(iii)]; or
  - d. The level established by the Regional Water Board in accordance with 40 CFR §122.44(f) [section 122.42(a)(1)(iv)].

2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" [*section 122.42(a)(2)*]:
  - a. 500 micrograms per liter ( $\mu\text{g/L}$ ) [*section 122.42(a)(2)(i)*];
  - b. 1 milligram per liter ( $\text{mg/L}$ ) for antimony [*section 122.42(a)(2)(ii)*];
  - c. Ten (10) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge [*section 122.42(a)(2)(iii)*]; or
  - d. The level established by the Regional Water Board in accordance with 40 CFR §122.44(f) [*section 122.42(a)(2)(iv)*].

**B. Publicly-Owned Treatment Works (POTWs)**

All POTWs shall provide adequate notice to the Regional Water Board of the following [*section 122.42(b)*]:

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to Sections 301 or 306 of the CWA if it were directly discharging those pollutants [*section 122.42(b)(1)*]; and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order [*section 122.42(b)(2)*].

Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW [*section 122.42(b)(3)*].

**Attachment E – Monitoring and Reporting Program – Table of Contents**

Attachment E – Monitoring and Reporting Program (MRP) No. 5985 ..... E-2

- I. General Monitoring Provisions..... E-2
- II. Monitoring Locations ..... E-4
- III. Influent Monitoring Requirements..... E-5
- IV. Effluent Monitoring Requirements ..... E-5
  - A. Monitoring Location M-001 ..... E-5
- V. Whole Effluent Toxicity Testing Requirements ..... E-6
  - A. Definition of Toxicity ..... E-6
  - B. Acute Toxicity Effluent Monitoring Program ..... E-7
  - C. Chronic Toxicity Effluent Monitoring Program..... E-7
  - D. Quality Assurance..... E-7
  - E. Accelerated Monitoring and Initial Investigation TRE Trigger ..... E-7
  - F. TRE/TIE Trigger..... E-8
  - G. Steps in TRE and TIE Procedures..... E-8
  - H. Reporting ..... E-10
- VI. Land Discharge Monitoring Requirements ..... E-11
- VII. Reclamation Monitoring Requirements..... E-11
- VIII. Receiving Water Monitoring Requirements – Surface Water..... E-11
  - A. Monitoring Location RSW-001 ..... E-11
  - B. Visual Monitoring of Receiving Water Sampling Point ..... E-11
- IX. Other Monitoring Requirements..... E-12
  - A. Storm Water Monitoring..... E-12
  - B. SWPPP, BMPP, and Spill Contingency Plan Status and Effectiveness Report..... E-12
  - C. Chemical Use Report..... E-12
- X. Reporting Requirements..... E-12
  - A. General Monitoring and Reporting Requirements..... E-12
  - B. Self Monitoring Reports (SMRs) ..... E-13
  - C. Discharge Monitoring Reports (DMRs) ..... E-14
  - D. Other Reports ..... E-14

## **ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP) NO. 5985**

The Code of Federal Regulations section 122.48 requires that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Board to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements which implement the federal and California regulations.

### **I. GENERAL MONITORING PROVISIONS**

- A. An effluent sampling station shall be established for the point of discharge (Discharge Point 001 [Latitude 33° 45' 54", Longitude 118° 15' 35"]) and shall be located where representative samples of that effluent can be obtained.
- B. Effluent samples shall be taken downstream of any addition to treatment works and prior to mixing with the receiving waters.
- C. The Regional Water Board shall be notified in writing of any change in the sampling stations once established or in the methods for determining the quantities of pollutants in the individual waste streams.
- D. Pollutants shall be analyzed using the analytical methods described in sections 136.3, 136.4, and 136.5 (revised March 12, 2007); or, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. Laboratories analyzing effluent samples and receiving water samples shall be certified by the California Department of Health Services Environmental Laboratory Accreditation Program (ELAP) or approved by the Executive Officer and must include quality assurance/quality control (QA/QC) data in their reports. A copy of the laboratory certification shall be provided each time a new certification and/or renewal of the certification is obtained from ELAP.
- E. For any analyses performed for which no procedure is specified in the USEPA guidelines or in the MRP, the constituent or parameter analyzed and the method or procedure used must be specified in the monitoring report.
- F. Each monitoring report must affirm in writing that "all analyses were conducted at a laboratory certified for such analyses by the Department of Health Services or approved by the Executive Officer and in accordance with current USEPA guideline procedures or as specified in this MRP".
- G. The monitoring reports shall specify the analytical method used the Method Detection Limit (MDL), and the Minimum Level (ML) for each pollutant. For the purpose of reporting compliance with numerical limitations, performance goals, and receiving water limitations, analytical data shall be reported by one of the following methods, as appropriate:
  1. An actual numerical value for sample results greater than or equal to the ML; or
  2. "Detected, but Not Quantified (DNQ)" if results are greater than or equal to the laboratory's MDL but less than the ML; or,
  3. "Not-Detected (ND)" for sample results less than the laboratory's MDL with the MDL indicated for the analytical method used.

Analytical data reported as "less than" for the purpose of reporting compliance with permit limitations shall be the same or lower than the permit limit(s) established for the given parameter.

Current MLs (Attachment H) are those published by the State Water Board in the Policy for the Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California, as amended on February 24, 2005, which became effective July 13, 2005.

- H. Where possible, the MLs employed for effluent analyses shall be lower than the permit limitations established for a given parameter. If the ML value is not below the effluent limitation, then the lowest ML value and its associated analytical method shall be selected for compliance purposes. At least once a year, the Discharger shall submit a list of the analytical methods employed for each test and associated laboratory QA/QC procedures.

The Regional Water Board, in consultation with the State Water Board Quality Assurance Program, shall establish a ML that is not contained in Attachment H to be included in the Discharger's permit in any of the following situations:

1. When the pollutant under consideration is not included in Attachment H;
  2. When the Discharger and Regional Water Board agree to include in the permit a test method that is more sensitive than that specified in 40 CFR Part 136 (revised May 14, 1999);
  3. When the Discharger agrees to use an ML that is lower than that listed in Attachment H;
  4. When the Discharger demonstrates that the calibration standard matrix is sufficiently different from that used to establish the ML in Attachment H, and proposes an appropriate ML for their matrix; or,
  5. When the Discharger uses a method whose quantification practices are not consistent with the definition of an ML. Examples of such methods are the USEPA-approved method 1613 for dioxins and furans, method 1624 for volatile organic substances, and method 1625 for semi-volatile organic substances. In such cases, the Discharger, the Regional Water Board, and the State Water Board shall agree on a lowest quantifiable limit and that limit will substitute for the ML for reporting and compliance determination purposes.
- I. Water/wastewater samples must be analyzed within allowable holding time limits as specified in section 136.3. All QA/QC items must be run on the same dates the samples were actually analyzed, and the results shall be reported in the Regional Water Board format, when it becomes available, and submitted with the laboratory reports. Proper chain of custody procedures must be followed, and a copy of the chain of custody shall be submitted with the report.
- J. All analyses shall be accompanied by the chain of custody, including but not limited to data and time of sampling, sample identification, and name of person who performed sampling, date of analysis, name of person who performed analysis, QA/QC data, method detection limits, analytical methods, copy of laboratory certification, and a perjury statement executed by the person responsible for the laboratory.

- K. The Discharger shall calibrate and perform maintenance procedures on all monitoring instruments and to insure accuracy of measurements, or shall insure that both equipment activities will be conducted.
- L. The Discharger shall have, and implement, an acceptable written quality assurance (QA) plan for laboratory analyses. The annual monitoring report required in section X.D shall also summarize the QA activities for the previous year. Duplicate chemical analyses must be conducted on a minimum of ten percent (10%) of the samples, or at least one sample per sampling period, whichever is greater. A similar frequency shall be maintained for analyzing spiked samples.
- M. When requested by the Regional Water Board or USEPA, the Discharger will participate in the NPDES discharge monitoring report QA performance study. The Discharger must have a success rate equal to or greater than 80%.
- N. For parameters that both average monthly and daily maximum limits are specified and the monitoring frequency is less than four times a month, the following shall apply. If an analytical result is greater than the average monthly limit, the Discharger shall collect four additional samples at approximately equal intervals during the month, until compliance with the average monthly limit has been demonstrated. All five analytical results shall be reported in the monitoring report for that month, or 45 days after results for the additional samples were received, whichever is later. In the event of noncompliance with an average monthly effluent limitation, the sampling frequency for that constituent shall be increased to weekly and shall continue at this level until compliance with the average monthly effluent limitation has been demonstrated. The Discharger shall provide for the approval of the Executive Officer a program to ensure future compliance with the average monthly limit.
- O. In the event wastes are transported to a different disposal site during the report period, the following shall be reported in the monitoring report:
  - 1. Types of wastes and quantity of each type;
  - 2. Name and address for each hauler of wastes (or method of transport if other than by hauling); and
  - 3. Location of the final point(s) of disposal for each type of waste.If no wastes are transported off-site during the reporting period, a statement to that effect shall be submitted.
- P. Each monitoring report shall state whether or not there was any change in the discharge as described in the Order during the reporting period.

## **II. MONITORING LOCATIONS**

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

**Table E-1. Monitoring Station Locations**

Discharge Point Name	Monitoring Location Name	Monitoring Location Description (include Latitude and Longitude when available)
001	EFF-001	Discharge pipe from the Facility (Latitude 33° 45' 54", Longitude 118° 15' 35")
--	RSW-001	50 feet away from effluent discharge point in Los Angeles Inner Harbor

**III. INFLUENT MONITORING REQUIREMENTS**

[Not Applicable]

**IV. EFFLUENT MONITORING REQUIREMENTS**

A. Monitoring Location EFF-001

1. The Discharger shall monitor storm water, steam condensate, boiler blowdown, and truck washing water at EFF-001 as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level.

**Table E-2. Effluent Monitoring**

Parameter	Units	Sample Type	Minimum Sampling Frequency <sup>1, 2</sup>	Required Analytical Test Method
Biochemical Oxygen Demand (BOD)(5-day @20 Deg. C)	mg/L	Grab	Once per discharge event	3
Oil and Grease	mg/L	Grab	Once per discharge event	3
pH	s.u.	Grab	Once per discharge event	3
Total Suspended Solids (TSS)	mg/L	Grab	Once per discharge event	3
Turbidity	NTU	Grab	Once per discharge event	3
Ammonia (as N)	mg/L	Grab	Once per discharge event	3
Arsenic, Total Recoverable	µg/L	Grab	Once per discharge event	3
Cadmium, Total Recoverable	µg/L	Grab	Once per discharge event	3
Copper, Total Recoverable	µg/L	Grab	Once per discharge event	3
Chromium, Total Recoverable	µg/L	Grab	Once per discharge event	3
Lead, Total Recoverable	µg/L	Grab	Once per discharge event	3
Mercury, Total	µg/L	Grab	Once per discharge event	3
Nickel, Total Recoverable	µg/L	Grab	Once per discharge event	3
Selenium, Total Recoverable	µg/L	Grab	Once per discharge event	3
Silver, Total Recoverable	µg/L	Grab	Once per discharge event	3
Zinc, Total Recoverable	µg/L	Grab	Once per discharge event	3

Parameter	Units	Sample Type	Minimum Sampling Frequency <sup>1,2</sup>	Required Analytical Test Method
Sulfides	mg/L	Grab	Once per discharge event	<sup>3</sup>
Benzene	µg/L	Grab	Once per discharge event	<sup>3</sup>
Ethylbenzene	µg/L	Grab	Once per discharge event	<sup>3</sup>
Toluene	µg/L	Grab	Once per discharge event	<sup>3</sup>
Remaining Priority Pollutants <sup>4</sup>	µg/L	Grab	Once per discharge event	<sup>3</sup>
Methyl tertiary butyl ether (MTBE)	µg/L	Grab	Once per discharge event	<sup>3</sup>
Phenolic Compounds, Total <sup>5</sup>	µg/L	Grab	Once per discharge event	<sup>3</sup>
Temperature	µg/L	Grab	Once per discharge event	<sup>3</sup>
Turbidity	µg/L	Grab	Once per discharge event	<sup>3</sup>
Xylenes	µg/L	Grab	Once per discharge event	<sup>3</sup>
Total coliform	CFU/100 ml or MPN/100 ml	Grab	Once per discharge event	
Enterococcus	CFU/100 ml or MPN/100 ml	Grab	Once per discharge event	
Fecal coliform	CFU/100 ml or MPN/100 ml	Grab	Once per discharge event	
Toxicity, Acute	% survival	Grab	Once per discharge event	<sup>3</sup>

- <sup>1</sup> Sampling shall be during the first hour of discharge. If for safety reasons, a sample cannot be obtained during the first hour of discharge a sample shall be obtained at the first safe opportunity and the reason for the delay shall be included in the report.
- <sup>2</sup> For all pollutants, if no discharge occurs from the NPDES discharge point during a calendar year, the Discharger shall provide the results of a sample from the discharge to the POTW during the year. The sampling results from the discharge to POTW will not be required to meet the NPDES effluent limitations.
- <sup>3</sup> Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for Priority Pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP, provided as Attachment H. Where no methods are specified for a given pollutant, the methods must be approved by this Regional Water Board or the State Water Board.
- <sup>4</sup> Priority Pollutants as defined by the CTR defined in Finding II.I of the Limitations and Discharge Requirements of this Order, and included as Attachment I. Annual samples shall be collected during the first hour of discharge from the first storm event of the wet season (October 1 – May 30).
- <sup>5</sup> Phenolic compounds include the sum of the following individual chlorinated and non-chlorinated phenolic compounds: 2-chlorophenol; 2-nitrophenol; phenol; 2,4-dimethylphenol; 2,4-dichlorophenol; 2,4,6-trichlorophenol; 4-chloro-3-methylphenol; 2,4-dinitrophenol; 2-methyl-4,6-dinitrophenol; pentachlorophenol; and 4-nitrophenol.

## V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

### A. Definition of Toxicity

#### 1. Acute Toxicity.

Acute toxicity is a measure of primarily lethal effects that occur over a 96-hour period. Acute toxicity shall be measured in percent survival measured in undiluted (100%) effluent.

- (a) The average survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay tests shall be at least 90%, and
- (b) No single test shall produce less than 70% survival.

B. Acute Toxicity Effluent Monitoring Program

1. Effluent samples shall be collected after all treatment processes and before discharge to the receiving water.
2. The Discharger shall conduct acute toxicity tests on effluent grab samples by methods specified in Part 136 which cites USEPA's *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, Fifth Edition, October 2002, USEPA, Office of Water, Washington D.C. (EPA/821-R-02-012) or a more recent edition to ensure compliance in 100 % effluent.
3. The fathead minnow, *Pimephales promelas*, shall be used as the test species for fresh water discharges and the topmelt, *Atherinops affinis*, shall be used as the test species for brackish effluent. The method for topmelt is found in USEPA's *Short-term Method for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms*, First Edition, August 1995 (EPA/600/R-95/136), or a more recent edition.
4. In lieu of conducting the standard acute toxicity testing with the fathead minnow, the Discharger may elect to report the results or endpoint from the first 48 hours of the chronic toxicity test as the results of the acute toxicity test.

C. Chronic Toxicity Effluent Monitoring Program

[Not applicable]

D. Quality Assurance

1. Concurrent testing with a reference toxicant shall be conducted. Reference toxicant tests shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc).
2. If either the reference toxicant test or effluent test does not meet all test acceptability criteria (TAC) as specified in the test methods manuals (EPA/600/4-91/002 and EPA/821-R-02-014), then the Discharger must re-sample and re-test at the earliest time possible.
3. Control and dilution water should be receiving water or laboratory water, as appropriate, as described in the manual. If the dilution water used is different from the culture water, a second control using culture water shall be used.

E. Accelerated Monitoring and Initial Investigation TRE Trigger

1. Special Provision VI.C.2.b of the Order requires the Discharger to develop and submit for approval an Initial Investigation TRE Workplan.
2. If the results of a toxicity test exceed the acute toxicity effluent limitations (as defined below):

Acute Toxicity:

- (a) The average survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay tests shall be at least 90%, and
- (b) No single test shall produce less than 70% survival.

then, the Discharger shall begin the investigation and evaluation as specified in the Dischargers's Initial Investigation TRE Workplan and begin accelerated monitoring by conducting six additional tests, approximately every 2 weeks, over a 12-week period. The samples shall be collected and the tests initiated no less than 7 days apart. The Discharger shall ensure that they receive results of a failing acute toxicity test within 24 hours of the close of the test and the additional tests shall begin within 3 business days of the receipt of the result.

3. If implementation of the Initial Investigation TRE Workplan indicates the source of toxicity (e.g., a temporary plant upset, etc.), then the Discharger may discontinue the Initial Investigation Toxicity Reduction Evaluation and resume routine testing frequency.
4. The first step in the Initial Investigation TRE Workplan for downstream receiving water toxicity can be a toxicity test protocol designed to determine if the effluent from Discharge Point No.001 causes or contributes to the measured downstream chronic or acute toxicity. If this first step TRE testing shows that the Discharge Point No. 001 effluent does not cause or contribute to downstream chronic or acute toxicity, using USEPA's *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, October 2002 (EPA/821/R-02-013), or USEPA's *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, Third Edition, October 2002, (EPA/821/R-02-014) then a report on this testing shall be submitted to the Regional Water Board and the Initial Investigation TRE will be considered to be completed. Routine testing in accordance with the MRP shall be continued thereafter.

F. TRE/TIE Trigger

1. If the accelerated testing shows consistent toxicity as defined below:
  - a. Acute Toxicity:
    - 1) If the results of any two of the six accelerated tests are less than 90% survival, or
    - 2) If the initial test and any of the additional six acute toxicity bioassay tests result in less than 70% survival

then, the Discharger shall immediately implement the Toxicity Reduction Evaluation (TRE) as described below.

G. Steps in TRE and TIE Procedures

1. Following a TRE trigger, the Discharger shall initiate a TRE in accordance with the facility's Initial Investigation TRE workplan. At a minimum, the Discharger shall use USEPA manuals EPA/600/2-88/070 (industrial) or EPA/833B-99/002 (municipal) as guidance. The Discharger shall expeditiously develop a more detailed TRE workplan for submittal to the Executive Officer within 30 days of the trigger, which will include, but not be limited to:

- a. Further actions to investigate and identify the cause of toxicity;
  - b. Actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity;
  - c. Standards the Discharger will apply to consider the TRE complete and to return to normal sampling frequency; and,
  - d. A schedule for these actions.
2. The following is a stepwise approach in conducting the TRE:
- a. Step 1 - Basic data collection. Data collected for the accelerated monitoring requirements may be used to conduct the TRE;
  - b. Step 2 - Evaluates optimization of the treatment system operation, facility housekeeping, and the selection and use of in-plant process chemicals;
  - c. Step 3 – If Steps 1 and 2 are unsuccessful, Step 3 implements a Toxicity Identification Evaluation (TIE) by employing all reasonable efforts and using currently available TIE methodologies. The Discharger shall use the USEPA acute manuals, EPA/600/6-91/005F (Phase I)/EPA/600/R-96-054 (for marine), EPA/600/R-92/080 (Phase II), and EPA-600/R-92/081 (Phase III) as guidance. The objective of the TIE is to identify the substance or combination of substances causing the observed toxicity;
  - d. Step 4 – Assuming successful identification or characterization of the toxicant(s), Step 4 evaluates final effluent treatment options;
  - e. Step 5 evaluates in-plant treatment options; and,
  - f. Step 6 consists of confirmation once a toxicity control method has been implemented.

Many recommended TRE elements parallel source control, pollution prevention, and storm water control program best management practices (BMPs). To prevent duplication of efforts, evidence of implementation of these control measures may be sufficient to comply with TRE requirements. By requiring the first steps of a TRE to be accelerated testing and review of the facility's TRE workplan, a TRE may be ended in its early stages. All reasonable steps shall be taken to reduce toxicity to the required level. The TRE may be ended at any stage if monitoring indicates there is no longer toxicity (or six consecutive acute toxicity test results are greater than 90% survival).

3. If a TRE/TIE is initiated prior to completion of the accelerated testing schedule required by this permit, then the accelerated testing schedule may be terminated, or used as necessary in performing the TRE/TIE, as determined by the Executive Officer.
4. Toxicity tests conducted as part of a TRE/TIE may also be used for compliance determination, if appropriate.
5. The Regional Water Board recognizes that toxicity may be episodic and identification of causes of and reduction of sources of toxicity may not be successful in all cases. Consideration of enforcement action by the Regional Water Board will be based in part on

the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.

#### H. Reporting

1. The Discharger shall submit a full report of the toxicity test results, including any accelerated testing conducted during the month as required by this permit. Test results shall be reported as % survival for acute toxicity test results with the self monitoring reports (SMR) for the month in which the test is conducted.
2. If an initial investigation indicates the source of toxicity and accelerated testing is unnecessary, then those results also shall be submitted with the SMR for the period in which the investigation occurred.
  - a. The full report shall be submitted on or before the end of the month in which the SMR is submitted.
  - b. The full report shall consist of (1) the results; (2) the dates of sample collection and initiation of each toxicity test; (3) the acute toxicity average limit or trigger and (4) printout of the ToxCalc or CETIS (Comprehensive Environment Toxicity Information System) program results.
3. Test results for toxicity tests also shall be reported according to the appropriate manual chapter on Report Preparation and shall be attached to the SMR. Routine reporting shall include, at a minimum, as applicable, for each test:
  - a. Sample date(s);
  - b. Test initiation date;
  - c. Test species;
  - d. End point values for each dilution (e.g., number of young, growth rate, percent survival);
  - e. NOEC value(s) in percent effluent;
  - f. IC<sub>15</sub>, IC<sub>25</sub>, IC<sub>40</sub> and IC<sub>50</sub> values in percent effluent;
  - g. TU<sub>c</sub> values  $\left(TU_c = \frac{100}{NOEC}\right)$  ;
  - h. Mean percent mortality (+standard deviation) after 96 hours in 100% effluent (if applicable);
  - i. NOEC and LOEC values for reference toxicant test(s);
  - j. IC<sub>25</sub> value for reference toxicant test(s);
  - k. Any applicable charts; and
  - l. Available water quality measurements for each test (e.g., pH, D.O., temperature, conductivity, hardness, salinity, ammonia).
4. The Discharger shall provide a compliance summary, which includes a summary table of toxicity data from all samples collected during that year.

The Discharger shall notify by telephone or electronically, this Regional Water Board of any toxicity exceedance of the limit or trigger within 24 hours of receipt of the results followed by a written report within 14 calendar days of receipt of the results. The verbal or electronic notification shall include the exceedance and the plan the Discharger has taken or will take to investigate and correct the cause(s) of toxicity. It may also include a status report on any

actions required by the permit, with a schedule for actions not yet completed. If no actions have been taken, the reasons shall be given.

**VI. LAND DISCHARGE MONITORING REQUIREMENTS**

[Not applicable]

**VII. RECLAMATION MONITORING REQUIREMENTS**

[Not applicable]

**VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER**

A. Monitoring Location RSW-001

1. The Discharger shall monitor the Los Angeles Inner Harbor at RSW-001 as follows:

**Table E-3. Receiving Water Monitoring Requirements**

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
pH	s.u.	Grab	annually	1,2
Ammonia (as N)	mg/L	Grab	annually	1,2
Priority Pollutants <sup>3</sup>	µg/L	Grab	annually	1
Salinity	ppt	Grab	annually	1,2
Temperature	°F	Grab	annually	1,2

<sup>1</sup> Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for Priority Pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP, provided as Attachment H. Where no methods are specified for a given pollutant, the methods must be approved by this Regional Water Board or the State Water Board.

<sup>2</sup> Receiving water pH, salinity, temperature, and ammonia must be analyzed at the same time the samples are collected for Priority Pollutants analysis.

<sup>3</sup> Priority Pollutants as defined by the California Toxics Rule (CTR) defined in Finding II.I of the Limitations and Discharge Requirements of this Order, and included as Attachment I.

B. Visual Monitoring of Receiving Water Sampling Point

1. A visual observation station shall be established in the vicinity of the discharge point of the storm drain to the receiving water, the Los Angeles Inner Harbor.

2. General observations of the receiving water shall be made at each discharge point when discharges occur. During months of no discharge, the receiving water observations shall be made on a monthly basis. All receiving water observations shall be reported in the quarterly monitoring report. If no discharge occurred during the observation period, this shall be reported. Observations shall be descriptive where applicable, such that colors, approximate amounts, or types of materials are apparent. The following observations shall be made:

- a. Tidal stage, time, and date of monitoring
- b. Weather conditions
- c. Color of water
- d. Appearance of oil films or grease, or floatable materials
- e. Extent of visible turbidity or color patches
- f. Direction of tidal flow
- g. Description of odor, if any, of the receiving water

- h. Presence and activity of California Least Tern and California Brown Pelican.

## **IX. OTHER MONITORING REQUIREMENTS**

### **A. Storm Water Monitoring**

1. Rainfall Monitoring.  
[Not applicable]
2. Visual Observation. The Discharger shall make visual observations of all storm water discharge locations during each discharge event to observe the presence of floating and suspended materials, oil and grease, discoloration, turbidity, and odor. A “significant storm water discharge” is a continuous discharge of storm water for a minimum of one hour, or the intermittent discharge of storm water for a minimum of 3 hours in a 12-hour period.

### **B. SWPPP, BMPP, and Spill Contingency Plan Status and Effectiveness Report**

1. As required under Special Provision VI.C.3 of this Order, the Discharger shall submit an updated SWPPP, BMPP, and Spill Contingency Plan to the Executive Officer of the Regional Water Board for approval within 90 days of the effective date of this permit
2. Annually the Discharger shall report the status of the implementation and the effectiveness of the SWPPP, BMPP, and Spill Contingency Plan Status required under Special Provision VI.C.3 of this Order. The SWPPP, BMPP, and Spill Contingency Plan Status shall be reviewed at a minimum once per year and updated as needed to ensure all actual or potential sources of pollutants in wastewater and storm water discharged from the facility are addressed in the SWPPP, BMPP, and Spill Contingency Plan Status. All changes or revisions to the SWPPP, BMPP, and Spill Contingency Plan Status will be summarized in the annual report required under section X.D.

### **C. Chemical Use Report**

1. The Discharger shall submit to the Regional Water Board, together with the first monitoring report required by this permit, a list of all chemicals and proprietary additives which could affect the waste discharge (i.e., chemicals present in boiler blowdown and steam condensate), including quantities of each.
2. The Discharger shall report annually summarizing the quantities of all chemicals, listed by both trade and chemical names, which are used at the Facility and which are discharged or have the potential to be discharged.

## **X. REPORTING REQUIREMENTS**

### **A. General Monitoring and Reporting Requirements**

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. If there is no discharge during any reporting period, the report shall so state.
3. Each monitoring report shall contain a separate section titled “Summary of Non-Compliance” which discusses the compliance record and corrective actions taken or planned that may be

needed to bring the discharge into full compliance with waste discharge requirements. This section shall clearly list all non-compliance with waste discharge requirements, as well as all excursions of effluent limitations.

4. The Discharger shall inform the Regional Water Board well in advance of any proposed construction activity that could potentially affect compliance with applicable requirements
5. The Discharger shall report the results of acute toxicity testing, TRE and TIE as required in section V.F.

**B. Self Monitoring Reports (SMRs)**

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit SMRs. Until such notification is given, the Discharger shall submit SMRs in accordance with the requirements described below.
2. The Discharger shall submit quarterly SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. Quarterly reports shall be due on May 1, August 1, November 1, and February 1 following each calendar quarter.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

**Table E-4. Monitoring Periods and Reporting Schedule**

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
yearly	January 1 following permit effective date	January 1 through December 31	February 1
Once per discharge event	First discharge event after December 1, 2007	January – March April – June July – August September - December	May 1 August 1 November 1 February 1

4. The Discharger shall report with each sample result the applicable Minimum Level (ML) and the current Method Detection Limit (MDL), as determined by the procedure in Part 136.
5. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. Where applicable, the Discharger shall include results of receiving water observations.
6. Each monitoring report shall state whether or not there was any change in the discharge as described in the Order during the reporting period.
7. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
8. SMRs must be submitted to the Regional Water Board, signed and certified as required by the standard provisions (Attachment D), to the address listed below:

California Regional Water Quality Control Board  
 Los Angeles Region  
 320 W. 4<sup>th</sup> Street, Suite 200  
 Los Angeles, CA 90013

C. Discharge Monitoring Reports (DMRs)

1. As described in section X.B.1 of this MRP, at any time during the term of this permit, the State or Regional Water Board may notify the discharger to electronically submit SMRs. Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharge shall submit the original DMR and one copy of the DMR to the address listed below:

<b>Standard Mail</b>	<b>FedEx/UPS/ Other Private Carriers</b>
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15th Floor Sacramento, CA 95814

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated or modified cannot be accepted.

D. Other Reports

1. Within 90 days of the effective date of this permit, the Discharger is required to submit the following to the Regional Water Board:
  - a. Initial Investigation TRE workplan
  - b. Updated SWPPP
  - c. Updated BMPP
  - d. Spill Contingency Plan
2. By March 1 of each year, the Discharger shall submit an annual report to the Regional Water Board. The report shall contain the following:
  - a. Both tabular and graphical summaries of the monitoring data obtained during the previous year,
  - b. A discussion on the compliance record and the corrective actions taken or planned to bring the discharge into full compliance with the waste discharge requirements,
  - c. A report discussing the following: 1) operation/maintenance problems; 2) changes to the facility operations and activities; 3) potential discharge of the pollutants associated with

the changes and how these changes are addressed in the BMPP; 3) calibration of flow meters or other equipment/device used to demonstrate compliance with effluent limitations of this Order.

- d. A report on the status of the implementation and the effectiveness of the SWPPP, BMPP, and Spill Contingency Plan (See section IX.B of the MRP, Attachment E).
- e. A report summarizing the quantities of all chemicals, listed by both trade and chemical names, which are used at the facility and which are discharged or have the potential to be discharged (See section IX.C of the MRP, Attachment E).

This Regional Water Board, after review of the technical report, may establish conditions which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions may be incorporated as part of this Order, upon notice to the Discharger.

**Attachment F – Fact Sheet – Table of Contents**

Attachment F – Fact Sheet.....	F-3
I. Permit Information .....	F-3
II. Facility Description .....	F-4
A. Description of Wastewater Treatment or Controls .....	F-4
B. Discharge Points and Receiving Waters.....	F-6
C. Summary of Existing Requirements.....	F-6
D. Compliance Summary.....	F-6
E. Planned Changes .....	F-6
III. Applicable Plans, Policies, and Regulations.....	F-7
A. Legal Authorities .....	F-7
B. California Environmental Quality Act (CEQA) .....	F-7
C. State and Federal Regulations, Policies, and Plans .....	F-7
D. Impaired Water Bodies on CWA 303(d) List .....	F-9
E. Other Plans, Polices and Regulations.....	F-10
IV. Rationale For Effluent Limitations and Discharge Specifications.....	F-10
A. Discharge Prohibitions.....	F-10
B. Technology-Based Effluent Limitations.....	F-11
1. Scope and Authority.....	F-11
2. Applicable Technology-Based Effluent Limitations .....	F-11
C. Water Quality-Based Effluent Limitations (WQBELs).....	F-14
1. Scope and Authority.....	F-14
2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	F-14
3. Determining the Need for WQBELs .....	F-15
4. WQBEL Calculations .....	F-15
5. WQBELs based on Basin Plan Objectives.....	F-15
6. Final WQBELs .....	F-16
7. Whole Effluent Toxicity (WET) .....	F-18
D. Final Effluent Limitations.....	F-18
1. Satisfaction of Anti-Backsliding Requirements.....	F-19
2. Satisfaction of Antidegradation Policy.....	F-19
3. Mass-based Effluent Limitations .....	F-19
E. Interim Effluent Limitations.....	F-22
F. Land Discharge Specifications.....	F-22
G. Reclamation Specifications.....	F-22
V. Rationale for Receiving Water Limitations.....	F-22
A. Surface Water .....	F-22
B. Groundwater .....	F-22
VI. rationale for Monitoring and Reporting Requirements .....	F-22
A. Influent Monitoring .....	F-22
B. Effluent Monitoring.....	F-22
C. Whole Effluent Toxicity Testing Requirements .....	F-23
D. Receiving Water Monitoring.....	F-23
1. Surface Water.....	F-23
2. Groundwater .....	F-23
E. Other Monitoring Requirements.....	F-23
VII. Rationale for Provisions.....	F-24
Attachment F – Fact Sheet .....	F-1

A.	Standard Provisions.....	F-24
1.	Federal Standard Provisions.....	F-24
2.	Regional Water Board Standard Provisions.....	F-24
B.	Special Provisions.....	F-24
1.	Reopener Provisions.....	F-24
2.	Special Studies and Additional Monitoring Requirements.....	F-24
3.	Best Management Practices and Pollution Prevention .....	F-24
4.	Compliance Schedules .....	F-24
5.	Construction, Operation, and Maintenance Specifications.....	F-25
6.	Special Provisions for Municipal Facilities (POTWs Only) .....	F-25
7.	Other Special Provisions.....	F-25
VIII.	Public Participation .....	F-25
A.	Notification of Interested Parties .....	F-25
B.	Written Comments .....	F-25
C.	Hearing Date and Location .....	F-26
D.	Availability of Documents.....	F-26
E.	Nature of Hearing .....	F-27
F.	Communications with Staff Before the Hearing .....	F-27
G.	Parties to the Hearing.....	F-27
H.	Public Comments and Submittal of Evidence .....	F-28
I.	Hearing Procedure.....	F-28
J.	Waste Discharge Requirements Petitions .....	F-28

## ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “Not Applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

### I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

**Table F-1 Facility Information**

<b>WDID</b>	4B199019001
<b>Discharger</b>	Vopak Terminal Los Angeles, Inc.
<b>Name of Facility</b>	Marine Terminal, Wilmington
<b>Facility Address</b>	401 Canal Street at Berths 187-188, Port of Los Angeles
	Wilmington, CA 90744
	Los Angeles County
<b>Facility Contact, Title and Phone</b>	Jeff Spagg, Safety, Health & Environmental Supervisor (310) 518-6409
<b>Authorized Person to Sign and Submit Reports</b>	Michael LaCavera, General Manager
<b>Mailing Address</b>	401 Canal Street Wilmington, CA 90744
<b>Billing Address</b>	SAME
<b>Type of Facility</b>	Bulk liquid storage terminal
<b>Major or Minor Facility</b>	Minor
<b>Threat to Water Quality</b>	2
<b>Complexity</b>	C
<b>Pretreatment Program</b>	NA
<b>Reclamation Requirements</b>	NA
<b>Facility Permitted Flow</b>	N/A
<b>Facility Design Flow</b>	Up to 12,000 mgd
<b>Watershed</b>	Los Angeles County Coastal
<b>Receiving Water</b>	Los Angeles Inner Harbor
<b>Receiving Water Type</b>	Coastal surface water

- A. Vopak Terminal Los Angeles, Inc. (hereinafter Discharger) is the owner and operator of Marine Terminal (hereinafter Facility) a petroleum transfer and bulk storage facility. For purposes of this Order, references to the “Discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B. The Facility discharges storm water runoff and external tank truck wash water, steam condensate, and boiler blowdown to the Los Angeles Inner Harbor, a water of the United States. The Facility is currently regulated by Order No. R4-2002-0079 adopted on March 28, 2002, and which expired on February 10, 2007. The terms and conditions of the current Order have been automatically continued and remain in effect until new Waste Discharge Requirements (WDRs) and National Pollutant Discharge Elimination System (NPDES) permit are adopted pursuant to this Order.
- C. The Discharger filed a report of waste discharge and submitted an application for renewal of its WDRs and NPDES permit on September 20, 2006. On February 1, 2007, a site visit was conducted to observe operations and collect additional data to develop permit limitations and conditions.

## II. FACILITY DESCRIPTION

Vopak Terminal Los Angeles, Inc. operates an oil transfer and bulk storage facility located at 401 Canal Street at Berths 187-188, Port of Los Angeles, Wilmington, California. According to the previous Order, the Facility consists of two portions – one of which is covered by the NPDES General Permit No. CAS000001 (Waste Discharge Recruitments for Discharges of Storm Water Associated with Industrial Activities) and another covered by this individual permit (CA0055247). The activities covered under the General Permit include: loading and unloading of oil from ships and barges along berths 187, 188, and 189; loading and unloading of concrete from ships and barges along berths 190 and 191; loading tank trucks with concrete; storage of cement in a covered building; and general truck traffic throughout the Facility.

Activities covered by this Order include: loading and unloading tank trucks of oil and caustic (sodium hydroxide) in contained areas adjacent to tank blocks; storage of oil and caustic in contained tank blocks; and truck traffic in areas internal to the tank blocks. The facility consists of 61 bulk storage tanks, vehicle loading and off-loading areas, five berths for vessels and barges, and a wastewater treatment system. Storage tanks hold primarily petroleum products; however, volatile organic compounds, vegetable oils, caustic soda, and caustic potash are stored on site as well. The existing Order states that storm water generated in the tank farms, loading and unloading stations, some of the internal roads, and all of the internal rail tracks and wastewaters are directed to an internal drainage system that drains to the on-site wastewater treatment system. Wastewater is comprised of external tank truck wash water, steam condensate, and boiler blowdown. Before trucks leave the loading station, the outside of the tank trucks are rinsed with water to remove any residual liquid that might have dripped outside the loading hatch, during the loading process. Truck rinsing is conducted on an individual basis and is isolated to the area of the truck around the loading hatch; it is not the entire vehicle that is rinsed, nor is it a continuous process. The loading and off-loading areas are cleaned by sweeping and steam cleaning. The steam condensate and the boiler blowdown is discharged to the wastewater treatment system. An annual average of 12,000 gallons per day (gpd) of storm water, truck rinse water, boiler blowdown, and steam condensate are generated.

### A. Description of Wastewater Treatment or Controls

The wastewater and storm water are collected and directed to an on-site wastewater treatment system. The wastewater is pumped into four holding/settling tanks placed in series. These four tanks have a combined capacity of 537,600 gallons. These tanks are piped together, but can be isolated should the need arise. The wastewater is then pumped from these tanks into a 12-stage, weir-type clarifier. The clarifier consists of two banks of six cells. Wastewater flows through all 12 cells and then through four carbon canisters in series to provide polishing before

discharge. Under normal circumstances, the water is then pumped through a series of monitors to the publicly owned treatment works (POTW), Joint Outfall System under industrial pretreatment permit No. 387757. The holding/settling tanks are used as holding tanks for excess storm water in the event that the POTW cannot handle the flow of water or a large storm event threatens to inundate the Facility. In an emergency situation, if the tanks cannot contain the excess storm water flow, the Facility discharges the treated water to Los Angeles Inner Harbor.

The intermittent discharge of wastewater would occur only on a short-term basis to prevent over-filling of the holding tanks during large storm events. Discharges are permitted only when exceedance of the storage capacity of the tanks and the allowable capacity for sanitary sewer discharge is imminent. Due to the intermittent nature of the discharge, a maximum discharge flow has not been established for the Facility's discharge.

No discharges occurred during the existing permit term. According to the existing permit, no discharges to surface water had occurred in the 20 years prior to issuance of Order R4-2002-0079. An average of 0.003 MGD of treated wastewater is discharged to the POTW.

The existing permit required that annual sampling of the POTW discharge be performed if no surface water discharges occurred. Two such sampling events were conducted. The following table summarizes this POTW discharge monitoring data:

**Table F-2. Summary of Sampling Data for POTW Discharges**

Parameter (units)	Monitoring Data
BOD <sub>5</sub> 20°C (mg/L)	5.7
Oil and Grease (mg/L)	<5
TSS (mg/L)	2 <sup>1</sup>
Turbidity (NTU)	3 – 3.4
Benzene (µg/L)	<0.5
Ethylbenzene	1.1 <sup>1</sup>
Toluene (µg/L)	<0.5
Phenols (mg/L)	0.92 <sup>1</sup>
Sulfides (mg/L)	<0.04
Xylenes (µg/L)	4.9 <sup>1</sup>

<sup>1</sup> Only one detected value reported.

**B. Discharge Points and Receiving Waters**

Treated wastewater from the Facility is discharged through Discharge Point No. 001 (33° 45' 54" North, 118° 15' 35" West), to the Los Angeles Inner Harbor, a water of the United States.

**C. Summary of Existing Requirements**

Effluent Limitations contained in the existing Order for discharges from Discharge Point 001 (Monitoring Location EFF-001) are summarized in Table F-3, below.

**Table F-3. Summary of Effluent Limitations (Order No. R4-2002-0079)**

Parameter (units)	Effluent Limitation
	Maximum Daily
BOD <sub>5</sub> 20°C (mg/L)	30
Oil and grease (mg/L)	15
Total Suspended Solids (mg/L)	150
Arsenic, Total Recoverable (µg/L)	50
Cadmium, Total Recoverable (µg/L)	10
Chromium, Total Recoverable (µg/L)	50
Copper, Total Recoverable (µg/L)	1,000
Lead, Total Recoverable (µg/L)	50
Mercury, Total (µg/L)	2.0
Selenium, Total Recoverable (µg/L)	10
Silver, Total Recoverable (µg/L)	50
Zinc, Total Recoverable (µg/L)	5,000
Benzene (µg/L)	1.0
Ethylbenzene (µg/L)	10
Toluene (µg/L)	10
Phenols (mg/L)	1.0
Sulfides (mg/L)	1.0
Turbidity (mg/L)	75
Xylene (mg/L)	10

**D. Compliance Summary**

There were no discharges during the permit term. A compliance evaluation inspection (CEI) was performed on February 2, 2007.

The Discharger is required to submit monitoring reports even when there is no discharge. One monitoring report was submitted late.

**E. Planned Changes**  
 [Not Applicable]

### III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the proposed Order are based on the requirements and authorities described in this section.

#### A. Legal Authorities

This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (commencing with section 13370). It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).

#### B. California Environmental Quality Act (CEQA)

Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provision of CEQA, Public Resources Code sections 21100 through 21177.

#### C. State and Federal Regulations, Policies, and Plans

1. Water Quality Control Plans. The Regional Water Board adopted a Water Quality Control Plan for the Los Angeles Region (hereinafter Basin Plan) on June 13, 1994 that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to Los Angeles Inner Harbor are as follows:

**Table F-4. Basin Plan Beneficial Uses**

Discharge Point	Receiving Water Name	Beneficial Uses
001	Los Angeles Inner Harbor	<p><u>Existing:</u>            Industrial service supply (IND), navigation (NAV), Non-contact water recreation (REC-2), commercial and sport fishing (COMM), marine habitat (MAR), and rare, threatened or endangered species (RARE).</p> <p><u>Potential:</u>            Water contact recreation (REC-1), and shellfish harvesting (SHELL).</p>

2. Ammonia Basin Plan Amendment. The 1994 Basin Plan provided water quality objectives for ammonia to protect aquatic life, in Tables 3-1 through 3-4. However, those ammonia objectives were revised on March 4, 2004, by the Regional Water Board with the adoption of Resolution No. 2004-022, *Amendment to the Water Quality Plan for the Los Angeles Region to Update the Ammonia Objectives for Inland Surface Waters Not Characteristic of Freshwater (including enclosed bays, estuaries and wetlands) with the Beneficial Use designations for protection of "Aquatic Life"*. The ammonia Basin Plan amendment was approved by the State Water Board on July 22, 2004, Office of Administrative Law on September 15, 2004, and by USEPA on May 19, 2005. The amendment revised the Basin

Plan by updating the ammonia objectives for inland surface waters not characteristic of freshwater such that they are consistent with USEPA's "Ambient Water Quality Criteria for Ammonia (Saltwater) – 1989." The amendment revised the regulatory provisions of the Basin Plan by adding language to Chapter 3, "Water Quality Objectives."

For inland surface waters not characteristic of freshwater (including enclosed bays, estuaries, and wetlands), the proposed objectives are a 4-day average concentration of unionized ammonia of 0.035 mg/L, and a 1-hour average concentration of unionized ammonia of 0.233 mg/L. The proposed objectives are fixed concentrations of unionized ammonia, independent of pH, temperature, or salinity. The proposed amendment includes an implementation procedure to convert un-ionized ammonia objectives to total ammonia effluent limits. The proposed amendment also simplifies the implementation procedures for translating ammonia objectives into effluent limits in situations where a mixing zone has been authorized by the Regional Board. Finally, the proposed amendment revises the implementation procedure for determining saltwater, brackish or freshwater conditions, to be consistent with the proposed objectives. The proposed objectives will apply only to inland surface waters not characteristic of freshwater (including enclosed bays, estuaries and wetlands) and do not impact the Ammonia Water Quality Objectives for ocean waters contained in the California Ocean Plan.

No limitation for ammonia is included in this Order because there is insufficient monitoring data to conduct reasonable potential analysis (RPA). The Order includes requirements for monitoring of ammonia for both effluent and receiving waters.

3. Thermal Plan. The State Water Board adopted a *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. This plan contains temperature objectives for surface waters. Requirements of the Order implement the Thermal Plan.
4. National Toxics Rule (NTR) and California Toxics Rule (CTR). USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.
5. State Implementation Policy. On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, and on July 13, 2005, it became effective. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
6. Alaska Rule. On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes (40 C.F.R. § 131.21, 65 Fed. Reg. 24641 (April 27, 2000)). Under the revised

regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA may be used for CWA purposes, by May 30, 2000, whether or not approved by USEPA.

7. Antidegradation Policy. Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. The permitted discharge must be consistent with the antidegradation provision of section 131.12 and State Water Board Resolution No. 68-16.

The discharge from this Facility is not a new discharge; the discharge has been permitted for at least the past 25 years. However, recent discharges only occur in emergency situations, during prolonged periods of rain when the storm water runoff and other wastewater streams (i.e., tank truck external rinse water, boiler blowdown and steam condensate) collected cannot be discharged to the sanitary sewer. During the tenure of the previous Order (2002-2007), there were no discharges from the Facility to the Los Angeles Inner Harbor. The discharge is treated prior to discharge to ensure that the WQBELs are met. Further, the Order also includes Reopener Provision VI.C.b which allows revision of effluent limitations for toxic pollutants based on the results of an RPA.

This NPDES permit includes effluent limits to ensure that the discharge does not adversely impact the beneficial uses of the Los Angeles Inner Harbor or degrade water quality. The inclusion of the effluent limits and prohibitions in the NPDES permit, which ensure that any discharge would not result in the lowering of water quality, coupled with the fact that the discharge occurs infrequently (none in the past 25 years) and is temporally limited, support the conclusion that no degradation will arise as a result of reissuing this permit. The issuance of this permit, therefore, is consistent with the state's antidegradation policy.

8. Anti-Backsliding Requirements. Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations<sup>1</sup> section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. The permit limits included in this Order are at least as stringent as those included in Order R4-2002-0079.

#### D. Impaired Water Bodies on CWA 303(d) List

Section 303(d) of the CWA requires states to identify specific water bodies where water quality standards are not expected to be met after implementation of technology-based effluent limitations on point sources. For all 303(d)-listed water bodies and pollutants, the Regional Water Board plans to develop and adopt TMDLs that will specify WLAs for point sources and load allocations (LAs) for non-point sources, as appropriate.

On November 20, 2006, USEPA gave final approval to California's 2006 section 303(d) List of Water Quality Limited Segments. This list was approved by the State Water Board during a

---

<sup>1</sup> All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

Board Meeting on October 25, 2006 (Resolution No. 2006-0079). Certain receiving waters in the Los Angeles and Ventura County watersheds do not fully support beneficial uses and therefore have been classified as impaired on the 2006 303(d) list and have been scheduled for TMDL development.

The 2006 State Water Board's California 303(d) List classifies the Los Angeles Inner Harbor as impaired. The pollutants of concern include beach closures, benthic community effects, DDT, PCBs, and sediment toxicity. Los Angeles Harbor Bacterial TMDL was adopted by Regional Board on July 1, 2004 (Resolution No. 2004-011). It became effective on March 10, 2005, after approval by State Water Board, Office of Administrative Law and USEPA. The Discharger is required to monitor bacterial indicators for compliance with the TMDL.

- E. Other Plans, Policies and Regulations  
[Not Applicable]

#### **IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS**

The CWA requires point source discharges to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations: section 122.44(a) requires that permits include applicable technology-based limitations and standards; and section 122.44(d) requires that permits include WQBELs to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

The Facility stores and transfers petroleum products, vegetable oil, caustics, and volatile organic chemicals. Effluent limitations in the existing permit were established for pH, temperature, BOD<sub>5</sub>20°C, oil and grease, TSS, turbidity, sulfides, phenols, benzene, toluene, xylene, ethylbenzene, arsenic, cadmium, chromium, copper, lead, mercury, selenium, silver, zinc, and acute toxicity. Sulfides, phenols, benzene, toluene, ethylbenzene, and xylenes are typical components of the petroleum products managed on-site, specifically fuel oil and cutter stock. Because the Facility manages vegetable oil and caustic, oil and grease and pH could impact the discharge. Truck traffic, truck washing, sweeping, steam cleaning condensate, and boiler blowdown may contribute solids and metals; therefore effluent limitations were established for turbidity, TSS, and metals.

Generally, mass-based effluent limitations ensure that proper treatment, and not dilution, is employed to comply with the final effluent concentration limitations. Section 122.45(f)(1) requires that all permit limitations, standards or prohibitions be expressed in terms of mass units except under the following conditions: (1) for pH, temperature, radiation or other pollutants that cannot appropriately be expressed by mass limitations; (2) when applicable standards or limitations are expressed in terms of other units of measure; or (3) if in establishing technology-based permit limitation, mass limitations are infeasible because the mass or pollutant cannot be related to a measure of production. The limitations, however, must ensure that dilution will not be used as a substitute for treatment.

##### **A. Discharge Prohibitions**

The discharge prohibitions are based on the requirements of the Basin Plan, State Water Board's plans and policies, the Water Code, and previous permit provisions, and are consistent with the requirements set for other discharges to Los Angeles Inner Harbor that are regulated by NPDES permits.

## B. Technology-Based Effluent Limitations

### 1. Scope and Authority

The CWA requires that technology-based effluent limitations be established based on several levels of controls:

- a. Best practicable treatment control technology (BPT) represents the average of the best performance by plants within an industrial category or subcategory. BPT standards apply to toxic, conventional, and nonconventional pollutants.
- b. Best available technology economically achievable (BAT) represents the best existing performance of treatment technologies that are economically achievable within an industrial point source category. BAT standards apply to toxic and nonconventional pollutants.
- c. Best conventional pollutant control technology (BCT) represents the control from existing industrial point sources of conventional pollutants including BOD, TSS, fecal coliform, pH, and oil and grease. The BCT standard is established after considering the “cost reasonableness” of the relationship between the cost of attaining a reduction in effluent discharge and the benefits that would result, and also the cost effectiveness of additional industrial treatment beyond BPT.
- d. New source performance standards (NSPS) represent the best available demonstrated control technology standards. The intent of NSPS guidelines is to set limitations that represent state-of-the-art treatment technology for new sources.

The CWA requires USEPA to develop effluent limitations, guidelines and standards (ELGs) representing application of BPT, BAT, BCT, and NSPS. Section 402(a)(1) of the CWA and section 125.3 of the Code of Federal Regulations authorize the use of best professional judgment (BPJ) to derive technology-based effluent limitations on a case-by-case basis where ELGs are not available for certain industrial categories and/or pollutants of concern. Where BPJ is used, the permit writer must consider specific factors outlined in section 125.3.

### 2. Applicable Technology-Based Effluent Limitations

ELGS have not been developed for the discharges from the Facility.

**Table F-5. Revised Technology-Based Effluent Limitations**

Parameter	Units	Order No. R4-2002-0079	Order No. R4-2007-0057
TSS	mg/L	150	75

Pursuant to State and federal anti-backsliding regulations, Order No. R4-2007-0057 carries over effluent limitations for BOD, oil and grease, turbidity, sulfides, phenols, toluene, xylene, and ethylbenzene as technology-based effluent limitations based on BPJ in accordance with section 125.3. The effluent limitations for TSS has been revised to reflect the expected levels from well-operated treatment systems that have been established in other recently adopted permits in the Regional Water Board. These limitations were determined on a

case-by-case basis and are similar to those established for similar facilities within the Los Angeles Region. Further, they continue to be appropriate for this facility.

The previous Order required the Discharger to develop and implement a *Storm Water Pollution Prevention Plan* (SWPPP). This Order will require the Discharger to update and continue to implement, consistent with the existing Order requirements, a SWPPP. The SWPPP will outline site-specific management processes for minimizing storm water runoff contamination and for preventing contaminated storm water runoff from being discharged directly into the storm drain. At a minimum, the management practices should ensure that raw materials and chemicals do not come into contact with storm water in the undiked areas, and that all storm water within the diked areas is contained within the diked areas at all times, treated by the treatment system, and discharged to the sanitary sewer system.

In addition, due to the lack of national ELGs for wastewater from petroleum and caustic transfer and bulk storage facilities and the absence of data to apply BPJ to develop numeric effluent limitations, and pursuant to section 122.44(k), the Regional Water Board will require the Discharger to develop and implement Best Management Practices Plan (BMPP) that entails site-specific plans and BMPs to be implemented to prevent hazardous waste/material from being discharged to waters of the State. The purpose of the BMPs will be to establish site-specific procedures that will ensure proper operation and maintenance of equipment and storage areas, to ensure that unauthorized non-storm water discharges (i.e., spills) do not occur at the Facility. The updated BMPP shall be consistent with the general guidance contained in the USEPA *Guidance Manual for Developing Best Management Practices (BMPs)* (EPA 833-B-93-004). In particular, a risk assessment of each area identified by the Discharger shall be performed to determine the potential for hazardous or toxic waste/material discharge to surface waters.

The plans shall cover all areas of the Facility and shall include an updated drainage map for the facility. The Discharger shall identify on a map of appropriate scale the areas that contribute runoff to the permitted discharge points (e.g., petroleum storage tanks); describe the activities in each area and the potential for contamination of storm water runoff and the discharge of hazardous waste/material.

This Order will require the Discharger to update and continue to implement their Spill Contingency Plan as well.

The combination of the SWPPP, BMPP, Spill Contingency Plan, and existing Order limitations based on BPJ will serve as the equivalent of technology-based effluent limitations, in the absence of established ELGs, in order to carry out the purposes and intent of the CWA.

The technology-based effluent limitations for Order No. R4-2007-0057 are summarized in Table F-6, below.

**Table F-6. Summary of Technology-based Effluent Limitations: Discharge Point 001**

Parameter	Units	Effluent Limitations
		Maximum Daily
BOD <sub>5</sub> 20°C	mg/L	30
Oil and Grease	mg/L	15
Total Suspended Solids (TSS)	mg/L	75
Turbidity	NTU	75
Ethylbenzene	µg/L	10
Toluene	µg/L	10
Phenols	mg/L	1.0
Sulfides	mg/L	1.0
Turbidity	NTU	75
Xylene	µg/L	10

## C. Water Quality-Based Effluent Limitations (WQBELs)

### 1. Scope and Authority

Section 301(b) of the CWA and section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

Section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

The specific procedures for determining reasonable potential for discharges from the Facility, and if necessary for calculating WQBELs, are contained in the SIP.

### 2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

As noted in section II of the Limitations and Discharge Requirements, the Regional Water Board adopted a Basin Plan that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the Basin Plan. The beneficial uses applicable to the Los Angeles Inner Harbor are summarized in section III.C.1 of this Fact Sheet. The Basin Plan includes both narrative and numeric water quality objectives applicable to the receiving water.

Priority pollutant water quality criteria in the CTR are applicable to Los Angeles Inner Harbor. The CTR contains both saltwater and freshwater criteria. Because a distinct separation generally does not exist between freshwater and saltwater aquatic communities, the following apply, in accordance with section 131.38(c)(3), freshwater criteria apply at salinities of 1 part per thousand (ppt) and below at locations where this occurs 95 percent or more of the time. The CTR criteria for saltwater or human health for consumption of organisms, whichever is more stringent, are used to prescribe the effluent limitations in this Order to protect the beneficial uses of the Los Angeles Inner Harbor, a water of the United States in the vicinity of the discharge.

No discharges occurred during the permit term. The Discharger sampled the POTW discharge only twice during the permit term (and for only two priority pollutants) and no

receiving water monitoring data were available, therefore adequate data were not available to evaluate reasonable potential.

### 3. Determining the Need for WQBELs

In accordance with section 1.3 of the SIP, the Regional Water Board conducts a reasonable potential analysis (RPA) for each priority pollutant with an applicable criterion or objective to determine if a WQBEL is required in the permit. The Regional Water Board analyzes effluent and receiving water data and identifies the maximum observed effluent concentration (MEC) and maximum background concentration (B) in the receiving water for each constituent. To determine reasonable potential, the MEC and the B are then compared with the applicable water quality objectives (C) outlined in the CTR, NTR, as well as the Basin Plan. For all pollutants that have a reasonable potential to cause or contribute to an excursion above a state water quality standard, numeric WQBELs are required. The RPA considers water quality criteria from the CTR and NTR, and when applicable, water quality objectives specified in the Basin Plan. To conduct the RPA, the Regional Water Board identifies the MEC and maximum background concentration in the receiving water for each constituent, based on data provided by the Discharger.

Section 1.3 of the SIP provides the procedures for determining reasonable potential to exceed applicable water quality criteria and objectives. The SIP specifies three triggers to complete a RPA:

- 1) Trigger 1 – If the MEC  $\geq$  C, a limit is needed.
- 2) Trigger 2 – If the background concentration (B)  $>$  C and the pollutant is detected in the effluent, a limit is needed.
- 3) Trigger 3 – If other related information such as CWA 303(d) listing for a pollutant, discharge type, compliance history, etc. indicates that a WQBEL is required.

Sufficient effluent and receiving water data are needed to conduct a complete RPA. If data are not sufficient, the Discharger will be required to gather the appropriate data for the Regional Water Board to conduct the RPA. Upon review of the data, and if the Regional Water Board determines that WQBELs are needed to protect the beneficial uses, the permit will be reopened for appropriate modification.

As previously stated, adequate priority pollutant monitoring data were not available; therefore, the RPA was not performed for the priority pollutants regulated in the CTR. No new WQBELs were developed for the discharge from the Facility.

### 4. WQBEL Calculations

WQBEL calculations are not depicted in this Fact Sheet since no new WQBELs were developed for the discharge from the Facility.

### 5. WQBELs based on Basin Plan Objectives

The effluent limitations for benzene, arsenic, chromium, and mercury in Order No. R4-2002-0079 were developed based on the water quality objectives contained in the Basin Plan. The Regional Water Board determined the need for effluent limitations for these

pollutants is still appropriate for this permit term. Thus, the WQBELs for these pollutants have been carried over in the proposed Order, in the absence of sufficient data to calculate a revised WQBEL based on other applicable water quality criteria.

The Basin Plan states that the pH of inland surface waters shall not be depressed below 6.5 or raised above 8.5 as a result of waste discharge. Based on the requirements of the Basin Plan an instantaneous minimum limitation of 6.5 and an instantaneous maximum limitation of 8.5 for pH are included in the proposed Order. The Basin Plan lists temperature requirements for the receiving waters and references the Thermal Plan. Based on the requirements of the Thermal Plan and a white paper developed by Regional Water Board staff entitled *Temperature and Dissolved Oxygen Impacts on Biota in Tidal Estuaries and Enclosed Bays in the Los Angeles Region*, a maximum effluent temperature limitation of 86 °F is included in the proposed Order. The white paper evaluated the optimum temperatures for steelhead, topsmelt, ghost shrimp, brown rock crab, jackknife clam, and blue mussel. The new temperature effluent limit is reflective of new information available that indicates that the 100°F temperature is not protective of aquatic organisms. A survey was completed for several kinds of fish and the 86°F temperature was found to be protective.

#### 6. Final WQBELs

Summaries of the WQBELs are described in Tables F-7.

**Table F-7. Summary of Water Quality-based Effluent Limitations: Discharge Point 001**

Parameter	Units	Effluent Limitations		
		Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
pH	s.u.	--	6.5	8.5
Temperature	°F	--	--	86
Arsenic, Total Recoverable	µg/L	50	--	--
Cadmium, Total Recoverable	µg/L	10	--	--
Chromium, Total	µg/L	50	--	--
Copper, Total Recoverable	µg/L	1,000	--	--
Lead, Total Recoverable	µg/L	50	--	--
Mercury, Total Recoverable	µg/L	2	--	--
Selenium, Total Recoverable	µg/L	10	--	--
Silver, Total Recoverable	µg/L	50	--	--
Zinc, Total Recoverable	µg/L	5,000	--	--
Benzene	µg/L	1.0	--	--

## 7. Whole Effluent Toxicity (WET)

Whole effluent toxicity (WET) protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. WET tests measure the degree of response of exposed aquatic test organisms to an effluent. The WET approach allows for protection of the narrative “no toxics in toxic amounts” criterion while implementing numeric criteria for toxicity. There are two types of WET tests: acute and chronic. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth.

The Basin Plan specifies a narrative objective for toxicity, requiring that all waters be maintained free of toxic substances in concentrations that are lethal to or produce other detrimental responses by aquatic organisms. Detrimental response includes but is not limited to decreased growth rate, decreased reproductive success of resident or indicator species, and/or significant alterations in population, community ecology, or receiving water biota. The existing Order contains acute toxicity limitations and monitoring requirements in accordance with the Basin Plan, in which the acute toxicity objective for discharges dictates that the average survival in undiluted effluent for any three consecutive 96-hour static or continuous flow bioassay tests shall be at least 90%, with no single test having less than 70% survival. No discharges occurred during the permit term; therefore, no acute toxicity monitoring data is available. Consistent with Basin Plan requirements, this Order carries over the acute toxicity limitations and monitoring requirements from the previous Order.

In addition to the Basin Plan requirements, section 4 of the SIP states that a chronic toxicity effluent limitation is required in permits for all discharges that will cause, have the reasonable potential to cause, or contribute to chronic toxicity in receiving waters. The discharges from Discharge Point 001 are intermittent and should not contribute to long-term toxic effects within the receiving water; therefore, no chronic toxicity limitations or monitoring requirements are included in this Order.

## D. Final Effluent Limitations

Section 402(o) of the CWA and section 122.44(l) require that effluent limitations or conditions in reissued Orders be at least as stringent as those in the existing Orders based on the submitted sampling data. Effluent limitations in the previous permit have been carried over and were established for sulfides, phenols, benzene, toluene, ethylbenzene, and xylenes because they are typical components of the petroleum products stored on-site, specifically fuel oil and cutter stock. Because the Discharger stores vegetable oil and caustic on-site, oil and grease as well as pH are likely to impact the discharge and thus effluent limits were established for these parameters. General truck traffic, truck wash, sweep cleaning operations, steam condensate, and boiler blowdown may contribute solids and metals to the discharge; therefore, limits were set for turbidity, suspended solids, and metals. The effluent limitation for TSS has been revised to reflect similar requirements that have been established in other recently adopted permits in the Regional Water Board. Further, effluent limitations for pH and temperature have been revised to reflect WQO changes in the Basin Plan and Thermal Plan.

### 1. Satisfaction of Anti-Backsliding Requirements

Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations 40 C.F.R. § 122.44(1) prohibit backsliding in NPDES permits. These antibacksliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.

### 2. Satisfaction of Antidegradation Policy

The discharge from Facility is not a new discharge; the discharge has been permitted for at least the past 25 years. However, recent discharges only occur in emergency situations, during prolonged periods of rain when the storm water runoff and other waste streams (i.e., tank truck external rinse water, boiler blowdown, and steam condensate) collected cannot be discharged to the sanitary sewer. During the tenure of the previous Order (2002-2007), there were no discharges from the Facility to the Los Angeles Inner Harbor. The discharge is treated prior to discharge to ensure that the WQBELs are met. The Order also includes Reopener Provision VI.C.b which allows revision of effluent limitations for toxic pollutants based on the results of an RPA.

This NPDES permit includes effluent limits to ensure that the discharge does not adversely impact the beneficial uses of the Los Angeles Inner Harbor or degrade water quality. The inclusion of the effluent limits and prohibitions in the NPDES permit, which ensure that any discharge would not result in the lowering of water quality, coupled with the fact that the discharge occurs infrequently (none in the past 25 years) and is temporally limited, support the conclusion that no degradation will arise as a result of reissuing this permit. The issuance of this permit, therefore, is consistent with the state's antidegradation policy.

### 3. Mass-based Effluent Limitations

Generally, mass-based effluent limitations ensure that proper treatment, and not dilution, is employed to comply with the final effluent concentration limitations. Section 122.45(f)(1) requires that all permit limitations, standards or prohibitions be expressed in terms of mass units except under the following conditions: (1) for pH, temperature, radiation or other pollutants that cannot appropriately be expressed by mass limitations; (2) when applicable standards or limitations are expressed in terms of other units of measure; or (3) if in establishing technology-based permit limitation mass limitations are infeasible because the mass or pollutant cannot be related to a measure of production. The limitations, however, must ensure that dilution will not be used as a substitute for treatment.

Consistent with the previous Order, mass-based effluent limitations for the periodic discharge from the Facility are not included in this Order.

**Table F-8. Summary of Final Effluent Limitations: Discharge Point 001**

Parameter	Units	Effluent Limitations			Basis
		Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
BOD <sub>5</sub> 20°C	mg/L	30	--	--	Previous Order <sup>1</sup>
Oil and Grease	mg/L	15	--	--	Previous Order <sup>1</sup>
pH	s.u.		6.5	8.5	Basin Plan <sup>2</sup>
Total Suspended Solids (TSS)	mg/L	75	--	--	Previous Order <sup>1</sup>
Turbidity	NTU	75			Previous Order <sup>1</sup>
Arsenic, Total Recoverable	µg/L	50	--	--	Previous Order <sup>1</sup>
Cadmium, Total Recoverable	µg/L	10	--	--	Previous Order <sup>1</sup>
Chromium, Total	µg/L	50	--	--	Previous Order <sup>1</sup>
Copper, Total Recoverable	µg/L	1,000	--	--	Previous Order <sup>1</sup>
Lead, Total Recoverable	µg/L	50	--	--	Previous Order <sup>1</sup>
Mercury, Total	µg/L	2.0	--	--	Previous Order <sup>1</sup>
Selenium, Total Recoverable	µg/L	10	--	--	Previous Order <sup>1</sup>
Silver, Total Recoverable	µg/L	50	--	--	Previous Order <sup>1</sup>
Zinc, Total Recoverable	µg/L	5,000	--	--	Previous Order <sup>1</sup>
Benzene	µg/L	1.0	--	--	Previous Order <sup>1</sup>
Ethylbenzene	µg/L	10	--	--	Previous Order <sup>1</sup>
Toluene	µg/L	10	--	--	Previous Order <sup>1</sup>
Phenols	mg/L	1.0	--	--	Previous Order <sup>1</sup>
Sulfides	mg/L	1.0	--	--	Previous Order <sup>1</sup>
Temperature	°F		--	86	Thermal Plan <sup>3</sup>
Turbidity	NTU	75	--	--	Previous Order <sup>1</sup>
Xylene	µg/L	10	--	--	Previous Order <sup>1</sup>

- 1 These effluent limitations have been carried over from the existing Order (No. R4-2002-0079) to comply with anti-backsliding regulations.
- 2 Basin Plan Objectives are instantaneous maximum concentrations of pollutants that when not exceeded are protective of the beneficial uses of the particular water body. They are generally set at the level required to protect the most sensitive beneficial use or at an even lower level based on antidegradation principles
- 3 The effluent limitation for temperature has been established based on the Basin Plan and a white paper developed by Regional Board staff entitled *Temperature and Dissolved Oxygen Impacts on Biota in Tidal Estuaries and Enclosed Bays in the Los Angeles Region*. The white paper evaluated the optimum temperatures for steelhead, topsmelt, ghost shrimp, brown rock crab, jackknife clam, and blue mussel.

- E. Interim Effluent Limitations  
[Not Applicable]
- F. Land Discharge Specifications  
[Not Applicable]
- G. Reclamation Specifications  
[Not Applicable]

## **V. RATIONALE FOR RECEIVING WATER LIMITATIONS**

### **A. Surface Water**

The Basin Plan contains numeric and narrative water quality objectives applicable to all surface waters within the Los Angeles Region. Water quality objectives include an objective to maintain the high quality waters pursuant to federal regulations (section 131.12) and State Water Board Resolution No. 68-16. Receiving water limitations in this Order are included to ensure protection of beneficial uses of the receiving water and are based on the water quality objectives contained in the Basin Plan.

- B. Groundwater  
[Not Applicable]

## **VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS**

Section 122.48 requires that all NPDES permits to specify recording and reporting of monitoring results. Water Code sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order, establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

- A. Influent Monitoring  
[Not Applicable]
- B. Effluent Monitoring

Monitoring for those pollutants expected to be present in the Monitoring Location EFF-001 at Discharge Point 001 will be required as shown in the proposed MRP. To determine compliance with effluent limitations, the proposed monitoring plan carries forward monitoring requirements from previous Order No. R4-2002-0079 with some modifications. In the proposed permit, monitoring requirements for BOD<sub>5</sub>20°C, oil and grease, TSS, turbidity, sulfides, phenols, benzene, toluene, xylene, ethylbenzene, arsenic, cadmium, chromium (total) copper, lead, mercury, selenium, silver, and zinc are carried over from the previous Order. However, the monitoring frequencies for some of these pollutants are modified. Because the discharge through Discharge Point 001 will occur only during storm events or other types of unforeseen emergencies, the proposed Order requires that the monitoring for the pollutants are performed once per discharge event.

According to the SIP, the Discharger is required to monitor the effluent for the CTR priority pollutants, to determine reasonable potential. Accordingly, the Regional Water Board is

requiring that the Discharger conduct effluent monitoring of the CTR priority pollutants during each discharge event.

In the event that no discharge occurs during a year, annual monitoring of the POTW discharge is required to characterize the wastewater. This sampling will not be used to determine compliance with effluent limitations nor as the sole factor in the determination of the need for WQBELs.

#### C. Whole Effluent Toxicity Testing Requirements

Whole effluent toxicity (WET) protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth. This Order includes limitations for acute toxicity, and therefore, monitoring requirements are included in the MRP to determine compliance with the effluent limitations established in Limitations and Discharge Requirements, Effluent Limitations, section IV.A.1.a.

Section 4 of the SIP states that a chronic toxicity effluent limitation is required in permits for all discharges that will cause, have the reasonable potential to cause, or contribute to chronic toxicity in receiving waters. The discharge is intermittent and infrequent, and it does not have the reasonable potential to cause toxicity. Therefore, the Discharger will not be required to conduct chronic toxicity testing.

#### D. Receiving Water Monitoring

##### 1. Surface Water

This Order includes receiving water limitations and therefore, monitoring requirements are included in the MRP to determine compliance with the receiving water limitations established in Limitations and Discharge Requirements, Receiving Water Limitations, section V.A. Monitoring for temperature, pH, and salinity in the receiving water is included in the proposed Order. The Facility is also required to perform general observations of the receiving water when discharges occur and report the observations in the monitoring report. Attention shall be given to the presence or absence of: floating or suspended matter, discoloration, aquatic life, visible film, sheen or coating, and fungi, slime, or objectionable growths.

According to the SIP, the Discharger is required to monitor the receiving water for the CTR priority pollutants, to determine reasonable potential. Accordingly, the Regional Water Board is requiring that the Discharger conduct upstream receiving water monitoring of the CTR priority pollutants at Monitoring Location RSW-001. The Discharger must analyze temperature, pH, and salinity of the receiving water at the same time the samples are collected for priority pollutants analysis.

##### 2. Groundwater

[Not Applicable]

#### E. Other Monitoring Requirements

[Not Applicable]

## VII. RATIONALE FOR PROVISIONS

### A. Standard Provisions

#### 1. Federal Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The Discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Section 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Section 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with section 123.25, this Order omits federal conditions that address enforcement authority specified in sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code section 13387(e).

#### 2. Regional Water Board Standard Provisions

Regional Water Board Standard Provisions are based on the CWA, USEPA regulations, and the Water Code.

### B. Special Provisions

#### 1. Reopener Provisions

These provisions are based on section 123 and the previous Order. The Regional Water Board may reopen the permit to modify permit conditions and requirements. Causes for modifications include the promulgation of new federal regulations, modification in toxicity requirements, or adoption of new regulations by the State Water Board or Regional Water Board, including revisions to the Basin Plan.

#### 2. Special Studies and Additional Monitoring Requirements

a. Initial Investigation Toxicity Reduction Evaluation Workplan. This provision is based on section 4 of the SIP, Toxicity Control Provisions.

#### 3. Best Management Practices and Pollution Prevention

This provision is based on section 122.44(k) and includes the requirement to develop a SWPPP.

#### 4. Compliance Schedules [Not Applicable]

5. Construction, Operation, and Maintenance Specifications

This provision is based on the requirements of section 122.41(e) and the previous Order.

6. Special Provisions for Municipal Facilities (POTWs Only)  
[Not Applicable]

7. Other Special Provisions  
[Not Applicable]

**VIII. PUBLIC PARTICIPATION**

The California Regional Water Quality Board, Los Angeles Region (Regional Water Board) is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollution Discharge Elimination System (NPDES) permit for the Vopak Terminal Los Angeles, Inc. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments should be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices on October 17, 2007, by 5:00 p.m.

C. Hearing Date and Location

The Regional Board is scheduled to hold a public hearing on:

November 1, 2007, at 9:00 AM  
City Of Simi Valley, Council Chambers  
2929 Tapo Canyon Road  
Simi Valley, California

Please check the Regional Board website (<http://www.waterboards.ca.gov/losangeles/>) for the most up to date public hearing location as it is subject to change.

D. Availability of Documents

The Report of Waste Discharge (ROWD), related documents, tentative requirements, comments received, and other information received on the discharge are available for inspection and copying between the hours of 8:00 a.m. and 4:30 p.m. at the following address:

California Regional Water Quality Control Board  
Los Angeles Region  
320 West 4<sup>th</sup> Street, Suite 200  
Los Angeles, CA 90013

Arrangements for file review and/or obtaining copies of the documents may be made by calling the Los Angeles Regional Board at (213) 576-6600. The entire file will become a part of the administrative record of this proceeding, irrespective of whether individual documents are specifically referenced during the hearing. The entire file will not be present in the hearing room. Should any interested persons desire staff to bring to the hearing any particular documents that are not included in the agenda packet, they must submit a written or electronic request to staff during business hours, not later than [5] business days before the hearing. The request must identify the documents with enough specificity for staff to locate them.

#### E. Nature of Hearing

This proceeding will be a formal adjudicatory proceeding. For such proceedings, the Regional Board follows procedures established by the State Water Resources Control Board, which are set forth in regulations commencing with section 647 of title 23 of the California Code of Regulations, in particular, Article 2, commencing with section 648. While this proceeding is formal, as an administrative proceeding, the Board does not generally require the prior identification or cross examination of witnesses, or other procedures not specified in this notice, that might typically be expected of parties in a courtroom.

#### F. Communications with Staff Before the Hearing

The lead staff member responsible for this item is:

Name: Mazhar Ali  
Address: 320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, CA 90013  
Telephone: 213-576-6652  
Fax: 213-576-6660  
Email: mali@waterboards.ca.gov

#### G. Parties to the Hearing

The following are the parties to this proceeding:

1. The Applicant/Permittee: Vopak Terminal Los Angeles, Inc. (Marine Terminal, Wilmington)
2. Regional Board Staff: Cassandra Owens, Chief  
Industrial Permitting Unit  
  
Mazhar Ali, Industrial Permitting Unit

Any other persons requesting party status must submit a written or electronic request to staff not later than [20] business days before the hearing. All parties will be notified if other persons are so designated.

#### H. Public Comments and Submittal of Evidence

Persons wishing to comment upon or object to the tentative waste discharge requirements, or submit evidence for the Board to consider, are invited to submit them in writing to the above address. To be evaluated and responded to by staff, included in the Board's agenda folder, and fully considered by the Board, written comments must be received no later than close of business on October 17, 2007. Comments or evidence received after that date will be submitted, ex agenda, to the Board for consideration, but only included in administrative record with express approval of the Chair during the hearing. Additionally, if the Board receives only supportive comments, the permit may be placed on the Board's consent calendar, and approved without an oral testimony.

#### I. Hearing Procedure

The meeting, in which the hearing will be a part of, will start at 9:00 a.m. Interested persons are invited to attend. Staff will present the matter under consideration, after which oral statements from parties or interested persons will be heard. For accuracy of the record, all important testimony should be in writing. The Board will include in the administrative record written transcriptions of oral testimony that is actually presented at the hearing. Oral testimony may be limited to 30 minutes maximum or less for each speaker, depending on the number of persons wishing to be heard. Parties or persons with similar concerns or opinions are encouraged to choose one representative to speak. At the conclusion of testimony, the Board will deliberate in open or close session, and render a decision.

Parties or persons with special procedural requests should contact staff. Any procedure not specified in this hearing notice will be waived pursuant to section 648(d) of title 23 of the California Code of Regulations. Objections to any procedure to be used during this hearing must be submitted in writing not later than close of 15 business days prior to the date of the hearing. Procedural objections will not be entertained at the hearing.

If there should not be a quorum on the scheduled date of this meeting, all cases will be automatically continued to the next scheduled meeting on December 6, 2007. A continuance will not extend any time set forth herein.

#### J. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board  
Office of Chief Counsel  
P.O. Box 100, 1001 I Street  
Sacramento, CA 95812-0100

## **ATTACHMENT G – STORM WATER POLLUTION PREVENTION PLAN REQUIREMENTS**

### **SECTION A: STORM WATER POLLUTION PREVENTION PLAN REQUIREMENTS**

#### **1. Objectives**

The SWPPP has two major objectives: (a) to identify and evaluate sources of pollutants associated with industrial activities that may affect the quality of storm water discharges and authorized non-storm water discharges from the facility; and (b) to identify and implement site-specific best management practices (BMPs) to reduce or prevent pollutants associated with industrial activities in storm water discharges and authorized non-storm water discharges. BMPs may include a variety of pollution prevention measures or other low-cost and pollution control measures. They are generally categorized as non-structural BMPs (activity schedules, prohibitions of practices, maintenance procedures, and other low-cost measures) and as structural BMPs (treatment measures, run-off controls, over-head coverage.) To achieve these objectives, facility operators should consider the five phase process for SWPPP development and implementation as shown in Table A.

The SWPPP requirements are designed to be sufficiently flexible to meet the needs of various facilities. SWPPP requirements that are not applicable to a facility should not be included in the SWPPP.

A facility's SWPPP is a written document that shall contain a compliance activity schedule, a description of industrial activities and pollutant sources, descriptions of BMPs, drawings, maps, and relevant copies or references of parts of other plans. The SWPPP shall be revised whenever appropriate and shall be readily available for review by facility employees or Regional Water Board inspectors.

#### **2. Planning and Organization**

##### **a. Pollution Prevention Team**

The SWPPP shall identify a specific individual or individuals and their positions within the facility organization as members of a storm water pollution prevention team responsible for developing the SWPPP, assisting the facility manager in SWPPP implementation and revision, and conducting all monitoring program activities required in the Monitoring and Reporting Program (Attachment E). The SWPPP shall clearly identify the related responsibilities, duties, and activities of each team member. For small facilities, storm water pollution prevention teams may consist of one individual where appropriate.

##### **b. Review Other Requirements and Existing Facility Plans**

The SWPPP may incorporate or reference the appropriate elements of other regulatory requirements. Facility operators should review all local, State, and Federal requirements that impact, complement, or are consistent with the requirements of this Order. Facility operators should identify any existing facility plans that contain storm water pollutant control measures or relate to the requirements of this Order. As examples, facility operators whose facilities are subject to Federal Spill Prevention Control and Countermeasures requirements should already have instituted a plan to control spills of certain hazardous materials. Similarly, facility operators whose facilities are subject to air quality related permits and regulations may already have evaluated industrial activities that generate dust or particulates.

### 3. Site Map

The SWPPP shall include a site map. The site map shall be provided on an 8-½ x 11 inch or larger sheet and include notes, legends, and other data as appropriate to ensure that the site map is clear and understandable. If necessary, facility operators may provide the required information on multiple site maps.

TABLE A  
FIVE PHASES FOR DEVELOPING AND IMPLEMENTING INDUSTRIAL  
STORM WATER POLLUTION PREVENTION PLANS

<p>PLANNING AND ORGANIZATION</p> <p>Form Pollution Prevention Team Review other plans</p>
<p>ASSESSMENT PHASE</p> <p>Develop a site map Identify potential pollutant sources Inventory of materials and chemicals List significant spills and leaks Identify non-storm water discharges Assess pollutant Risks</p>
<p>BEST MANAGEMENT PRACTICES IDENTIFICATION PHASE</p> <p>Non-structural BMPs Structural BMPs Select activity and site-specific BMPs</p>
<p>IMPLEMENTATION PHASE</p> <p>Train employees Implement BMPs Conduct recordkeeping and reporting</p>
<p>EVALUATION / MONITORING</p> <p>Conduct annual site evaluation Review monitoring information Evaluate BMPs Review and revise SWPPP</p>

The following information shall be included on the site map:

- a. The facility boundaries; the outline of all storm water drainage areas within the facility boundaries; portions of the drainage area impacted by run-on from surrounding areas; and direction of flow of each drainage area, on-site surface water bodies, and areas of soil erosion. The map shall also identify nearby water bodies (such as rivers, lakes, and ponds) and municipal storm drain inlets where the facility's storm water discharges and authorized non-storm water discharges may be received.
- b. The location of the storm water collection and conveyance system, associated points of discharge, and direction of flow. Include any structural control measures that affect storm water discharges, authorized non-storm water discharges, and run-on. Examples of structural control measures are catch basins, berms, detention ponds, secondary containment, oil/water separators, diversion barriers, etc.
- c. An outline of all impervious areas of the facility, including paved areas, buildings, covered storage areas, or other roofed structures.
- d. Locations where materials are directly exposed to precipitation and the locations where significant spills or leaks have occurred.
- e. Areas of industrial activity. This shall include the locations of all storage areas and storage tanks, shipping and receiving areas, fueling areas, vehicle and equipment storage/maintenance areas, material handling and processing areas, waste treatment and disposal areas, dust or particulate generating areas, cleaning and rinsing areas, and other areas of industrial activity which are potential pollutant sources.

#### 4. List of Significant Materials

The SWPPP shall include a list of significant materials handled and stored at the site. For each material on the list, describe the locations where the material is being stored, received, shipped, and handled, as well as the typical quantities and frequency. Materials shall include raw materials, intermediate products, final or finished products, recycled materials, and waste or disposed materials.

#### 5. Description of Potential Pollutant Sources

- a. The SWPPP shall include a narrative description of the facility's industrial activities associated potential pollutant sources, and potential pollutants that could be discharged in storm water discharges or authorized non-storm water discharges. At a minimum, the following items related to a facility's industrial activities shall be considered:

- i. Industrial Processes

Describe each industrial process, the type, characteristics, and quantity of significant materials used in or resulting from the process, and a description of the manufacturing, cleaning, rinsing, recycling, disposal, or other activities related to the process. Where applicable, areas protected by containment structures and the corresponding containment capacity shall be described.

ii. Material Handling and Storage Areas

Describe each handling and storage area, type, characteristics, and quantity of significant materials handled or stored, description of the shipping, receiving, and loading procedures, and the spill or leak prevention and response procedures. Where applicable, areas protected by containment structures and the corresponding containment capacity shall be described.

iii. Dust and Particulate Generating Activities

Describe all industrial activities that generate dust or particulates that may be deposited within the facility's boundaries and identify their discharge locations; the characteristics of dust and particulate pollutants; the approximate quantity of dust and particulate pollutants that may be deposited within the facility boundaries; and a description of the primary areas of the facility where dust and particulate pollutants would settle.

iv. Significant Spills and Leaks

Describe materials that have spilled or leaked in significant quantities in storm water. The description shall include the type, characteristics, and approximate quantity of the material spilled or leaked, the cleanup or remedial actions that have occurred or are planned, the approximate remaining quantity of materials that may be exposed to storm water or non-storm water discharges, and the preventative measures taken to ensure spill or leaks do not reoccur. Such list shall be updated as appropriate during the term of this Order.

v. Non-Storm Water Discharges

Facility operators shall investigate the facility to identify all non-storm water discharges and their sources not authorized by this Order. As part of this investigation, all drains (inlets and outlets) shall be evaluated to identify whether they connect to the storm drain system.

All unauthorized non-storm water discharges shall be described. This shall include the source, quantity, frequency, and characteristics of the unauthorized non-storm water discharges and associated drainage area.

The SWPPP must include BMPs to prevent or reduce contact of unauthorized non-storm water discharges with significant materials or equipment.

vi. Soil Erosion

Describe the facility locations where soil erosion may occur as a result of industrial activity, storm water discharges associated with industrial activity, or authorized non-storm water discharges.

- b. The SWPPP shall include a summary of all areas of industrial activities, potential pollutant sources, and potential pollutants. This information should be summarized similar to Table B. The last column of Table B, "Control Practices", should be completed in accordance with Section 7. below.

## 6. Assessment of Potential Pollutant Sources

- a. The SWPPP shall include a narrative assessment of all industrial activities and potential pollutant sources as described above to determine:
  - i. Which areas of the facility are likely sources of pollutants in storm water discharges and authorized non-storm water discharges, and
  - ii. Which pollutants are likely to be present in storm water discharges and authorized non-storm water discharges. Facility operators shall consider and evaluate various factors when performing this assessment such as current storm water BMPs; quantities of significant materials handled, produced, stored, or disposed of; likelihood of exposure to storm water or authorized non-storm water discharges; history of spill or leaks; and run-on from outside sources.
- b. Facility operators shall summarize the areas of the facility that are likely sources of pollutants and the corresponding pollutants that are likely to be present in storm water discharges and authorized non-storm water discharges.

Facility operators are required to develop and implement additional BMPs as appropriate and necessary to prevent or reduce pollutants associated with each pollutant source. The BMPs will be narratively described in Section 7 below.

## 7. Storm Water Best Management Practices

The SWPPP shall include a narrative description of the storm water BMPs to be implemented at the facility for each potential pollutant and its source identified in the site assessment phase (Sections 5. and 6. above). The BMPs shall be developed and implemented to reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. Each pollutant and its source may require one or more BMPs. Some BMPs may be implemented for multiple pollutants and their sources, while other BMPs will be implemented for a very specific pollutant and its source.

**TABLE B**  
**EXAMPLE ASSESSMENT OF POTENTIAL POLLUTION SOURCES AND**  
**CORRESPONDING BEST MANAGEMENT PRACTICES**  
**SUMMARY**

<b>Area</b>	<b>Activity</b>	<b>Pollutant Source</b>	<b>Pollutant</b>	<b>Best Management Practices</b>
Vehicle & Equipment Fueling	Fueling	Spills and leaks during delivery.  Spills caused by topping off fuel tanks.  Hosing or washing down fuel oil fuel area.  Leaking storage tanks.  Rainfall running off fuel oil, and rainfall running onto and off fueling area.	Fuel oil	Use spill and overflow protection.  Minimize run-on of storm water into the fueling area.  Cover fueling area.  Use dry cleanup methods rather than hosing down area.  Implement proper spill prevention control program.  Implement adequate preventative maintenance program to preventive tank and line leaks.  Inspect fueling areas regularly to detect problems before they occur.  Train employees on proper fueling, cleanup, and spill response techniques.

The description of the BMPs shall identify the BMPs as (1) existing BMPs, (2) existing BMPs to be revised and implemented, or (3) new BMPs to be implemented. The description shall also include a discussion on the effectiveness of each BMP to reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. The SWPPP shall provide a summary of all BMPs implemented for each pollutant source. This information should be summarized similar to Table B.

Facility operators shall consider the following BMPs for implementation at the facility:

a. Non-Structural BMPs

Non-structural BMPs generally consist of processes, prohibitions, procedures, schedule of activities, etc., that prevent pollutants associated with industrial activity from contacting with storm water discharges and authorized non-storm water discharges. They are considered low technology, cost-effective measures. Facility operators should consider all possible non-structural BMPs options before considering additional structural BMPs (see Section 7.b. below). Below is a list of non-structural BMPs that should be considered:

i. Good Housekeeping

Good housekeeping generally consist of practical procedures to maintain a clean and orderly facility.

ii. Preventive Maintenance

Preventive maintenance includes the regular inspection and maintenance of structural storm water controls (catch basins, oil/water separators, etc.) as well as other facility equipment and systems.

iii. Spill Response

This includes spill clean-up procedures and necessary clean-up equipment based upon the quantities and locations of significant materials that may spill or leak.

iv. Material Handling and Storage

This includes all procedures to minimize the potential for spills and leaks and to minimize exposure of significant materials to storm water and authorized non-storm water discharges.

v. Employee Training

This includes training of personnel who are responsible for (1) implementing activities identified in the SWPPP, (2) conducting inspections, sampling, and visual observations, and (3) managing storm water. Training should address topics such as spill response, good housekeeping, and material handling procedures, and actions necessary to implement all BMPs identified in the SWPPP. The SWPPP shall identify periodic dates for such training. Records shall be maintained of all training sessions held.

vi. Waste Handling/Recycling

This includes the procedures or processes to handle, store, or dispose of waste materials or recyclable materials.

vii. Recordkeeping and Internal Reporting

This includes the procedures to ensure that all records of inspections, spills, maintenance activities, corrective actions, visual observations, etc., are developed, retained, and provided, as necessary, to the appropriate facility personnel.

viii. Erosion Control and Site Stabilization

This includes a description of all sediment and erosion control activities. This may include the planting and maintenance of vegetation, diversion of run-on and runoff, placement of sandbags, silt screens, or other sediment control devices, etc.

ix. Inspections

This includes, in addition to the preventative maintenance inspections identified above, an inspection schedule of all potential pollutant sources. Tracking and follow-up procedures shall be described to ensure adequate corrective actions are taken and SWPPPs are made.

x. Quality Assurance

This includes the procedures to ensure that all elements of the SWPPP and Monitoring Program are adequately conducted.

b. Structural BMPs

Where non-structural BMPs as identified in Section 7.a. above are not effective, structural BMPs shall be considered. Structural BMPs generally consist of structural devices that reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. Below is a list of structural BMPs that should be considered:

i. Overhead Coverage

This includes structures that provide horizontal coverage of materials, chemicals, and pollutant sources from contact with storm water and authorized non-storm water discharges.

ii. Retention Ponds

This includes basins, ponds, surface impoundments, bermed areas, etc. that do not allow storm water to discharge from the facility.

iii. Control Devices

This includes berms or other devices that channel or route run-on and runoff away from pollutant sources.

iv. Secondary Containment Structures

This generally includes containment structures around storage tanks and other areas for the purpose of collecting any leaks or spills.

v. Treatment

This includes inlet controls, infiltration devices, oil/water separators, detention ponds, vegetative swales, etc. that reduce the pollutants in storm water discharges and authorized non-storm water discharges.

8. SWPPP General Requirements

- a. The SWPPP shall be retained on site and made available upon request of a representative of the Regional Water Board and/or local storm water management agency (local agency) which receives the storm water discharges.
- b. The Regional Water Board and/or local agency may notify the facility operator when the SWPPP does not meet one or more of the minimum requirements of this Section. As requested by the Regional Water Board and/or local agency, the facility operator shall submit an SWPPP revision and implementation schedule that meets the minimum requirements of this section to the Regional Water Board and/or local agency that requested the SWPPP revisions.
- c. The SWPPP shall be revised, as appropriate, and implemented prior to changes in industrial activities which (i) may significantly increase the quantities of pollutants in storm water discharge, (ii) cause a new area of industrial activity at the facility to be exposed to storm water, or (iii) begin an industrial activity which would introduce a new pollutant source at the facility.
- d. The SWPPP shall be revised and implemented in a timely manner, but in no case more than 90 days after a facility operator determines that the SWPPP is in violation of any requirement(s) of this Order.
- e. When any part of the SWPPP is infeasible to implement by the deadlines specified in this Order due to proposed significant structural changes, the facility operator shall submit a report to the Regional Water Board prior to the applicable deadline that (i) describes the portion of the SWPPP that is infeasible to implement by the deadline, (ii) provides justification for a time extension, (iii) provides a schedule for completing and implementing that portion of the SWPPP, and (iv) describes the BMPs that will be implemented in the interim period to reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. Such reports are subject to Regional Water Board approval and/or modifications. Facility operators shall provide written notification to the Regional Water Board within 14 days after the SWPPP revisions are implemented.
- f. The SWPPP shall be provided, upon request, to the Regional Water Board. The SWPPP is considered a report that shall be available to the public by the Regional Water Board under Section 308(b) of the Clean Water Act.

## ATTACHMENT H – STATE WATER BOARD MINIMUM LEVELS (ML)

The Minimum Levels (MLs) in this appendix are for use in reporting and compliance determination purposes in accordance with section 2.4 of the State Implementation Policy. These MLs were derived from data for priority pollutants provided by State certified analytical laboratories in 1997 and 1998. These MLs shall be used until new values are adopted by the State Water Board and become effective. The following tables (Tables 2a - 2d) present MLs for four major chemical groupings: volatile substances, semi-volatile substances, inorganics, and pesticides and PCBs.

Table 2a - VOLATILE SUBSTANCES*	GC	GCMS
1,1 Dichloroethane	0.5	1
1,1 Dichloroethylene	0.5	2
1,1,1 Trichloroethane	0.5	2
1,1,2 Trichloroethane	0.5	2
1,1,2,2 Tetrachloroethane	0.5	1
1,2 Dichlorobenzene (volatile)	0.5	2
1,2 Dichloroethane	0.5	2
1,2 Dichloropropane	0.5	1
1,3 Dichlorobenzene (volatile)	0.5	2
1,3 Dichloropropene (volatile)	0.5	2
1,4 Dichlorobenzene (volatile)	0.5	2
Acrolein	2.0	5
Acrylonitrile	2.0	2
Benzene	0.5	2
Bromoform	0.5	2
Methyl Bromide	1.0	2
Carbon Tetrachloride	0.5	2
Chlorobenzene	0.5	2
Chlorodibromo-methane	0.5	2
Chloroethane	0.5	2
Chloroform	0.5	2
Chloromethane	0.5	2
Dichlorobromo-methane	0.5	2
Dichloromethane	0.5	2
Ethylbenzene	0.5	2
Tetrachloroethylene	0.5	2
Toluene	0.5	2
Trans-1,2 Dichloroethylene	0.5	1
Trichloroethene	0.5	2
Vinyl Chloride	0.5	2

\*The normal method-specific factor for these substances is 1; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance.

Table 2b - SEMI-VOLATILE SUBSTANCES*	GC	GCMS	LC	COLOR
Benzo (a) Anthracene	10	5		
1,2 Dichlorobenzene (semivolatile)	2	2		
1,2 Diphenylhydrazine		1		
1,2,4 Trichlorobenzene	1	5		
1,3 Dichlorobenzene (semivolatile)	2	1		
1,4 Dichlorobenzene (semivolatile)	2	1		
2 Chlorophenol	2	5		
2,4 Dichlorophenol	1	5		

Table 2b - SEMI-VOLATILE SUBSTANCES*	GC	GCMS	LC	COLOR
2,4 Dimethylphenol	1	2		
2,4 Dinitrophenol	5	5		
2,4 Dinitrotoluene	10	5		
2,4,6 Trichlorophenol	10	10		
2,6 Dinitrotoluene		5		
2- Nitrophenol		10		
2-Chloroethyl vinyl ether	1	1		
2-Chloronaphthalene		10		
3,3' Dichlorobenzidine		5		
Benzo (b) Fluoranthene		10	10	
3-Methyl-Chlorophenol	5	1		
4,6 Dinitro-2-methylphenol	10	5		
4- Nitrophenol	5	10		
4-Bromophenyl phenyl ether	10	5		
4-Chlorophenyl phenyl ether		5		
Acenaphthene	1	1	0.5	
Acenaphthylene		10	0.2	
Anthracene		10	2	
Benzidine		5		
Benzo(a) pyrene		10	2	
Benzo(g,h,i)perylene		5	0.1	
Benzo(k)fluoranthene		10	2	
bis 2-(1-Chloroethoxyl) methane		5		
bis(2-chloroethyl) ether	10	1		
bis(2-Chloroisopropyl) ether	10	2		
bis(2-Ethylhexyl) phthalate	10	5		
Butyl benzyl phthalate	10	10		
Chrysene		10	5	
di-n-Butyl phthalate		10		
di-n-Octyl phthalate		10		
Dibenzo(a,h)-anthracene		10	0.1	
Diethyl phthalate	10	2		
Dimethyl phthalate	10	2		
Fluoranthene	10	1	0.05	
Fluorene		10	0.1	
Hexachloro-cyclopentadiene	5	5		
Hexachlorobenzene	5	1		
Hexachlorobutadiene	5	1		
Hexachloroethane	5	1		
Indeno(1,2,3,cd)-pyrene		10	0.05	
Isophorone	10	1		
N-Nitroso diphenyl amine	10	1		
N-Nitroso-dimethyl amine	10	5		
N-Nitroso -di n-propyl amine	10	5		
Naphthalene	10	1	0.2	
Nitrobenzene	10	1		
Pentachlorophenol	1	5		
Phenanthrene		5	0.05	
Phenol **	1	1		50
<b>Pyrene</b>		10	0.05	

\* With the exception of phenol by colorimetric technique, the normal method-specific factor for these

substances is 1,000; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance multiplied by 1,000.

\*\* Phenol by colorimetric technique has a factor of 1.

Table 2c – INORGANICS*	FAA	GFAA	ICP	ICPMS	SPGFAA	HYDRIDE	CVAA	COLOR	DCP
Antimony	10	5	50	0.5	5	0.5			1,000
Arsenic		2	10	2	2	1		20	1,000
Beryllium	20	0.5	2	0.5	1				1,000
Cadmium	10	0.5	10	0.25	0.5				1,000
Chromium (total)	50	2	10	0.5	1				1,000
Chromium VI	5							10	
Copper	25	5	10	0.5	2				1,000
Cyanide								5	
Lead	20	5	5	0.5	2				10,000
Mercury				0.5			0.2		
Nickel	50	5	20	1	5				1,000
Selenium		5	10	2	5	1			1,000
Silver	10	1	10	0.25	2				1,000
Thallium	10	2	10	1	5				1,000
Zinc	20		20	1	10				1,000

\* The normal method-specific factor for these substances is 1; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance.

Table 2d – PESTICIDES – PCBs*	GC
4,4'-DDD	0.05
4,4'-DDE	0.05
4,4'-DDT	0.01
a-Endosulfan	0.02
alpha-BHC	0.01
Aldrin	0.005
b-Endosulfan	0.01
Beta-BHC	0.005
Chlordane	0.1
Delta-BHC	0.005
Dieldrin	0.01
Endosulfan Sulfate	0.05
Endrin	0.01
Endrin Aldehyde	0.01
Heptachlor	0.01
Heptachlor Epoxide	0.01
Gamma-BHC (Lindane)	0.02
PCB 1016	0.5
PCB 1221	0.5
PCB 1232	0.5
PCB 1242	0.5
PCB 1248	0.5
PCB 1254	0.5
PCB 1260	0.5
Toxaphene	0.5

- \* The normal method-specific factor for these substances is 100; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance multiplied by 100.

**Techniques:**

GC - Gas Chromatography

GCMS - Gas Chromatography/Mass Spectrometry

HRGCMS - High Resolution Gas Chromatography/Mass Spectrometry (i.e., EPA 1613, 1624, or 1625)

LC - High Pressure Liquid Chromatography

FAA - Flame Atomic Absorption

GFAA - Graphite Furnace Atomic Absorption

HYDRIDE - Gaseous Hydride Atomic Absorption

CVAA - Cold Vapor Atomic Absorption

ICP - Inductively Coupled Plasma

ICPMS - Inductively Coupled Plasma/Mass Spectrometry

SPGFAA - Stabilized Platform Graphite Furnace Atomic Absorption (i.e., EPA 200.9)

DCP - Direct Current Plasma

COLOR – Colorimetric

**ATTACHMENT I – PRIORITY POLLUTANTS**

<b>CTR Number <sup>1</sup></b>	<b>Parameter</b>	<b>CAS Number</b>	<b>Suggested Analytical Methods</b>
	<b><u>Metals</u></b>		
1	Antimony	7440360	4
2	Arsenic	7440382	4
3	Beryllium	7440417	4
4	Cadmium	7440439	4
5a	Chromium (III)	16065831	4
5a	Chromium (VI)	18540299	4
6	Copper	7440508	4
7	Lead	7439921	4
8	Mercury	7439976	4
9	Nickel	7440020	4
10	Selenium	7782492	4
11	Silver	7440224	4
12	Thallium	7440280	4
13	Zinc	7440666	4
	<b><u>Miscellaneous</u></b>		
14	Cyanide	57125	4
15	Asbestos	1332214	4
16	2,3,7,8-TCDD	1746016	4
	<b><u>Volatile Organics</u></b>		
17	Acrolein	107028	4
18	Acrylonitrile	107131	4
19	Benzene	71432	4
20	Bromoform	75252	4
21	Carbon Tetrachloride	56235	4
22	Chlorobenzene	108907	4
23	Chlorodibromomethane	124481	4
24	Chloroethane	75003	4
25	2-Chloroethylvinyl Ether	110758	4
26	Chloroform	67663	4
27	Dichlorobromomethane	75274	4
28	1,1-Dichloroethane	75343	4
29	1,2-Dichloroethane	107062	4
30	1,1-Dichloroethylene	75354	4
31	1,2-Dichloropropane	78875	4
32	1,3-Dichloropropylene	542756	4
33	Ethylbenzene	100414	4
34	Methyl Bromide	74839	4
35	Methyl Chloride	74873	4

CTR Number <sup>1</sup>	Parameter	CAS Number	Suggested Analytical Methods
36	Methylene Chloride	75092	4
37	1,1,2,2-Tetrachloroethane	79345	4
38	Tetrachloroethylene	127184	4
39	Toluene	108883	4
40	1,2-Trans-Dichloroethylene	156605	4
41	1,1,1-Trichloroethane	71556	4
42	1,1,2-Trichloroethane	79005	4
43	Trichloroethylene	79016	4
44	Vinyl Chloride	75014	4
	Xylenes <sup>2</sup>		4
	<b><u>Acid Extractables</u></b>		
45	2-Chlorophenol	95578	4
46	2,4-Dichlorophenol	120832	4
47	2,4-Dimethylphenol	105679	4
48	2-Methyl-4,6-Dinitrophenol	534521	4
	(4,6-dinitro-o-cresol) <sup>3</sup>		4
49	2,4-Dinitrophenol	51285	4
50	2-Nitrophenol	88755	4
51	4-Nitrophenol	100027	4
52	3-Methyl-4-Chlorophenol	59507	4
	(P-chloro-m-cresol) <sup>3</sup>		4
53	Pentachlorophenol	87865	4
54	Phenol	108952	4
55	2,4,6-Trichlorophenol	88062	4
	<b><u>Base/Neutral Extractables</u></b>		
56	Acenaphthene	83329	4
57	Acenaphthylene	208968	4
58	Anthracene	120127	4
59	Benzidine	92875	4
60	Benzo(a)Anthracene	56553	4
61	Benzo(a)Pyrene	50328	4
62	Benzo(b)Fluoranthene	205992	4
63	Benzo(ghi)Perylene	191242	4
	(1,12-Benzoperylene) <sup>3</sup>		4
64	Benzo(k)Fluoranthene	207089	4
65	Bis(2-Chloroethoxy)Methane	111911	4
66	Bis(2-Chloroethyl)Ether	111444	4
67	Bis(2-Chloroisopropyl)Ether	108601	4
68	Bis(2-Ethylhexyl)Phthalate	117817	4
69	4-Bromophenyl Phenyl Ether	101553	4
70	Butylbenzyl Phthalate	85687	4
71	2-Chloronaphthalene	91587	4
72	4-Chlorophenyl Phenyl Ether	7005723	4

CTR Number <sup>1</sup>	Parameter	CAS Number	Suggested Analytical Methods
73	Chrysene	218019	4
74	Dibenzo(a,h)Anthracene (1,2,5,6-Dibenzanthracene) <sup>3</sup>	53703	4
75	1,2-Dichlorobenzene	95501	4
76	1,3-Dichlorobenzene	541731	4
77	1,4-Dichlorobenzene	106467	4
78	3,3'-Dichlorobenzidine	91941	4
79	Diethyl Phthalate	84662	4
80	Dimethyl Phthalate	131113	4
81	Di-n-Butyl Phthalate	84742	4
82	2,4-Dinitrotoluene	121142	4
83	2,6-Dinitrotoluene	606202	4
84	Di-n-Octyl Phthalate	117840	4
85	1,2-Diphenylhydrazine	122667	4
86	Fluoranthene	206440	4
87	Fluorene	86737	4
88	Hexachlorobenzene	118741	4
89	Hexachlorobutadiene	87863	4
90	Hexachlorocyclopentadiene	77474	4
91	Hexachloroethane	67721	4
92	Indeno(1,2,3-cd)Pyrene	193395	4
93	Isophorone	78591	4
94	Naphthalene	91203	4
95	Nitrobenzene	98953	4
96	N-Nitrosodimethylamine	62759	4
97	N-Nitrosodi-n-Propylamine	621647	4
98	N-Nitrosodiphenylamine	86306	4
99	Phenanthrene	85018	4
100	Pyrene	129000	4
101	1,2,4-Trichlorobenzene	120821	4
	<b><u>Pesticides &amp; PCBs</u></b>		
102	Aldrin	309002	4
103	alpha-BHC	319846	4
104	beta-BHC	319857	4
105	gamma-BHC	58899	4
106	delta-BHC	319868	4
107	Chlordane	57749	4
108	4,4'-DDT	50293	4
109	4,4'-DDE	72559	4
110	4,4'-DDD	72548	4
111	Dieldrin	60571	4
112	alpha-Endosulfan	959988	4
113	beta-Endosulfan	33213659	4
114	Endosulfan Sulfate	1031078	4
115	Endrin	72208	4

<b>CTR Number <sup>1</sup></b>	<b>Parameter</b>	<b>CAS Number</b>	<b>Suggested Analytical Methods</b>
116	Endrin Aldehyde	7421934	4
117	Heptachlor	76448	4
118	Heptachlor Epoxide	1024573	4
119	PCB-1016	12674112	4
120	PCB-1221	11104282	4
121	PCB-1232	11141165	4
122	PCB-1242	53469219	4
123	PCB-1248	12672296	4
124	PCB-1254	11097691	4
125	PCB-1260	11096825	4
126	Toxaphene	8001352	4

1. 40 CFR 131.38(b)(1) number
2. Xylenes are to be analyzed in addition to the priority pollutants
3. Synonym
4. Pollutants shall be analyzed using methods described in 40 CFR Part 136

VOPAK TERMINAL LOS ANGELES, INC.  
MARINE TERMINAL  
ORDER NO. R4-2007-0057  
NPDES NO. CA0055247