

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION

MONITORING AND REPORTING PROGRAM NO. 6203
FOR
BANK OF AMERICA NT&SA
(CA0057690)

The discharger shall implement this monitoring program on the effective date of this Order. The first monitoring report under this program is due by October 15, 1994.

Monitoring reports shall be submitted by the dates in the following schedule:

<u>Reporting Period</u>	<u>Report Due</u>
January - March	April 15
April - June	July 15
July - September	October 15
October - December	January 15

In no flow occurred during the quarter the report shall so state.

Effluent Monitoring

A sampling station shall be established for each point of discharge and shall be located where representative samples of the effluent can be obtained. The following shall constitute the effluent monitoring program:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum Frequency of Analysis</u>
pH	pH units	grab	annually
Temperature	°F	grab	monthly
Total waste flow	gal/day	----	monthly
Suspended solids	mg/l	grab	monthly
Settleable solids	ml/l	grab	monthly
BOD ₅ ,20°C	mg/l	grab	annually
Oil and grease	mg/l	grab	annually
Turbidity	TU	grab	annually

Bank of America NT&SA

CA0057690

The report for the January - March quarter shall include the results of all annual analyses.

Ordered by:

Robert P. Ghirelli

ROBERT P. GHIRELLI, D.Env.
Executive Officer

Date: 7-25-94

/TRB

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

101 CENTRE PLAZA DRIVE
MONTEREY PARK, CA 91754-2156
(213) 266-7500
FAX: (213) 266-7600



July 25, 1994

Mr. Peter Bennett
Manager, Corporate Real Estate
Bank of America National Trust and Savings Association
1000 West Temple Street
Los Angeles, CA 90012

WASTE DISCHARGE REQUIREMENTS (NPDES PERMIT NO. CA0057690)


Reference is made to our letter dated June 1, 1994, transmitting a draft of tentative requirements for your disposal of wastes to surface waters.

Pursuant to Division 7 of the California Water Code, this California Regional Water Quality Control Board, at a public hearing on July 18, 1994, reviewed these tentative requirements, considered all factors in the case, and adopted the requirements without change as Order No. 94-071 (copy attached) relative to this waste discharge. This Order serves as a permit under the National Pollutant Discharge Elimination System, and will expire July 10, 1999. It will be necessary for you to file an application for a new permit at least 180 days in advance of that date.

You are required to implement the new monitoring program as stated in the Monitoring and Reporting Program on the effective date of this Order. Please note that any monitoring report due under your previous Monitoring and Reporting Program is still required and must be submitted by the due date. Please reference all technical and monitoring reports to Compliance File No. 6203. We would appreciate it if you would not combine other reports, such as progress or technical reports, with your monitoring reports, but would submit each type of report as a separate document.

To reduce postage and mailing costs, copies of Order No. 94-071 are not being sent to parties on the mailing list, who have already received copies of the tentative Order. However, a copy of the adopted Order will be furnished on request.

Very truly yours,

for 
Lawrence A. Meyerson
Supervising Water Resource Control Engineer

cc: See attached mailing list
Enclosures

Bank of America NT & SA

July 25, 1994

Mailing List

cc: Environmental Protection Agency, Region 9, Administrative
Service Division (W-5-1)
U.S. Army Corps of Engineers
NOAA, National Marine Fisheries Service
Department of Interior, U.S. Fish and Wildlife Service
Mr. John Youngerman, State Water Resources Control Board,
Division of Water Quality
Mr. Jorge Leon, State Water Resources Control
Board, Office of Chief Counsel
Department of Fish and Game, Marine Resources Region
Department of Fish and Game, Region 5
Department of Health Services, Sanitary Engineering Section
Los Angeles County, Department of Public Works, Waste
Management Division
Los Angeles County, Department of Public Works,
Hydraulics/Water Conservation Division
City of Los Angeles, Bureau of Sanitation, Industrial Waste
Management

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION

ORDER NO. 94-071

NPDES NO. CA0057690

WASTE DISCHARGE REQUIREMENTS
FOR
BANK OF AMERICA NATIONAL TRUST & SAVING ASSOCIATION
(Data Processing Center)

The California Regional Water Quality Control Board, Los Angeles Region, finds:

1. Bank of America National Trust & Saving Association (a corporation) discharges wastes under waste discharge requirements contained in Order No. 84-15 (NPDES Permit No. CA0057690), adopted by this Board on February 27, 1994.
2. Bank of America National Trust & Savings Association has filed a report of waste discharge and has applied for renewal of its waste discharge and applied for renewal of its waste discharge requirements and National Pollutant Discharge Elimination System Permit for discharge of groundwater seepage to surface waters.
3. Bank of America National Trust & Saving Association operates a data processing center at 1000 West Temple Street, Los Angeles, California, and discharges up to 7,750 gallons per day of groundwater seepage into storm drains at the following discharge points:

Discharge Serial No. 001 - up to 1,000 gallons per day from the building's groundwater sump into a storm drain in Temple Street.

Discharge Serial No. 002 - up to 6,750 gallons per day from a parking structure groundwater sump into a storm drain in Beaudry Avenue.

The wastes flow via a storm drain in Second Street to Los Angeles River, a water of the United States, at a point about 700 feet downstream from First Street, above the tidal prism.

4. All other industrial and domestic wates from this facility are discharged to the community sewer system, including the bleed-off from four internal cooling towers used for air conditioning of computer rooms/equipment.

5. The Board adopted a revised Water Quality Control Plan for the Los Angeles River Basin on June 3, 1991. The Plan identifies the beneficial uses of Los Angeles River and its tributaries and enumerates the water quality objectives necessary to protect these uses.
6. The beneficial uses of the receiving waters are: groundwater recharge, water-contact and non-contact water recreation, warm freshwater habitat, wildlife habitats, and (within the tidal prism), industrial service supply, ocean commercial and sport fishing, preservation habitat, and saline water habitat.
7. The requirements contained in this Order, as they are met, will be in conformance with the goals of the Water Quality Control Plan.
8. The issuance of waste discharge requirements for this discharge is exempt from the provisions of Chapter 3 (commencing with Section 21000) of Division 13 of the Public Resources Code in accordance with Water Code Section 13389.
9. Effluent limitation standards established pursuant to Section 301 of the Federal Clean Water Act and amendments thereto are applicable to the discharge.

The Board has notified the discharger and interested agencies and persons of its intent to renew waste discharge requirements for this discharge and has provided them with an opportunity to submit their written views and recommendations.

The Board, in a public hearing heard, and considered all comments pertaining to the discharge and to the tentative requirements.

This Order shall serve as a National Pollutant Discharge Elimination System (NPDES) permit pursuant to Section 402 of the Federal Water Pollution Control Act, or amendments thereto, and shall take effect at the end of ten days from the date of its adoption provided the Regional Administrator of the United States Environmental Protection Agency (EPA) has no objections.

IT IS HEREBY ORDERED that Bank of America, in order to meet the provision contained in Division 7 of the California Water Code and regulations adopted thereunder, and the provisions of the Federal Clean Water Act and regulations and guidelines adopted thereunder, shall comply with the following:

A. Effluent Limitations

1. Wastes discharged shall be limited to groundwater seepage only, as proposed.
2. The discharge of wastes in excess of the following limits is prohibited:

<u>Constituent</u>	<u>Units</u>	<u>Discharge Limitations*</u>
		<u>Daily Maximum</u>
Suspended solids	mg/l	150
	lbs/day	9.7
BOD ₅ 20°C	mg/l	40
	lbs/day	2.9
Oil and grease	mg/l	15
	lbs/day	1.0
Turbidity	TU	150

* The mass emission rate (lbs/day) is based on a maximum rate of 7,750 gallons per day.

3. The pH of wastes discharged shall at all times be within the range of 6.0 to 9.0.
4. The temperature of wastes discharged shall not exceed 100°F.

B. Narrative Water Quality Limitations

1. Surface water communities and populations, including vertebrate, invertebrate, and plant species, shall not be degraded as a result of this waste discharge.
2. The natural taste and odor of fish, shellfish, or other surface water resources used for human consumption shall not be impaired.
3. Toxic pollutants shall not be discharged at levels that will bioaccumulate in aquatic resources to levels which are harmful to human health.
4. The concentration of toxic pollutants in the water column, sediments, or biota shall not adversely affect any beneficial use as a result of this discharge.

C. Requirements and Provisions

1. This Order includes the attached "Standard Provisions and General Monitoring and Reporting Requirements" ("Standard Provisions"). If there is any conflict between requirements stated herein, including limitations and objectives, and the "Standard Provisions", the requirements shall prevail.

D. Expiration Date

This Order expires on July 10, 1999. The discharger must file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, not later than 180 days in advance of that date as application for issuance of new waste discharge requirements and NPDES permit.

E. Rescission

Order No. 84-15, adopted by this Board on February 27, 1984, is hereby rescinded.

I, Robert P. Ghirelli, Executive Officer, do hereby certify that the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region on July 18, 1994.

Robert P. Ghirelli
ROBERT P. GHIRELLI, D.Env.
Executive Officer