

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles
FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CENTER FOR EARLY EDUCATION
(Glendale Gateway Business Park)

NPDES NO. CAG914001
CI-6832

FACILITY LOCATION

563 N. Alfred Street
West Hollywood, CA 90048

FACILITY MAILING ADDRESS

563 N. Alfred Street
West Hollywood, CA 90048

PROJECT DESCRIPTION

Center of Early Education (CFEE) operates a school facility at 563 N. Alfred Street, West Hollywood. Groundwater beneath the site is impacted by volatile organic compounds, primarily tetrachloroethylene (PCE). Groundwater is extracted and treated, then discharged to a storm drain located at the site. The treatment system consists of two activated carbon canisters connected in series to remove organic compounds.

VOLUME AND DESCRIPTION OF DISCHARGE

CFEE discharges up to 36,000 gallons per day of treated groundwater to a storm drain located at (Latitude 34°04' 52", Longitude 118°22'31"), thence to Ballona Creek, a water of the United States. The site location map and the schematic of waste flow diagram are shown as Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE

The discharge is continuous through the remediation project.

REUSE OF WATER

Due to lack of landscaping area at the site, there are no other feasible reuse options for the discharge. Therefore, the wastewater is discharged to the Ballona Creek.