

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
HOFFMANN-WOLYNEC LIMITED, LLC
(MALIBU MEDIA CENTER)**

**ORDER NO. 01-031
FILE NO. 90-050**

FACILITY ADDRESS

22483 Pacific Coast Highway
Malibu, CA 90265

FACILITY MAILING ADDRESS

925 De La Vina Street, Suite 103
Santa Barbara, CA 93101-3202

PROJECT DESCRIPTION:

Hoffmann-Wolyneec Limited, LLC, owns and operates the Malibu Media Center which is a commercial building occupying approximately 0.57 acre in the City of Malibu. Domestic wastewater from the facility is discharged to a septic disposal system consisting of a 1,200-gallon septic tank and approximately 550 square feet of leach lines.

A geologic investigation performed in 1983 at the subject site indicated groundwater depth is more than 13.5 feet below ground surface. In addition, according to the City of Malibu consulting geologists, the groundwater is at a depth of approximately 17 feet below ground surface on the land side of Pacific Coast Highway about ¼ to ½ mile north of the subject site.

VOLUME AND DESCRIPTION OF DISCHARGE:

Approximately 132 gallons per day (on average) of domestic wastewater are discharged to the septic disposal system located at latitude: 34° 01' 31" and longitude: 118° 39' 30".