

**State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
HONEYWELL INTERNATIONAL, INC.
(Former Honeywell Sepulveda Facility)**

**NPDES NO. CAG914001
CI-8302**

PROJECT LOCATION

9851 Sepulveda Boulevard
Los Angeles, CA 90045

FACILITY MAILING ADDRESS

2525 W. 190th St., M/S23-1-80
Torrance, CA 90504-6099

PROJECT DESCRIPTION

Honeywell International, Inc. (Honeywell) extracts and treats contaminated groundwater beneath its facility located at 9851 Sepulveda Boulevard, Los Angeles, and then discharges the treated groundwater to a storm drain located at the site. The facility is currently a parking facility and is a former Allied Signal Aerospace site. The treatment system includes a settling tank to remove suspended solids, and two activated carbon canisters in series to remove chlorinated hydrocarbons.

VOLUME AND DESCRIPTION OF DISCHARGE

Honeywell discharges up to 10,000 gallons per day of treated groundwater to a storm drain located at (Latitude 33° 57' 00", Longitude 118° 23' 40"), thence to Ballona Creek, a water of the United States. The site location and the schematic of waste flow diagram are shown as Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE

The continuous discharge was started in the 4th quarter of 1999 and will last up to four years.

REUSE OF WATER

Due to lack of landscaping area at the site, there are no feasible reuse options for the discharge. Therefore, the wastewater is discharged to Ballona Creek.