

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
EAST PASADENA WATER COMPANY
(WELL NOS. 8 AND 10)
NPDES NO. CAG994001
CI-8131

PROJECT LOCATION

Well Nos. 8 and 10
East Mountain View Avenue
Pasadena, California

FACILITY MAILING ADDRESS

3725 East Mountain View Avenue
Pasadena, CA 91107

PROJECT DESCRIPTION

East Pasadena Water Company supplies potable water to local residents in Pasadena area. East Pasadena Water Company proposes to discharge groundwater from the refurbishment of Well No. 8, located at 3725 East Mountain View Avenue, and Well No. 10, located at the northeast corner of Walnut Court and Mountain View Avenue. Wastewater will be generated during dynamic spinner log tests, zone sampling, and drawdown tests. Groundwater from the wells will flow through settling tanks to remove sediments prior to discharge to a storm drain.

VOLUME AND DESCRIPTION OF DISCHARGE

East Pasadena Water Company proposes to discharge up to 1.7 MGD of groundwater to a storm drain located at the corner of Mountain View Avenue and Michillinda Avenue (Latitude 34° 08' 32", Longitude 118° 04' 16"), thence to the Rio Hondo River, a water of the United States, above the estuary. See Figure 1, Well Location.

FREQUENCY OF DISCHARGE

Discharge from the Well No. 8 is proposed to begin in September 2002 and will last for two to three weeks. Discharge from the Well No. 10 is scheduled in 2003 and will last for two to three weeks.

REUSE OF WATER

East Pasadena Water Company has studied the feasibility of reusing the groundwater and other alternative disposal options. These options are not feasible at the site; therefore, the groundwater will be discharged to a storm drain.