

**State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
CHROMIZING COMPANY  
(CHROMALLOY LOS ANGELES)**

**NPDES NO. CAG914001  
CI-8254**

**PROJECT LOCATION**

2100 West 139<sup>th</sup> Street  
Gardena, CA 90249

**FACILITY MAILING ADDRESS**

3636 Arrowhead Drive  
Carson City, NV 89706

**PROJECT DESCRIPTION**

Chromalloy Los Angeles (Chromalloy) is remediating volatile organic compounds (mostly Tetrachloroethylene and Trichloroethylene) impacted soil and groundwater at the project site. The treatment system consists of a high-vacuum dual-phase extraction system with granular activated carbon treatment. Chromalloy discharges the treated groundwater to a storm drain.

**VOLUME AND DESCRIPTION OF DISCHARGE**

Chromalloy discharges up to 7,200 gallons per day of wastewater from the treatment system. The wastewater from the treatment system is discharged through an underground discharge line located at Outfall No. 1 (Latitude 33° 53' 16", Longitude 118° 18' 53") into the Dominguez Channel, a water of the United States. See Figures 1 and 2 for the schematic diagram and site location.

**FREQUENCY OF DISCHARGE**

The discharge will be intermittent.

**REUSE OF WATER**

Chromalloy considered reuse of treated wastewater at the facility for irrigation purposes. However, due to the size of the facility, it could not accommodate the planned flow rate. Therefore, reuse is not feasible.