

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CITY OF PASADENA
(GROUNDWATER WELL 58)

NPDES NO. CAG994001
CI-8278

FACILITY ADDRESS

3000 E. Alameda Street
Pasadena, CA 91107

FACILITY MAILING ADDRESS

150 S Los Robles Avenue, Suite 200
Pasadena, CA 91101

PROJECT DESCRIPTION

The City of Pasadena proposes to construct a water supply well at the above-referenced site. Water from the well will be used as a source of potable water. Groundwater generated from constructing the well and from periodic pumping tests of the well will be discharged to the Eaton Wash.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 37,500 gallons per day of groundwater will be discharged into the Eaton Wash at 35° 09' 00"N, 118° 05' 30"W. The discharge into the Eaton Wash flows to the Rio Hondo, thence to the Los Angeles River, a water of the United States.

FREQUENCY OF DISCHARGE

Discharge will occur during the initial well testing and during periodic well start-up, approximately four times a year. Discharge is not anticipated during normal pumping operation.

REUSE OF WATER

Because of the intermittent nature of the discharge, there is no feasible reuse option for the water at the site.