

STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013

FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
RIO CAFÉ & GROCERIES

ORDER NO. 01-031  
FILE NO. 01-055

**FACILITY ADDRESS**

9411 Soledad Canyon Road  
Santa Clarita, CA 91350

**FACILITY MAILING ADDRESS**

9411 Soledad Canyon Road  
Santa Clarita, CA 91350

**PROJECT DESCRIPTION:**

Rio Café & Groceries proposes to discharge domestic wastes into on-site sewage disposal system that consists of a 1,500 gallon capacity septic tank and two seepage pits having a maximum depth of 18 feet. The domestic wastes go to the septic tank, which will reduce pollutant levels and produce an effluent of fairly uniform quality. The effluent from the septic tank will go through a distribution box that directs the flow of the effluent to a seepage pit system, which disperses the sewage effluent into the natural soil.

**VOLUME AND DESCRIPTION OF DISCHARGE:**

Up to 30 gallons per day of domestic wastes will be discharged to an on-site sewage disposal system located at 9411 Soledad Canyon Road, Santa Clarita, California (Latitude: 34° 26' 25", Longitude: 118° 17' 45").