

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
JACK IN THE BOX #3304**

**ORDER NO. 01-031
FILE NO. 01-085**

FACILITY ADDRESS

3838 Sierra Highway
Acton, CA 93510

FACILITY MAILING ADDRESS

100 N. Barranca, Suite 200
West Covina, CA 91791-1600

PROJECT DESCRIPTION:

Jack in the Box # 3304 proposes to upgrade the existing septic disposal system by installing four additional seepage pits (44" diameter x 50' depth), with a total liquid capacity of 17,384 gallons. The existing system consists of two individual septic disposal systems. The first contains a 1500-gallon grease interceptor, a sampling box, concrete distribution box, a 2500-gallon septic tank, and two 44" x 40' seepage pits. The second system contains a concrete distribution box, two 2500-gallon septic tanks, and two seepage pits (44" diameter x 50' depth). Both of these units will remain in operation and will be connected to the new seepage pits in series.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 3550 gallons per day of domestic wastes will be discharged to an on-site sewage disposal system located at 3838 Sierra Highway, Acton, California (Latitude: 34° 29' 34", Longitude: 118° 11' 55"). The on-site sewage disposal system will consist of a 1500-gallon grease interceptor, a sampling box, two concrete distribution box's, three 2500-gallon septic tanks, and eight seepage pits (44" diameter x 50' depth).