

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles
FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
PACIFIC PIPELINE SYSTEM LLC

NPDES NO. CAG674001
CI-8433

FACILITY LOCATION

5900 Cherry Avenue
Long Beach, CA 90805

FACILITY MAILING ADDRESS

5900 Cherry Avenue
Long Beach, CA 90805

PROJECT DESCRIPTION

Pacific Pipeline System LLC (PPS) proposes to install a treatment system to treat the waste- water used in conducting hydrostatic testing at the subject site. The average annual volume of water generated from these tests is approximately 500,000 gallons. The source of the hydrotest water is from municipal water agencies. Treatment and discharge is anticipated to occur twice annually for a period of up to 10 days each. The proposed treatment system consists of an oil/water separator, particulate filtration unit, and a granular activated carbon unit to remove organics.

VOLUME AND DESCRIPTION OF DISCHARGE

PPS will discharge up to 72,000 gallons per day of treated groundwater. The water will be discharged into a storm drain located at Cherry Avenue (Latitude 33°46' 01", Longitude 118°11' 18"), thence to the Los Angeles River, a water of the United States.

FREQUENCY OF DISCHARGE

The discharge will be intermittent and will begin in August 2002.

REUSE OF WATER

Due to lack of landscaping area at the site, there are no feasible reuse options for the groundwater.