

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
VENTURA REGIONAL SANITATION DISTRICT**

**ORDER NO. 01- 031
FILE NO. 01-142**

FACILITY ADDRESS

3500 Toland Road
Santa Paula, CA 93060

FACILITY MAILING ADDRESS

1001 Partridge Drive, Suite 150
Ventura, CA 93003

PROJECT DESCRIPTION:

Ventura Regional Sanitation District proposes to install an on-site sanitary treatment system at the Toland Road Landfill located at 3500 Toland Road in Santa Paula, California. The purpose of the system is to treat and discharge on-site sewage generated from toilets, hand washing, floor sinks, and showers. The estimated treatment flow is a maximum of 400 gallons per day.

The proposed system is called the Orenco AdvanTex AX and RX Series septic treatment system. It will consist of two 1,500 gallon tanks with internal treatment systems that outlet treated effluent to a subsurface distribution system. A sand filter will be incorporated between the textile filter and the leachfield. The leachfield will have an area of 1,600 square feet and a minimum depth of 12-inches.

VOLUME AND DESCRIPTION OF DISCHARGE:

The estimated discharge from the subject facility (Latitude: 34°23'955", Longitude: 118°59'886") is approximately 400 gallons per day which is within the system operating limits. The wastewater is composed of domestic wastewater generated from toilets, hand washing, floor sinks, and showers. The wastewater shall be treated and disposed of using the Orenco System.