

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
SHELL OIL PRODUCTS US
(SHELL VAN NUYS TERMINAL)

NPDES NO. CAG674001
CI-8454

FACILITY ADDRESS

8100 Haskell Avenue
Van Nuys, CA 91406

FACILITY MAILING ADDRESS

20945 South Wilmington Avenue
Carson, CA 90810

PROJECT DESCRIPTION:

Shell Oil Products US (Shell) will be constructing a new aboveground storage tank at their facility located at 8100 Haskell Avenue, Van Nuys. Shell proposes to conduct hydrostatic testing of Tank No. 60. Potable water supplied by the City of Los Angeles Department of Water and Power will be used for the hydrostatic testing. Shell proposes to discharge the hydrostatic test water to a nearby storm drain.

VOLUME AND DESCRIPTION OF DISCHARGE:

Approximately 290,300 gallons of hydrostatic test water will be discharged to the storm drain located (Latitude: 34° 13' 02", Longitude: 118° 28' 30") along Haskell Avenue that drains into the Sepulveda Flood Control Basin. From the Basin, the discharge flows into the Los Angeles River, a water of the United States. The discharge will occur over a period of five days. The vicinity map and map site plan are shown in Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE:

The discharge will be intermittent. Shell anticipates that the hydrostatic testing will be conducted during September 2002.

REUSE OF WATER:

Water reuse options, such as dust control and soil compaction, were evaluated. However, they were infeasible because the facility is located in a commercial area with no demand for water reuse. Therefore, the hydrostatic test water will be discharged into the storm drain.