



Los Angeles Regional Water Quality Control Board

May 17, 2019

Mr. Mark Pestrella, Director
County of Los Angeles Public Works
900 South Fremont Avenue
Alhambra, CA 91803-1331

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
CLAIM NO. 7018 2290 0001 8905 2657

TERMINATION OF WASTEWATER DISCHARGE REQUIREMENTS FOR MALIBU ADMINISTRATIVE CENTER AT 23519 WEST CIVIC CENTER WAY, MALIBU, CA 90265 (ORDER NO. 01-031, FILE NO. 01-155, CI NO. 8469, GLOBAL ID WDR100001182)

Dear Mr. Pestrella:

The Los Angeles Region Water Quality Control Board (Regional Water Board), is the public agency with primary responsibility for the protection of ground and surface water quality for all beneficial uses of water within major portions of Los Angeles and Ventura Counties. The Malibu Administrative Center (Facility) is located within the Regional Water Board's jurisdiction.

On October 8, 2002, the Facility was authorized to discharge wastewater to land under waste discharge requirements contained in the General Waste Discharge Requirements (WDR) for Small Commercial and Multi-family Residential Subsurface Sewage Disposal Systems, Order No. 01-031 adopted by the Regional Water Board on February 22, 2001. The Facility is equipped with an onsite wastewater treatment system consisting of a 16,000-gallon septic tank and a leach field. The estimated maximum daily volume of wastewater being discharged into the septic system is less than 5,000 gallons per day.

On November 5, 2009 the Regional Water Board adopted Resolution No. R4-2009-007 approving an amendment to Chapter 4 of the Water Quality Control Plan for the Coastal Watersheds of Los Angeles and Ventura Counties (Basin Plan), to prohibit on-site wastewater disposal systems (OWDSs) in the Malibu Civic Center Area (Basin Plan Amendment). The Basin Plan Amendment requires that all commercial discharges to OWDSs in the Malibu Civic Center Area cease by November 5, 2015. In August 2011, the Regional Water Board, the State Water Resources Control Board, and the City of Malibu (City) entered into a Memorandum of Understanding, which was subsequently revised on December 4, 2014 and February 2, 2017, for the City to construct and startup the Malibu Civic Center Wastewater Treatment Facility (MCCWTF) and connect commercial properties within the Phase I boundaries, including the Facility, by September 30, 2018.

On October 30, 2018, the City reported that the wastewater generated from this Facility was diverted to the MCCWTF before the September 30, 2018 deadline. Therefore, permit coverage

IRMA MUÑOZ, CHAIR | RENEE PURDY, EXECUTIVE OFFICER

320 West 4th St., Suite 200, Los Angeles, CA 90013 | www.waterboards.ca.gov/losangeles

under General WDR Order No. 01-031 and the associated monitoring and reporting program CI No. 8469 are terminated.

If you have any questions, please contact the Project Manager, Dr. Don Tsai, at (213) 620-2264 (Don.Tsai@waterboards.ca.gov), or the Chief of Groundwater Permitting Unit, Dr. Eric Wu at (213) 576-6683 (Eric.Wu@waterboards.ca.gov).

Sincerely,



Renee Purdy

Executive Officer, Los Angeles Regional Water Quality Control Board

cc (via email): Ms. Reva Feldman, City of Malibu
Mr. Craig George, City of Malibu
Ms. Michelle Tsiebos, County of Los Angeles Public Health
Mr. John Skinner, County of Los Angeles Beaches and Harbors