

**State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles
FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
EQUILON ENTERPRISES, LLC
(Former Texaco Service Station)
NPDES NO. CAG834001
CI-8495**

PROJECT LOCATION

18910 Crenshaw Boulevard
Torrance, CA 90504

FACILITY MAILING ADDRESS

P.O. Box 7869
Burbank, CA 91510-7869

PROJECT DESCRIPTION

The former Texaco Service Station is located in the City of Torrance. The site is owned and operated by Equilon Enterprises, LCC. Shallow groundwater beneath the site is contaminated with a plume of petroleum hydrocarbon. The subject site is currently under the oversight of this Regional Board for remediation of impacted groundwater. The project consultant, WGR Southwest, Inc., will be conducting a extraction/treatment system through on-site groundwater monitoring wells. The extracted groundwater will be filtered through a series of three canisters containing granular activated carbon (GAC) prior to discharge into the storm drain.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 21,600 gallons per day of treated groundwater will be discharged. The water will be discharged into a storm drain which drains into Dominguez Channel (Latitude 33°52' 30", Longitude 118°17'30"), a water of the United States. The site location and the schematic of waste flow diagram are shown as Figures I and II, respectively.

FREQUENCY OF DISCHARGE

The groundwater remedial activity is scheduled to begin in January 2003. The discharge will be continuous.

REUSE OF WATER

Due to lack of landscaping area at the site, there are no feasible reuse options for the discharge.