

STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
AUGEAS CORPORATION  
(FORMER JUST GAS)**

**NPDES NO. CAG834001  
CI-8557**

**FACILITY ADDRESS**

2441 Vineyard Avenue  
Oxnard, California

**FACILITY MAILING ADDRESS**

P. O. Box 1541  
Santa Cruz, CA 95060

**PROJECT DESCRIPTION:**

Augeas Corporation proposes to discharge treated groundwater generated during groundwater monitoring at the former gasoline station located at 2441 Vineyard Avenue, Oxnard. Groundwater beneath the site is impacted with petroleum-fuel compounds. Prior to discharge, the groundwater will be pumped into a holding tank and treated by two granular activated carbon filters installed in series.

**VOLUME AND DESCRIPTION OF DISCHARGE:**

Up to 20,000 gallons per day of treated groundwater will be discharged. The groundwater will be discharged to the Santa Clara River, (Latitude: 34° 13' 46", Longitude: 119° 10' 32"), a water of the United States. The project location map is shown in Figure 1.

**FREQUENCY OF DISCHARGE:**

The groundwater discharge will be intermittent.

**REUSE OF WATER:**

The reuse of pumped groundwater at the site was evaluated. The immediate vicinity of the site is for commercial use. The pumped groundwater cannot be reused for irrigation because there are no immediate areas that will need irrigation at the site. The disposal of water to a treatment facility is not feasible because it is not cost effective. Therefore, the majority of the groundwater will be discharged into Santa Clara River.