

**State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles
FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CONOCOPILLIPS COMPANY
(76 Station No. 0981)**

**NPDES NO. CAG834001
CI-8599**

FACILITY LOCATION

1004 S. La Cienega Boulevard
Los Angeles, CA 90035

FACILITY MAILING ADDRESS

P. O. Box 25376
Santa Ana, CA 92799

PROJECT DESCRIPTION

The subject site is a 76 Service Station located at 1004 S. La Cienega Boulevard, Los Angeles. Shallow groundwater beneath the site is contaminated with petroleum hydrocarbons. The subject site is currently under the oversight of this Regional Board for remediation of impacted groundwater. The project consultant, TRC Alton Geoscience, will be conducting groundwater extraction through on-site groundwater monitoring wells. The extracted groundwater will be treated through a series of three canisters containing granular activated carbon (GAC) to remove fuel hydrocarbons. Post-treatment water samples will be taken for analyses prior to discharge into the storm drain.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 7,200 gallons per day of treated groundwater will be discharged to the storm drain located at Latitude 34° 03' 33", Longitude 118° 22' 33", which drains into Ballona Creek, a water of the United States. The site location map and the schematic of waste flow diagram are shown as Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE

The continuous discharge is scheduled to begin in July 2003 and it will last until the cleanup project has been completed.

REUSE OF WATER

Due to lack of landscaped area at the site, there are no feasible reuse options for the discharge. Therefore, the treated groundwater will be discharged to the storm drain.