

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

MONITORING AND REPORTING PROGRAM NO. CI 8673
FOR
WESTERN LOS ANGELES COUNTY COUNCIL, INC.
BOY SCOUTS OF AMERICA, ("Discharger")
(Timothy M. Pennington IV, Marine Science Center)
(File No. 03-062)

I. REPORTING REQUIREMENTS

- A. The Discharger shall implement this Monitoring Program on the effective date of WDR Order No. R4-2003-0142 (Order). The first monitoring report under this program, for October – December 2003, shall be received at the Regional Board by January 15, 2004. Subsequent monitoring reports shall be received at the Regional Board according to the following schedule:

<u>Reporting Period</u>	<u>Report Due</u>
January – March	April 15
April – June	July 15
July – September	October 15
October – December	January 15

- B. If there is no discharge during any reporting period, the report shall so state. Monitoring reports must be addressed to the Regional Board, Attention: Information Technology Unit.
- C. By January 30th of each year, beginning January 30, 2005, the Discharger shall submit an annual summary report to the Regional Board. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous calendar year. In addition, the Discharger shall discuss the compliance record and the corrective actions taken or planned which may be needed to bring the discharge into full compliance with the waste discharge requirements.
- D. Laboratory analyses – all chemical, bacteriological, and toxicity analyses shall be conducted at a laboratory certified for such analyses by the California Department of Health Services Environmental Laboratory Accreditation Program (ELAP). A copy of the laboratory certification shall be provided each time a new and/or renewal certification is obtained from ELAP.
- E. The method limits (MLs) employed for effluent analyses shall be lower than the permit limits established for a given parameter, unless the Discharger can

September 23, 2003
Revised: October 15, 2003

demonstrate that a particular ML is not attainable and obtains approval for a higher ML from the Executive Officer.

- F. Water/wastewater samples must be analyzed within allowable holding time limits as specified in 40 CFR Part 136. All Quality Assurance/Quality Control (QA/QC) samples must be run on the same dates when samples were actually analyzed. At least once a year, the Discharger shall maintain and update a list of the analytical methods employed for each test and the associated laboratory QA/QC procedures. The Discharger shall make available for inspection and/or submit the QA/QC documentation upon request by Regional Board staff.
- G. Each monitoring report must affirm in writing that "All analyses were conducted at a laboratory certified for such analyses by the California Department of Health Services, and in accordance with current United States Environmental Protection Agency (USEPA) guideline procedures or as specified in this Monitoring Program." Proper chain of custody procedures must be followed and a copy of the completed chain of custody form shall be submitted with the report.
- H. Each monitoring report shall contain a separate section titled "Summary of Non-Compliance" which discusses the compliance record and the corrective actions taken or planned that may be needed to bring the discharge into full compliance with waste discharge requirements. This section shall be located at the front of the report and shall clearly list all non-compliance with discharge requirements, as well as all excursions of effluent limitations.
- I. For every item where the requirements are not met, the Discharger shall submit a statement of the cause(s), and actions undertaken or proposed which will bring the discharge into full compliance with waste discharge requirements at the earliest possible time, including a timetable for implementation of those actions.
- J. The Discharger shall maintain all records of sampling and analytical results: date; exact place, and time of sampling; dates analyses were performed; analyst's name; analytical techniques used; and results of all analyses. Such records shall be retained for a minimum of three years. This period of retention shall be extended during the course of any unresolved litigation regarding this discharge, or when requested by the Regional Board.
- K. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized to demonstrate compliance with the requirements and, where applicable, shall include results of receiving water observations.
- L. Any mitigation/remedial activity including any pre-discharge treatment conducted at the site must be reported in the quarterly monitoring report. In addition, if effluent r

groundwater monitoring programs have not yet been implemented, a short description of the status of both shall also be included.

II. WATER QUALITY MONITORING REQUIREMENTS

A. Influent Monitoring

An influent monitoring program shall be designed to quarterly measure the concentrations of settleable and suspended solids and dissolved oxygen. The Discharger shall provide influent monitoring information with quarterly reports.

B. Effluent Monitoring

An effluent monitoring program shall be designed to evaluate the water quality of the discharge of circulated seawater from the proposed seawater life support system. An effluent sampling station(s) shall be established at a location(s) where representative samples of treated effluent can be obtained prior to discharge to the leachfield disposal system.

1. The following shall constitute the effluent monitoring program:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum Frequency of Analysis</u> ¹
Total Flow	gal/day	--	monthly
pH	pH units	grab	quarterly
Ammonia-N	mg/L	grab	quarterly
Total coliform	MPN/100mL	grab	quarterly
Enterococcus	MPN/100mL	grab	quarterly
BOD ₅ 20° C	mg/L	grab	annually
Dissolved oxygen	mg/L	grab	quarterly
Suspended solids	mg/L	grab	quarterly
Settleable solids	mg/L	grab	quarterly
<u>Total residual chlorine</u>	<u>µg/L</u>	<u>grab</u>	<u>quarterly</u>

^[1] The Discharger's compliance point is at "end of pipe".

2. The quarterly reports shall contain the following information:

- a. Average and maximum daily waste flow (effluent from retention basin) for each month of the quarter in gallons per day.
- b. Results of at least monthly observations in the disposal area for any over flow or surfacing of wastes.

3. In addition, the Discharger shall annually inspect the wastewater system including disposal area and submit an operation and maintenance report on the system. The information to be contained in the report shall include, at a minimum, the following:

- a. Results of annual inspection;
- b. The maintenance records for the wastewater treatment system;
- c. Type of maintenance (preventive or corrective action performed);
- d. Frequency of maintenance, if preventive;
- e. The name of the person responsible for the operation and maintenance of the facility.

III. WASTE HAULING REPORTING

In the event that waste sludge or other wastes are hauled offsite, the name and address of the hauler shall be reported, along with types and quantities hauled during the reporting period and the location of final point of disposal. In the event that no wastes are hauled during the reporting period, a statement to that effect shall be submitted.

IV. OPERATION AND MAINTENANCE REPORT

The Discharger shall annually submit a technical report to the Executive Officer relative to the operation and maintenance program for the Timothy M. Pennington IV, Marine Science Center. The information to be contained in the report shall include the following:

- a. The name and address of the person or company responsible for the operation and maintenance of the facility;
- b. Type of maintenance (preventive or corrective action performed);
- c. Frequency of maintenance, if preventive;
- d. Maintenance record of leaching/disposal fields system; and
- e. Results of at least monthly observations in the disposal area for any overflow or surfacing of waste.

This operations and maintenance record shall be kept current and filed with the annual report due by January 30.

V. CERTIFICATION STATEMENT

Each report shall contain the following declaration:

"I certify under penalty of law that this document, including all attachments and supplemental information, was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of a fine and imprisonment.

Executed on the ____ day of _____ at _____.

_____(Signature)

_____(Title)"

VI. MONITORING FREQUENCIES

Monitoring frequencies may be adjusted to a less frequent basis or parameters dropped by the Executive Officer if the Discharger makes a request and the Executive Officer determines that the request is adequately supported by statistical trends of monitoring data submitted.

These records and reports are public documents and shall be made available for inspection during normal business hours at the office of the California Regional Water Quality Control Board, Los Angeles Region.

Ordered by: _____
Dennis A. Dickerson
Executive Officer

Date: November 6, 2003