

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
AL-SAL OIL COMPANY
(STATION NO. 4)**

**NPDES NO. CAG834001
CI-8688**

FACILITY ADDRESS

9081 W. Pico Boulevard
Los Angeles, California 90035

FACILITY MAILING ADDRESS

3410 E. Foothill Boulevard
Pasadena, CA 91107

PROJECT DESCRIPTION:

Al-Sal Oil Company proposes to discharge wastewater from the groundwater cleanup project at 9081 W. Pico Boulevard, Los Angeles, California. Groundwater beneath the site is impacted with petroleum-fuel. Prior to discharge, the extracted groundwater will be treated by passing it through three 1,000-lbs granular activated carbon (GAC) absorption vessels.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 72,000 gallons per day of treated groundwater will be discharged into a storm drain located along Pico Boulevard (Latitude: 34° 2' 0", Longitude: 118° 22' 30"). The discharge from the storm drain flows into Benedict Canyon Creek, thence to Ballona Creek, a water of the United States. The site location map and process flow diagram are shown in Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE:

The discharge of treated groundwater will be intermittent.

REUSE OF WATER:

Offsite disposal of treated waste is not feasible due to high cost of disposal. The property and the immediate vicinity have no landscaped areas that require irrigation. Since there are no feasible reuse options, the groundwater will be discharged to the storm drain.