

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
BERGLUND PROPERTY
(TRIANGLE GAS STATION)**

**NPDES NO. CAG834001
CI-8732**

FACILITY ADDRESS

2900-2918 Riverside Drive
Los Angeles, California 90039

FACILITY MAILING ADDRESS

2204 Moreno Drive
Los Angeles, California 90039

PROJECT DESCRIPTION:

Berglund Property proposes to discharge wastewater from the groundwater cleanup project located at 2900-2918 Riverside Drive, Los Angeles, California. Groundwater beneath the site is impacted with petroleum-fuel hydrocarbons. Prior to discharge, the extracted groundwater will be treated by passing it through four 1,000-lbs granular activated carbon (GAC) absorption vessels.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 21,600 gallons per day of treated groundwater will be discharged into a storm drain located along Riverside Drive (Latitude: 34° 6' 39", Longitude: 118° 15' 55"). The discharge from the storm drain flows into the Los Angeles River, a water of the United States. The site location map and process flow diagram are shown in Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE:

The discharge of treated groundwater will be intermittent.

REUSE OF WATER:

Offsite disposal of treated waste is not feasible due to high cost of disposal. The property and the immediate vicinity have no landscaped areas that require irrigation. Since there are no feasible reuse options, the treated groundwater will be discharged to the storm drain.