

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
HARRISON/ROBERTS ENVIRONMENTAL MANAGEMENT
(FORMER SERVICE STATION)**

**NPDES NO. CAG834001
CI-8806**

FACILITY ADDRESS

7228 Beverly Boulevard
Los Angeles, California 90036

FACILITY MAILING ADDRESS

11140 Los Alamitos Blvd., Ste. 203
Los Alamitos, CA 90720

PROJECT DESCRIPTION:

Harrison/Roberts Environmental Management (Discharger) has completed a feasibility study for removal of petroleum contaminants from the groundwater beneath the subject site. The Discharger is proposing to implement full-scale groundwater treatment. See Figure 1 for the location of the site, and Figure 2 for the diagram of the treatment process. The treated groundwater generated during the feasibility study is contained in a Baker tank located at the site. The Discharger proposes to discharge the treated groundwater that is in the Baker tank along with the effluent from the full-scale treatment into a nearby stormwater drain.

VOLUME AND DESCRIPTION OF DISCHARGE:

The Discharger plans to discharge up to 5,000 gallons per day of groundwater from the facility. The groundwater is discharged to Outfall No. 1 (Latitude: 34° 04' 41", Longitude: 118° 20' 08") and flows into Ballona Creek, a water of the United States.

FREQUENCY OF DISCHARGE:

The groundwater discharge will be continuous for the duration of the treatment system operation.

REUSE OF WATER:

Offsite disposal of the groundwater is not feasible due to high cost of disposal. The property and the immediate vicinity have no landscaped areas that require irrigation using the groundwater. Since there are no feasible reuse options, the groundwater will be discharged to the storm drain.

October 1, 2004