

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CRESTVIEW MUTUAL WATER COMPANY
(WATER WELL NO. 6)**

CI-8964

FACILITY ADDRESS

109 N. Avocado Place
Camarillo, CA 93010

FACILITY MAILING ADDRESS

328 Valley Vista Drive
Camarillo, CA 93010

PROJECT DESCRIPTION:

Crestview Mutual Water Company (Crestview) proposes to discharge groundwater associated with construction and development of Well No. 6, located at 109 N. Avocado Place, Camarillo. A desilting tank will be installed to allow sediment to settle out before the discharge. Approximately 2.2 million gallons per day of groundwater will be discharged during well development and subsequent pumping and aquifer tests. It is anticipated that well development and aquifer tests will be completed within one month after the well construction.

VOLUME AND DESCRIPTION OF DISCHARGE:

Approximately 2.2 million gallons per day (MGD) of groundwater will be discharged into the Barranca Creek (Latitude: 34° 13' 51", Longitude: 119° 04' 55"). The discharge from the Creek flows into Beardsley Wash, thence into Revolon Slough (Below Potrero Road), a water of the United States. The site location map is shown in Figure 1.

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed on the Table below have been determined to show reasonable potential to exist in the discharge. The discharge flows into the Revolon Slough that has designated beneficial use of MUN (Potential). The discharge limitations in Attachment B of Order No. R4-2003-0108 is not applicable to your discharge.

September 23, 2005

This Table lists the specific constituents and effluent limitations applicable to the discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD ₅ 20°C	mg/L	30	20
Settleable Solids	ml/L	0.3	0.1
Residual Chlorine	mg/L	0.1	---

FREQUENCY OF DISCHARGE:

The discharge will be intermittent and will last approximately one month.

REUSE OF WATER:

Water reuse alternatives and applicability were evaluated. A small volume of the groundwater will be used for dust control and soil compaction within the project area. The majority of the groundwater will be discharged to Beardsley Wash.