

STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
SIMA MANAGEMENT CORPORATION  
(Paseo Camarillo Shopping Center)  
NPDES NO. CAG914001**

**CI-9022**

**FACILITY ADDRESS**

115 West Canon Perdido, Suite 200  
Santa Barbara, CA 93101

**FACILITY MAILING ADDRESS**

2355 Main Street, Suite 140  
Irvine, CA 92614

**PROJECT DESCRIPTION:**

SIMA Management Corporation proposes to discharge treated groundwater generated from the groundwater extraction and treatment system at the Paseo Camarillo Shopping Center to a nearby storm drain. The facility is located at 370 Lantana Street, Camarillo. The extracted groundwater from on-site wells will be treated by passing it through a series of two 1,000 pounds canisters containing granular activated carbon (GAC) to remove volatile organic compounds. Post-treatment water samples will be collected and analyzed prior to discharge into the storm drain.

**VOLUME AND DESCRIPTION OF DISCHARGE**

Up to 15,000 gallons per day of treated groundwater will be discharged to storm drain located along Lantana Street (Latitude 34° 13' 12", Longitude 119° 3' 14"). The discharge from the storm drain flows into Camarillo Hills Drain, thence into the Calleguas Creek (Below Potrero Road), a water of the United States. The site location and the schematic of waste flow diagram are shown as Figures 1 and 2, respectively.

**FREQUENCY OF DISCHARGE:**

The discharge of treated groundwater is continuous. The discharge will last until the groundwater cleanup project is completed.

**REUSE OF WATER:**

It is not economically feasible to haul the groundwater for off-site disposal and the facility lacks sufficient landscaped area at the site for irrigation. There are no feasible reuse options for the discharge, therefore, the treated groundwater will be discharged to storm drain.

January 31, 2006