

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
RIBOST TERMINAL, LLC
(ROBOST TERMINAL PIER C)

(ORDER NO. R4-2004-0109, SERIES NO. 018)
(NPDES NO. CAG674001)
CI-9169

FACILITY ADDRESS

1405 Pier C, Berth C73
Long Beach, CA

FACILITY MAILING ADDRESS

9302 Garfield Avenue
South Gate, CA 90280

PROJECT DESCRIPTION:

Ribost Terminal, LLC proposes to discharge hydrostatic test water from storage Tank Nos. 43016, 43015, 67010, 6701, 84014, 940112, and 94013 at the facility. The facility is located at 1405 Pier C, Berth C73, Long Beach. Hydrostatic testing is required at the facility to test the above ground tanks for leaks and structural integrity. Potable water from City of Long Beach Department of Water and Power will be used for the hydrostatic testing.

VOLUME AND DESCRIPTION OF DISCHARGE:

Approximately 500,000 gallons per day (gpd) of hydrostatic test water will be discharged from the project site. The discharge will be released into the Channel (Latitude: 33° 46' 03", Longitude: 118° 12' 03"), thence to the Outer Long Beach Harbor, waters of the United States. The facility location map and site plan are shown in Figures 1 and 2.

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided, the analytical data did not show reasonable potential for toxics to exist in hydrostatic test above the *Screening Levels for Potential Pollutants of Concern in Potable Water Used for Hydrostatic Testing in Attachment A*. The discharge flows into the Long Beach Harbor. The effluent limitation in Attachment B is not applicable to your discharge.

September 7, 2006

This Table lists the specific constituents and effluent limitations applicable to the discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD ₅ 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settable Solids	ml/L	0.3	0.1
Residual Chlorine	mg/L	0.1	

FREQUENCY OF DISCHARGE:

The discharge will be intermittent. Ribost Terminal anticipates conducting the hydrostatic testing during October 2006.

REUSE OF WATER:

Reuse of water at the facility for irrigation and dust control was evaluated, but found to be infeasible at the site. Therefore, the hydrostatic test water will be discharged into Outer Long Beach Harbor.