

ATTACHMENT A

SCREENING LEVELS FOR POTENTIAL POLLUTANTS OF CONCERN IN GROUNDWATER FROM POTABLE WATER SUPPLY WELLS *(Screening to be conducted on untreated groundwater sample.)*

Pollutant	Screening Criteria		Maximum Contaminant Levels	Minimum Levels (ML)
	MUN ^(a)	Others ^(b)		
	(µg/L)	(µg/L)	(µg/L)	(µg/L)
1,1 Dichloroethane	5	5	5	1
1,1 Dichloroethylene	0.057	3.2	6	0.5
1,1,1 Trichloroethane	200	200	200	2
1,1,2 Trichloroethane	0.60	42	5	0.5
1,1,2,2 Tetrachloroethane	0.17	1	1	0.5
1,2 Dichloroethane	0.38	99	0.5	0.5
1,2-Trans Dichloroethylene	10	10	10	1
Tetrachloroethylene	0.8	8.85	5	0.5
Trichloroethylene	2.7	5	5	0.5
Carbon Tetrachloride	0.25	0.5	0.5	0.5
Vinyl Chloride	0.5	0.5	0.5	0.5
Total Trihalomethanes	--	--	80	--
Benzene	1	1	1	0.5
Methyl tertiary butyl ether (MTBE)	5	5	5	na

(a) = Applies to water with Municipal and Domestic Supply (MUN)
(indicated with E and I in the Basin Plan) beneficial uses designations.

(b) = Applies to all other receiving waters.