



Central Valley Regional Water Quality Control Board

30 June 2020

Paul Salcido
Project Manager, Remediation
Kinder Morgan, Inc.
7776 Pointe Parkway West, #185
Phoenix, AZ 85044

VIA EMAIL
paul_salcido@kindermorgan.com

NOTICE OF APPLICABILITY (NOA) AMENDMENT; GENERAL WASTE DISCHARGE REQUIREMENTS ORDER R5-2016-0076-01 FOR LIMITED THREAT DISCHARGES TO SURFACE WATER; SFPP, L.P., OPERATING PARTNERSHIP OF KINDER MORGAN ENERGY PARTNERS, L.P., FOX ROAD PETROLEUM RELEASE SITE GROUNDWATER REMEDIATION SYSTEM PROJECT, SOLANO COUNTY

SFPP, L.P., operating partnership of Kinder Morgan Energy Partners, L.P (Discharger), Fox Road Petroleum Release Site Groundwater Remediation Project (Project) was issued a Notice of Applicability (NOA) on 2 May 2018 for coverage under the General Order for Limited Threat Discharges to Surface Water (Limited Threat General Order), and was assigned Limited Threat General Order number R5-2016-0076-038. On 21 February 2020, the Discharger requested an amendment of the NOA. The requested amendment is hereby approved and NOA R5-2016-0076-038 is amended as described below.

AMENDMENT

The Discharger’s request for amendment noted that the current NOA requirement of continuous influent and effluent flow sampling frequency is not possible with the current system. The Discharger requested that the influent and effluent flow sampling frequency be changed to weekly as the Project site is unmanned and meters are read once per week. Effective immediately, the NOA is amended (as shown in items 1 and 2 below) to change the influent and effluent flow sampling frequency from continuous to weekly.

1. **Influent Monitoring – Table 3.** Modify the influent monitoring table to change the flow monitoring sample frequency from continuous to weekly as shown below:

Table 3. Influent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	MGD	Meter	1/Week	--

2. **Effluent Monitoring – Table 4.** Modify the effluent monitoring table to change the flow monitoring sample frequency from continuous to weekly, and add requirement to calculate the total volume of water treated on a monthly basis, as shown below:

Table 4. Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Flow	MGD	Meter	1/Week	--
Total Volume of Water Treated	gallons	Calculated	1/Month	--

Any person aggrieved by this action of the Central Valley Water Board may petition the State Water Board to review the action in accordance with California Water Code section 13320 and California Code of Regulations, title 23, sections 2050 and following. The State Water Board must receive the petition by 5:00 p.m., 30 days after the date of this NOA amendment, except that if the thirtieth day following the date of this NOA falls on a Saturday, Sunday, or state holiday, the petition must be received by the State Water Board by 5:00 p.m. on the next business day. Copies of the law and regulations applicable to filing petitions may be found on the [Petitions Home Page](#) located at: http://www.waterboards.ca.gov/public_notices/petitions/water_quality or will be provided upon request.

Patrick Pulupa
Executive Officer

Enclosure: Attachment 1 – Amended Notice of Applicability (Discharger only)

cc: Peter Kozelka, U.S. EPA, Region IX, San Francisco (email only)
Elizabeth Sablad, U.S. EPA, Region IX, San Francisco (email only)
Afrooz Farsimadan, Division of Water Quality, State Water Board,
Sacramento (email only)