

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION

ADMINISTRATIVE CIVIL LIABILITY COMPLAINT R5-2010-0524

MANDATORY PENALTY  
IN THE MATTER OF

PLACER COUNTY DEPARTMENT OF FACILITY SERVICES  
PLACER COUNTY SEWER MAINTENANCE DISTRICT NO. 1  
WASTEWATER TREATMENT PLANT  
PLACER COUNTY

This Complaint is issued to the Placer County Department of Facility Services, Placer County Sewer Maintenance District No. 1, (hereafter Discharger) pursuant to California Water Code (CWC) section 13385, which authorizes the imposition of Administrative Civil Liability, and CWC section 13323, which authorizes the Executive Officer to issue this Complaint. This Complaint is based on findings that the Discharger violated provisions of Waste Discharge Requirements (WDRs) Order R5-2005-0074 (NPDES No. CA0079316).

The Executive Officer of the Central Valley Regional Water Quality Control Board (Central Valley Water Board or Board) finds the following:

1. The Discharger owns and operates a wastewater collection, treatment, and disposal system, and provides sewerage service to the unincorporated area of North Auburn in Placer County. The wastewater treatment plant provides tertiary treatment when influent flows are 3.5 million gallons per day (mgd) or less and a mixture of secondary and tertiary treatment when flows are greater than 3.5 mgd. Treated municipal wastewater is discharged to Rock Creek, a water of the United States.
2. On 23 June 2005, the Central Valley Water Board issued WDRs Order R5-2005-0074, which contained new requirements and rescinded Order 97-113. The WDRs include effluent limitations and other requirements regarding the wastewater discharges.
3. On 12 November 2009, the Executive Officer of the Central Valley Water Board issued Administrative Civil Liability Complaint R5-2009-0567 for mandatory minimum penalties for effluent violations from 1 January 2009 through 31 July 2009. The Discharger paid the administrative civil liability charged in Complaint R5-2009-0567, and the Board considers the matter resolved.
4. This Complaint covers the period of 1 August 2009 through 28 February 2010. On 29 April 2010, Central Valley Water Board staff issued the Discharger a Notice of Violation and draft Record of Violations for effluent limitation violations for this period. The Discharger responded on 17 May 2010, and agreed with the violations.
5. CWC section 13385(i) requires assessment of mandatory penalties and states, in part, the following:

CWC section 13385(i)(1) states, in part:

Notwithstanding any other provision of this division, and except as provided in subdivisions (j), (k), and (l), a mandatory minimum penalty of three thousand dollars (\$3,000) shall be assessed for each violation whenever the person does any of the following four or more times in any period of six consecutive months, except that the requirement to assess the mandatory minimum penalty shall not be applicable to the first three violations:

- A) Violates a waste discharge requirement effluent limitation.
- B) Fails to file a report pursuant to Section 13260.
- C) Files an incomplete report pursuant to Section 13260.
- D) Violates a toxicity effluent limitation contained in the applicable waste discharge requirements where the waste discharge requirements do not contain pollutant-specific effluent limitations for toxic pollutants.

6. CWC section 13323 states, in part:

Any executive officer of a regional board may issue a complaint to any person on whom administrative civil liability may be imposed pursuant to this article. The complaint shall allege the act or failure to act that constitutes a violation of law, the provision authorizing civil liability to be imposed pursuant to this article, and the proposed civil liability.

7. WDRs Order R5-2005-0074 Effluent Limitations B.1. states, in part:

Effluent shall not exceed the following limits:

Constituents	Units	30-Day Average	4-Day Average <sup>1</sup>	1-hour Average <sup>2</sup>
Total Ammonia <sup>4</sup>	mg/L	Attach. E <sup>1</sup>	Attach D	Attach. C

<sup>1</sup> Continuous Concentration (Chronic)

<sup>2</sup> Maximum concentration (Acute)

<sup>4</sup> Temperature and pH must be determined concurrently.

Note: Attachment C is a table entitled "pH Dependent Effluent Limitations For Ammonia Criteria Maximum Concentrations (CMC)"

Attachment D is a table entitled "Temperature and pH Dependent Effluent Limitations For Ammonia (2.5CCC)"

Attachment E is a table entitled "Temperature and pH Dependent Effluent Limitations For Ammonia ... (CCC)"

The applicable effluent limitations from Attachments C, D, and E of Order R5-2005-0074, based upon appropriate discharge temperature and pH, are as listed in Attachment A of this Complaint.

8. WDRs Order R5-2005-0074 Effluent Limitations B.2. states, in part

When flow is less than or equal to 3.5 mgd:

Constituents	Units	Monthly Average	Weekly Average	7-Day Median	24-Hour Average	Daily Maximum
Total Coliform Organisms	MPN/100 mL	---	---	2.2 <sup>4</sup>	---	23/240 <sup>5</sup>

<sup>4</sup> 7-Day Median based on previous seven daily sample results

<sup>5</sup> In a 30-day period, only a single sample may exceed 23 MPN/100 mL and no sample shall exceed 240 MPN/100 mL.

9. According to the Discharger's self-monitoring reports, the Discharger committed six (6) non-serious violations of the above effluent limitations contained in Order R5-2005-0074 during the period beginning 1 August 2009 and ending 28 February 2010. All six of the non-serious violations are subject to mandatory penalties under CWC section 13385(i)(1) because these violations were preceded by three or more similar violations within a six-month period. The mandatory minimum penalty for the six non-serious violations is **eighteen thousand dollars (\$18,000)**.
10. The total amount of the mandatory penalties assessed for the cited effluent violations is **eighteen thousand dollars (\$18,000)**. A detailed list of the cited effluent violations is included in Attachment A, a part of this Order.
11. Issuance of this Administrative Civil Liability Complaint to enforce CWC Division 7, Chapter 5.5 is exempt from the provisions of the California Environmental Quality Act (Pub. Resources Code section 21000 et seq.), in accordance with California Code of Regulations, title 14, section 15321(a)(2).

**PLACER COUNTY DEPARTMENT OF FACILITY SERVICES, PLACER COUNTY SEWER MAINTENANCE DISTRICT NO. 1, IS HEREBY GIVEN NOTICE THAT:**

1. The Executive Officer of the Central Valley Water Board proposes that the Discharger be assessed an Administrative Civil Liability in the amount of **eighteen thousand dollars (\$18,000)**.
2. A hearing on this matter will be conducted at the Central Valley Water Board meeting scheduled on **22/23/24 September 2010**, unless either of the following occurs by **26 July 2010**:
  - a) The Discharger waives the hearing by completing the attached form (checking off the box next to Option #1) and returning it to the Central Valley Water Board, along with payment for the proposed civil liability of **eighteen thousand dollars (\$18,000)**; or
  - b) The Central Valley Water Board agrees to postpone any necessary hearing after the Discharger requests to engage in settlement discussions by checking off the box next to Option #2 on the attached form, and returns it to the Board along with a letter describing the issues to be discussed; or
  - c) The Central Valley Water Board agrees to postpone any necessary hearing after the Discharger requests a delay by checking off the box next to Option #3 on the attached form, and returns it to the Board along with a letter describing the issues to be discussed.
3. If a hearing on this matter is conducted, the Central Valley Water Board will consider whether to affirm, reject, or modify the proposed Administrative Civil Liability, or whether to refer the matter to the Attorney General for recovery of judicial civil liability.

If this matter proceeds to hearing, the Executive Officer reserves the right to amend the proposed amount of civil liability to conform to the evidence presented, including but not limited to, increasing the proposed amount to account for the costs of enforcement (including staff, legal and expert witness costs) incurred after the date of the issuance of this Complaint through completion of the hearing.

*Original signed by Frederick Moss for*  
\_\_\_\_\_  
PAMELA C. CREEDON, Executive Officer

25 June 2010  
\_\_\_\_\_

DATE

Attachment A: Record of Violations  
BLH: 23 June 2010

**WAIVER FORM  
FOR ADMINISTRATIVE CIVIL LIABILITY COMPLAINT**

By signing this waiver, I affirm and acknowledge the following:

I am duly authorized to represent Placer County Facility Services Department, Sewer Maintenance District No. 1 (hereafter Discharger) in connection with Administrative Civil Liability Complaint R5-2010-0524 (hereafter Complaint). I am informed that California Water Code section 13323, subdivision (b), states that, "a hearing before the regional board shall be conducted within 90 days after the party has been served. The person who has been issued a complaint may waive the right to a hearing."

**(OPTION 1: Check here if the Discharger waives the hearing requirement and will pay in full.)**

- a. I hereby waive any right the Discharger may have to a hearing before the Central Valley Water Board.
- b. I certify that the Discharger will remit payment for the proposed civil liability in the full amount of **eighteen thousand dollars (\$18,000)** by check that references "ACL Complaint R5-2010-0524" made payable to the *State Water Pollution Cleanup and Abatement Account*. Payment must be received by the Central Valley Water Board by **26 July 2010**.
- c. I understand the payment of the above amount constitutes a proposed settlement of the Complaint, and that any settlement will not become final until after a 30-day public notice and comment period. Should the Central Valley Water Board receive significant new information or comments during this comment period, the Central Valley Water Board's Executive Officer may withdraw the complaint, return payment, and issue a new complaint. I also understand that approval of the settlement will result in the Discharger having waived the right to contest the allegations in the Complaint and the imposition of civil liability.
- d. I understand that payment of the above amount is not a substitute for compliance with applicable laws and that continuing violations of the type alleged in the Complaint may subject the Discharger to further enforcement, including additional civil liability.

**(OPTION 2: Check here if the Discharger waives the 90-day hearing requirement in order to engage in settlement discussions.)** I hereby waive any right the Discharger may have to a hearing before the Central Valley Water Board within 90 days after service of the complaint, but I reserve the ability to request a hearing in the future. I certify that the Discharger will promptly engage the Central Valley Water Board Prosecution Team in settlement discussions to attempt to resolve the outstanding violation(s). By checking this box, the Discharger requests that the Central Valley Water Board delay the hearing so that the Discharger and the Prosecution Team can discuss settlement. It remains within the discretion of the Central Valley Water Board to agree to delay the hearing. Any proposed settlement is subject to the conditions described above under "Option 1."

**(OPTION 3: Check here if the Discharger waives the 90-day hearing requirement in order to extend the hearing date and/or hearing deadlines. Attach a separate sheet with the amount of additional time requested and the rationale.)** I hereby waive any right the Discharger may have to a hearing before the Central Valley Water Board within 90 days after service of the complaint. By checking this box, the Discharger requests that the Central Valley Water Board delay the hearing and/or hearing deadlines so that the Discharger may have additional time to prepare for the hearing. It remains within the discretion of the Central Valley Water Board to approve the extension.

---

(Print Name and Title)

---

(Signature)

---

(Date)

**ATTACHMENT A  
ADMINISTRATIVE CIVIL LIABILITY COMPLAINT NO. R5-2010-0524**

**Placer County Facility Services Department  
Sewer Maintenance District No. 1  
Wastewater Treatment Plant**

RECORD OF VIOLATIONS (1 August 2009 – 28 February 2010) MANDATORY PENALTIES  
(Data reported under Monitoring and Reporting Program R5-2005-0074)

	<u>Date</u>	<u>Violation Type</u>	<u>Units</u>	<u>Limit</u>	<u>Measured</u>	<u>Period</u>	<u>Remarks</u>	<u>CIWQS</u>
*	5-Jun-09	Ammonia	mg/L	9.21	10.4	4-day avg	4	841001
*	6-Jun-09	Ammonia	mg/L	9.26	10.2	4-day avg	4	841002
*	30-Jun-09	Ammonia	mg/L	3.75	4.73	Monthly	4	841003
1	31-Oct-09	Ammonia	mg/L	4.04	4.36	Monthly	4	856980
2	30-Nov-09	Ammonia	mg/L	4.73	6.09	Monthly	4	868435
3	16-Dec-09	Coliform	MPN/100ml	2.2	4	7-day median	4	868437
4	10-Feb-10	Coliform	MPN/100ml	2.2	4	7-day median	4	868439
5	11-Feb-10	Coliform	MPN/100ml	2.2	4	7-day median	4	868441
6	12-Feb-10	Coliform	MPN/100ml	2.2	4	7-day median	4	868442

Remarks:

1. Serious Violation: For Group I pollutants that exceed the effluent limitation by 40 percent or more.
2. Serious Violation: For Group II pollutants that exceed the effluent limitation by 20 percent or more.
3. Non-serious violations falls within the first three violations in a six-month period, thus is exempt.
4. Non-serious violation subject to mandatory minimum penalties.

**VIOLATIONS AS OF: 02/28/2010**

Group I Serious Violations:	0
Group II Serious Violations:	0
Non-Serious Exempt from MMPs:	0
Non-serious Violations Subject to MMPs:	6
<b><u>Total Violations Subject to MMPs:</u></b>	<b><u>6</u></b>

**Mandatory Minimum Penalty = (0 serious Violation + 6 Non-Serious Violations) x \$3,000 = \$18,000**

\* Mandatory minimum penalties assessed in ACLC R5-2009-0567