

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 82-11

WASTE DISCHARGE REQUIREMENTS
FOR
CRYSTAL SPRINGS MOBILEHOME ESTATES
Southeast of Desert Hot Springs - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. George S. Markel (hereinafter also referred to as the discharger), 21782 Eveningside Lane, El Toro, California 92630, submitted a Report of Waste Discharge, dated January 20, 1982.
2. The discharger proposes to discharge a maximum of 90,000 gallons-per-day of domestic sewage from a mobile home park designed to have 346 spaces and a recreation building. Waste would be discharged into septic tank/seepage pit disposal systems to be located in the NW 1/4 of Section 13, T3S, R5E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
4. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No.. 2 and 3 (above).
5. Wastewater from a swimming pool would be periodically discharged onto landscape plantings.
6. This Order updates waste discharge requirements adopted in Board Order No. 81-98 for a significant expansion of proposed facilities.
7. The Water Quality Control Plan for the West Colorado River Basin Region was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for Coachella Hydrologic Subunit.
8. The beneficial uses of the groundwater of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
9. This proposed park is located in the Miracle Hill Subarea of the Coachella Hydrologic Subunit. Groundwater in this area is warm and mineralized, and is used in hot pools and for landscape irrigation.
10. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.

*Cancelled
1/17/90*

11. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
12. The Riverside County Planning Department has approved Negative Declaration No. CZ 405 (filing date February 9, 1982) for this proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool wastewater shall not be discharged into a sewage disposal system.


B. Provisions


1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any change of ownership of this mobile home park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the development for the purpose of providing additional subsurface sewage disposal

capacity, until such time as this complex is connected to a municipal sewerage system.

- b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.
5. The discharger shall submit to the Board, at least 30 days prior to commencement of discharge, a technical report containing design data of flood protection facilities, and a certificate signed by a California Registered Civil Engineer stating that said facilities are designed to meet Specification A.4 of this Order.
6. This Order supersedes Order No. 81-98.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on March 24, 1982.


Executive Officer



Scale:
1"=2,000'

SITE MAP

CRYSTAL SPRINGS MOBILEHOME ESTATES
Southeast of Desert Hot Springs - Riverside County
Portion of NW1/4 of Section 13, T3S, R5E, SBB&M
USGS Seven Palms Valley 7.5 min. Topographic Map